



འབྲུག་རྒྱལ་ཁབ་ཀྱི་རྒྱུ་རྩུབ་ལྷན་ཁག་
Ministry of Energy and Natural Resources
Royal Government of Bhutan
Bhutan Power System Operator
Thimphu: Bhutan



THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 13-Aug-2026(-ve:import, +ve:export)						
Report Details	Date	Time	National Coincidental Peak Load (MW)		Date	Time
	August 13, 2026	9:00 AM			06-Aug-26	19:11:47
						1,615.00
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks
1	6 x 170 MW THP (Tala)	Unit-I	187.52	400kV THP - Siliguri Line - I	227.33	All Units and Feeders are in Service.
		Unit-II	187.77	400kV THP - Siliguri Line - II	225.64	
		Unit-III	187.01	400kV THP - Norbugang - IV	242.57	
		Unit-IV	187.25	400kV THP - Malbase Line - III	418.35	
		Unit-V	186.91	400kV Malbase - Siliguri Line	166.44	
		Unit-VI	187.12	400kV Norbugang-Siliguri Line	186.95	
		Total	1,123.58	Auxiliary Consumption & Transformation Losses at Generator end	0.86%	
2	4 x 180 MW MHP (Mangdechhu)	Unit-I	197.88	400kV MHP - Jigmeling Line - I	264.36	400kV MHP-JLG Line -III on Standby.
		Unit-II	197.91	400kV MHP - Jigmeling Line - II	263.61	
		Unit-III	192.83	400kV MHP - Jigmeling Line - III	0.00	
		Unit-IV	198.36	400kV MHP - Jigmeling Line - IV	257.31	
		-	-	220kV Jigmeling - BitDeer Line - I	188.49	
		-	-	220kV Jigmeling - BitDeer Line - II	169.95	
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	413.82	
		-	-	400kV Jigmeling - Alipurduar Line - I	319.27	
		-	-	400kV Jigmeling - Alipurduar Line - II	317.82	
		-	-	80MVA, 220/132kV ICT - I (HV)	28.51	
		-	-	80MVA, 220/132kV ICT - II (HV)	28.29	
		-	-	132kV MHP - Yurmo Line - II	51.07	
		-	-	132kV MHP - Tintibi Line	69.07	
		-	-	132kV Gelephu - Salakati Line	-14.15	
		Total	786.98	Auxiliary Consumption & Transformation Losses at Generator end	1.33%	
3	6 x 170 MW PHP-II (Punatsangchhu)	Unit-I	183.64	400kV PHP II - Jigmeling -I	137.96	All Units and Feeders are in Service.
		Unit-II	173.74	400kV PHP II - Jigmeling -II	137.22	
		Unit-III	182.90	400kV PHP II - Alipurduar -I	395.06	
		Unit-IV	178.64	400kV PHP II - Alipurduar -II	394.71	
		Unit-V	165.20	-	-	
		Unit-VI	180.09	-	-	
		Total	1,064.21	Auxiliary Consumption & Transformation Losses at Generator end	-0.07%	
4	4 x 84 MW CHP (Chukha)	Unit-I	91.45	220kV CHP - Birpara Line - I	20.51	All Units and Feeders are in Service.
		Unit-II	91.19	220kV CHP - Birpara Line - II	20.20	
		Unit-III	91.51	220kV CHP - Gedu	103.73	
		Unit-IV	91.42	220kV CHP - Jamjee - I	72.12	
		-	-	220kV CHP - Jamjee - II	71.36	
		-	-	220kV CHP - Jamjee - III	69.00	
		-	-	220kV Malbase - Birpara Line	-5.35	
		-	-	66kV CHP - Gedu Line	7.28	
		Total	365.57	Auxiliary Consumption & Transformation Losses at Generator end	0.37%	
5	2 x 12 MW BHP (U/S) (Basochhu)	Unit-I	12.10	220kV BHP - Semtokha Line	92.81	All Units & Feeders are in Service.
		Unit-II	12.00	66kV BHP - Lobeysa Line	7.09	
		Total	24.10	220kV BHP - Tsirang Line	-35.32	
6	2 x 20 MW BHP (L/S) (Basochhu)	Unit-I	20.50	5MVA, 66/11kV TFR	0.33	All Units & Feeders are in Service.
		Unit-II	20.52	30MVA ICT, 220/66kV (HV)	-16.33	
		Total	41.02	Auxiliary Consumption & Transformation Losses at Generator end	0.32%	
7	2 x 63 MW DHP (Dagachhu)	Unit-I	55.63	220kV DHP - Tsirang Line	0.00	220kV DHP-Tsirang line on Standby.
		Unit-II	48.04	220kV DHP - Dagapela Line	103.00	
		-	-	220kV BitDeer - Dagapela Line	-41.61	
		-	-	5MVA, 220/33kV TFR	0.30	
		Total	103.67	Auxiliary Consumption & Transformation Losses at Generator end	0.36%	
8	4 x 15 MW KHP (Kurichhu)	Unit-I	16.48	132kV KHP - Nangkhor Line	52.00	All Units & Feeders are in Service.
		Unit-II	16.47	132kV KHP - Kilikhar Line	13.44	
		Unit-III	16.64	5MVA, 132/11kV TFR	0.34	
		Unit-IV	16.59	132kV Motanga - Rangja Line	38.78	
		Total	66.18	Auxiliary Consumption & Transformation Losses at Generator end	0.60%	
9	2 x 59 MW NHP (Nikachhu)	Unit-I	64.96	132kV NHP-MHP-I	64.46	All Units & Feeders are in Service.
		Unit-II	64.87	132kV NHP-MHP-II	64.47	
		Total	129.83	Auxiliary Consumption & Transformation Losses at Generator end	0.69%	
10	2 x 9 MW SHP (Suchhu)	Unit-I	6.99	66kV SHP-Damdhum (Samtse)	14.73	All Units & Feeders are in Service.
		Unit-II	7.88	-	-	
		Total	14.87	Auxiliary Consumption & Transformation Losses at Generator end	0.94%	
11	22.38 MWp SSP (Sephu Solar Plant)	Inverter-1	0.46	33kV SSP-Wangdue	1.17	All Inverters and Feeders in Service
		Inverter-2	0.37	33kV SSP-Trongsa	5.09	
		Inverter-3	0.36	-	-	
		Inverter-4	2.68	-	-	
		Inverter-5	2.39	-	1000.00%	
		Total	6.27	Auxiliary Consumption & Transformation Losses at Generator end	0.18%	
12	2 x 16 MW YHP (Yungichhu)	Unit-I	0.00	132kV YHP-Kilikhar	15.06	Unit-I under Shutdown.
		Unit-II	16.03	5MVA, 132/33kV TFR	0.75	
		Total	16.03	Auxiliary Consumption & Transformation Losses at Generator end	1.37%	
13	2 x 27 MW BSHP (Burgangchhu Small HP)	Unit-I	27.27	132kV BSHP-Panbang	49.80	All Units & Feeders are in Service.
		Unit-II	27.03	132kV BSHP-Tintibi	3.91	
		Total	54.30	Auxiliary Consumption & Transformation Losses at Generator end	1.09%	


Note: Generation-Load Summary (MW) for 13-Aug-26 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	3,796.61	1,583.40	2,213.21

Note: Generation-Load Summary (MW) for 13-Aug-25 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	3,416.05	977.10	2,438.95

09:00 hrs Statistical Comparison (MW) for this and last year



THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 13-Aug-2026(-ve:import,+ve:export)						
Report Details	Date	Time	National Coincidental Peak Load (MW)		Date	Time
	August 12, 2026	19:00:00			06-Aug-26	19:11:47
						1,615.00
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks
1	6 x 170 MW THP (Tala)	Unit-I	185.57	400kV THP - Siliguri Line - I	215.78	All Units & Feeders are in Service.
		Unit-II	185.72	400kV THP - Siliguri Line - II	214.46	
		Unit-III	185.08	400kV THP - Norbugang Line - IV	244.86	
		Unit-IV	185.24	400kV THP - Malbase Line - III	439.18	
		Unit-V	186.89	400kV Malbase - Siliguri Line	148.92	
		Unit-VI	185.06	400kV Norbugang-Siliguri Line	92.98	
		Total	1,113.56	Auxiliary Consumption & Transformation Losses at Generator end	-0.06%	
2	4 x 180 MW MHP (Mangdechhu)	Unit-I	197.68	400kV MHP - Jigmeling Line - I	264.12	400kV MHP-JLG Line -III on Standby.
		Unit-II	197.54	400kV MHP - Jigmeling Line - II	263.67	
		Unit-III	192.80	400kV MHP - Jigmeling Line - III	0.00	
		Unit-IV	198.00	400kV MHP - Jigmeling Line - IV	257.20	
		-	-	220kV Jigmeling - BitDeer Line - I	177.43	
		-	-	220kV Jigmeling - BitDeer Line - II	161.21	
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	432.00	
		-	-	400kV Jigmeling - Alipurdur Line - I	311.27	
		-	-	400kV Jigmeling - Alipurdur Line - II	311.27	
		-	-	80MVA, 220/132kV ICT - I (HV)	47.47	
		-	-	80MVA, 220/132kV ICT - II (HV)	47.00	
		-	-	132kV MHP - Yurmo Line - II	58.00	
		-	-	132kV MHP - Tintibi Line	77.25	
		-	-	132kV Gelephu - Salakati Line	-8.85	
		Total	786.02	Auxiliary Consumption & Transformation Losses at Generator end	-0.68%	
3	6 x 170 MW PHP-II (Punatsangchhu)	Unit-I	183.64	400kV PHP II - Jigmeling -I	140.42	All Units & Feeders are in Service.
		Unit-II	171.91	400kV PHP II - Jigmeling -II	139.65	
		Unit-III	180.51	400kV PHP II - Alipurdur -I	389.37	
		Unit-IV	177.02	400kV PHP II - Alipurdur -II	388.74	
		Unit-V	168.54	-	-	
		Unit-VI	178.08	-	-	
		Total	1,059.70	Auxiliary Consumption & Transformation Losses at Generator end	0.14%	
4	4 x 84 MW CHP (Chhukha)	Unit-I	91.38	220kV CHP - Birpara Line - I	24.13	All Units & Feeders are in Service.
		Unit-II	91.03	220kV CHP - Birpara Line - II	23.53	
		Unit-III	91.39	220kV CHP - Gedu	78.59	
		Unit-IV	91.26	220kV CHP - Jamjee - I	78.33	
		-	-	220kV CHP - Jamjee - II	77.51	
		-	-	220kV CHP - Jamjee - III	74.89	
		-	-	220kV Malbase - Birpara Line	19.57	
		-	-	66kV CHP - Gedu Line	6.60	
		Total	365.06	Auxiliary Consumption & Transformation Losses at Generator end	0.41%	
5	2 x 12 MW BHP (U/S) (Basochhu)	Unit-I	0.00	220kV BHP - Semtokha Line	84.70	U/S Unit-I tripped at 18:08:02hrs.
		Unit-II	12.00	66kV BHP - Lobeysa Line	12.19	
		Total	12.00	220kV BHP - Tsirang Line	-44.52	
6	2 x 20 MW BHP (L/S) (Basochhu)	Unit-I	28.46	5MVA, 66/11kV TFR	0.65	
		Unit-II	28.77	30MVA ICT, 220/66kV (HV)	0.03	
		Total	41.23	Auxiliary Consumption & Transformation Losses at Generator end	0.39%	
7	2 x 63 MW DHP (Dagachhu)	Unit-I	55.63	220kV DHP - Tsirang Line	0.00	220kV DHP-Tsirang line on Standby.
		Unit-II	48.04	220kV DHP - Dagapela Line	103.00	
		-	-	220kV BitDeer - Dagapela Line	-44.06	
		-	-	5MVA, 220/33kV TFR	0.20	
		Total	103.67	Auxiliary Consumption & Transformation Losses at Generator end	0.45%	
8	4 x 15 MW KHP (Kurichhu)	Unit-I	16.51	132kV KHP - Nangkor Line	48.12	All Units & Feeders are in Service.
		Unit-II	16.60	132kV KHP - Kilikhar Line	17.08	
		Unit-III	16.45	5MVA, 132/11kV TFR	0.47	
		Unit-IV	16.70	132kV Motanga - Rangla Line	52.37	
		Total	66.26	Auxiliary Consumption & Transformation Losses at Generator end	0.89%	
9	2 x 59 MW NHP (Nikachhu)	Unit-I	64.88	132kV NHP-MHP-I	64.44	All Units & Feeders are in Service.
		Unit-II	64.93	132kV NHP-MHP-II	64.46	
		Total	129.81	Auxiliary Consumption & Transformation Losses at Generator end	0.70%	
10	2 x 9 MW SHP (Suchhu)	Unit-I	6.99	66kV SHP-Damdum (Samtse)	15.32	All Units & Feeders are in Service.
		Unit-II	8.48	-	-	
		Total	15.47	Auxiliary Consumption & Transformation Losses at Generator end	0.97%	
11	2 x 16 MW YHP (Yungichhu)	Unit-I	0.00	132kV YHP-Kilikhar	14.31	Unit-I under Shutdown.
		Unit-II	16.21	5MVA, 132/33kV TFR	1.64	
		Total	16.21	Auxiliary Consumption & Transformation Losses at Generator end	1.60%	
12	2 x 27 MW BSHP (Burgangchhu Small HP)	Unit-I	27.26	132kV BSHP-Panbang	70.00	All Units & Feeders are in Service.
		Unit-II	27.19	132kV BSHP-Tintibi	-15.20	
		Total	54.45	Auxiliary Consumption & Transformation Losses at Generator end	-0.64%	

Note: Generation-Load Summary (MW) for 12-Aug-2026 at 18:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	3,763.44	1,579.90	2,183.54


Note: Generation-Load Summary (MW) for 12-Aug-2025, at 19:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	3,331.97	1,069.92	2,262.05

Note: Daily Energy (MUS) and Power(MW) Statistics for 12-Aug-2026

Sl. No.	Total Energy Generation	Daily Energy Met	Net Energy Import (IEX and Solar)	Net Energy Export	Peak Cross- border (MW)
1	90.35	36.83	0.00	53.52	2,294.64

19:00 hrs Statistical Comparison
(MW) for this and last year



- The Instantaneous load balance does not tend towards zero. This could be due to the following reasons:
 - Not all the meters are digital and not all the meter at all locations can be read at same time (say 9:00hrs) due to many meter to be read manually.
 - The clocks of all the locations are not synchronized.
- This report, compiled using the SCADA data, is prepared to give an overall idea of the generation & load flow for the system at a particular instant. This report also gives energy and import/export figures.
- When SCADA data are unavailable for certain stations due to technical issues, required data are collected from the site.