



འཇུག་ལྷན་པོའི་རྒྱུ་ལྷན་ཁག་ རྒྱུ་ལྷན་ཁག་གི་འཇུག་ལྷན་པོ།
 Ministry of Energy and Natural Resources
 Royal Government of Bhutan
 Office of the Bhutan Power System Operator
 Thimphu: Bhutan



THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 26-Nov-2024(-ve:import, +ve:export)

Report Details	Date	Time	National Coincidental Peak Load (MW)	Date	Time	Load
	24-Nov-24	09:00 hrs		24-Nov-24	17:57:28 hrs	981.169

Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks
1	6 x 170MW THP	Unit-I	152.08	400kV THP - Siliguri Line - I	0.00	Unit-II & Unit III on Standby. Unit-V under AMP. 400kV THP-MAL line under Shutdown. 400kV THP_SIL Line I on Standby.
		Unit-II	0.00	400kV THP - Siliguri Line - II	206.20	
		Unit-III	0.00	400kV THP - Siliguri Line - IV	201.31	
		Unit-IV	126.08	400kV THP - Malbase Line - III	0.00	
		Unit-V	0.00	400kV Malbase - Siliguri Line	-243.71	
		Unit-VI	129.36	-	-	
		Total	407.52	Auxiliary Consumption & Transformation Losses at Generator end	0.00%	
2	4 x 180MW MHP	Unit-I	105.07	400kV MHP - Jigmeling Line - I	116.83	Unit-II on Standby. Unit-IV on Standby. 400kV MHP-JLG Line II & IV on Standby. 132kV MHP_Yurmoo Line - I not in Service. 400kV JLG_ALI Interim Line I & 400kV JLG_ALI Direct Line I on Standby.
		Unit-II	0.00	400kV MHP - Jigmeling Line - II	0.00	
		Unit-III	153.37	400kV MHP - Jigmeling Line - III	117.28	
		Unit-IV	0.00	400kV MHP - Jigmeling Line - IV	0.00	
		-	-	132kV MHP - Yurmo Line - I	0.00	
		-	-	132kV MHP - Yurmo Line - II	63.63	
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	124.36	
		-	-	400kV Jigmeling - Puna - Alipurduar Line - I	0.00	
		-	-	400kV Jigmeling - Puna - Alipurduar Line - II	49.25	
		-	-	400kV Jigmeling - Alipurduar Line - I	0.00	
		-	-	400kV Jigmeling - Alipurduar Line - II	32.98	
		-	-	80MVA, 220/132kV ICT - I (HV)	19.05	
		-	-	80MVA, 220/132kV ICT - II (HV)	18.84	
		-	-	220kV Tsirang - Jigmeling Line	-66.85	
-	-	132kV Gelephu - Salakati Line	4.09			
Total	258.44	Auxiliary Consumption & Transformation Losses at Generator end	0.15%			
3	4 x 84MW CHP	Unit-I	0.00	220kV CHP - Birpara Line - I	-64.12	Unit-I under AMP.
		Unit-II	29.98	220kV CHP - Birpara Line - II	-63.55	
		Unit-III	54.85	220kV CHP - Gedu	22.29	
		Unit-IV	55.15	220kV CHP - Jamjee (old) - I	79.69	
		-	-	220kV CHP - Jamjee - II (new)	80.06	
		-	-	220kV CHP - Jamjee - III (new)	77.26	
		-	-	220kV Malbase - Birpara Line	-79.13	
		-	-	66kV CHP - Gedu Line	7.17	
-	-	3x3MVA, 66/11kV TFR	1.62			
Total	139.98	Auxiliary Consumption & Transformation Losses at Generator end	-0.31%			
4	2 x 12MW BHP (U/S)	Unit-I	0.00	220kV BHP - Semtokha Line	104.90	U/S Unit-I Under Breakdown. L/S Unit-I on Standby.
		Unit-II	10.20	66kV BHP - Lobeyasa Line	26.00	
Total	10.20	220kV BHP - Tsirang Line	-102.00			
5	2 x 20MW BHP (L/S)	Unit-I	0.00	30MVA, 66/11kV TFR	0.44	Unit-I under AMP.
		Unit-II	19.20	30MVA ICT, 220/66kV (HV)	16.65	
Total	19.20	Auxiliary Consumption & Transformation Losses at Generator end	0.20%			
6	2 x 63MW DHP	Unit-I	0.00	220kV DHP - Tsirang Line	38.74	Unit I on Standby. 220kV DHP_Dagapela line under Shutdown.
		Unit-II	38.96	220kV DHP - Dagapela Line	0.00	
		-	-	220kV Jigmeling - Dagapela Line	52.82	
		-	-	5MVA, 220/33kV TFR	0.20	
Total	38.96	Auxiliary Consumption & Transformation Losses at Generator end	0.05%			
7	4 x 15MW KHP	Unit-I	13.18	132kV KHP - Nangkhor Line	12.92	Unit-II on Standby. Unit-III under AMP.
		Unit-II	0.00	132kV KHP - Kilikhar Line	12.95	
		Unit-III	0.00	5MVA, 132/11kV TFR	0.25	
		Unit-IV	13.20	132kV Motanga - Rangia Line	4.05	
		Total	26.38	Auxiliary Consumption & Transformation Losses at Generator end	0.99%	
8	2 x 59MW NHP	Unit-I	0.00	132kV NHP-MHP-I	0.00	Unit-I under AMP. 132kV NHP-MHP line-I under Shutdown.
		Unit-II	40.00	132kV NHP-MHP-II	39.70	
		Total	40.00	Auxiliary Consumption & Transformation Losses at Generator end	0.75%	

Note: Generation-Load Summary (MW) for 24-Nov-24 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	615.86	725.71	726.06	-43.00	-0.35
2	Eastern Grid	324.82	167.60	166.64	90.37	0.96
Total		940.68	893.31	892.70	47.37	0.61

Note: Generation-Load Summary for 24-Nov-23 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	494.70	692.46	692.71	-95.29	-0.25
2	Eastern Grid	204.53	182.94	180.58	-80.88	2.36
Total		699.23	875.40	873.29	-176.17	2.11

THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 26-Nov-2024(-ve:import, +ve:export)							
Report Details	Date	Time	National Coincidental Peak Load (MW)		Date	Time	Load
	24-Nov-2024	18:00 hrs			24-Nov-2024	17:57:28 hrs	981.169
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks	
1	6 x 170MW THP	Unit-I	152.32	400kV THP - Siliguri Line - I	0.00	Unit-II & Unit III on Standby. Unit-V under AMP. 400kV THP-MAL line under Shutdown. 400kV THP-SIL Line I on Standby.	
		Unit-II	0.00	400kV THP - Siliguri Line - II	219.80		
		Unit-III	0.00	400kV THP - Siliguri Line - IV	214.62		
		Unit-IV	132.46	400kV THP - Malbase Line - III	0.00		
		Unit-V	0.00	400kV Malbase - Siliguri Line	-249.16		
		Unit-VI	149.67		-		
		Total	434.45	Auxiliary Consumption & Transformation Losses at Generator end	0.01%		
2	4 x 180MW MHP	Unit-I	114.70	400kV MHP - Jigmeling Line - I	122.41	Unit-II and Unit-IV on Standby. 400kV MHP-JLG Line II & IV on Standby. 132kV MHP_Yurmo Line-I not in Service. 400kV JLG_ALI Interim Line I & 400kV JLG_ALI Direct Line I on Standby.	
		Unit-II	0.00	400kV MHP - Jigmeling Line - II	0.00		
		Unit-III	157.47	400kV MHP - Jigmeling Line - III	123.96		
		Unit-IV	0.00	400kV MHP - Jigmeling Line - IV	0.00		
		-	-	132kV MHP - Yurmo Line - I	0.00		
		-	-	132kV MHP - Yurmo Line - II	63.79		
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	179.27		
		-	-	400kV Jigmeling - Puna - Alipurduar Line - I	0.00		
		-	-	400kV Jigmeling - Puna - Alipurduar Line - II	25.46		
		-	-	400kV Jigmeling - Alipurduar Line - I	0.00		
		-	-	400kV Jigmeling - Alipurduar Line - II	37.82		
		-	-	80MVA, 220/132kV ICT - I (HV)	23.56		
		-	-	80MVA, 220/132kV ICT - II (HV)	23.34		
		-	-	220kV Tsirang - Jigmeling Line	-76.50		
		-	-	132kV Gelephu - Salakati Line	-0.37		
Total	272.17	Auxiliary Consumption & Transformation Losses at Generator end	0.66%				
3	4 x 84MW CHP	Unit-I	0.00	220kV CHP - Birpara Line - I	-62.59	Unit-I under AMP.	
		Unit-II	64.30	220kV CHP - Birpara Line - II	-62.49		
		Unit-III	56.84	220kV CHP - Gedu	24.51		
		Unit-IV	59.75	220kV CHP - Jamjee (old) - I	91.54		
				220kV CHP - Jamjee - II (new)	91.89		
				220kV CHP - Jamjee - III (new)	88.60		
		-	-	220kV Malbase - Birpara Line	-78.90		
		-	-	66kV CHP - Gedu Line	7.93		
		-	-	3x3MVA, 66/11kV TFR	2.36		
		Total	180.89	Auxiliary Consumption & Transformation Losses at Generator end	-0.48%		
4	2 x 12MW BHP (U/S)	Unit-I	0.00	220kV BHP - Sertokha Line	108.09	L/S Unit-I & U/S unit-I on Standby.	
		Unit-II	10.08	66kV BHP - Lobeysa Line	30.15		
		Total	10.08	220kV BHP - Tsirang Line	-109.18		
5	2 x 20MW BHP (L/S)	Unit-I	0.00	5MVA, 66/11kV TFR	0.73	L/S Unit-I & U/S unit-I on Standby.	
		Unit-II	19.20	30MVA ICT, 220/66kV (HV)	20.91		
		Total	19.20	Auxiliary Consumption & Transformation Losses at Generator end	-1.74%		
6	2 x 63MW DHP	Unit-I	0.00	220kV DHP - Tsirang Line	38.17	Unit I on Standby. 220kV DHP_Dagapela line under Shutdown.	
		Unit-II	38.40	220kV DHP - Dagapela Line	0.00		
		-	-	220kV Jigmeling - Dagapela Line	54.59		
		-	-	5MVA, 220/33kV TFR	0.22		
Total	38.40	Auxiliary Consumption & Transformation Losses at Generator end	0.03%				
7	4 x 15MW KHP	Unit-I	15.46	132kV KHP - Nangkor Line	13.03	Unit-II on Standby. Unit-III under AMP.	
		Unit-II	0.00	132kV KHP - Kilikhar Line	17.18		
		Unit-III	0.00	5MVA, 132/11kV TFR	0.47		
		Unit-IV	15.50	132kV Motanga - Rangia Line	4.64		
		Total	30.96	Auxiliary Consumption & Transformation Losses at Generator end	0.90%		
8	2 x 59MW NHP	Unit-I	0.00	132kV NHP-MHP-I	0.00	Unit-I under AMP. 132kV NHP-MHP line-I under Shutdown.	
		Unit-II	40.03	132kV NHP-MHP-II	39.79		
		Total	40.03	Auxiliary Consumption & Transformation Losses at Generator end	0.60%		

Note: Generation-Load Summary (MW) for 24-Nov-2024 at 18:00 hrs						
Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	683.02	778.24	779.57	-18.72	-1.33
2	Eastern Grid	343.16	199.11	196.79	67.55	2.32
	Total	1,026.18	977.35	976.36	48.83	0.99

Note: Generation-Load Summary (MW) for 24-Nov-2023, at 18:00 hrs						
Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	486.30	652.2	649.73	-52.16	2.47
2	Eastern Grid	200.41	190.82	189.53	-104.15	1.29
	Total	686.71	843.02	839.26	-156.31	3.76

Note: Daily Energy (MUs) and Power(MW) Statistics for 24-Nov-2024						
Sl. No.	Net Energy Export (Bilateral)	Net Energy Import (Bilateral)	Daily Energy Met	Total Energy Generation	Peak Cross-border (MW)	Imp./Exp. through Exchange (MUs)
1	0.59	0.00	21.53	20.61	-226.73	-1.49

1. The Instantaneous load balance, calculated as (Total generation - (Total export-Import) - Total domestic load), do not tend towards zero. This could be due to the following reasons:

- i) Not all the meters are digital and nor are all the meter at all locations can be read at same time (say 9:00hrs) due to many meter to be read manually. ii) The clocks of all the locations are not synchronized.
2. This report, compiled using the SCADA data, is prepared to give an overall idea of the generation & load flow for the system at a particular instant. This report also gives energy and import/export figures.
3. When SCADA data are unavailable for certain stations due to technical issues, required data are collected from the site.