



ལྷན་ཁྲིམས་དང་ལོ་ལོ་ཤིང་གི་འཕུལ་གཤམ་ རྒྱལ་ཁབ་རྒྱུ་ལྷན་ཁྲིམས་ལྷན་ཁྲིམས་
 Ministry of Energy and Natural Resources
 Royal Government of Bhutan
 Office of the Bhutan Power System Operator
 Thimphu: Bhutan



THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 28-Dec-2024(-ve:import, +ve:export)

Report Details	Date	Time	National Coincidental Peak Load (MW)		Date	Time	Load
	27-Dec-24	09:00 hrs			25-Dec-24	18:38:16	1026.44
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks	
1	6 x 170MW THP	Unit-I	149.44	400kV THP - Silguri Line - I	0.00	Unit-II & IV on Standby. Unit-VI under AMP. 400kV THP-SIL Line I under Shutdown. 400kV THP-SIL Line IV on Standby.	
		Unit-II	0.00	400kV THP - Silguri Line - II	107.64		
		Unit-III	154.07	400kV THP - Silguri Line - IV	0.00		
		Unit-IV	0.00	400kV THP - Malbase Line - III	343.23		
		Unit-V	145.37	400kV Malbase - Silguri Line	49.00		
		Unit-VI	0.00	-	-		
		Total	448.88	Auxiliary Consumption & Transformation Losses at Generator end	-0.44%		
2	4 x 180MW MHP	Unit-I	0.00	400kV MHP - Jigmeling Line - I	0.00	Unit-I on standby. Unit IV under AMP. 400kV MHP-JLG Line II under shutdown. 400kV MHP-JLG Line I on standby. 132kV MHP_Yurmoo Line-I not in Service. 400kV JLG_ALI Interim Line I & II under Shutdown.	
		Unit-II	145.85	400kV MHP - Jigmeling Line - II	0.00		
		Unit-III	135.49	400kV MHP - Jigmeling Line - III	119.52		
		Unit-IV	0.00	400kV MHP - Jigmeling Line - IV	119.09		
		-	-	132kV MHP - Yurmo Line - I	0.00		
		-	-	132kV MHP - Yurmo Line - II	60.49		
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	201.82		
		-	-	400kV Jigmeling - Alipurduar Line - I	18.20		
		-	-	400kV Jigmeling - Alipurduar Line - II	16.60		
		-	-	80MVA, 220/132kV ICT - I (HV)	13.31		
		-	-	80MVA, 220/132kV ICT - II (HV)	13.16		
		-	-	220kV Tsirang - Jigmeling Line	-122.00		
		-	-	132kV Gelephu - Salakati Line	-20.68		
		Total	281.34	Auxiliary Consumption & Transformation Losses at Generator end	1.45%		
3	6 x 170MW PHP-II	Unit-I	0.00	400kV PHP II - Jigmeling - I	0.00	erstwhile interim lines	
		Unit-II	0.00	400kV PHP II - Jigmeling - II	0.00		
		Unit-III	0.00	400kV PHP II - Alipurduar - I	0.00		
		Unit-IV	0.00	400kV PHP II - Alipurduar - II	0.00		
		Unit-V	0.00	-	-		
		Unit-VI	0.00	-	-		
		Total	0.00	Auxiliary Consumption & Transformation Losses at Generator end	0.00%		
4	4 x 84MW CHP	Unit-I	0.00	220kV CHP - Birpara Line - I	-43.84	Unit-I under AMP. Unit-II on Shutdown.	
		Unit-II	0.00	220kV CHP - Birpara Line - II	-43.51		
		Unit-III	84.72	220kV CHP - Gedu	16.46		
		Unit-IV	84.65	220kV CHP - Jamjee (old) - I	78.64		
		-	-	220kV CHP - Jamjee - II (new)	78.91		
		-	-	220kV CHP - Jamjee - III (new)	76.09		
		-	-	220kV Malbase - Birpara Line	-41.34		
		-	-	66kV CHP - Gedu Line	6.55		
		-	-	3x3MVA, 66/11kV TFR	1.71		
Total	169.37	Auxiliary Consumption & Transformation Losses at Generator end	-0.97%				
5	2 x 12MW BHP (U/S)	Unit-I	7.00	220kV BHP - Semtokha Line	134.57	U/S Unit-II under AMP. L/S Unit-I on Standby	
		Unit-II	0.00	66kV BHP - Lobeyasa Line	28.41		
		Total	7.00	220kV BHP - Tsirang Line	-142.76		
6	2 x 20MW BHP (L/S)	Unit-I	0.00	5MVA, 66/11kV TFR	0.55		
		Unit-II	13.90	30MVA ICT, 220/66kV (HV)	22.09		
		Total	13.90	Auxiliary Consumption & Transformation Losses at Generator end	0.62%		
7	2 x 63MW DHP	Unit-I	0.00	220kV DHP - Tsirang Line	26.05	Unit I under Shutdown 220kV DHP_Dagapela line on Standby.	
		Unit-II	26.28	220kV DHP - Dagapela Line	0.00		
		-	-	220kV Jigmeling - Dagapela Line	53.71		
		-	-	5MVA, 220/33kV TFR	0.20		
Total	26.28	Auxiliary Consumption & Transformation Losses at Generator end	0.11%				
8	4 x 15MW KHP	Unit-I	12.69	132kV KHP - Nangkhor Line	11.05	Unit-III on Standby. Unit-IV under AMP	
		Unit-II	12.69	132kV KHP - Kikhar Line	13.67		
		Unit-III	0.00	5MVA, 132/11kV TFR	0.29		
		Unit-IV	0.00	132kV Motanga - Rangia Line	1.85		
		Total	25.38	Auxiliary Consumption & Transformation Losses at Generator end	1.46%		
9	2 x 59MW NHP	Unit-I	0.00	132kV NHP-MHP-I	0.00	Unit-I under AMP. 132kV NHP-MHP line-I under Shutdown.	
		Unit-II	22.01	132kV NHP-MHP-II	21.84		
		Total	22.01	Auxiliary Consumption & Transformation Losses at Generator end	0.77%		

Note: Generation-Load Summary (MW) for 27-Dec-24 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	665.43	759.48	762.95	27.95	-3.47
2	Eastern Grid	328.73	190.76	186.14	15.97	4.62
Total		994.16	950.24	949.09	43.92	1.15

Note: Generation-Load Summary for 27-Dec-23 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	690.78	694.77	688.91	118.3	5.86
2	Eastern Grid	232.28	185.89	182.98	-75.9	2.91
Total		923.06	880.66	871.89	42.40	8.77

THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 28-Dec-2024(-ve:import, +ve:export)

Report Details	Date	Time	National Coincidental Peak Load (MW)		Date	Time	Load
	27-Dec-2024	18:00 hrs			25-Dec-2024	18:36	1026.44
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks	
1	6 x 170MW THP	Unit-I	169.37	400kV THP - Siliguri Line - I	0.00	Unit-II & IV on Standby. Unit-VI under AMP. 400kV THP-SIL Line I under Shutdown. 400kV THP-SIL Line IV on Standby.	
		Unit-II	0.00	400kV THP - Siliguri Line - II	124.23		
		Unit-III	166.04	400kV THP - Siliguri Line - IV	0.00		
		Unit-IV	0.00	400kV THP - Malbase Line - III	381.60		
		Unit-V	168.76	400kV Malbase - Siliguri Line	57.01		
		Unit-VI	0.00	-	-		
		Total	504.17	Auxiliary Consumption & Transformation Losses at Generator end	-0.33%		
2	4 x 180MW MHP	Unit-I	0.00	400kV MHP - Jigmeling Line - I	0.00	Unit-I on Standby. Unit-IV under AMP. 400kV MHP-JLG Line I on Standby. 400kV MHP-JLG Line II under Shutdown. 132kV MHP_Yurmo Line - I not in Service. 400kV JLG_ALL Interim Line I & II under Shutdown.	
		Unit-II	149.81	400kV MHP - Jigmeling Line - II	0.00		
		Unit-III	130.33	400kV MHP - Jigmeling Line - III	118.19		
		Unit-IV	0.00	400kV MHP - Jigmeling Line - IV	117.87		
		-	-	132kV MHP - Yurmo Line - I	0.00		
		-	-	132kV MHP - Yurmo Line - II	60.50		
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	224.00		
		-	-	400kV Jigmeling - Alipurduar Line - I <i>direct lines</i>	0.68		
		-	-	400kV Jigmeling - Alipurduar Line - II	-0.65		
		-	-	80MVA, 220/132kV ICT - I (HV)	14.10		
		-	-	80MVA, 220/132kV ICT - II (HV)	13.92		
		-	-	220kV Tsirang - Jigmeling Line	-139.22		
		-	-	132kV Gelephu - Salakati Line	-29.93		
		Total	280.14	Auxiliary Consumption & Transformation Losses at Generator end	1.90%		
3	6 x 170MW PHP-II	Unit-I	0.00	400kV PHP II - Jigmeling - I	0.00	<i>erstwhile interim lines</i>	
		Unit-II	0.00	400kV PHP II - Jigmeling - II	0.00		
		Unit-III	0.00	400kV PHP II - Alipurduar - I	0.00		
		Unit-IV	0.00	400kV PHP II - Alipurduar - II	0.00		
		Unit-V	0.00	-	-		
		Unit-VI	0.00	-	-		
		Total	0.00	Auxiliary Consumption & Transformation Losses at Generator end	0.00%		
4	4 x 84MW CHP	Unit-I	0.00	220kV CHP - Birpara Line - I	-45.92	Unit-I under AMP. Unit-II under Shutdown.	
		Unit-II	0.00	220kV CHP - Birpara Line - II	-45.29		
		Unit-III	80.43	220kV CHP - Gedu	2.60		
		Unit-IV	79.10	220kV CHP - Jamjee - I	80.65		
		-	-	220kV CHP - Jamjee - II	81.17		
		-	-	220kV CHP - Jamjee - III	78.33		
		-	-	220kV Malbase - Birpara Line	-34.11		
		-	-	66kV CHP - Gedu Line	6.81		
		-	-	3x3MVA, 66/11kV TFR	2.33		
		Total	159.53	Auxiliary Consumption & Transformation Losses at Generator end	-0.72%		
5	2 x 12MW BHP (U/S)	Unit-I	6.80	220kV BHP - Sementokha Line	148.00	BHP (L/S) Unit-I on Standby. BHP (U/S) Unit-II under AMP.	
		Unit-II	0.00	66kV BHP - Lobeyasa Line	29.99		
		Total	6.80	220kV BHP - Tsirang Line	-158.14		
6	2 x 20MW BHP (L/S)	Unit-I	0.00	5MVA, 66/11kV TFR	0.86		
		Unit-II	13.90	30MVA ICT, 220/66kV (HV)	24.03		
		Total	13.90	Auxiliary Consumption & Transformation Losses at Generator end	-0.05%		
7	2 x 63MW DHP	Unit-I	0.00	220kV DHP - Tsirang Line	26.04	Unit-I under Shutdown. 220kV DHP-Dagapela line on Standby.	
		Unit-II	26.27	220kV DHP - Dagapela Line	0.00		
		-	-	220kV Jigmeling - Dagapela Line	54.47		
		-	-	5MVA, 220/33kV TFR	0.22		
		Total	26.27	Auxiliary Consumption & Transformation Losses at Generator end	0.04%		
8	4 x 15MW KHP	Unit-I	12.68	132kV KHP - Nangkor Line	8.85	Unit-III on Standby. Unit-IV under AMP	
		Unit-II	12.66	132kV KHP - Kilikhar Line	15.73		
		Unit-III	0.00	5MVA, 132/11kV TFR	0.43		
		Unit-IV	0.00	132kV Motanga - Rangia Line	3.86		
		Total	25.34	Auxiliary Consumption & Transformation Losses at Generator end	1.30%		
9	2 x 59MW NHP	Unit-I	0.00	132kV NHP-MHP-I	0.00	Unit-I under AMP. 132kV NHP-MHP line-I under Shutdown.	
		Unit-II	21.98	132kV NHP-MHP-II	21.75		
		Total	21.98	Auxiliary Consumption & Transformation Losses at Generator end	1.05%		

Note: Generation-Load Summary (MW) for 27-Dec-2024 at 18:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	710.67	793.97	796.78	55.92	-2.81
2	Eastern Grid	327.46	214.28	208.39	-26.04	5.89
	Total	1,038.13	1,008.25	1,005.17	29.88	3.08

Note: Generation-Load Summary (MW) for 27-Dec-2023, at 18:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	721.82	728.53	724.86	132.46	3.67
2	Eastern Grid	252.17	208.55	204.24	-95.55	4.31
	Total	973.99	937.08	929.10	36.91	7.98

Note: Daily Energy (MUs) and Power(MW) Statistics for 27-Dec-2024

Sl. No.	Net Energy Export (Bilateral)	Net Energy Import (Bilateral)	Daily Energy Met	Total Energy Generation	Peak Cross-border (MW)	Imp./Exp. through Exchange (MUs)
1	0.27	0.00	21.95	14.33	-672.02	-7.38

1. The Instantaneous load balance, calculated as (Total generation - (Total export-Import) - Total domestic load), do not tend towards zero. This could be due to the following reasons:
 i) Not all the meters are digital and nor are all the meter at all locations can be read at same time (say 9:00hrs) due to many meter to be read manually. ii) The clocks of all the locations are not synchronized.
 2. This report, compiled using the SCADA data, is prepared to give an overall idea of the generation & load flow for the system at a particular instant. This report also gives energy and import/export figures.
 3. When SCADA data are unavailable for certain stations due to technical issues, required data are collected from the site.