



ལྷན་ཁག་ལྷན་དང་ལའཛིན་ཚོན་གྱི་ཉེན་ལག་ ལྷན་ལས་ལྷན་འབྲེག་གཞུང་།
 Ministry of Energy and Natural Resources
 Royal Government of Bhutan
Office of the Bhutan Power System Operator
 Thimphu: Bhutan



THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 20-Feb-2025(+ve:import, -ve:export)

Report Details	Date	Time	National Coincidental Peak Load (MW)		Date	Time	Load
	19-Feb-25	09:00 hrs			25-Dec-24	18:38:16	1026.44
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks	
1	6 x 170MW THP	Unit-I	30.41	400kV THP - Siliguri Line - I	-22.47	Unit-II & III under AMP. Unit -V under shutdown. 400kV THP-SIL Line IV on Standby. 400kV THP-SIL Line II under AMP	
		Unit-II	0.00	400kV THP - Siliguri Line - II	0.00		
		Unit-III	0.00	400kV THP - Siliguri Line-IV	0.00		
		Unit-IV	128.58	400kV THP - Malbase Line - III	217.76		
		Unit-V	0.00	400kV Malbase - Siliguri Line	-70.63		
		Unit-VI	36.93	-	-		
		Total	195.92	Auxiliary Consumption & Transformation Losses at Generator end	0.32%		
2	4 x 180MW MHP	Unit-I	90.27	400kV MHP - Jigmeling Line - I	0.00	Unit-III under Shutdown. Unit-IV under AMP. 400kV MHP-JLG Line I & IV on Standby. 132kV MHP_Yurmoo Line- I not in Service. 400kV JLG-ALI (Direct II) under shutdown.	
		Unit-II	130.18	400kV MHP - Jigmeling Line - II	86.57		
		Unit-III	0.00	400kV MHP - Jigmeling Line - III	87.05		
		Unit-IV	0.00	400kV MHP - Jigmeling Line - IV	0.00		
		-	-	132kV MHP - Yurmo Line - I	0.00		
		-	-	132kV MHP - Yurmo Line - II	63.43		
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	100.00		
		-	-	400kV Jigmeling - Aliparduar Line - I	231.91		
		-	-	400kV Jigmeling - Aliparduar Line - II	0.00		
		-	-	80MVA, 220/132kV ICT - I (HV)	31.11		
		-	-	80MVA, 220/132kV ICT - II (HV)	30.89		
		-	-	220kV Tsirang - Jigmeling Line	14.96		
		-	-	132kV Gelephu - Salakati Line	5.22		
		Total	220.45	Auxiliary Consumption & Transformation Losses at Generator end	0.56%		
3	6 x 170MW PHP-II	Unit-I	160.83	400kV PHP II - Jigmeling -I	0.00	Unit-II on standby. 400kV PHP-II_ALL line I on Standby.	
		Unit-II	0.00	400kV PHP II - Jigmeling -II	162.02		
		Unit-III	0.00	400kV PHP II - Aliparduar -I	0.00		
		Unit-IV	0.00	400kV PHP II - Aliparduar -II	0.00		
		Unit-V	0.00	-	-		
		Unit-VI	0.00	-	-		
		Total	160.83	Auxiliary Consumption & Transformation Losses at Generator end	-0.74%		
4	4 x 84MW CHP	Unit-I	41.98	220kV CHP - Birpara Line - I	-147.22	Unit-II under AMP. Unit-III under Shutdown. 220kV CHP_Gedu line is kept open in order to avoid over loading of 220kV MAL-GEDU line. 220kV MAL-Birpara Line under shutdown.	
		Unit-II	0.00	220kV CHP - Birpara Line - II	-146.04		
		Unit-III	0.00	220kV CHP - Gedu	0.00		
		Unit-IV	39.04	220kV CHP - Jamjee (old) - I	127.00		
		-	-	220kV CHP - Jamjee - II (new)	127.38		
		-	-	220kV CHP - Jamjee - III (new)	122.39		
		-	-	220kV Malbase - Birpara Line	0.00		
		-	-	66kV CHP - Gedu Line	-1.98		
		-	-	3x3MVA, 66/11kV TFR	1.33		
Total	81.02	Auxiliary Consumption & Transformation Losses at Generator end	-2.27%				
5	2 x 12MW BHP (U/S)	Unit-I	5.16	220kV BHP - Semtokha Line	-9.15	U/S Unit-II under Shutdown. L/S Unit-I on Standby. 220kV BHP_TSI line under breakdown.	
		Unit-II	0.00	66kV BHP - Lobeysa Line	23.59		
		Total	5.16	220kV BHP - Tsirang Line	0.00		
6	2 x 20MW BHP (L/S)	Unit-I	0.00	5MVA, 66/11kV TFR	0.64		
		Unit-II	10.07	30MVA ICT, 220/66kV (HV)	19.06		
		Total	10.07	Auxiliary Consumption & Transformation Losses at Generator end	0.98%		
7	2 x 63MW DHP	Unit-I	18.20	220kV DHP - Tsirang Line	18.00	Unit II under AMP. 220kV DHP-Dagapela line on Standby.	
		Unit-II	0.00	220kV DHP - Dagapela Line	0.00		
		-	-	220kV Jigmeling - Dagapela Line	53.21		
		-	-	5MVA, 220/33kV TFR	0.18		
		Total	18.20	Auxiliary Consumption & Transformation Losses at Generator end	0.11%		
8	4 x 15MW KHP	Unit-I	0.00	132kV KHP - Nangkor Line	9.02	Unit-I under AMP. Unit-Unit-IV on Standby.	
		Unit-II	11.23	132kV KHP - Kiliikhar Line	12.91		
		Unit-III	11.26	5MVA, 132/11kV TFR	0.40		
		Unit-IV	0.00	132kV Motanga - Rangia Line	3.60		
		Total	22.49	Auxiliary Consumption & Transformation Losses at Generator end	0.71%		
9	2 x 59MW NHP	Unit-I	18.02	132kV NHP-MHP-I	17.83	Unit-II under AMP. 132kV NHP-MHP line-II on Standby.	
		Unit-II	0.00	132kV NHP-MHP-II	0.00		
		Total	18.02	Auxiliary Consumption & Transformation Losses at Generator end	1.05%		

Note: Generation-Load Summary (MW) for 19-Feb-25 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	732.16	877.79	-145.63

Note: Generation-Load Summary (MW) for 19-Feb-24 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	930.46	888.00	42.46

THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 20-Feb-2025(+ve:import, +ve:export)							
Report Details	Date	Time	National Coincidental Peak Load (MW)		Date	Time	Load
	19-Feb-2025	18:00 hrs			25-Dec-2024	18:36	1026.44
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks	
1	6 x 170MW THP	Unit-I	117.00	400kV THP - Siliguri Line - I	52.32	Unit-II & III under AMP. Unit -V under shutdown. 400kV THP-SIL Line IV on Standby. 400kV THP-SIL Line II under AMP	
		Unit-II	0.00	400kV THP - Siliguri Line - II	0.00		
		Unit-III	0.00	400kV THP - Siliguri Line - IV	0.00		
		Unit-IV	120.00	400kV THP - Malbase Line - III	289.26		
		Unit-V	0.00	400kV Malbase - Siliguri Line	-2.90		
		Unit-VI	105.00	-	-		
		Total	342.00	Auxiliary Consumption & Transformation Losses at Generator end	0.12%		
2	4 x 180MW MHP	Unit-I	164.72	400kV MHP - Jigmeling Line - I	0.00	Unit-IV under AMP. Unit-III under Shutdown 400kV MHP-JLG line I & IV on Standby. 132kV MHP_Yurmo line-I not in service.	
		Unit-II	79.76	400kV MHP - Jigmeling Line - II	96.77		
		Unit-III	0.00	400kV MHP - Jigmeling Line - III	97.18		
		Unit-IV	0.00	400kV MHP - Jigmeling Line - IV	0.00		
		-	-	132kV MHP - Yurmo Line - I	0.00		
		-	-	132kV MHP - Yurmo Line - II	64.45		
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	99.47		
		-	-	400kV Jigmeling - Alipurduar Line - I <i>direct lines</i>	128.25		
		-	-	400kV Jigmeling - Alipurduar Line - II	127.64		
		-	-	80MVA, 220/132kV ICT - I (HV)	29.85		
		-	-	80MVA, 220/132kV ICT - II (HV)	29.65		
		-	-	220kV Tsirang - Jigmeling Line	14.26		
		-	-	132kV Gelephu - Salakati Line	-4.61		
		Total	244.48	Auxiliary Consumption & Transformation Losses at Generator end	0.43%		
3	6 x 170MW PHP-II	Unit-I	162.04	400kV PHP II - Jigmeling -I	0.00	Unit II on Standby 400kV PHP II-ALI line I on Standby.	
		Unit-II	0.00	400kV PHP II - Jigmeling -II	161.95		
		Unit-III	0.00	400kV PHP II - Alipurduar-I	0.00		
		Unit-IV	0.00	400kV PHP II - Alipurduar -II	0.00		
		Unit-V	0.00	-	-		
		Unit-VI	0.00	-	-		
		Total	162.04	Auxiliary Consumption & Transformation Losses at Generator end	0.06%		
4	4 x 84MW CHP	Unit-I	64.45	220kV CHP - Birpara Line - I	-135.59	Unit-II under AMP. Unit-III under Shutdown. 220kV CHP_Gedu line is kept open in order to avoid over loading of 220kV MAL-GEDU line. 220kV MAL-Birpara Line under shutdown.	
		Unit-II	0.00	220kV CHP - Birpara Line - II	-134.01		
		Unit-III	0.00	220kV CHP - Gedu	0.00		
		Unit-IV	65.60	220kV CHP - Jamjee - I	134.45		
		-	-	220kV CHP - Jamjee - II	135.45		
		-	-	220kV CHP - Jamjee - III	131.28		
		-	-	220kV Malbase - Birpara Line	0.00		
		-	-	66kV CHP - Gedu Line	0.00		
		-	-	3x3MVA, 66/11kV TFR	1.90		
		Total	130.05	Auxiliary Consumption & Transformation Losses at Generator end	-2.64%		
5	2 x 12MW BHP (U/S)	Unit-I	5.20	220kV BHP - Semtokha Line	-10.80	U/S Unit-II under Shutdown. L/S Unit-I on Standby. 220kV BHP_TSI line under breakdown.	
		Unit-II	0.00	66kV BHP - Lobeysa Line	25.60		
		Total	5.20	220kV BHP - Tsirang Line	0.00		
6	2 x 20MW BHP (L/S)	Unit-I	0.00	5MVA, 66/11kV TFR	0.65		
		Unit-II	10.30	30MVA ICT, 220/66kV (HV)	20.83		
		Total	10.30	Auxiliary Consumption & Transformation Losses at Generator end	0.32%		
7	2 x 63MW DHP	Unit-I	18.18	220kV DHP - Tsirang Line	18.00	Unit II under AMP. 220kV DHP-Dagapela line on Standby.	
		Unit-II	0.00	220kV DHP - Dagapela Line	0.00		
		-	-	220kV Jigmeling - Dagapela Line	53.83		
		-	-	5MVA, 220/33kV TFR	0.10		
Total	18.18	Auxiliary Consumption & Transformation Losses at Generator end	0.44%				
8	4 x 15MW KHP	Unit-I	0.00	132kV KHP - Nangkhon Line	2.14	Unit-I under AMP. Unit-II & IV on Standby.	
		Unit-II	0.00	132kV KHP - Kilikhar Line	12.68		
		Unit-III	15.41	5MVA, 132/11kV TFR	0.46		
		Unit-IV	0.00	132kV Motanga - Rangia Line	1.24		
		Total	15.41	Auxiliary Consumption & Transformation Losses at Generator end	0.84%		
9	2 x 59MW NHP	Unit-I	15.01	132kV NHP-MHP-I	14.98	Unit-II under AMP. 132kV NHP-MHP line-II on Standby.	
		Unit-II	0.00	132kV NHP-MHP-II	0.00		
		Total	15.01	Auxiliary Consumption & Transformation Losses at Generator end	0.20%		

Note: Generation-Load Summary (MW) for 19-Feb-2025 at 18:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	942.67	910.33	32.34

Note: Generation-Load Summary (MW) for 19-Feb-2024, at 18:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	358.17	896.94	-538.77

Note: Daily Energy (MUs) and Power(MW) Statistics for 19-Feb-2025

Sl. No.	Total Energy Generation	Daily Energy Met	Net Energy Import (IEX and Solar)	Net Energy Export	Peak Cross-border (MW)
1	13.04	21.78	8.98	0.23	-625.16

1. The Instantaneous load balance,calculated as (Total generation - (Total export-Import) - Total domestic load), do not tend towards zero. This could be due to the following reasons:
i) Not all the meters are digital and nor are all the meter at all locations can be read at same time (say 9:00hrs) due to many meter to be read manually. ii) The clocks of all the locations are not synchronized.
2. This report, compiled using the SCADA data, is prepared to give an overall idea of the generation & load flow for the system at a particular instant. This report also gives energy and import/export figures.
3. When SCADA data are unavailable for certain stations due to technical issues, required data are collected from the site.