



ལྷན་ཁག་ལྷན་དང་ལའཛིན་ཆེན་གྱི་ཉེན་འགག་དཔལ་ལྷན་འབྲུག་གཞུང་།
 Ministry of Energy and Natural Resources
 Royal Government of Bhutan
Office of the Bhutan Power System Operator
 Thimphu: Bhutan



THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 21-Feb-2025(-ve:import, +ve:export)

Report Details	Date	Time	National Coincidental Peak Load (MW)	Date	Time	Load
	20-Feb-25	09:00 hrs		25-Dec-24	18:38:16	1026.44

Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks
1	6 x 170MW THP	Unit-I	101.58	400kV THP - Siliguri Line - I	36.34	Unit-II & III under AMP. Unit-V under shutdown. 400kV THP-SIL Line IV on Standby. 400kV THP-SIL Line II under AMP
		Unit-II	0.00	400kV THP - Siliguri Line - II	0.00	
		Unit-III	0.00	400kV THP - Siliguri Line - IV	0.00	
		Unit-IV	108.65	400kV THP - Malbase Line - III	293.21	
		Unit-V	0.00	400kV Malbase - Siliguri Line	-17.43	
		Unit-VI	119.43	-	-	
		Total	329.66	Auxiliary Consumption & Transformation Losses at Generator end	0.03%	
2	4 x 180MW MHP	Unit-I	135.14	400kV MHP - Jigmeling Line - I	0.00	Unit-III under Shutdown. Unit-IV under AMP. 400kV MHP-JLG Line I & IV on Standby. 132kV MHP_Yurmoo Line- I not in Service.
		Unit-II	105.82	400kV MHP - Jigmeling Line - II	95.65	
		Unit-III	0.00	400kV MHP - Jigmeling Line - III	96.11	
		Unit-IV	0.00	400kV MHP - Jigmeling Line - IV	0.00	
		-	-	132kV MHP - Yurmo Line - I	0.00	
		-	-	132kV MHP - Yurmo Line - II	64.14	
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	93.84	
		-	-	400kV Jigmeling - Aliparduar Line - I	126.55	
		-	-	400kV Jigmeling - Aliparduar Line - II	127.27	
		-	-	80MVA, 220/132kV ICT - I (HV)	28.64	
		-	-	80MVA, 220/132kV ICT - II (HV)	28.40	
		-	-	220kV Tsirang - Jigmeling Line	14.85	
		-	-	132kV Gelephu - Salakati Line	-3.28	
Total	240.96	Auxiliary Consumption & Transformation Losses at Generator end	-0.05%			
3	6 x 170MW PHP-II	Unit-I	160.50	400kV PHP II - Jigmeling - I	0.00	Unit-II on standby. 400kV PHP-II_ALL line I on Standby.
		Unit-II	0.00	400kV PHP II - Jigmeling - II	161.51	
		Unit-III	0.00	400kV PHP II - Aliparduar - I	0.00	
		Unit-IV	0.00	400kV PHP II - Aliparduar - II	0.00	
		Unit-V	0.00	-	-	
		Unit-VI	0.00	-	-	
		Total	160.50	Auxiliary Consumption & Transformation Losses at Generator end	-0.63%	
4	4 x 84MW CHP	Unit-I	58.74	220kV CHP - Birpara Line - I	-129.31	Unit-II under AMP. Unit-III under Shutdown. 220kV CHP_Gedu line is kept open in order to avoid over loading of 220kV MAL-GEDU line.
		Unit-II	0.00	220kV CHP - Birpara Line - II	-128.49	
		Unit-III	0.00	220kV CHP - Gedu	0.00	
		Unit-IV	61.93	220kV CHP - Jamjee (old) - I	127.87	
		-	-	220kV CHP - Jamjee - II (new)	128.26	
		-	-	220kV CHP - Jamjee - III (new)	124.16	
		-	-	220kV Malbase - Birpara Line	20.64	
		-	-	66kV CHP - Gedu Line	-1.29	
		-	-	3x3MVA, 66/11kV TFR	1.35	
Total	120.67	Auxiliary Consumption & Transformation Losses at Generator end	-1.56%			
5	2 x 12MW BHP (U/S)	Unit-I	5.11	220kV BHP - Semtokha Line	-9.12	U/S Unit-II under Shutdown. L/S Unit-I on Standby. 220kV BHP_TSI line under breakdown.
		Unit-II	0.00	66kV BHP - Lobeyssa Line	23.50	
		Total	5.11	220kV BHP - Tsirang Line	0.00	
6	2 x 20MW BHP (L/S)	Unit-I	0.00	5MVA, 66/11kV TFR	0.54	
		Unit-II	9.98	30MVA ICT, 220/66kV (HV)	19.00	
		Total	9.98	Auxiliary Consumption & Transformation Losses at Generator end	1.13%	
7	2 x 63MW DHP	Unit-I	18.08	220kV DHP - Tsirang Line	17.89	Unit II under AMP. 220kV DHP-Dagapela line on Standby.
		Unit-II	0.00	220kV DHP - Dagapela Line	0.00	
		-	-	220kV Jigmeling - Dagapela Line	53.29	
		-	-	5MVA, 220/33kV TFR	0.18	
		Total	18.08	Auxiliary Consumption & Transformation Losses at Generator end	0.06%	
8	4 x 15MW KHP	Unit-I	0.00	132kV KHP - Nangkor Line	4.11	Unit-I under AMP. Unit-Unit-II & IV on Standby.
		Unit-II	0.00	132kV KHP - Kilihar Line	10.71	
		Unit-III	15.40	5MVA, 132/11kV TFR	0.29	
		Unit-IV	0.00	132kV Motanga - Rangia Line	3.58	
		Total	15.40	Auxiliary Consumption & Transformation Losses at Generator end	1.88%	
9	2 x 59MW NHP	Unit-I	14.98	132kV NHP-MHP-I	14.83	Unit-II under AMP. 132kV NHP-MHP line-II on Standby.
		Unit-II	0.00	132kV NHP-MHP-II	0.00	
		Total	14.98	Auxiliary Consumption & Transformation Losses at Generator end	1.00%	

Note: Generation-Load Summary (MW) for 20-Feb-25 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	915.34	879.47	35.87

Note: Generation-Load Summary (MW) for 20-Feb-24 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	909.27	868.22	41.05

THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 21-Feb-2025(+ve:import, +ve:export)							
Report Details	Date	Time	National Coincidental Peak Load (MW)		Date	Time	Load
	20-Feb-2025	18:00 hrs			25-Dec-2024	18:36	1026.44
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks	
1	6 x 170MW THP	Unit-I	103.00	400kV THP - Siliguri Line - I	62.65	Unit-II & III under AMP. Unit -V under shutdown. 400kV THP-SIL Line IV on Standby. 400kV THP-SIL Line II under AMP	
		Unit-II	0.00	400kV THP - Siliguri Line - II	0.00		
		Unit-III	0.00	400kV THP - Siliguri Line - IV	0.00		
		Unit-IV	150.00	400kV THP - Malbase Line - III	307.79		
		Unit-V	0.00	400kV Malbase - Siliguri Line	9.00		
		Unit-VI	120.00	-	-		
		Total	373.00	Auxiliary Consumption & Transformation Losses at Generator end	0.69%		
2	4 x 180MW MHP	Unit-I	149.90	400kV MHP - Jigmeling Line - I	0.00	Unit-IV under AMP. Unit-III under Shutdown 400kV MHP-JLG line I & IV on Standby. 132kV MHP_Yurmoo line-I not in service.	
		Unit-II	70.85	400kV MHP - Jigmeling Line - II	84.77		
		Unit-III	0.00	400kV MHP - Jigmeling Line - III	85.18		
		Unit-IV	0.00	400kV MHP - Jigmeling Line - IV	0.00		
		-	-	132kV MHP - Yurmo Line - I	0.00		
		-	-	132kV MHP - Yurmo Line - II	64.82		
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	98.46		
		-	-	400kV Jigmeling - Alipurduar Line - I	114.23		
		-	-	400kV Jigmeling - Alipurduar Line - II	113.23		
		-	-	80MVA, 220/132kV ICT - I (HV)	29.90		
		-	-	80MVA, 220/132kV ICT - II (HV)	29.61		
		-	-	220kV Tsirang - Jigmeling Line	14.27		
		-	-	132kV Gelephu - Salakati Line	-5.32		
		Total	220.75	Auxiliary Consumption & Transformation Losses at Generator end	0.29%		
3	6 x 170MW PHP-II	Unit-I	160.16	400kV PHP II - Jigmeling -I	0.00	Unit II on Standby 400kV PHP II-ALI line I on Standby.	
		Unit-II	0.00	400kV PHP II - Jigmeling -II	160.00		
		Unit-III	0.00	400kV PHP II - Alipurduar-I	0.00		
		Unit-IV	0.00	400kV PHP II - Alipurduar -II	0.00		
		Unit-V	0.00	-	-		
		Unit-VI	0.00	-	-		
		Total	160.16	Auxiliary Consumption & Transformation Losses at Generator end	0.10%		
4	4 x 84MW CHP	Unit-I	59.99	220kV CHP - Birpara Line - I	-136.86	Unit-II under AMP. Unit-III under Shutdown. 220kV CHP_Gedu line is kept open in order to avoid over loading of 220kV MAL-GEDU line.	
		Unit-II	0.00	220kV CHP - Birpara Line - II	-135.44		
		Unit-III	0.00	220kV CHP - Gedu	0.00		
		Unit-IV	60.12	220kV CHP - Jamjee - I	131.79		
		-	-	220kV CHP - Jamjee - II	133.17		
		-	-	220kV CHP - Jamjee - III	128.78		
		-	-	220kV Malbase - Birpara Line	15.00		
		-	-	66kV CHP - Gedu Line	-2.40		
		-	-	3x3MVA, 66/11kV TFR	1.94		
		Total	120.11	Auxiliary Consumption & Transformation Losses at Generator end	-0.72%		
5	2 x 12MW BHP (U/S)	Unit-I	5.10	220kV BHP - Semtokha Line	-11.70	U/S Unit-II under Shutdown. L/S Unit-II on Standby. 220kV BHP_TSI line under breakdown.	
		Unit-II	0.00	66kV BHP - Lobeysa Line	25.68		
		Total	5.10	220kV BHP - Tsirang Line	0.00		
6	2 x 20MW BHP (L/S)	Unit-I	9.80	5MVA, 66/11kV TFR	0.69		
		Unit-II	0.00	30MVA ICT, 220/66kV (HV)	21.30		
		Total	9.80	Auxiliary Consumption & Transformation Losses at Generator end	1.54%		
7	2 x 63MW DHP	Unit-I	17.98	220kV DHP - Tsirang Line	17.78	Unit II under AMP. 220kV DHP-Dagapela line on Standby.	
		Unit-II	0.00	220kV DHP - Dagapela Line	0.00		
		-	-	220kV Jigmeling - Dagapela Line	53.82		
		-	-	5MVA, 220/33kV TFR	0.19		
Total	17.98	Auxiliary Consumption & Transformation Losses at Generator end	0.06%				
8	4 x 15MW KHP	Unit-I	0.00	132kV KHP - Nangkhon Line	1.41	Unit-I under AMP. Unit-II & IV on Standby.	
		Unit-II	0.00	132kV KHP - Kilikhar Line	13.31		
		Unit-III	15.38	5MVA, 132/11kV TFR	0.46		
		Unit-IV	0.00	132kV Motanga - Rangia Line	1.96		
		Total	15.38	Auxiliary Consumption & Transformation Losses at Generator end	1.33%		
9	2 x 59MW NHP	Unit-I	14.95	132kV NHP-MHP-I	14.66	Unit-II under AMP. 132kV NHP-MHP line-II on Standby.	
		Unit-II	0.00	132kV NHP-MHP-II	0.00		
		Total	14.95	Auxiliary Consumption & Transformation Losses at Generator end	1.94%		

Note: Generation-Load Summary (MW) for 20-Feb-2025 at 18:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	937.23	898.78	38.45

Note: Generation-Load Summary (MW) for 20-Feb-2024, at 18:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	900.29	903.95	-3.66

Note: Daily Energy (MUs) and Power(MW) Statistics for 20-Feb-2025

Sl. No.	Total Energy Generation	Daily Energy Met	Net Energy Import (IEX and Solar)	Net Energy Export	Peak Cross-border (MW)
1	13.32	21.58	8.49	0.27	-585.14

- The Instantaneous load balance, calculated as (Total generation - (Total export-Import) - Total domestic load), do not tend towards zero. This could be due to the following reasons:
 - Not all the meters are digital and nor are all the meter at all locations can be read at same time (say 9:00hrs) due to many meter to be read manually.
 - The clocks of all the locations are not synchronized.
- This report, compiled using the SCADA data, is prepared to give an overall idea of the generation & load flow for the system at a particular instant. This report also gives energy and import/export figures.
- When SCADA data are unavailable for certain stations due to technical issues, required data are collected from the site.