



ལྷན་འབྲེལ་འཛུགས་ཀྱི་རྒྱུ་ཉེན་ལག་དཔལ་ལྷན་འབྲེལ་གྲུབ་ལུགས།
 Ministry of Energy and Natural Resources
 Royal Government of Bhutan
Office of the Bhutan Power System Operator
 Thimphu: Bhutan



THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 19-Feb-2025(-ve:import, +ve:export)

Report Details	Date	Time	National Coincidental Peak Load (MW)		Date	Time	Load
	18-Feb-25	09:00 hrs			25-Dec-24	18:38:16	1026.44
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks	
1	6 x 170MW THP	Unit-I	132.41	400kV THP - Siliguri Line - I	46.10	Unit-II & III under AMP. Unit - VI under Breakdown. 400kV THP-SIL Line IV on Standby. 400kV THP-SIL Line II under AMP	
		Unit-II	0.00	400kV THP - Siliguri Line - II	0.00		
		Unit-III	0.00	400kV THP - Siliguri Line-IV	0.00		
		Unit-IV	118.71	400kV THP - Malbase Line - III	314.11		
		Unit-V	109.18	400kV Malbase - Siliguri Line	-11.77		
		Unit-VI	0.00	-	-		
		Total	360.30	Auxiliary Consumption & Transformation Losses at Generator end	0.02%		
2	4 x 180MW MHP	Unit-I	184.84	400kV MHP - Jigmeling Line - I	0.00	Unit-III under Shutdown. Unit-IV under AMP. 400kV MHP-JLG Line I & IV on Standby. 132kV MHP_Yurmo Line- I not in Service.	
		Unit-II	94.75	400kV MHP - Jigmeling Line - II	114.53		
		Unit-III	0.00	400kV MHP - Jigmeling Line - III	115.09		
		Unit-IV	0.00	400kV MHP - Jigmeling Line - IV	0.00		
		-	-	132kV MHP - Yurmo Line - I	0.00		
		-	-	132kV MHP - Yurmo Line - II	63.42		
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	100.36		
		-	-	400kV Jigmeling - Aliparduar Line - I	172.36		
		-	-	400kV Jigmeling - Aliparduar Line - II	173.82		
		-	-	80MVA, 220/132kV ICT - I (HV)	31.52		
		-	-	80MVA, 220/132kV ICT - II (HV)	31.12		
		-	-	220kV Tsirang - Jigmeling Line	15.68		
		-	-	132kV Gelephu - Salakati Line	1.14		
		Total	279.59	Auxiliary Consumption & Transformation Losses at Generator end	0.49%		
3	6 x 170MW PHP-II	Unit-I	169.92	400kV PHP II - Jigmeling -I	0.00	400kV PHP-II_ALI line I on Standby.	
		Unit-II	49.75	400kV PHP II - Jigmeling -II	220.96		
		Unit-III	0.00	400kV PHP II - Aliparduar -I	0.00		
		Unit-IV	0.00	400kV PHP II - Aliparduar -II	0.00		
		Unit-V	0.00	-	-		
		Unit-VI	0.00	-	-		
Total	219.67	Auxiliary Consumption & Transformation Losses at Generator end	-0.59%				
4	4 x 84MW CHP	Unit-I	0.00	220kV CHP - Birpara Line - I	-184.94	All Units are opened for Dam Scouring (Total Shutdown). 220kV CHP_Gedu line is kept open in order to avoid over loading of 220kV MAL-GEDU line as 220kV BHP_TSI line is under breakdown.	
		Unit-II	0.00	220kV CHP - Birpara Line - II	-183.27		
		Unit-III	0.00	220kV CHP - Gedu	0.00		
		Unit-IV	0.00	220kV CHP - Jamjee (old) - I	126.21		
		-	-	220kV CHP - Jamjee - II (new)	126.54		
		-	-	220kV CHP - Jamjee - III (new)	122.16		
		-	-	220kV Malbase - Birpara Line	30.16		
		-	-	66kV CHP - Gedu Line	-6.32		
		-	-	3x3MVA, 66/11kV TFR	1.32		
Total	0.00	Auxiliary Consumption & Transformation Losses at Generator end	0.00%				
5	2 x 12MW BHP (U/S)	Unit-I	5.16	220kV BHP - Semtokha Line	-8.99	U/S Unit-II under Shutdown. L/S Unit-I on Standby.	
		Unit-II	0.00	66kV BHP - Lobeyssa Line	23.80		
Total	5.16	Auxiliary Consumption & Transformation Losses at Generator end	0.00%				
6	2 x 20MW BHP (L/S)	Unit-I	0.00	220kV BHP - Tsirang Line	0.00	220kV BHP_TSI line under breakdown.	
		Unit-II	10.40	5MVA, 66/11kV TFR	0.55		
Total	10.40	Auxiliary Consumption & Transformation Losses at Generator end	1.29%				
7	2 x 63MW DHP	Unit-I	18.67	220kV DHP - Tsirang Line	18.47	Unit II under AMP. 220kV DHP-Dagapela line on Standby.	
		Unit-II	0.00	220kV DHP - Dagapela Line	0.00		
		-	-	220kV Jigmeling - Dagapela Line	52.95		
		-	-	5MVA, 220/33kV TFR	0.19		
Total	18.67	Auxiliary Consumption & Transformation Losses at Generator end	0.05%				
8	4 x 15MW KHP	Unit-I	0.00	132kV KHP - Nangkor Line	3.86	Unit-I under AMP. Unit-II & Unit-IV on Standby.	
		Unit-II	0.00	132kV KHP - Kilihar Line	11.10		
		Unit-III	15.51	5MVA, 132/11kV TFR	0.34		
		Unit-IV	0.00	132kV Motanga - Rangia Line	-0.66		
Total	15.51	Auxiliary Consumption & Transformation Losses at Generator end	1.35%				
9	2 x 59MW NHP	Unit-I	14.96	132kV NHP-MHP-I	14.83	Unit-II under AMP. 132kV NHP-MHP line-II on Standby.	
		Unit-II	0.00	132kV NHP-MHP-II	0.00		
Total	14.96	Auxiliary Consumption & Transformation Losses at Generator end	0.87%				

Note: Generation-Load Summary (MW) for 18-Feb-25 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	924.26	881.32	42.94

Note: Generation-Load Summary (MW) for 18-Feb-24 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	921.63	880.46	41.17

THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 19-Feb-2025(+ve:import, +ve:export)							
Report Details	Date	Time	National Coincidental Peak Load (MW)		Date	Time	Load
	18-Feb-2025	18:00 hrs			25-Dec-2024	18:36	1026.44
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks	
1	6 x 170MW THP	Unit-I	66.17	400kV THP - Siliguri Line - I	13.16	Unit-II & III under AMP. Unit - V under Shutdown. 400kV THP-SIL Line II under AMP .	
		Unit-II	0.00	400kV THP - Siliguri Line - II	0.00		
		Unit-III	0.00	400kV THP - Siliguri Line - IV	13.08		
		Unit-IV	148.04	400kV THP - Malbase Line - III	287.32		
		Unit-V	0.00	400kV Malbase - Siliguri Line	-40.04		
		Unit-VI	99.44	-	-		
		Total	313.65	Auxiliary Consumption & Transformation Losses at Generator end	0.03%		
2	4 x 180MW MHP	Unit-I	145.85	400kV MHP - Jigmeling Line - I	0.00	Unit-IV under AMP. Unit-III under Shutdown 400kV MHP-JLG line I & IV on Standby. 132kV MHP_Yurmoo line-I not in service.	
		Unit-II	145.16	400kV MHP - Jigmeling Line - II	119.78		
		Unit-III	0.00	400kV MHP - Jigmeling Line - III	120.39		
		Unit-IV	0.00	400kV MHP - Jigmeling Line - IV	0.00		
		-	-	132kV MHP - Yurmo Line - I	0.00		
		-	-	132kV MHP - Yurmo Line - II	65.34		
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	106.18		
		-	-	400kV Jigmeling - Alipurdur Line - I	206.55		
		-	-	400kV Jigmeling - Alipurdur Line - II	206.55		
		-	-	80MVA, 220/132kV ICT - I (HV)	33.88		
		-	-	80MVA, 220/132kV ICT - II (HV)	33.56		
		-	-	220kV Tsirang - Jigmeling Line	14.56		
		-	-	132kV Gelephu - Salakati Line	3.48		
		Total	291.01	Auxiliary Consumption & Transformation Losses at Generator end	0.12%		
3	6 x 170MW PHP-II	Unit-I	139.56	400kV PHP II - Jigmeling -I	0.00	400kV PHP II-ALI line I on Standby.	
		Unit-II	140.54	400kV PHP II - Jigmeling -II	279.69		
		Unit-III	0.00	400kV PHP II - Alipurdur-I	0.00		
		Unit-IV	0.00	400kV PHP II - Alipurdur -II	0.00		
		Unit-V	0.00	-	-		
		Unit-VI	0.00	-	-		
		Total	280.10	Auxiliary Consumption & Transformation Losses at Generator end	0.15%		
4	4 x 84MW CHP	Unit-I	0.00	220kV CHP - Birpara Line - I	-193.27	All Units are opened for Dam Scouring (Total Shutdown). 220kV CHP_Gedu line is kept open in order to avoid over loading of 220kV MAL-GEDU line as 220kV BHP_TSI line is under breakdown.	
		Unit-II	0.00	220kV CHP - Birpara Line - II	-192.28		
		Unit-III	0.00	220kV CHP - Gedu	0.00		
		Unit-IV	0.00	220kV CHP - Jamjee - I	132.08		
		-	-	220kV CHP - Jamjee - II	132.07		
		-	-	220kV CHP - Jamjee - III	127.68		
		-	-	220kV Malbase - Birpara Line	22.18		
		-	-	66kV CHP - Gedu Line	-6.02		
		-	-	3x3MVA, 66/11kV TFR	1.59		
		Total	0.00	Auxiliary Consumption & Transformation Losses at Generator end	0.00%		
5	2 x 12MW BHP (U/S)	Unit-I	5.00	220kV BHP - Semtokha Line	-9.33	U/S Unit-II under Shutdown. L/S Unit-I on Standby. 220kV BHP_TSI line under breakdown.	
		Unit-II	0.00	66kV BHP - Lobeysa Line	23.67		
		Total	5.00	220kV BHP - Tsirang Line	0.00		
6	2 x 20MW BHP (L/S)	Unit-I	0.00	5MVA, 66/11kV TFR	0.70		
		Unit-II	10.30	30MVA ICT, 220/66kV (HV)	19.38		
		Total	10.30	Auxiliary Consumption & Transformation Losses at Generator end	1.70%		
7	2 x 63MW DHP	Unit-I	18.37	220kV DHP - Tsirang Line	18.15	Unit II under AMP. 220kV DHP-Dagapela line on Standby.	
		Unit-II	0.00	220kV DHP - Dagapela Line	0.00		
		-	-	220kV Jigmeling - Dagapela Line	53.48		
		-	-	5MVA, 220/33kV TFR	0.20		
Total	18.37	Auxiliary Consumption & Transformation Losses at Generator end	0.11%				
8	4 x 15MW KHP	Unit-I	0.00	132kV KHP - Nangkhon Line	7.19	Unit-I under AMP. Unit-IV on Standby.	
		Unit-II	11.24	132kV KHP - Kilikhar Line	14.65		
		Unit-III	11.24	5MVA, 132/11kV TFR	0.42		
		Unit-IV	0.00	132kV Motanga - Rangia Line	1.22		
		Total	22.48	Auxiliary Consumption & Transformation Losses at Generator end	0.98%		
9	2 x 59MW NHP	Unit-I	14.98	132kV NHP-MHP-I	14.86	Unit-II under AMP. 132kV NHP-MHP line-II on Standby.	
		Unit-II	0.00	132kV NHP-MHP-II	0.00		
		Total	14.98	Auxiliary Consumption & Transformation Losses at Generator end	0.80%		

Note: Generation-Load Summary (MW) for 18-Feb-2025 at 18:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	955.89	915.26	40.63

Note: Generation-Load Summary (MW) for 18-Feb-2024, at 18:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	885.34	915.54	-30.20

Note: Daily Energy (MUs) and Power(MW) Statistics for 18-Feb-2025

Sl. No.	Total Energy Generation	Daily Energy Met	Net Energy Import (IEX and Solar)	Net Energy Export	Peak Cross-border (MW)
1	13.85	21.66	7.84	0.30	-741.27

- The Instantaneous load balance, calculated as (Total generation - (Total export-Import) - Total domestic load), do not tend towards zero. This could be due to the following reasons:
 - Not all the meters are digital and nor are all the meter at all locations can be read at same time (say 9:00hrs) due to many meter to be read manually.
 - The clocks of all the locations are not synchronized.
- This report, compiled using the SCADA data, is prepared to give an overall idea of the generation & load flow for the system at a particular instant. This report also gives energy and import/export figures.
- When SCADA data are unavailable for certain stations due to technical issues, required data are collected from the site.