



ལྷན་སྐྱོད་ལྷན་པོའི་རྒྱུ་ཉེན་འགན་དཔལ་ལྷན་པོའི་འཕུལ་གཞི་ལྷན་པོ།  
 Ministry of Energy and Natural Resources  
 Royal Government of Bhutan  
**Office of the Bhutan Power System Operator**  
 Thimphu: Bhutan



**THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 22-Feb-2025(+ve:import, -ve:export)**

Report Details	Date	Time	National Coincidental Peak Load (MW)		Date	Time	Load
	21-Feb-25	09:00 hrs			25-Dec-24	18:38:16	1026.44
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks	
1	6 x 170MW THP	Unit-I	72.00	400kV THP - Siliguri Line - I	33.27	Unit-II & III under AMP. Unit-V under Shutdown. 400kV THP-SIL Line IV on Standby. 400kV THP-SIL Line II under AMP	
		Unit-II	0.00	400kV THP - Siliguri Line - II	0.00		
		Unit-III	0.00	400kV THP - Siliguri Line - IV	0.00		
		Unit-IV	150.00	400kV THP - Malbase Line - III	266.93		
		Unit-V	0.00	400kV Malbase - Siliguri Line	-16.00		
		Unit-VI	80.00	-	-		
		<b>Total</b>	<b>302.00</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.60%</b>		
2	4 x 180MW MHP	Unit-I	171.16	400kV MHP - Jigmeling Line - I	0.00	Unit-III under Shutdown. Unit-IV under AMP. 400kV MHP-JLG Line I & IV on Standby. 132kV MHP_Yurmoo Line- I not in Service.	
		Unit-II	70.19	400kV MHP - Jigmeling Line - II	96.49		
		Unit-III	0.00	400kV MHP - Jigmeling Line - III	96.15		
		Unit-IV	0.00	400kV MHP - Jigmeling Line - IV	0.00		
		-	-	132kV MHP - Yurmo Line - I	0.00		
		-	-	132kV MHP - Yurmo Line - II	63.93		
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	92.16		
		-	-	400kV Jigmeling - Aliparduar Line - I <i>direct lines</i>	129.31		
		-	-	400kV Jigmeling - Aliparduar Line - II <i>direct lines</i>	128.74		
		-	-	80MVA, 220/132kV ICT - I (HV)	27.72		
		-	-	80MVA, 220/132kV ICT - II (HV)	27.86		
		-	-	220kV Tsirang - Jigmeling Line	-14.98		
		-	-	132kV Gelephu - Salakati Line	-2.00		
<b>Total</b>	<b>241.35</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>-0.30%</b>				
3	6 x 170MW PHP-II	Unit-I	160.04	400kV PHP II - Jigmeling - I <i>erstwhile interim lines</i>	0.00	Unit-II on Standby. 400kV PHP-II_ALL line I on Standby.	
		Unit-II	0.00	400kV PHP II - Jigmeling - II	159.90		
		Unit-III	0.00	400kV PHP II - Aliparduar - I	0.00		
		Unit-IV	0.00	400kV PHP II - Aliparduar - II	0.00		
		Unit-V	0.00	-	-		
		Unit-VI	0.00	-	-		
		<b>Total</b>	<b>160.04</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.09%</b>		
4	4 x 84MW CHP	Unit-I	65.61	220kV CHP - Birpara Line - I	-118.06	Unit-II under AMP. Unit-III under Shutdown. 220kV CHP_Gedu line is kept open in order to avoid over loading of 220kV MAL-GEDU line.	
		Unit-II	0.00	220kV CHP - Birpara Line - II	-117.38		
		Unit-III	0.00	220kV CHP - Gedu	0.00		
		Unit-IV	66.20	220kV CHP - Jamjee (old) - I	122.94		
		-	-	220kV CHP - Jamjee - II (new)	123.56		
		-	-	220kV CHP - Jamjee - III (new)	119.22		
		-	-	220kV Malbase - Birpara Line	1.92		
		-	-	66kV CHP - Gedu Line	-0.40		
		-	-	3x3MVA, 66/11kV TFR	1.40		
<b>Total</b>	<b>131.81</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.40%</b>				
5	2 x 12MW BHP (U/S)	Unit-I	5.10	220kV BHP - Semtokha Line	-8.40	U/S Unit-II under Shutdown. L/S Unit-I on Standby. 220kV BHP_TSI line under Breakdown.	
		Unit-II	0.00	66kV BHP - Lobeyasa Line	22.50		
		<b>Total</b>	<b>5.10</b>	220kV BHP - Tsirang Line	0.00		
6	2 x 20MW BHP (L/S)	Unit-I	0.00	5MVA, 66/11kV TFR	0.55		
		Unit-II	9.80	30MVA ICT, 220/66kV (HV)	18.20		
		<b>Total</b>	<b>9.80</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>1.68%</b>		
7	2 x 63MW DHP	Unit-I	17.89	220kV DHP - Tsirang Line	17.69	Unit II under AMP. 220kV DHP-Dagapela line on Standby.	
		Unit-II	0.00	220kV DHP - Dagapela Line	0.00		
		-	-	220kV Jigmeling - Dagapela Line	52.88		
		-	-	5MVA, 220/33kV TFR	0.19		
		<b>Total</b>	<b>17.89</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.06%</b>		
8	4 x 15MW KHP	Unit-I	0.00	132kV KHP - Nangkor Line	9.88	Unit-I under AMP. Unit-II Standby.	
		Unit-II	0.00	132kV KHP - Kiliikhar Line	11.95		
		Unit-III	11.22	5MVA, 132/11kV TFR	0.32		
		Unit-IV	11.23	132kV Motanga - Rangia Line	4.72		
		<b>Total</b>	<b>22.45</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>1.36%</b>		
9	2 x 59MW NHP	Unit-I	14.67	132kV NHP-MHP-I	14.50	Unit-II under AMP. 132kV NHP-MHP line-II on Standby.	
		Unit-II	0.00	132kV NHP-MHP-II	0.00		
		<b>Total</b>	<b>14.67</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>1.16%</b>		

Note: Generation-Load Summary (MW) for 21-Feb-25 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	905.11	860.59	44.52

Note: Generation-Load Summary (MW) for 21-Feb-24 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	894.59	855.23	39.36

THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 22-Feb-2025(+ve:import, +ve:export)							
Report Details	Date	Time	National Coincidental Peak Load (MW)		Date	Time	Load
	21-Feb-2025	18:00 hrs			25-Dec-2024	18:36	1026.44
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks	
1	6 x 170MW THP	Unit-I	10.00	400kV THP - Siliguri Line - I	60.15	Unit-II & III under AMP. 400kV THP-SIL Line IV on Standby. 400kV THP-SIL Line II under AMP	
		Unit-II	0.00	400kV THP - Siliguri Line - II	0.00		
		Unit-III	0.00	400kV THP - Siliguri Line - IV	0.00		
		Unit-IV	150.00	400kV THP - Malbase Line - III	289.64		
		Unit-V	43.00	400kV Malbase - Siliguri Line	7.00		
		Unit-VI	150.00	-	-		
		<b>Total</b>	<b>353.00</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.91%</b>		
2	4 x 180MW MHP	Unit-I	150.17	400kV MHP - Jigmeling Line - I	0.00	Unit-IV under AMP. Unit-III under Shutdown 400kV MHP-JLG line I & IV on Standby. 132kV MHP_Yurmo line-I not in service.	
		Unit-II	60.35	400kV MHP - Jigmeling Line - II	80.63		
		Unit-III	0.00	400kV MHP - Jigmeling Line - III	80.65		
		Unit-IV	0.00	400kV MHP - Jigmeling Line - IV	0.00		
		-	-	132kV MHP - Yurmo Line - I	0.00		
		-	-	132kV MHP - Yurmo Line - II	63.96		
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	94.84		
		-	-	400kV Jigmeling - Alipurduar Line - I <i>direct lines</i>	110.72		
		-	-	400kV Jigmeling - Alipurduar Line - II	109.88		
		-	-	80MVA, 220/132kV ICT - I (HV)	27.57		
		-	-	80MVA, 220/132kV ICT - II (HV)	27.36		
		-	-	220kV Tsirang - Jigmeling Line	14.20		
		-	-	132kV Gelephu - Salakati Line	-4.24		
		<b>Total</b>	<b>210.52</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.09%</b>		
3	6 x 170MW PHP-II	Unit-I	160.80	400kV PHP II - Jigmeling -I	0.00	Unit II on Standby 400kV PHP II-ALI line I on Standby.	
		Unit-II	0.00	400kV PHP II - Jigmeling -II	160.10		
		Unit-III	0.00	400kV PHP II - Alipurduar-I	0.00		
		Unit-IV	0.00	400kV PHP II - Alipurduar -II	0.00		
		Unit-V	0.00	-	-		
		Unit-VI	0.00	-	-		
		<b>Total</b>	<b>160.80</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.44%</b>		
4	4 x 84MW CHP	Unit-I	60.72	220kV CHP - Birpara Line - I	-134.58	Unit-II under AMP. Unit-III under Shutdown. 220kV CHP_Gedu line is kept open in order to avoid over loading of 220kV MAL-GEDU line.	
		Unit-II	0.00	220kV CHP - Birpara Line - II	-133.46		
		Unit-III	0.00	220kV CHP - Gedu	0.00		
		Unit-IV	60.10	220kV CHP - Jamjee - I	130.16		
		-	-	220kV CHP - Jamjee - II	131.09		
		-	-	220kV CHP - Jamjee - III	126.43		
		-	-	220kV Malbase - Birpara Line	17.00		
		-	-	66kV CHP - Gedu Line	1.60		
		-	-	3x3MVA, 66/11kV TFR	1.80		
		<b>Total</b>	<b>120.82</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>-1.84%</b>		
5	2 x 12MW BHP (U/S)	Unit-I	4.60	220kV BHP - Semtokha Line	-10.60	U/S Unit-II under Shutdown. L/S Unit-II on Standby. 220kV BHP_TSI line under Breakdown.	
		Unit-II	0.00	66kV BHP - Lobeysa Line	24.34		
		<b>Total</b>	<b>4.60</b>	220kV BHP - Tsirang Line	0.00		
6	2 x 20MW BHP (L/S)	Unit-I	10.00	5MVA, 66/11kV TFR	0.72		
		Unit-II	0.00	30MVA ICT, 220/66kV (HV)	20.45		
		<b>Total</b>	<b>10.00</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.96%</b>		
7	2 x 63MW DHP	Unit-I	18.18	220kV DHP - Tsirang Line	17.90	Unit II under AMP. 220kV DHP-Dagapela line on Standby.	
		Unit-II	0.00	220kV DHP - Dagapela Line	0.00		
		-	-	220kV Jigmeling - Dagapela Line	53.85		
		-	-	5MVA, 220/33kV TFR	0.10		
<b>Total</b>	<b>18.18</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.99%</b>				
8	4 x 15MW KHP	Unit-I	0.00	132kV KHP - Nangkhon Line	6.98	Unit-I under AMP. Unit-II Standby.	
		Unit-II	0.00	132kV KHP - Kilikhar Line	14.81		
		Unit-III	11.22	5MVA, 132/11kV TFR	0.28		
		Unit-IV	11.18	132kV Motanga - Rangia Line	9.14		
		<b>Total</b>	<b>22.40</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>1.47%</b>		
9	2 x 59MW NHP	Unit-I	15.00	132kV NHP-MHP-I	14.90	Unit-II under AMP. 132kV NHP-MHP line-II on Standby.	
		Unit-II	0.00	132kV NHP-MHP-II	0.00		
		<b>Total</b>	<b>15.00</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.67%</b>		

Note: Generation-Load Summary (MW) for 21-Feb-2025 at 18:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	915.32	873.71	41.61

Note: Generation-Load Summary (MW) for 21-Feb-2024, at 18:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	382.43	696.68	-314.25

Note: Daily Energy (MUs) and Power(MW) Statistics for 21-Feb-2025

Sl. No.	Total Energy Generation	Daily Energy Met	Net Energy Import (IEX and Solar)	Net Energy Export	Peak Cross-border (MW)
1	13.19	21.45	8.57	0.30	-602.84

- The Instantaneous load balance, calculated as (Total generation - (Total export-Import) - Total domestic load), do not tend towards zero. This could be due to the following reasons:
  - Not all the meters are digital and nor are all the meter at all locations can be read at same time (say 9:00hrs) due to many meter to be read manually.
  - The clocks of all the locations are not synchronized.
- This report, compiled using the SCADA data, is prepared to give an overall idea of the generation & load flow for the system at a particular instant. This report also gives energy and import/export figures.
- When SCADA data are unavailable for certain stations due to technical issues, required data are collected from the site.