



ལྷན་སྐྱོང་པོ་དང་འཕེལ་རྒྱུ་ལྷན་ཁག་གི་ལྷན་པོ་ལྷན་པོ།  
 Ministry of Energy and Natural Resources  
 Royal Government of Bhutan  
**Office of the Bhutan Power System Operator**  
 Thimphu: Bhutan



**THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 06-Mar-2025(-ve:import, +ve:export)**

Report Details	Date	Time	National Coincidental Peak Load (MW)	Date	Time	Load
	05-Mar-25	09:00 hrs		25-Dec-24	18:38:16	1026.44

Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks
1	6 x 170MW THP	Unit-I	100.78	400kV THP - Siliguri Line - I	28.21	Unit-II & III under AMP. Unit-IV on Standby. 400kV THP-SIL Line IV on Standby. 400kV THP-SIL Line II under AMP
		Unit-II	0.00	400kV THP - Siliguri Line - II	0.00	
		Unit-III	0.00	400kV THP - Siliguri Line-IV	0.00	
		Unit-IV	0.00	400kV THP - Malbase Line - III	263.59	
		Unit-V	70.57	400kV Malbase - Siliguri Line	-24.08	
		Unit-VI	119.34	-	-	
		<b>Total</b>	<b>290.69</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>-0.38%</b>	
2	4 x 180MW MHP	Unit-I	156.12	400kV MHP - Jigmeling Line - I	91.75	Unit-III under Shutdown. Unit-II On Standby. 400kV MHP-JLG Line II & III on Standby. 132kV MHP_Yurmo Line- I not in Service.
		Unit-II	0.00	400kV MHP - Jigmeling Line - II	0.00	
		Unit-III	0.00	400kV MHP - Jigmeling Line - III	0.00	
		Unit-IV	76.40	400kV MHP - Jigmeling Line - IV	92.31	
		-	-	132kV MHP - Yurmo Line - I	0.00	
		-	-	132kV MHP - Yurmo Line - II	62.70	
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	188.36	
		-	-	400kV Jigmeling - Aliparduar Line - I	87.00	
		-	-	400kV Jigmeling - Aliparduar Line - II	85.71	
		-	-	80MVA, 220/132kV ICT - I (HV)	15.96	
		-	-	80MVA, 220/132kV ICT - II (HV)	15.76	
		-	-	220kV Tsirang - Jigmeling Line	-102.22	
		-	-	132kV Gelephu - Salakati Line	-10.05	
		<b>Total</b>	<b>232.52</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.20%</b>	
3	6 x 170MW PHP-II	Unit-I	180.25	400kV PHP II - Jigmeling -I	0.00	Unit-II on Standby. 400kV PHP-II_ALL line I on Standby.
		Unit-II	0.00	400kV PHP II - Jigmeling -II	179.00	
		Unit-III	0.00	400kV PHP II - Aliparduar -I	0.00	
		Unit-IV	0.00	400kV PHP II - Aliparduar -II	0.00	
		Unit-V	0.00	-	-	
		Unit-VI	0.00	-	-	
		<b>Total</b>	<b>180.25</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.69%</b>	
4	4 x 84MW CHP	Unit-I	36.92	220kV CHP - Birpara Line - I	-56.25	Unit-II on Standby. Unit-III under Shutdown.
		Unit-II	0.00	220kV CHP - Birpara Line - II	-55.90	
		Unit-III	0.00	220kV CHP - Gedu	-53.36	
		Unit-IV	44.32	220kV CHP - Jamjee (old) - I	80.51	
		-	-	220kV CHP - Jamjee - II (new)	80.75	
		-	-	220kV CHP - Jamjee - III (new)	77.89	
		-	-	220kV Malbase - Birpara Line	-35.84	
		-	-	66kV CHP - Gedu Line	6.26	
		-	-	3x3MVA, 66/11kV TFR	1.45	
		<b>Total</b>	<b>81.24</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>-0.14%</b>	
5	2 x 12MW BHP (U/S)	Unit-I	4.90	220kV BHP - Semtokha Line	104.60	U/S Unit-II under Shutdown. L/S Unit-I on Standby.
		Unit-II	0.00	66kV BHP - Lobeysa Line	24.91	
		<b>Total</b>	<b>4.90</b>	220kV BHP - Tsirang Line	-115.43	
6	2 x 20MW BHP (L/S)	Unit-I	0.00	5MVA, 66/11kV TFR	0.45	
		Unit-II	9.50	30MVA ICT, 220/66kV (HV)	20.90	
		<b>Total</b>	<b>9.50</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>-0.90%</b>	
7	2 x 63MW DHP	Unit-I	17.38	220kV DHP - Tsirang Line	17.16	Unit II under AMP. 220kV DHP-Dagapela line on Standby.
		Unit-II	0.00	220kV DHP - Dagapela Line	0.00	
		-	-	220kV Jigmeling - Dagapela Line	52.56	
		-	-	5MVA, 220/33kV TFR	0.21	
		<b>Total</b>	<b>17.38</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.06%</b>	
8	4 x 15MW KHP	Unit-I	0.00	132kV KHP - Nangkor Line	14.84	Unit-I under AMP. Unit-IV on Standby.
		Unit-II	14.23	132kV KHP - Kiliikhar Line	13.04	
		Unit-III	14.23	5MVA, 132/11kV TFR	0.24	
		Unit-IV	0.00	132kV Motanga - Rangia Line	12.00	
		<b>Total</b>	<b>28.46</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>1.19%</b>	
9	2 x 59MW NHP	Unit-I	14.99	132kV NHP-MHP-I	14.71	Unit-II under AMP. 132kV NHP-MHP line-II on Standby.
		Unit-II	0.00	132kV NHP-MHP-II	0.00	
		<b>Total</b>	<b>14.99</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>1.87%</b>	

Note: Generation-Load Summary (MW) for 05-Mar-25 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	859.93	829.13	30.80

Note: Generation-Load Summary (MW) for 04-Mar-24 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	332.05	738.49	-406.44

THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 06-Mar-2025(-ve:import, +ve:export)							
Report Details	Date	Time	National Coincidental Peak Load (MW)		Date	Time	Load
	5-Mar-2025	18:00 hrs			25-Dec-2024	18:36	1026.44
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks	
1	6 x 170MW THP	Unit-I	100.29	400kV THP - Siliguri Line - I	27.79	Unit-II & III under AMP. Unit-IV on Standby. 400kV THP-SIL Line IV on Standby. 400kV THP-SIL Line II under AMP	
		Unit-II	0.00	400kV THP - Siliguri Line - II	0.00		
		Unit-III	0.00	400kV THP - Siliguri Line - IV	0.00		
		Unit-IV	0.00	400kV THP - Malbase Line - III	258.06		
		Unit-V	139.50	400kV Malbase - Siliguri Line	-25.76		
		Unit-VI	46.30	-	-		
		<b>Total</b>	<b>286.09</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.08%</b>		
2	4 x 180MW MHP	Unit-I	76.86	400kV MHP - Jigmeling Line - I	86.00	Unit-II on Standby. Unit-III under Shutdown 400kV MHP-JLG line II & III on Standby. 132kV MHP_Yurmo line-I not in service.	
		Unit-II	0.00	400kV MHP - Jigmeling Line - II	0.00		
		Unit-III	0.00	400kV MHP - Jigmeling Line - III	0.00		
		Unit-IV	145.11	400kV MHP - Jigmeling Line - IV	86.42		
		-	-	132kV MHP - Yurmo Line - I	0.00		
		-	-	132kV MHP - Yurmo Line - II	63.60		
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	193.09		
		-	-	400kV Jigmeling - Alipurdur Line - I	76.36		
		-	-	400kV Jigmeling - Alipurdur Line - II	77.82		
		-	-	80MVA, 220/132kV ICT - I (HV)	18.53		
		-	-	80MVA, 220/132kV ICT - II (HV)	18.41		
		-	-	220kV Tsirang - Jigmeling Line	-104.38		
		-	-	132kV Gelephu - Salakati Line	-10.77		
		<b>Total</b>	<b>221.97</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.34%</b>		
		3	6 x 170MW PHP-II	Unit-I	179.86		400kV PHP II - Jigmeling -I
Unit-II	0.00			400kV PHP II - Jigmeling -II	179.00		
Unit-III	0.00			400kV PHP II - Alipurdur-I	0.00		
Unit-IV	0.00			400kV PHP II - Alipurdur -II	0.00		
Unit-V	0.00			-	-		
Unit-VI	0.00			-	-		
<b>Total</b>	<b>179.86</b>			<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.48%</b>		
4	4 x 84MW CHP	Unit-I	49.86	220kV CHP - Birpara Line - I	-56.31	Unit-II under AMP. Unit-III under Shutdown.	
		Unit-II	0.00	220kV CHP - Birpara Line - II	-55.74		
		Unit-III	0.00	220kV CHP - Gedu	-55.07		
		Unit-IV	56.57	220kV CHP - Jamjee - I	89.29		
		-	-	220kV CHP - Jamjee - II	89.67		
		-	-	220kV CHP - Jamjee - III	86.69		
		-	-	220kV Malbase - Birpara Line	-34.72		
		-	-	66kV CHP - Gedu Line	6.02		
		-	-	3x3MVA, 66/11kV TFR	1.81		
		<b>Total</b>	<b>106.43</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.07%</b>		
5	2 x 12MW BHP (U/S)	Unit-I	5.01	220kV BHP - Semtokha Line	103.31	U/S Unit-II under Shutdown. L/S Unit-I on Standby.	
		Unit-II	0.00	66kV BHP - Lobeysa Line	27.11		
		<b>Total</b>	<b>5.01</b>	220kV BHP - Tsirang Line	-116.36		
6	2 x 20MW BHP (L/S)	Unit-I	0.00	5MVA, 66/11kV TFR	0.62		
		Unit-II	9.80	30MVA ICT, 220/66kV (HV)	23.44		
		<b>Total</b>	<b>9.80</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.88%</b>		
7	2 x 63MW DHP	Unit-I	17.69	220kV DHP - Tsirang Line	17.51	Unit II under AMP. 220kV DHP-Dagapela line on Standby.	
		Unit-II	0.00	220kV DHP - Dagapela Line	0.00		
		-	-	220kV Jigmeling - Dagapela Line	53.69		
		-	-	5MVA, 220/33kV TFR	0.17		
<b>Total</b>	<b>17.69</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.06%</b>				
8	4 x 15MW KHP	Unit-I	16.22	132kV KHP - Nangkhon Line	16.00	Unit-II & IV on Standby.	
		Unit-II	0.00	132kV KHP - Kilikhar Line	15.83		
		Unit-III	16.21	5MVA, 132/11kV TFR	0.29		
		Unit-IV	0.00	132kV Motanga - Rangia Line	14.50		
		<b>Total</b>	<b>32.43</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.96%</b>		
9	2 x 59MW NHP	Unit-I	14.97	132kV NHP-MHP-I	14.80	Unit-II under AMP. 132kV NHP-MHP line-II on Standby.	
		Unit-II	0.00	132kV NHP-MHP-II	0.00		
		<b>Total</b>	<b>14.97</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>1.14%</b>		

Note: Generation-Load Summary (MW) for 05-Mar-2025 at 18:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	874.25	861.08	13.17

Note: Generation-Load Summary (MW) for 04-Mar-2024, at 18:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	218.40	870.70	-652.30

Note: Daily Energy (MUs) and Power(MW) Statistics for 05-Mar-2025

Sl. No.	Total Energy Generation	Daily Energy Met	Net Energy Import (IEX and Solar)	Net Energy Export	Peak Cross-border (MW)
1	15.27	20.15	5.24	0.35	-591.17

- The Instantaneous load balance, calculated as (Total generation - (Total export-Import) - Total domestic load), do not tend towards zero. This could be due to the following reasons:
  - Not all the meters are digital and nor are all the meter at all locations can be read at same time (say 9:00hrs) due to many meter to be read manually.
  - The clocks of all the locations are not synchronized.
- This report, compiled using the SCADA data, is prepared to give an overall idea of the generation & load flow for the system at a particular instant. This report also gives energy and import/export figures.
- When SCADA data are unavailable for certain stations due to technical issues, required data are collected from the site.