



ལྷན་སྐྱོང་དང་འཕེལ་རྒྱུ་ཉམས་ལེན་ དཔལ་འབྲས་སྐྱོང་གཞིའི་ལྷན་ཚོགས་
 Ministry of Energy and Natural Resources
 Royal Government of Bhutan
Office of the Bhutan Power System Operator
 Thimphu: Bhutan



THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 02-Apr-2025(-ve:import, +ve:export)

Report Details		Date	Time	National Coincidental Peak Load (MW)		Date	Time	Load
		April 1, 2025	9:00 AM			25-Dec-24	18:38:16	1026.44
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks		
1	6 x 170MW THP	Unit-I	40.15	400kV THP - Siliguri Line - I	0.00	Unit-IV under AMP. Unit- II, III & VI on Standby. 400kV THP-SIL Line I on Standby. 400kV THP-SIL Line IV under Shutdown.		
		Unit- II	0.00	400kV THP - Siliguri Line - II	-97.17			
		Unit- III	0.00	400kV THP - Siliguri Line- IV	0.00			
		Unit- IV	0.00	400kV THP - Malbase Line - III	148.71			
		Unit- V	11.60	400kV Malbase - Siliguri Line	-141.00			
		Unit- VI	0.00	-	-			
		Total	51.75	Auxiliary Consumption & Transformation Losses at Generator end	0.41%			
2	4 x 180MW MHP	Unit-I	0.00	400kV MHP - Jigmeling Line - I	44.31	Unit-II under AMP. Unit I on Standby. 400kV MHP-JLG line-III & IV on Standby. 132kV MHP_Yurmo Line- I not in Service.		
		Unit-II	0.00	400kV MHP - Jigmeling Line - II	44.09			
		Unit-III	42.04	400kV MHP - Jigmeling Line - III	0.00			
		Unit-IV	93.77	400kV MHP - Jigmeling Line - IV	0.00			
		-	-	132kV MHP - Yurmo Line - I	0.00			
		-	-	132kV MHP - Yurmo Line - II	61.61			
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	207.36			
		-	-	400kV Jigmeling - Alipurduar Line - I	81.46			
		-	-	400kV Jigmeling - Alipurduar Line - II	82.91			
		-	-	80MVA, 220/132kV ICT - I (HV)	19.95			
		-	-	80MVA, 220/132kV ICT - II (HV)	18.74			
		-	-	220kV Tsirang - Jigmeling Line	-116.25			
		-	-	132kV Gelephu - Salakati Line	-12.51			
		Total	135.81	Auxiliary Consumption & Transformation Losses at Generator end	0.34%			
		3	6 x 170MW PHP-II	Unit-I	139.63		400kV PHP II - Jigmeling-I	0.00
Unit- II	0.00			400kV PHP II - Jigmeling-II	290.00			
Unit- III	150.40			400kV PHP II - Alipurduar-I	0.00			
Unit- IV	0.00			400kV PHP II - Alipurduar-II	0.00			
Unit- V	0.00			-	-			
Unit- VI	0.00			-	-			
Total	290.03			Auxiliary Consumption & Transformation Losses at Generator end	0.01%			
4	4 x 84MW CHP	Unit- I	20.07	220kV CHP - Birpara Line - I	-78.49	Unit-II & Unit-III under AMP.		
		Unit- II	0.00	220kV CHP - Birpara Line - II	-77.51			
		Unit- III	0.00	220kV CHP - Gedu	-11.43			
		Unit- IV	21.90	220kV CHP - Jamjee (old) - I	69.48			
		-	-	220kV CHP - Jamjee - II (new)	68.97			
		-	-	220kV CHP - Jamjee - III (new)	66.62			
		-	-	220kV Malbase - Birpara Line	-77.00			
		-	-	66kV CHP - Gedu Line	4.44			
		-	-	3x3MVA, 66/11kV TFR	1.38			
		Total	41.97	Auxiliary Consumption & Transformation Losses at Generator end	-3.55%			
5	2 x 12MW BHP (U/S)	Unit- I	0.00	220kV BHP - Semtokha Line	117.80	U/S Unit-I & L/S Unit-II on Standby.		
		Unit- II	4.35	66kV BHP - Lobeysha Line	23.00			
		Total	4.35	220kV BHP - Tsirang Line	-128.11			
6	2 x 20MW BHP (L/S)	Unit- I	8.56	5MVA, 66/11kV TFR	0.41			
		Unit- II	0.00	30MVA ICT, 220/66kV (HV)	19.35			
		Total	8.56	Auxiliary Consumption & Transformation Losses at Generator end	-1.47%			
7	2 x 63MW DHP	Unit-I	0.00	220kV DHP - Tsirang Line	15.23	Unit-I on Standby. 220kV DHP-Dagapela line on Standby.		
		Unit-II	15.44	220kV DHP - Dagapela Line	0.00			
		-	-	220kV Jigmeling - Dagapela Line	52.26			
		-	-	5MVA, 220/33kV TFR	0.20			
		Total	15.44	Auxiliary Consumption & Transformation Losses at Generator end	0.06%			
8	4 x 15MW KHP	Unit- I	15.22	132kV KHP - Nangkhor Line	17.15	Unit- II under AMP. Unit-III under shutdown.		
		Unit-II	0.00	132kV KHP - Kilikhar Line	12.62			
		Unit- III	0.00	5MVA, 132/11kV TFR	0.28			
		Unit- IV	15.22	132kV Motanga - Rangia Line	0.90			
		Total	30.44	Auxiliary Consumption & Transformation Losses at Generator end	1.28%			
9	2 x 59MW NHP	Unit-I	15.00	132kV NHP-MHP-I	14.66	Unit-II under AMP. 132kV NHP-MHP line-II under AMP.		
		Unit-II	0.00	132kV NHP-MHP-II	0.00			
		Total	15.00	Auxiliary Consumption & Transformation Losses at Generator end	2.27%			
10	2 x 9MW SHP	Unit- I	0.00	66kV SHP-Damdhum (Samtse)	0.00	Interim measure: evacuation is through 33kV system		
		Unit- II	0.00	-	-			
		Total	0.00	Auxiliary Consumption & Transformation Losses at Generator end	0.00%			

Note: Generation-Load Summary (MW) for 01-Apr-25 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	593.35	911.76	-318.41

Note: Generation-Load Summary (MW) for 01-Apr-24 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	250.64	859.78	-609.14

THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 02-Apr-2025(-ve:import, +ve:export)							
Report Details	Date	Time	National Coincidental Peak Load (MW)		Date	Time	Load
	April 1, 2025	18:00:00			25-Dec-2024	18:36	1026.44
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks	
1	6 x 170MW THP	Unit-I	115.47	400kV THP - Siliguri Line - I	0.00	Unit-IV under AMP. Unit- II, III & VI on Standby. 400kV THP-SIL Line I on Standby. 400kV THP-SIL Line IV under Shutdown .	
		Unit-II	0.00	400kV THP - Siliguri Line - II	-57.02		
		Unit-III	0.00	400kV THP - Siliguri Line - IV	0.00		
		Unit-IV	0.00	400kV THP - Malbase Line - III	182.15		
		Unit-V	9.60	400kV Malbase - Siliguri Line	-103.00		
		Unit-VI	0.00	-	-		
		Total	125.07	Auxiliary Consumption & Transformation Losses at Generator end	-0.05%		
2	4 x 180MW MHP	Unit-I	0.00	400kV MHP - Jigmeling Line - I	74.46	Unit-I on Standby. Unit II under AMP. 400kV MHP-JLG Line III on Standby. 400kV MHP-JLG Line IV under shutdown. 132kV MHP_Yurmoo Line- I not in Service.	
		Unit-II	0.00	400kV MHP - Jigmeling Line - II	74.33		
		Unit-III	45.67	400kV MHP - Jigmeling Line - III	0.00		
		Unit-IV	149.53	400kV MHP - Jigmeling Line - IV	0.00		
		-	-	132kV MHP - Yurmoo Line - I	0.00		
		-	-	132kV MHP - Yurmoo Line - II	61.61		
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	46.18		
		-	-	400kV Jigmeling - Alipurduar Line - I	106.63		
		-	-	400kV Jigmeling - Alipurduar Line - II	101.97		
		-	-	80MVA, 220/132kV ICT - I (HV)	0.00		
		-	-	80MVA, 220/132kV ICT - II (HV)	44.58		
		-	-	220kV Tsirang - Jigmeling Line	-114.32		
		-	-	132kV Gelephu - Salakati Line	-4.46		
		Total	195.20	Auxiliary Consumption & Transformation Losses at Generator end	-0.22%		
3	6 x 170MW PHP-II	Unit-I	140.37	400kV PHP II - Jigmeling -I	0.00	Unit-II on Standby. 400kV PHP-II - Jigmeling Line-I on Standby.	
		Unit-II	0.00	400kV PHP II - Jigmeling -II	285.12		
		Unit-III	144.99	400kV PHP II - Alipurduar -I	0.00		
		Unit-IV	0.00	400kV PHP II - Alipurduar -II	0.00		
		Unit-V	0.00	-	-		
		Unit-VI	0.00	-	-		
		Total	285.36	Auxiliary Consumption & Transformation Losses at Generator end	0.08%		
4	4 x 84MW CHP	Unit-I	40.98	220kV CHP - Birpara Line - I	-66.61	Unit-II & Unit-III under AMP.	
		Unit-II	0.00	220kV CHP - Birpara Line - II	-65.95		
		Unit-III	0.00	220kV CHP - Gedu	3.26		
		Unit-IV	45.50	220kV CHP - Jamjee - I	70.74		
		-	-	220kV CHP - Jamjee - II	70.09		
		-	-	220kV CHP - Jamjee - III	67.72		
		-	-	220kV Malbase - Birpara Line	-67.00		
		-	-	66kV CHP - Gedu Line	5.85		
		-	-	3x3MVA, 66/11kV TFR	1.50		
		Total	86.48	Auxiliary Consumption & Transformation Losses at Generator end	-0.14%		
5	2 x 12MW BHP (U/S)	Unit-I	0.00	220kV BHP - Semtokha Line	120.51	U/S Unit-I & L/S Unit-II on Standby	
		Unit-II	4.50	66kV BHP - Lobeyssa Line	23.57		
		Total	4.50	220kV BHP - Tsirang Line	-131.48		
6	2 x 20MW BHP (L/S)	Unit-I	8.70	5MVA, 66/11kV TFR	0.55		
		Unit-II	0.00	30MVA ICT, 220/66kV (HV)	20.25		
		Total	8.70	Auxiliary Consumption & Transformation Losses at Generator end	0.38%		
7	2 x 63MW DHP	Unit-I	0.00	220kV DHP - Tsirang Line	15.37	Unit-I on Standby. 220kV DHP-Dagapela line on Standby	
		Unit-II	15.59	220kV DHP - Dagapela Line	0.00		
		-	-	220kV Jigmeling - Dagapela Line	51.88		
		-	-	5MVA, 220/33kV TFR	0.22		
		Total	15.59	Auxiliary Consumption & Transformation Losses at Generator end	0.00%		
8	4 x 15MW KHP	Unit-I	12.07	132kV KHP - Nangkhor Line	20.41	Unit- II under AMP.	
		Unit-II	0.00	132kV KHP - Kilikhar Line	15.26		
		Unit-III	12.16	5MVA, 132/11kV TFR	0.26		
		Unit-IV	12.12	132kV Motanga - Rangia Line	-1.05		
		Total	36.35	Auxiliary Consumption & Transformation Losses at Generator end	1.16%		
9	2 x 59MW NHP	Unit-I	14.99	132kV NHP-MHP-I	14.78	Unit-II under AMP. 132kV NHP-MHP line-II under AMP.	
		Unit-II	0.00	132kV NHP-MHP-II	0.00		
		Total	14.99	Auxiliary Consumption & Transformation Losses at Generator end	1.40%		
10	2 x 9MW SHP	Unit-I	0.00	66kV SHP-Damdhum (Samtse)	0.00	Interim measure: evacuation is through 33kV system	
		Unit-II	0.00	-	-		
		Total	0.00	Auxiliary Consumption & Transformation Losses at Generator end	0.00%		

Note: Generation-Load Summary (MW) for 01-Apr-2025 at 18:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	772.24	928.73	-156.49

Note: Generation-Load Summary (MW) for 01-Apr-2024, at 18:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	863.17	868.97	-5.80

Note: Daily Energy (MUs) and Power(MW) Statistics for 01-Apr-2025

Sl. No.	Total Energy Generation	Daily Energy Met	Net Energy Import (IEX and Solar)	Net Energy Export	Peak Cross-border (MW)
1	19.05	21.80	3.42	0.67	-369.62

- The Instantaneous load balance,calculated as (Total generation - (Total export-Import) - Total domestic load), do not tend towards zero. This could be due to the following reasons:
 - Not all the meters are digital and nor are all the meter at all locations can be read at same time (say 9:00hrs) due to many meter to be read manually.
 - The clocks of all the locations are not synchronized.
- This report, compiled using the SCADA data, is prepared to give an overall idea of the generation & load flow for the system at a particular instant. This report also gives energy and import/export figures.
- When SCADA data are unavailable for certain stations due to technical issues, required data are collected from the site.