



ལྷན་ཁུངས་དང་འཛམ་གླིང་ཚོད་ལྷན་ཁུངས་ དཔལ་འདུན་འཛུགས་ལྷན་ཁུངས་།
 Ministry of Energy and Natural Resources
 Royal Government of Bhutan
 Office of the Bhutan Power System Operator
 Thimphu: Bhutan



THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 09-Sep-2024(-ve:import, +ve:export)

Report Details	Date	Time	National Coincidental Peak Load (MW)	Date	Time	Load
	08-Sep-24	09:00 hrs		30-Dec-23	18:00 hrs	955.51

Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks
1	6 x 170MW THP	Unit- I	185.25	400kV THP - Siliguri Line - I	233.46	
		Unit- II	185.67	400kV THP - Siliguri Line - II	231.38	
		Unit- III	185.62	400kV THP - Siliguri Line- IV	222.54	
		Unit- IV	186.53	400kV THP - Malbase Line - III	427.95	
		Unit- V	185.71	400kV Malbase - Siliguri Line	176.00	
		Unit- VI	185.73	-	-	
		Total	1,114.51	Auxiliary Consumption & Transformation Losses at Generator end	-0.07%	
2	4 x 180MW MHP	Unit-I	197.57	400kV MHP - Jigmeling Line - I	286.30	400kV MHP-JLG Line III on Standby. 132kV MHP_Yurmoo Line- I not in Service. 400kV JLG_ALI Interim Line I on Standby.
		Unit-II	197.66	400kV MHP - Jigmeling Line - II	285.37	
		Unit-III	195.44	400kV MHP - Jigmeling Line - III	0.00	
		Unit-IV	197.67	400kV MHP - Jigmeling Line - IV	278.87	
		-	-	132kV MHP - Yurmo Line - I	0.00	
		-	-	132kV MHP - Yurmo Line - II	60.98	
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	108.83	
		-	-	400kV Jigmeling - Puna - Alipurduar Line - I	0.00	
		-	-	400kV Jigmeling - Puna - Alipurduar Line - II	184.00	
		-	-	400kV Jigmeling - Alipurduar Line - I	274.91	
		-	-	400kV Jigmeling - Alipurduar Line - II	273.46	
		-	-	80MVA, 220/132kV ICT - I (HV)	33.89	
		-	-	80MVA, 220/132kV ICT - II (HV)	34.69	
		-	-	220kV Tsirang - Jigmeling Line	13.40	
		-	-	132kV Gelephu - Salakati Line	25.34	
Total	788.34	Auxiliary Consumption & Transformation Losses at Generator end	0.51%			
3	4 x 84MW CHP	Unit- I	90.98	220kV CHP - Birpara Line - I	34.63	
		Unit- II	91.36	220kV CHP - Birpara Line - II	34.33	
		Unit- III	91.38	220kV CHP - Gedu	105.07	
		Unit- IV	91.47	220kV CHP - Jamjee (old) - I	60.52	
		-	-	220kV CHP - Jamjee - II (new)	61.35	
		-	-	220kV CHP - Jamjee - III (new)	59.01	
		-	-	220kV Malbase - Birpara Line	19.16	
		-	-	66kV CHP - Gedu Line	9.30	
Total	365.19	Auxiliary Consumption & Transformation Losses at Generator end	0.06%			
4	2 x 12MW BHP (U/S)	Unit- I	11.10	220kV BHP - Semtokha Line	95.20	
		Unit- II	10.20	66kV BHP - Lobeyasa Line	25.67	
		Total	21.30	220kV BHP - Tsirang Line	-62.76	
5	2 x 20MW BHP (L/S)	Unit- I	19.00	5MVA, 66/11kV TFR	0.45	
		Unit- II	18.30	30MVA ICT, 220/66kV (HV)	5.27	
		Total	37.30	Auxiliary Consumption & Transformation Losses at Generator end	0.07%	
6	2 x 63MW DHP	Unit-I	39.33	220kV DHP - Tsirang Line	78.37	220kV DHP_Dagapela Line on Standby.
		Unit-II	39.51	220kV DHP - Dagapela Line	0.00	
		-	-	220kV Jigmeling - Dagapela Line	53.69	
		-	-	5MVA, 220/33kV TFR	0.46	
Total	78.84	Auxiliary Consumption & Transformation Losses at Generator end	0.01%			
7	4 x 15MW KHP	Unit- I	16.05	132kV KHP - Nangkor Line	41.42	
		Unit-II	16.35	132kV KHP - Kilikhar Line	23.17	
		Unit- III	16.61	5MVA, 132/11kV TFR	0.30	
		Unit- IV	16.54	132kV Motanga - Rangia Line	53.36	
		Total	65.55	Auxiliary Consumption & Transformation Losses at Generator end	1.01%	
8	2 x 59MW NHP	Unit-I	64.06	132kV NHP-MHP-I	63.58	
		Unit-II	64.04	132kV NHP-MHP-II	63.59	
		Total	128.10	Auxiliary Consumption & Transformation Losses at Generator end	0.73%	

Note: Generation-Load Summary (MW) for 08-Sep-24 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,617.14	652.24	652.79	951.50	-0.55
2	Eastern Grid	981.99	184.32	178.74	811.07	5.58
	Total	2,599.13	836.56	831.53	1,762.57	5.03

Note: Generation-Load Summary for 08-Sep-23 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,363.61	546.17	537.74	792.00	8.43
2	Eastern Grid	842.75	188.21	184.79	679.98	3.42
	Total	2,206.36	734.38	722.53	1,471.98	11.85

THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 09-Sep-2024(-ve:import, +ve:export)							
Report Details	Date	Time	National Coincidental Peak Load (MW)		Date	Time	Load
	8-Sep-2024	19:00 hrs			30-Dec-2023	18:00 hrs	955.51
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks	
1	6 x 170MW THP	Unit-I	185.48	400kV THP - Siliguri Line - I	222.61		
		Unit-II	185.54	400kV THP - Siliguri Line - II	221.00		
		Unit-III	185.39	400kV THP - Siliguri Line - IV	209.51		
		Unit-IV	186.24	400kV THP - Malbase Line - III	458.86		
		Unit-V	185.77	400kV Malbase - Siliguri Line	156.00		
		Unit-VI	185.15	-	-		
		Total	1,113.57	Auxiliary Consumption & Transformation Losses at Generator end	0.14%		
2	4 x 180MW MHP	Unit-I	197.82	400kV MHP - Jigmeling Line - I	285.26	400kV MHP-JLG Line III on Standby. 132kV MHP_Yurmo Line-I not in Service. 400kV JLG_ALI Interim Line I on Standby.	
		Unit-II	197.80	400kV MHP - Jigmeling Line - II	284.73		
		Unit-III	195.64	400kV MHP - Jigmeling Line - III	0.00		
		Unit-IV	197.58	400kV MHP - Jigmeling Line - IV	285.26		
		-	-	132kV MHP - Yurmo Line - I	0.00		
		-	-	132kV MHP - Yurmo Line - II	60.98		
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	139.27		
		-	-	400kV Jigmeling - Puna - Alipurduar Line - I	0.00		
		-	-	400kV Jigmeling - Puna - Alipurduar Line - II	176.00		
		-	-	400kV Jigmeling - Alipurduar Line - I	262.55		
		-	-	400kV Jigmeling - Alipurduar Line - II	262.55		
		-	-	80MVA, 220/132kV ICT - I (HV)	41.27		
		-	-	80MVA, 220/132kV ICT - II (HV)	40.95		
		-	-	220kV Tsirang - Jigmeling Line	-0.66		
		-	-	132kV Gelephu - Salakati Line	29.01		
Total	788.84	Auxiliary Consumption & Transformation Losses at Generator end	-0.02%				
3	4 x 84MW CHP	Unit-I	91.76	220kV CHP - Birpara Line - I	31.41		
		Unit-II	91.45	220kV CHP - Birpara Line - II	30.80		
		Unit-III	91.53	220kV CHP - Gedu	77.30		
		Unit-IV	91.78	220kV CHP - Jamjee (old) - I	72.77		
		-	-	220kV CHP - Jamjee - II (new)	73.33		
		-	-	220kV CHP - Jamjee - III (new)	70.81		
		-	-	220kV Malbase - Birpara Line	34.45		
		-	-	66kV CHP - Gedu Line	8.76		
		-	-	3x3MVA, 66/11kV TFR	1.02		
Total	366.52	Auxiliary Consumption & Transformation Losses at Generator end	0.09%				
4	2 x 12MW BHP (U/S)	Unit-I	10.78	220kV BHP - Sentsokha Line	99.76		
		Unit-II	9.81	66kV BHP - Lobeyasa Line	28.05		
		Total	20.59	220kV BHP - Tsirang Line	-71.91		
5	2 x 20MW BHP (L/S)	Unit-I	17.78	5MVA, 66/11kV TFR	0.75		
		Unit-II	18.13	30MVA ICT, 220/66kV (HV)	8.77		
		Total	35.91	Auxiliary Consumption & Transformation Losses at Generator end	-0.27%		
6	2 x 63MW DHP	Unit-I	38.30	220kV DHP - Tsirang Line	75.30	220kV DHP_Dagapela Line on Standby.	
		Unit-II	37.50	220kV DHP - Dagapela Line	0.00		
		-	-	220kV Jigmeling - Dagapela Line	55.05		
		-	-	5MVA, 220/33kV TFR	0.49		
Total	75.80	Auxiliary Consumption & Transformation Losses at Generator end	0.01%				
7	4 x 15MW KHP	Unit-I	16.44	132kV KHP - Nangkor Line	39.11		
		Unit-II	16.50	132kV KHP - Kilikhar Line	25.82		
		Unit-III	16.56	5MVA, 132/11kV TFR	0.43		
		Unit-IV	16.60	132kV Motanga - Rangia Line	56.10		
		Total	66.10	Auxiliary Consumption & Transformation Losses at Generator end	1.12%		
8	2 x 59MW NHP	Unit-I	64.02	132kV NHP-MHP-I	63.62		
		Unit-II	63.99	132kV NHP-MHP-II	63.61		
		Total	128.01	Auxiliary Consumption & Transformation Losses at Generator end	0.61%		

Note: Generation-Load Summary (MW) for 08-Sep-2024 at 19:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,612.39	707.27	705.50	905.78	1.77
2	Eastern Grid	982.95	196.08	194.72	786.21	1.36
	Total	2,595.34	903.35	900.22	1,691.99	3.13

Note: Generation-Load Summary (MW) for 08-Sep-2023, at 19:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,421.51	631.61	621.71	781.37	9.90
2	Eastern Grid	840.04	204.91	200.46	643.66	4.45
	Total	2,261.55	836.52	822.17	1,425.03	14.35

Note: Daily Energy (MUs) and Power(MW) Statistics for 08-Sep-2024

Sl. No.	Net Energy Export (Bilateral)	Net Energy Import (Bilateral)	Daily Energy Met	Total Energy Generation	Peak Cross-border (MW)	Imp./Exp. through Exchange (MUs)
1	40.73	0.00	20.18	62.30	1,795.08	1.53

- The Instantaneous load balance, calculated as (Total generation - (Total export-Import) - Total domestic load), do not tend towards zero. This could be due to the following reasons:
 - Not all the meters are digital and nor are all the meter at all locations can be read at same time (say 9:00hrs) due to many meter to be read manually. ii) The clocks of all the locations are not synchronized.
- This report, compiled using the SCADA data, is prepared to give an overall idea of the generation & load flow for the system at a particular instant. This report also gives energy and import/export figures.
- When SCADA data are unavailable for certain stations due to technical issues, required data are collected from the site.