

BHUTAN POWER CORPORATION LIMITED

BHUTAN POWER SYSTEM OPERATOR

THIMPHU: BHUTAN



ANNUAL TRANSMISSION SYSTEM PERFORMANCE REPORT FOR THE YEAR 2021

JANUARY-2022

Sl. No.	Table of Contents	Page No.
1.0	INTRODUCTION	3
2.0	PERFORMANCE OF GENERATING STATIONS	3
2.1	POWER GENERATION	3
2.2	PLANT FACTOR	5
3.0	PEAK DEMAND, ENERGY AVAILABILITY AND REQUIREMENT FOR THE COUNTRY.....	8
3.1	NATIONAL LOAD	8
3.2	WESTERN GRID PEAK LOAD	10
3.3	EASTERN GRID PEAK LOAD	11
4.0	EXPORT AND IMPORT OF ELECTRICITY TO/FROM NEIGHBORING COUNTRIES.....	12
4.1	EXPORT OF ELECTRICITY TO NEIGHBORING COUNTRY	12
4.2	IMPORT OF ELECTRICITY FROM NEIGHBORING COUNTRY	13
5.0	FREQUENCY PROFILE: MAXIMUM AND MINIMUM FREQUENCY RECORDED AND THE FREQUENCY DURATION IN DIFFERENT FREQUENCY BANDS	15
6.0	VOLTAGE PROFILE OF SELECTED SUBSTATIONS.....	16
7.0	MAJOR GENERATING AND TRANSMISSION OUTAGE	19
8.0	TRANSMISSION CONSTRAINTS.....	19
9.0	INSTANCES OF PERSISTENT OR SIGNIFICANT NON-COMPLIANCE WITHIN THE GIRD CODE REGULATION.....	19

1.0 INTRODUCTION

In compliance to Grid Code Regulation 2008, Clause No. 6.14.2.1, this office prepared an annual report covering the performance of the Transmission System and details as required by the Ministry and the Authority annually for development of power system master plan and formulation of other policy decisions, thus this report contains the performance of Transmission System for the year 2019.

All the index and other calculations in this report have been executed based on the data received from substations and generating plants.

2.0 PERFORMANCE OF GENERATING STATIONS


2.1 POWER GENERATION

The maximum individual plant generation was recorded as 1122.00 MW by the Tala Hydropower Plant, followed by 792.05 MW by Mangdichu Hydropower Plant.


Table: 2.1.1 Monthly maximum and minimum generation summary

Sl.No	Hydropower Plant	Monthly Maximum and Minimum Generation (MW)												Max/Min of year (MW)		
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec			
1	BHP	Max	25.50	19.43	26.44	21.83	65.84	65.79	66.22	66.55	66.63	66.34	59.91	50.02	66.63	
		Min	6.54	14.81	2.93	4.41	4.12	0.00	24.51	2.24	0.00	47.05	4.15	8.47	0.00	
2	CHP	Max	169.33	101.90	171.12	182.08	278.79	369.79	66.00	371.92	369.70	371.66	365.32	185.32	371.92	
		Min	66.80	66.62	3.00	49.24	124.81	217.70	31.62	275.68	275.86	11.15	172.54	58.57	3.00	
3	THP	Max	270.00	320.00	300.00	263.81	1,122.00	1,122.00	1,122.00	1,122.00	1,122.00	1,122.00	750.00	440.00	1,122.00	
		Min	130.00	70.00	60.00	27.60	270.00	430.00	360.00	100.00	100.00	280.00	240.00	130.00	27.60	
4	KHP	Max	31.68	31.15	64.49	60.33	66.18	66.00	66.00	66.00	66.00	66.00	60.62	45.33	66.18	
		Min	10.13	10.11	11.09	10.08	31.58	12.67	31.62	30.23	16.50	48.26	27.97	10.46	10.08	
5	DHP	Max	27.72	26.66	40.29	25.02	126.92	127.47	95.10	100.70	100.79	100.70	52.27	40.03	127.47	
		Min	19.19	1.23	9.75	11.06	17.16	0.00	5.50	1.13	40.30	48.74	31.31	23.06	0.00	
6	MHP	Max	144.91	179.50	264.71	357.70	792.05	594.06	594.16	790.86	790.56	789.00	441.67	363.67	792.05	
		Min	89.50	9.64	49.73	19.70	180.03	190.64	79.29	239.72	236.31	226.31	101.38	30.19	9.64	


Graph: 2.1.1 Basochhu generation summary




Graph: 2.1 Chhukha generation summary




Graph: 2.1.3 Tala generation summary



Graph: 2.1.4 Kurichhu generation summary



Graph: 2.1.5 Dagachhu generation summary



Graph: 2.1.6 Mangdichu generation summary



2.2 PLANT FACTOR

The plant factor of each generating plant was calculated as below:


$$\text{Plant factor} = (\text{Actual output of a plant over a period of time}) / (\text{Output when operated at name plate rated capacity for entire time})$$

$$= (\text{Total energy plant has produced over a period}) / (\text{Total energy plant would produce when operated at full rated capacity})$$


Table: 2.2.1 Monthly plant factor of the hydropower plants

Sl. No	Hydropower Plant	Monthly Plant Factor (%)												Max/Min of year	
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Max	Min
1	BHP	33.23	24.23	23.77	20.76	37.81	62.00	102.32	99.48	99.64	93.84	69.92	45.04	102.32	20.76
2	CHP	27.96	20.74	24.45	25.97	65.93	96.71	19.33	108.76	105.64	99.04	70.17	43.78	108.76	19.33
3	THP	18.14	14.12	16.23	13.04	56.25	82.38	78.63	96.48	87.56	78.47	45.41	28.10	96.48	13.04
4	KHP	34.63	26.87	39.37	43.86	97.93	102.30	108.23	106.79	101.73	105.07	64.16	45.25	108.23	26.87
5	DHP	18.18	13.44	13.92	11.58	32.59	56.93	93.50	86.62	81.25	64.58	44.39	28.29	93.50	11.58
6	MHP	0.00	0.12	11.92	0.00	56.25	0.00	0.00	25.68	28.08	30.75	23.93	31.55	56.25	0.00


Graph: 2.2.1 Plant factor of Basochhu Hydropower Plant




Graph: 2.2.2 Plant factor of Chhukha Hydropower Plant




Graph: 2.2.3 Plant factor of Tala Hydropower Plant




Graph: 2.2.4 Plant factor of Kurichhu Hydropower Plant



Graph: 2.2.4 Plant factor of Dagachhu Hydropower Plant



Graph: 2.2.4 Plant factor of Mangdichu Hydropower Plant



3.0 PEAK DEMAND, ENERGY AVAILABILITY AND REQUIREMENT FOR THE COUNTRY

Calculation of coincidental peak load for the eastern grid, western grid and national load, we use the following methods:

1. *National Demand = (Sum of all total generation of each plant) – (Sum of all Export/Import)*
2. *National Demand = (Sum of all feeders loading at hydropower plant) – (Sum of all Export/Import)*
3. *National Demand = (Sum of all substation loading)*

The national load calculated using method-3 is considered in the report.

3.1 NATIONAL LOAD


The national coincidental peak load for the year was recorded 43535 MW (Increased by 16 % compare to 2020 (374.53 MW)) on December 27, 2020 at 18:02:18 Hrs. using method-2 (sum of all feeder loading at hydropower plant minus sum of export/import). The main factor contributing towards the increase in Bhutan peak load in 2021 could be because of more production by the industries numbers of new substations came up in 2020.

Year	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021
Peak Load (MW)	157.36	187.05	237.17	256.95	276.24	282.44	313.94	333.41	336.52	335.87	362.09	399.35	387.66	374.53	435.35
% Growth over previous Year	-	18.87	26.79	8.34	7.51	2.24	11.15	6.20	0.93	-0.19	7.81	10.29	-2.93	-3.39	16.24

Table: 3.1.2 Monthly national peak load and corresponding generation using method- 3

Sl. No	Months	Date	Time	Total Grid (MW)		Western Grid (MW)		Eastern Grid (MW)	
				Load	Generation	Load	Generation	Load	Generation
1	Jan	23-Jan-21	19:00	330.32	408.90	259.39	277.62	70.93	131.28
2	Feb	6-Feb-21	19:00	321.55	363.75	248.79	258.85	72.76	104.90
3	Mar	14-Mar-21	19:00	332.75	570.68	252.60	355.78	80.16	214.90
4	Apr	14-Feb-21	19:00	320.23	372.57	251.62	219.29	68.93	153.28
5	May	6-May-21	19:00	304.53	966.50	235.12	630.70	69.41	335.80
6	Jun	28-Jun-21	22:00	362.79	1,506.50	328.00	973.60	34.79	532.90
7	Jul	6-Jul-21	20:00	303.69	1,971.76	227.70	1,314.02	110.52	657.74
8	Aug	15-Aug-21	21:00	429.77	2,280.06	304.00	1,620.83	125.77	659.23
9	Sep	2-Sep-21	19:00	345.54	2,475.19	345.00	1,619.82	123.49	855.37
10	Oct	30-Oct-21	18:00	422.69	1,562.45	286.94	1,220.36	135.75	342.09
11	Nov	7-Oct-21	18:00	391.05	1,156.09	257.55	872.44	133.50	283.65
12	Dec	26-Dec-21	18:00	435.35	700.94	276.64	405.53	158.70	295.41
National Peak Load of the year (MW)				435.35					

Graph: 3.1.2 Monthly national peak load and corresponding generation using method- 3




3.2 WESTERN GRID PEAK LOAD

Using method-3, the peak load for the western grid was 46251 MW which occurred on May 23, 2021.

Table: 3.2.1 Monthly western peak load and corresponding generation

Sl. No	Months	Date	Time	Western Grid (MW)	
				Load	Generation
1	Jan	8-Jan-21	19:00	259.54	303.82
2	Feb	6-Feb-21	19:00	254.95	258.85
3	Mar	21-Mar-21	19:00	256.08	410.23
4	Apr	14-Feb-21	19:00	251.30	219.29
5	May	6-May-21	19:00	235.12	630.70
6	Jun	28-Jun-21	22:00	328.00	973.60
7	Jul	9-Jul-21	16:00	227.70	1,314.02
8	Aug	15-Aug-21	14:00	311.01	1,620.45
9	Sep	2-Sep-21	19:00	345.00	1,621.18
10	Oct	7-Oct-21	22:00	321.48	1,110.01
11	Nov	8-Oct-21	9:00	329.21	917.96
12	Dec	27-Dec-21	18:00	286.78	409.31
Western Peak Load of the year (MW)				345.00	

Graph: 3.2.1 Monthly western peak load and corresponding generation




3.3 EASTERN GRID PEAK LOAD

Using method-2, the peak load for the eastern grid was 12759 which occurred on July, 2021.

Table: 3.3.1 Monthly eastern peak load and corresponding generation

Sl. No	Months	Date	Time	Eastern Grid (MW)	
				Load	Generation
1	Jan	17-Jan-21	18:00	76.54	132.33
2	Feb	4-Feb-21	19:00	76.28	104.76
3	Mar	22-Mar-21	19:00	84.70	139.13
4	Apr	21-Apr-21	19:00	70.94	157.65
5	May	3-May-21	19:00	79.10	226.39
6	Jun	14-Jun-21	20:00	77.56	455.26
7	Jul	1-Jul-21	17:00	110.52	658.77
8	Aug	21-Aug-21	19:00	168.54	840.26
9	Sep	1-Sep-21	19:00	125.12	854.17
10	Oct	30-Oct-21	18:00	135.75	647.46
11	Nov	4-Oct-21	7:00	141.42	458.84
12	Dec	26-Dec-21	18:00	158.70	295.41
Eastern Peak Load of the year (MW)				168.54	

Graph: 3.3.1 Monthly eastern peak load and corresponding generation



4.0 EXPORT AND IMPORT OF ELECTRICITY TO/FROM NEIGHBORING COUNTRIES


4.1 EXPORT OF ELECTRICITY TO NEIGHBORING COUNTRY

Maximum export of electricity for the year was 1,114.00MW to Binaguri substation in September, 2021, followed by 361.00MW to Birpara substation. The minimum export was 0.00 MW to Binaguri substation.


Table: 4.1.1 Monthly power export summary

SL No	Substation in India	Monthly Maximum and Minimum Export (MW)												Max/Min of year (MW)	
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
1	Binaguri	Max	192.00	79.00	204.00	194.00	1,041.00	238.00	355.00	1,113.00	1,114.00	453.00	0.00	457.00	1,114.00
		Min	41.00	1.00	1.00	11.00	211.00	1.00	0.90	1.09	1.00	1.00	0.00	21.00	0.00
2	Birpara	Max	50.40	35.30	58.40	67.40	228.47	319.50	216.89	361.00	324.80	292.87	194.73	53.31	361.00
		Min	0.10	0.60	0.10	0.30	2.10	11.00	68.08	160.46	129.00	8.76	0.28	0.04	0.04
3	Salakoti & Rangia	Max	14.20	11.02	32.35	33.61	106.55	165.23	109.41	102.47	99.36	48.57	50.56	23.73	165.23
		Min	1.02	0.56	0.13	0.16	0.59	16.94	29.80	9.04	7.56	0.56	0.10	0.08	0.08


Graph: 4.1.1 Monthly power export to Binaguri substation



Graph: 4.1.2 Monthly power export to Birpara substation



Graph: 4.1.3 Monthly net power export to Salakoti and Rangia substation




4.2 IMPORT OF ELECTRICITY FROM NEIGHBORING COUNTRY

Maximum import of power was 116.20 MW from Birpara substation which occurred in February, 2019 followed by 89.50 MW and 75 MW from Salakoti and Rangia and Binaguri respectively.


Table: 4.2.1 Monthly power import summary

SL No	Substation in India	Monthly Maximum and Minimum Import (MW)												Max/Min of year (MW)		
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec			
1	Binaguri	Max	40.00	101.00	43.00	0.00	0.00	297.00	188.00	23.00	27.00	300.00	358.00	108.00	358.00	
		Min	40.00	2.00	1.00	0.00	0.00	1.00	0.30	0.36	2.00	1.00	2.00	9.00	0.00	0.00
2	Birpara	Max	62.40	70.00	102.23	65.02	25.30	0.00	0.00	0.00	0.00	0.00	100.90	69.18	102.23	
		Min	0.30	0.05	0.40	0.03	1.20	0.00	0.00	0.00	0.00	0.00	0.38	0.04	0.00	0.00
3	Salakoti & Rangia	Max	64.05	54.90	54.22	45.50	29.03	18.03	0.00	0.00	1.16	0.00	4.00	17.20	64.05	
		Min	0.19	1.50	0.07	0.03	0.17	18.03	0.00	0.00	0.26	0.00	1.53	0.03	0.00	0.00


Graph: 4.2.1 Power import from Binaguri substation summary



Graph: 4.2.2 Power import from Birpara substation summary



Graph: 4.2.3 Power import from Salakoti and Rangia substation summary



5.0 FREQUENCY PROFILE: MAXIMUM AND MINIMUM FREQUENCY RECORDED AND THE FREQUENCY DURATION IN DIFFERENT FREQUENCY BANDS

As per the Grid Code Regulation 2008, Clause 6.4.1 the transmission system frequency was classified into three different bands as follows:

1. *Normal state*
The transmission system frequency is within the limit of 49.5Hz to 50.5Hz
2. *Alert state*
The transmission system frequency is beyond the normal operating limit but within 49.0Hz to 51.0Hz
3. *Emergency state*
There is generation deficiency and frequency is below 49.0Hz.

We base our frequency at 220kV Bus frequency at 220/66/11kV Semtokha substation in the western grid and 132kV Bus frequency at 50Hz and Kurichhu Hydropower Plant in the eastern grid.

Table: 5.0.1 Frequency profile at Semtokha substation

220/66/11kV Semtokha Substation					
Sl No	Months	220kV Bus Frequency Operation State (%)			
		Normal	Alert	Emergency	Blackout/Other
1	Jan	100.00	0.00	0.00	0.00
2	Feb	100.00	0.00	0.00	0.00
3	Mar	100.00	0.00	0.00	0.00
4	Apr	96.51	0.13	0.00	3.36
5	May	100.00	0.00	0.00	0.00
6	Jun	100.00	0.00	0.00	0.00
7	Jul	100.00	0.00	0.00	0.00
8	Aug	99.23	0.00	0.00	0.00
9	Sep	96.51	0.13	0.00	3.36
10	Oct	100.00	0.00	0.00	0.00
11	Nov	100.00	0.00	0.00	0.00
12	Dec	0.00	0.00	0.00	0.00
Operation State for the year		91.02%	0.02%	0.00%	0.56%

Graph: 5.0.1 Frequency profile at Semtokha substation





Table: 5.0.2 Frequency profile at Kurichhu Hydropower plant

Sl. No	Months	132kV Bus Frequency Operation State (%)			
		Normal	Alert	Emergency	Blackout/Other
1	Jan	99.87	0.13	0.00	0.00
2	Feb	90.32	0.00	0.00	9.68
3	Mar	99.60	0.00	0.27	0.13
4	Apr	96.37	0.00	0.00	3.63
5	May	100.00	0.00	0.00	0.00
6	Jun	96.77	0.00	0.00	3.23
7	Jul	100.00	0.00	0.00	0.00
8	Aug	100.00	0.00	0.13	0.00
9	Sep	96.77	0.00	0.00	3.23
10	Oct	99.73	0.00	0.13	0.13
11	Nov	96.37	0.13	0.13	3.36
12	Dec	0.00	0.00	0.00	0.13
Operation State for the year		89.65%	0.02%	0.06%	1.96%

Graph: 5.0.2 Frequency profile at Kurichhu Hydropower Plant



6.0 VOLTAGE PROFILE OF SELECTED SUBSTATIONS

As the Grid Code Regulation 2008, Clause 6.4.1, the voltage at all connection points was classified into three different bands as follows:


1. *Normal state*
The voltages at all connection point are within the limits of 0.95 times and 1.05 times of the normal values
2. *Alert state*
The voltage at all connection points are outside the normal limit but within the limits of 0.9 times and 1.1 times of the normal values
3. *Emergency state*
Transmission system voltages are outside the limits of 0.9 times and 1.1 times of nominal values.

The voltage profile of 400/220/66/11kV Malbase substation in western grid and 132/33/11kV Nangkhor substation in the eastern grid are considered in the report.

Table: 6.0.1 Voltage profile at Malbase substation

400/220/66/11kV Malbase Substation									
Sl. No	Months	400kV Bus Voltage Operation State (%)				220kV Bus Voltage Operation State (%)			
		Normal	Alert	Emergency	Blackout/Other	Normal	Alert	Emergency	Blackout/Other
1	Jan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
2	Feb	89.78	0.54	0.00	9.68	90.05	0.00	0.27	9.68
3	Mar	98.39	1.61	0.00	0.00	100.00	0.00	0.00	0.00
4	Apr	96.10	0.27	0.00	3.63	92.07	4.44	0.00	3.49
5	May	100.00	0.00	0.00	0.00	99.87	0.13	0.00	0.00
6	Jun	96.77	0.00	0.00	3.23	96.51	0.27	0.00	3.23
7	Jul	98.12	1.61	0.27	0.00	100.00	0.00	0.00	0.00
8	Aug	0.00	0.00	0.00	0.00	100.00	0.00	0.00	0.00
9	Sep	96.77	0.00	0.00	3.23	96.77	0.00	0.00	3.23
10	Oct	100.00	0.00	0.00	0.00	100.00	0.00	0.00	0.00
11	Nov	70.97	14.52	0.27	14.25	96.77	0.00	0.00	3.23
12	Dec	93.95	0.00	0.00	0.06	100.00	0.00	0.00	0.00
Operation State for year		78.41%	1.55%	0.04%	2.84%	89.34%	0.40%	0.02%	1.90%

Graph: 6.0.1 Voltage profile at Malbase substation at 400kV bus



Graph: 6.0.2 Voltage profile at Malbase substation at 220kV bus





Table: 6.0.2 Voltage profile at Nangkhon substation

Sl. No	Months	132kV Bus Voltage Operation State (%)			
		Normal	Alert	Emergency	Blackout/Other
1	Jan	100.00	0.00	0.00	0.00
2	Feb	90.32	0.00	0.00	9.68
3	Mar	99.33	0.00	0.00	0.67
4	Apr	94.89	4.97	0.00	0.13
5	May	97.18	2.82	0.00	0.00
6	Jun	96.77	0.00	0.00	3.23
7	Jul	100.00	0.00	0.00	0.00
8	Aug	0.00	0.00	0.00	0.67
9	Sep	92.74	0.13	0.00	7.12
10	Oct	99.87	0.00	0.00	0.13
11	Nov	96.77	0.00	0.00	3.23
12	Dec	0.00	0.00	0.00	0.00
Operation State for year		80.66%	0.66%	0.00%	2.07%

Graph: 6.0.3 Voltage profile at Nangkhon substation



7.0 MAJOR GENERATING AND TRANSMISSION OUTAGE

The summary of the major transmission outages for the eastern grid and western grid are attached as Annexure- I and Annexure- II respectively.

The outages of transmission line or transformer or any power system equipment below 66kV, tripping/outage of less than 30minutes and planned shutdown which do not cause supply interruption to the customers are not reflected.

8.0 TRANSMISSION CONSTRAINTS

There are no instant of transmission constraints during normal condition in Bhutan Power System.

9.0 INSTANCES OF PERSISTENT OR SIGNIFICANT NON-COMPLIANCE WITHIN THE GRID CODE REGULATION

The instance of non-compliance with the Grid Code Regulation 2008 for the year 2019 was not recorded.

**Eastern Grid Outages
January 2021**

Tripping Report for the of month January, 2021 under SMD Deothang Substation,TD,BPC													
Sl. No.	Date of Tripping	Time of outages	Date of Normalization	Time of fault was cleared	Duration of Outages (Hrs)	MW before outage (MW)	MU Lost during outages	Feeder Name	Name of the Substation/lines affected by the fault	Reasons of fault	Relay operations	Exact location of fault (Line segment/ Substation)	Remarks
L.131/33/11KV K300kar Substation													
132kV Feeder													
NO TRIPPING													
J.131/33/11KV Kanglung Substation													
132kV Feeder(No Tripping)													
K.131/33/11KV Deothang Substation													
132kV Feeder													
1	25.01.2021	8:30	25.01.2021	17:20	8	11.916		132kV Motonga	Motonga Line	NA	Nil	DR fldr between Deothang-Matonga	As per Approved order REF/MSG No.10A/BPC/BPSO/PSOD/Vol-1/2021/09, dated 21-01-2021, Code No 0050 by Madham Tshering Yangzom, BPSO, Thimphu dated 25.01.2021.(Breaker, both isolator open and Earth switch closed done).Charge the fldr with closing code:1189(Tshering Yangzom BPSO) and found normal.
2	26.01.2021	8:30	26.01.2021	14:43	6	9.11		132kV Motonga	Motonga Line	NA	Nil	DR fldr between Deothang-Matonga	As per Approved order REF/MSG No.10A/BPC/BPSO/PSOD/Vol-1/2021/09, dated 21-01-2021, Code No 0054 by Miss Tshering Choden, BPSO, Thimphu dated 26.01.2021.(Breaker, both isolator open and Earth switch closed done).Charge the fldr with closing code:1193(Karma BPSO) and found normal.
3	27.01.2021	8:10	27.01.2021	15:19	7	6.948		132kV Motonga	Motonga Line	NA	Nil	DR fldr between Deothang-Matonga	As per Approved order REF/MSG No.10A/BPC/BPSO/PSOD/Vol-1/2021/09, dated 21-01-2021, Code No 0059 by Miss Tshering Choden, BPSO, Thimphu dated 27.01.2021.(Breaker, both isolator open and Earth switch closed done).Fldr charged with closing code 1198. Yshering Choden BPSO, fldr found normal
K.131/33/11KV Nangkhoe substation													
132kV Feeder													
1	16.01.2021	07:19hrs	16.01.2021	07:23hrs	0	0.35		5MVA Trf-IL132/11KV	All 11KV & 11KV feeders	Transient fault	Non directional EDMT O/C Relay-58A,51A,50C,51C & tripping relay 88 operated.	Nangkhoe Substation	Tripped while test charging 11KV Wamrong Feeder.
2	26.01.2021	14:10 hrs	26.01.2021	16:02 hrs	1	2.34		Nangkhoe-Nanglam	Nangkhoe-Nanglam line	NA	-	Nanglam Substation	V phase Disc Insulator decapped/junctured at Nanglam Substation. Closed the CB with closing code-1193 from BPSO, Thimphu.
S.132/33/11KV Nanglam substation													
NO TRIPPING													
1	20.01.2021	18:18	20.01.2021	18:03	1	-2.15		Nangkhoe Nanglam	Nangkhoe Nanglam	Suspension insulator for V Phase got fractured and Jumper got touch with structure	NA	Substation	V Phase Suspension insulator got Fractured and Jumper has touched with tower structure so Emergency CB had trip was done to avoid any other damages to Line equipments and informed to BPSO regarding the matter. Supply was restored after replacing of broken Insulator with switch ON code# 1193 issued by Miss. Thering Yangzom, BPSO
1	21.12.2020	14:39	21.12.2020	15:18	0	+7.2		Gel-Gal	non	Temporary fault	sp.YB-PL,Zone -1,dr	Sakarti line	

February 2021

Tripping Report for the of month February, 2021 under SMD Bhutan, TBSPC												
Sl. No.	Date of Tripping	Time of Outages	Date of Normalization	Time of Fault was Cleared	Duration of Outages (Hrs)	MVA before outage (MW)	Feeder Name	Name of the Substation/lines affected by the fault	Reasons of fault	Relay operations	Exact location of fault [Line segment/ Substation]	Remarks
2. 332-35311kV Kampong Substation (110kV Feeder/No Tripping)												
1	07.02.2021	06.01	07.02.2021	10.10	2.09	2222	Phunthochang	Phunthochang	Breaker failure	Distance relay-4pt.	Kampong to	Transfer done since not tripping with same fault due to breaker protection supply was broken through transfer bus(charging code 2307,Agas main breaker charging code 1307,Transfer bus opening code 0117)
4. 332-35311kV Wangdue substation (110kV Feeder)												
1	03.02.2021	15:00 hrs	03.02.2021	06:40 hrs	1	0.04	L12:10KV, 5MVA Tr-F	L12:10KV, 5MVA Tr-F	SA	-	Namghar Substation	Emergency shut down taken by Substation incharge to attend oil leakage. No supply was interrupted.
2	25.02.2021	13:20 hrs	25.02.2021	13:41 hrs	0	0.47	L12:10KV, 5MVA Tr-F	AD 11KV & 11KV feeders	Tripped on fault	Non-directional IDMT OC-SA,FA, NC, TIC & tripping relay BS operated	Namghar Substation	Tripped due to fault on 10KV Yarang feeder.
3	25.02.2021	13:20 hrs	25.02.2021	13:41 hrs	0	0.27	L12:10KV, 5MVA Tr-F	AD 11KV & 11KV feeders	Tripped on fault	Non-directional IDMT OC-SA,FA, TIC, & tripping relay BS operated	Namghar Substation	Tripped due to fault on 10KV Yarang feeder.
5. 332-35311kV Ngangsan substation (110kV Feeder)												
1	20.01.2021	09:00	20.01.2021	09:15	0	1.00	10kV Transformer	10kV Transformer	Over current Earth Fault	OC & E-F Aligned	110kV Decoupling feeder	Tripped due to 10KV Decoupling feeder fault
6. 110KV Miranga substation												
1	17/01/21	14:23 hrs	17/01/21	14:26 hrs	0	0.05	15MVA case 1	---	Tripped on fault	BA-420	Miranga to	CB tripped while charging of transformer at 16hrs and returned BPO and charged transformer at 16:20hrs from our end
2	17/01/21	16:00 hrs	17/01/21	16:30hrs	0	4.2	Heating oil system	---	Tripped on fault	BA & 400-075/0/07 at our end	Miranga to	returned BPO with code no 1401 CB closed at 16:30hrs from our end
3	17/01/21	16:00 hrs	17/01/21	16:20hrs	0	05.30	Miranga Range 06	---	Tripped on fault	BA & 400-075/0/07 at our end	Miranga to	returned BPO with code no 1401 CB closed at 16:20hrs from our end
4	17/01/21	16:00 hrs	17/01/21	17:15hrs	1	1.00	Miranga Phunthochang 06	---	Tripped on fault	BA & 400-075/0/07 at our end	Miranga to	returned BPO with code no 1401 CB closed at 17:15hrs from our end
L-400-220-110-10kV Signaling Substation												
Sl. No.	Date of Tripping	Time of Outages/ Time of Tripping	Date of Normalization	Time of Fault was Cleared	Duration of Outages (Hrs)	MVA before Outage (MW)	Name of Feeder	Name of the Substation/lines Affected by the Fault	Reasons of Fault	Relay Operations	Fault Location(KM)	Remarks
0) 400KV												
1	08.02.2021	14:17hrs	08.02.2021	14:40hrs	0	101.00	MOPA line 2	Algorithm SS	Line-Earth Fault	Main-1 = R,Y,Abph -Ground Pickup and DTT trip Main-2 = R,Y,Abph pick up	Main-1 - 82.8km Main-2 - 82.8km	
2	10.02.2021	11:19 hrs	10.02.2021	12:36 hrs	1		Alpine CRT3	Algorithm SS	Line-Earth Fault	R,YB phase pick up, DTT Tripped	Main-1 = 78.8km Main-2 = 77.8km	
3	20.02.2021	14:06 hrs	20.02.2021	14:24 hrs	0	93.80	MOPA line 3	Algorithm SS	Line-Earth Fault	Main-1 = Rph pickup, DTT trip, 2 = Rph pick up	Main-1 = 78.8km Main-2 = 77.8km	
00-220 kv and 110 KV												
1	28.02.2021	5:09:00hrs	28.02.2021	5:32:00hrs	0	9.70	Tayang-Signaling	Chayap and Signaling substation	phase to phase fault	Main-1 Rph=2.020KA, Yph=2.020KA, Bph=0.04KA, and Main-2 Rph=2053.8kph, Yph=2052.70KA, Bph=16.27KA, F08 BOTH 808E-1071-007D	Main-1=4.0KM, Main-2=1.41KM	breaker at our end is closed first then only breaker at signaling end is closed.

Tripping Report for the of month March, 2021 under SMD Deothang, TD,BPC

Sl. No.	Date of Tripping	Time of outages	Date of Normalization	Time of fault was cleared	Duration of Outages (Hrs)	MW before outage (MW)	Feeder Name	Name of the Substation lines affected by the fault	Reasons of fault	Relay operations	Exact location of fault [Line segment/ Substation]	Remarks
3. 132/33/11kV Deothang substation												
132kV Feeder												
1	1.03.2020	15:01	1.03.2020	15:33	0	17.20	132kV Deothang-Nangkhor	Deothang-Nangkhor line	NA	Nil	Nangkor s/s	Incomer tripped with opening code 0229 & breaker closed closing code 1272 by Tshering Cheki
2	6.03.2021	12:58	06.03.2021	13:11	0	8.028	132kV Deothang-Nangkhor	Deothang-Nangkhor	NA	Nil	Unknown	Grid fail, at our end all breaker are in normal condition at 13:11 supply resumed from Motenga SS. Deothang breaker kept opened at Deothang substation.
3	6.03.2021	12:58	06.03.2021	13:11	0	8.028	132kV Deothang-Motenga	Deothang-Motenga	NA	Nil	Unknown	Grid fail, at our end all breaker are in normal condition at 13:11 supply resumed from Motenga SS.
4	06.03.2021	12:58	06.03.2021	16:24	3	-9.252	132kV Deothang-Nangkhor	Deothang-Nangkhor	33/11kV 2.5MVA Transformer blast	NA	Nangkor s/s	Emergency shut down taken by Nangkor S/S since both 33/11kV 2.5MVA Transformer got blast. Avoided through phone by BPSO and Nangkor substation Head.
5	30.03.2021	20:22	30.03.2021	20:25	0	26.49	132 kV Deothang-Motenga	Deothang-Motenga	NA	Nil		Emergency shut down by BPSO Tshering Yangzom opening code 0334 due to low Voltage system in eastern grid. Cabaged via closing code 1901 BPSO Jangchub
3. 132/33/11kV Nangkor substation												
132kV Feeder												
1	05.03.2021	18:43 hrs	05.03.2021	19:09 hrs	0	1.13	132/33kV, 5MVA Trf-I	All 33kV & 11kV feeders	Transient fault	Non directional IDMT O/C Relay-50A/50C & tripping relay 86 operated	Nangkor Substation	Tripped while test charging 33kV Namung feeder
2	05.03.2021	18:43 hrs	05.03.2021	18:48 hrs	0	0.85	132/33kV, 5MVA Trf-II	All 33kV & 11kV feeders	Transient fault	Non directional IDMT O/C Relay-50A/50C & tripping relay 86 operated	Nangkor Substation	Tripped while test charging 33kV Namung feeder
3	06.03.2021	12:56 hrs	06.03.2021	16:23 hrs	3	-7.89	Nangkor-Ngunglun	Nangkor-Ngunglun line	NA	-	Nangkor Substation	Emergency hand trip requested from our end and same was informed to BPSO, Thimphu. Due to 2.5MVA Transformer fire incident
4	06.03.2021	12:57 hrs	06.03.2021	16:36 hrs	3	-4.89	Koricho-Nangkor	Koricho-Nangkor line	NA	-	Nangkor Substation	Emergency hand trip requested from our end and same was informed to BPSO, Thimphu. Due to 2.5MVA Transformer fire incident
5	06.03.2021	12:58 hrs	06.03.2021	16:24 hrs	3	11.94	Nangkor-Deothang	Nangkor-Deothang line	NA	-	Nangkor Substation	Emergency hand trip requested from our end and same was informed to BPSO, Thimphu. Due to 2.5MVA Transformer fire incident
6	06.03.2021	12:50 hrs	08.03.2021	16:23 hrs	51	0.21	132/33kV, 5MVA Trf-I	All 33kV & 11kV feeders	NA		Nangkor Substation	Due to 2.5MVA Transformer fire incident
7	06.03.2021	12:50 hrs	08.03.2021	14:33 hrs	49	0.85	132/33kV, 5MVA Trf-II	All 33kV & 11kV feeders	NA		Nangkor Substation	Due to 2.5MVA Transformer fire incident
3. 132/33/11kV Ngunglun substation												
132kV Feeder												
1	01.03.2021	14:00	01.03.2021	14:15	0	0.58	1MVA transformer-2	1MVA transformer-2	Over current	O/C tripped	Deothang Feeder	Tripped due to 132V Deothang feeder fault
2	01.03.2021	14:42	01.03.2021	14:49	0	0.059	1MVA transformer-2	1MVA transformer-2	Over current	O/C tripped	Deothang Feeder	Tripped due to 132V Deothang feeder fault
3	08.03.2021	12:52	16.03.2021	16:25	3	11.18	Nangkor-Ngunglun	Nangkor-Ngunglun	Earth Fault	E.F. opened, 86 op'd	Nangkor-Ngunglun	Fault Value: I1=36.44, I2=38.14, I3=91.4, I0=13.14, I1+I2+I3+I0=187.127+13.14=200.267 The feeder was overloaded as per the faulted line coded 1301 causes by Miss. Tshering Yangzom BPSO Thimphu.
3. 132/33/11kV Deothang substation												
132kV Feeder												
1	3/7/2021	12:38 hrs	3/7/2021	13:33 hrs	0	13.83	Deothang 132 Incomer	Deothang 132 Incomer	Tripped on fault	86A & 86B (PT2,OK,OT) at our end	Motenga in	Informed BPSO as per their instruction CB closed at 13:20hrs from our end.
2	3/7/2021	00:43 hrs	3/7/2021	00:48hrs	0	0.26	132kV Incomer	132kV Incomer	Tripped on fault	GIC at our end	Motenga in	CB closed at 1:48hrs from our end.
3	3/7/2021	14:40 hrs	3/7/2021	15:20hrs	0	0	132V Incomer	132V Incomer	Weld opened		Motenga in	132hrs disconnector by 132V for maintenance work at Deothang
4	3/7/2021	19:30hrs	3/7/2021	21:50hrs	0	8.81	Motenga 132kV Incomer	Motenga 132kV Incomer	Tripped on fault	86A & 86B (PT2,OK,OT) at our end	Motenga in	Informed BPSO as per their instruction CB closed at 19:30hrs with code 86,DC, 86a, 86b,DC, 86c, 86d and 86,DC, 86e, 86f from our end.
3. 400/720/132/33kV Bapcha substation												
Sl. No.	Date of Tripping	Time of Outages/ Time of Tripping	Date of Normalization	Time of Fault was Cleared	Duration of Outages (Hrs)	MW before Outage (MW)	Name of Feeder	Name of the Substation lines Affected by the Fault	Reasons of Fault	Relay Operations	Fault Location(KM)	Remarks
0.400kV												
1	04/27/20	12:52 hrs	04/27/20	12:22 hrs	0 hrs	138.17 MW	MBPA Line 4	Alipochang substation	DTT trip while opening line Alipochang CB 2 at their end	DTT trip		
3. 132/33/11kV Tingthi substation												
110kV and Above												
1.00	04/28/20	0:54	04/28/20	0:55	0:00	23.76	132kV Tingthi-Nanglun	132kV Tingthi-Nanglun	Temporary fault	Distance Protection Relay Trip phase ABC, Fault Location: 139.4KM, Fault Zone-3	132kV Tingthi-Nanglun	

Tripping Report for the of month April, 2021 under SMD Doochang, TB/EPC													
Sl. No.	Date of Tripping	Time of outages	Date of Normalization	Time of fault was cleared	Duration of Outages (Hrs)	MW before outage (MW)	Feeder Name	Name of the Substation/lines affected by the fault	Reasons of fault	Relay operations	Exact location of fault (Line segment/ Substation)	Type of outages	Remarks
1.132/33/11kV Khorika Substation													
132kV Feeder													
	30.04.2021	16:59	30.04.2021	17:06		-13.75	132kv khorika	All feeders	NA	Nil	khorika end	trip	Line tripped from khorika end, all unit are trip due to under voltage.
2. 132/33/11kV Kanglung Substation													
132kV Feeder													
1	01.04.2021	14:30	1.4.2021	14:34	0:04	-7.182	Corlung	Kanglung	E/F	E/F	Corlung Line	Tripped on fault	Line Tripped due to Lightning
2	07.04.2021	21:34	07.04.2021	21:37	0:00	-12.358	Corlung	kanglung	O/c	o/c	Corlung Line	Tripped on fault	line tripped due to over current at our end due to heavy rainfall with thundering lightning
3	28.04.2021	17:03	28.04.2021	17:13	0:00	-11.412	Corlung	kanglung	O/C & E/F	O/C & E/F relay operated I-27.56A, Iy-801.8A, B-720.2A. Distance relay operated with Zone 1, at 17.88KM	Corlung Line	Tripped on fault	It normalised after getting clearance from ms. Karma, (mng). BPSO. At 17:13 hrs.
4	28.04.2022	17:03	28.04.2021	17:14	0:00	9.758	Phuntschohang	Kanglung	NA	over relay zone 1 open	Phuntschohang line	Tripped on fault	It normalised after getting clearance from ms. Karma, (mng). BPSO. At 17:14hrs.
5	28.04.2021	17:43	28.04.2021	17:45	0:00	-11.412	Corlung	kanglung	O/C & E/F	O/C & E/F relay operated I-576.8A, Iy-57.85A, B-821A. Distance relay operated with Zone 2, at 25.71KM	Corlung Line	Tripped on fault	It normalised after getting clearance from ms. Karma, (mng). BPSO. At 17:45hrs.
6	28.04.2021	17:43	28.04.2021	19:36	2:00	9.758	Phuntschohang	Kanglung	NA	over relay zone 1 open	Phuntschohang line	Tripped on fault	It normalised after getting clearance from ms. Karma, (mng). BPSO with charging code 2050
7	30.04.2021	16:55	30.04.2021	17:16	0:00	-11.872	Corlung	kanglung	O/C & E/F	O/C & E/F relay operated IA-32.78A, IB-72.51A, IC-797.6A, VAB-134.18V, VBC-81.70V, VCA-77.96V. Distance relay operated with Zone 1, at 5.66KM, IA-32.71A, IB-72.2AJC-822.3A, VAN-78.66kV, VBN-76.44kV, VCN-5.706kV	Corlung Line	Tripped on fault	Feeder normalised after getting clearance from BPSO.
8	30.04.2021	16:55	30.04.2021	17:16	0:00	9.486	Phuntschohang	Kanglung	NA	NA	Phuntschohang line	Tripped on fault	Feeder normalised after getting clearance from BPSO.

4. 132/33kV Nangkor substation													
132kV Feeder													
ID	Date	Start Time	End Date	End Time	Duration	Severity	Location	Equipment	Event	Category	Substation	Status	Remarks
1	04.04.2021	18:43 hrs	04.04.2021	19:57 hrs	0	0.84	132/33kV, 5MVA Tr-F1	All 33kV & 11kV feeders	Transient fault	Non directional IDMT O/C Relay-50A & tripping relay 86 operated	Nangkor Substation	Tripped on fault	Tripped due to fault on 33kV Tsebu feeder
2	04.04.2021	18:43 hrs	04.04.2021	18:47 hrs	0	0.61	132/33kV, 5MVA Tr-F1	All 33kV & 11kV feeders	Transient fault	Non directional IDMT O/C Relay-50A & tripping relay 86 operated	Nangkor Substation	Tripped on fault	Tripped due to fault on 33kV Tsebu feeder
3	04.04.2021	19:33 hrs	04.04.2021	19:37 hrs	0	0.46	132/33kV, 5MVA Tr-F1	All 33kV & 11kV feeders	Transient fault	Non directional IDMT O/C Relay-50A & tripping relay 86 operated	Nangkor Substation	Tripped on fault	Tripped due to fault on 33kV Tsebu feeder
4	04.04.2021	20:50 hrs	04.04.2021	21:03 hrs	0	11.7	Nangkor-Droothang	Nangkor-Droothang line	Tripped on fault	Non directional E/F O/C relay & tripping relay 86 operated	Nangkor-Droothang line	Tripped on fault	Start D CN, Trip D N, O/C start D-1, E/F start IN1-12, trip IN1-2, IA-60.35A, IB-52.54AJC-404.0A, IN measured-353.5A. Informed to BPSO, and charged the feeder with instruction from BPSO.
5	10.04.2021	20:53 hrs	10.04.2021	21:06 hrs	0	35.7	Nangkor-Droothang	Nangkor-Droothang line	Tripped on fault	Non directional E/F O/C relay & tripping relay 86 operated	Nangkor-Droothang line	Tripped on fault	Start D CN, Trip D N, O/C start D-1, E/F start IN1-12, trip IN1-2, IA-102.4A, IB-100.5AJC-447.5A, IN measured-361.4A. Informed to BPSO, and charged the feeder with instruction from BPSO.
6	14.04.2021	04:32 hrs	14.04.2021	14:50 hrs	0	0.39	132/33kV, 5MVA Tr-F1	All 33kV & 11kV feeders	NA	Non directional IDMT O/C Relay-50A,50C & tripping relay 86 operated	Nangkor Substation	Tripped on fault	Due to fault on 33kV Tsebu feeder.
7	16.04.2021	15:58 hrs	16.04.2021	16:03 hrs	0	0.42	132/33kV, 5MVA Tr-F1	All 33kV & 11kV feeders	Transient fault	Non directional IDMT O/C Relay-50A,50C & tripping relay 86 operated	Nangkor Substation	Tripped on fault	Tripped due to fault on 33kV Yarang feeder
8	16.04.2021	15:58 hrs	16.04.2021	16:03 hrs	0	0.24	132/33kV, 5MVA Tr-F1	All 33kV & 11kV feeders	Transient fault	Non directional IDMT O/C Relay-50A,50C & tripping relay 86 operated	Nangkor Substation	Tripped on fault	Tripped due to fault on 33kV Yarang feeder
9	22.04.2021	02:26 hrs	22.04.2021	02:40 hrs	0	0.38	132/33kV, 5MVA Tr-F1	All 33kV & 11kV feeders	Transient fault	Non directional IDMT O/C Relay-50A,50C & tripping relay 86 operated	Nangkor Substation	Tripped on fault	Tripped due to fault on 33kV Nangang feeder & Nangang Feeder
10	22.04.2021	02:26 hrs	22.04.2021	02:40 hrs	0	0.43	132/33kV, 5MVA Tr-F1	All 33kV & 11kV feeders	Transient fault	Non directional IDMT O/C Relay-50A,50C & tripping relay 86 operated	Nangkor Substation	Tripped on fault	Tripped due to fault on 33kV Nangang feeder & Nangang Feeder
11	28.04.2021	00:03 hrs	28.04.2021	00:28 hrs	0	24.1	Nangkor-Droothang	Nangkor-Droothang line	Tripped on fault	Non directional O/C E/F Relay & tripping relay 86 operated	Nangkor-Droothang line	Tripped on fault	Start D CN, Trip D N, O/C start D-1, E/F start IN1-12, trip IN1-2, IA-100.2A, IB-96.92AJC-467.0A, IN measured-391.2A. Informed to BPSO, and charged the feeder with instruction from BPSO.
12	28.04.2021	08:23 hrs	28.04.2021	09:58 hrs	1	0.24	132/33kV, 5MVA Tr-F1	132/33kV, 5MVA Tr-F1	Tripped on fault	Auto-Relay DiffProt 87c,64a, 30CWDG wsep, Alarm, 30D Busk, Alarm & tripping relay 86 operated	Nangkor Substation	Tripped on fault	No supply interrupted. Tripped due to Shocks of Earth Quake. Charged the Nang after inspection.
13	30.04.2021	16:03 hrs	30.04.2021	16:15 hrs	0	28.6	Nangkor-Nanglam	Nangkor-Nanglam line	Tripped on fault	Directional O/C E/F & tripping relay 86 operated	Nangkor-Nanglam line	Tripped on fault	Directional O/C & E/F & trip relay 86 operated at our end: Start phase IB, trip phase N, O/C start D-1, E/F start E/F IN1-12, trip IN3-2, IA-78.17A, IB-670A, IC-141.2A, VAB-109.8kV, VBC-107.3kV, VCA-130.5kV, VAN-72.7kV, VBN-53.0kV, VCN-78.15kV, VN-0.00, 49.980k, IN measured-456.0A, IN derived-455.8A. Informed to BPSO & charged the feeder as per their instruction.
14	30.04.2021	16:57 hrs	30.04.2021	17:04 hrs	0	28.6	Main Grid	All 33kV & 11kV feeders	-	-	Motonga Substation & Tumbi Substation	Tripped on fault	Supply failed from Motonga Substation and Tumbi Substation and received from Motonga Substation.

6. 132KV Motanga substation													
1	4/4/2021	20:53 hrs	4/4/2021	20:58 hrs	--	-10.5	Deochang 5M in-comer	--	Tripped on Fault	86A & 86B OPTD,OC/EF at our end	Motanga ss	--	Informed BPSO, as per there instruction by Karma Yangzom without closing code CB closed at 20:54hrs from our end as emergency.
2	4/8/2021	10:15 hrs	4/8/2021	11:52hrs	3	0.1	15MVA Xuser	--	Hand tripped	--	Motanga ss	--	Informed BPSO and CB closed at 11:52hrs from our end.
3	4/10/2021	20:52 hrs	4/10/2021	21:01hrs	--	-34.5	Deochang 5M in-comer	--	Tripped on Fault	86A & 86B OPTD,OC/EF at our end	Motanga ss	--	Taken shutdowns by DCSD for maintenance work at Arista end.
4	4/11/2021	08:02hrs	4/11/2021	08:40hrs	--	0.02	33KV POP Factory	--	Hand tripped	--	Motanga ss	--	Shutdowns taken by DCSD S/Jongkhur to replace Fuse at three end.
5	28/04/201	08:25hrs	28/04/201	09:22hrs	--	-22.47	Deochang 5M in-comer	--	Hand tripped	--	Motanga ss	--	Informed BPSO, Thimphu as instructed to closed CB with code no.2048 CB closed from our end at 09:22hrs. Due to heavy earthquake all isolators alignment was slightly gone out and Rangja main isolator and line isolator and Phuntsokhang line isolator got burnt. So firstly control the fire at isolators by hand tripping CB for Deochang, Rangja and Phuntsokhang bidders and then we the staffs physically check all the structures and alignment for all bays manually closed all isolators to confirmed fully closed and inform BPSO to charge the line.
6	28/04/201	08:25hrs	28/04/201	13:07hrs	4 hrs	6.11	Motanga-Rangja line	--	Hand tripped	--	Motanga ss	--	Informed BPSO, Thimphu as instructed to closed CB with code no. NLDC B0-2047, NLDC India-1349, NERLDC -1875 CB closed from our end at 13:07hrs. Due to earthquake main isolator and line isolator alignment gone out and got burnt. Informed maintenance team at Deochang and done all alignment works both for Rangja and Phuntsokhang isolators and both line charged from our end.
7	28/04/201	08:25hrs	28/04/201	13:20hrs	5 hrs	-8.97	anga-Phuntsokhang line	--	Hand tripped	--	Motanga ss	--	Informed BPSO, Thimphu as instructed to closed CB with code 2048 from our end at 13:20hrs. Due to earthquake isolator got burnt and informed maintenance team and after completing alignment works only line charged from our end.
8	28/04/201	17:04hrs	28/04/201	17:16hrs	--	-8.96	anga-Phuntsokhang line	--	Tripped on Fault	86A & 86B OPTD,OC/EF at our end	Motanga ss	--	Informed BPSO and closed the CB from our end at 17:16hrs from our end.
9	28/04/201	17:39hrs	28/04/201	17:45hrs	--	-8.96	anga-Phuntsokhang line	--	Tripped on Fault	86A & 86B OPTD,OC/EF at our end	Motanga ss	--	Informed BPSO and closed the CB from our end at 17:45hrs from our end.
10	30/04/201	16:55hrs	30/04/201	17:04hrs	--	-26.9	Motanga-Deochang line	--	Tripped on Fault	86A & 86B OPTD,OC/EF at our end	Motanga ss	--	Informed BPSO and closed the CB from our end at 17:04hrs from our end.
11	30/04/201	16:55hrs	30/04/201	17:05hrs	--	-6.47	anga-Phuntsokhang line	--	Tripped on Fault	86A & 86B OPTD,OC/EF at our end	Motanga ss	--	Informed BPSO and closed the CB from our end at 17:05hrs from our end.
7. 132-33KV Corlung substation													
132KV Feeder													
1	30/04/2021	16:58 hrs	30/04/2021	17:04 hrs	0	9.57	132 Khilbar-Corlung line and 132 KV Corlung-Kanglung Line	132 Khilbar-Corlung line and 132 KV Corlung-Kanglung Line	Incoming supply fail	NA	Karichha Supply fail	Grid fail	At 16:58 hrs incoming supply from Khilbar substation fail and Corlung substation was blackout but no breaker tripping has occurred at Corlung substation.
7. 132-33KV Phuntsokhang substation													
132KV Feeder													
1	1/04/2021	14:20	4/1/2021	14:47	--	7.02	Kanglung Line	Kanglung line	Zone one Distance Relay Trip for Kanglung s/s	86A and 86B	Kanglung Line	Trip	Kanglung s/s zone one distance relay trip
2	7/04/2021	21:09	4/7/2021	21:17	--	10.50	V in-comer Kanglung	Kanglung Line	1OPTD (R,Y,B Phase	89A and 89B	Kanglung Line	Trip	Zone-1 OPTD R,Y,B Phase trip
3	28/04/2021	17:03	4/28/2021	17:24	--	9.39	KANGLUNG LINE	Kanglung Line	Zone one Distance Relay Trip for Kanglung s/s	86A and 86B	Kanglung Line	TRIP	Kanglung s/s zone one distance relay trip
4	28/04/2021	17:42	4/28/2021	19:39	2	9.39	KANGLUNG LINE	Kanglung Line	1OPTD (R,Y,B Phase zone -1OPTD(B Phase trip) and over voltage	89A and 89B	Kanglung Line	TRIP	Zone-1 OPTD R,B Phase trip
5	30/04/21	16:55	4/30/2021	17:15	--	11.03	KANGLUNG LINE	Kanglung Line	Zone -1OPTD(B Phase trip) and over voltage	89A and 89B	Kanglung Line	TRIP	Zone-1 OPTD B Phase trip (grid fail)

0. 66kV													
1	22.04.2021	12:44 hrs			0	04.02PW	ADPPA Line-2	Agnering Substation	DOT trip, RYB phase Tripped			Transient Fault (Lightning and Switching)	
2	09.08.2021	02:50 hrs	09.04.2021	14:57 hrs			Wheat Reactor-1		RYB phase - Ground fault			Transient Fault (Lightning and Switching)	
02.220 kV and 132 kV													
1	19.08.2021	09:20hrs	09.04.2021	09:42hrs		09.07.1.08.05	BIMFA RCT1 & 2	Agnering sub	LV REF open	NON-TCN Trip. (Ia=0.55kA, Ib=0kA, Ic=0.5A for RCT 01, NON-TCN Trip. (Ia=0.50kA, Ib=0kA, Ic=0.5A for RCT 02)		Transient (Lightning and Switching)	Both RCT1&2 Trip at the same time.
2	22.09.2020	02:02hrs	22.04.2021	01:05hrs	0	12.1900PW	Tawang Feeder	Agnering sub	Earthfault (L2-E)	NON-TCN pick up, L2E phase tripped, main 1 operated. Dist. 25.9km	Dist. 25.9km	Transient (Lightning and Switching)	
3	22.09.2021	02:20hrs	22.04.2021	12:22hrs	0	1.1150PW	Dagapola Feeder	Agnering sub	Line Fault	T&R phase tripped, main 1 open, Dist. 21.08km	Dist. 21.08km	Transient (Lightning and Switching)	
4	09.08.2021	07:20hrs	09.04.2021	07:50hrs	0	20.03	132kV Agnering-Golappa Line	Agnering & Tangle	Ground fault	main 1 - Relay General Trip and R & Y phase with ground fault trip	Distance -67.9km	Transient	
2. 120-06-33kV Dhaqar Substation 0.66kV and above													
1	22.04.2021	09:05:30hrs	22.04.2021	1:46:30hrs	0	17.2	Agnering Feeder	Dhaqar Ss	main 1 to 0.75kA, 0.96-1.62, Distance to main 1-10.5km, Max Tripped			Whole Feeder is black, not as line accident extend from Agnering since then line	
3. 132-06-33-22kV Golappa Substation 0.66kV and above													
1	04.04.2021	07:22hrs	04.04.2021	10:20hrs	0.0	132kV Gal-Gol	132kV Gal-Gol	bad weather	Dist protection, REL 470 General trip, RYB phase, Dist. 05.93km towards Substation	Substation line		Charging Code: NLDC BTY-0307, NLDC IND-011 & NERLDC-215	
2	04.04.2021	07:22hrs	05.04.2021	13:00hrs	19	132kV Gal-Gol	132kV Gal-Gol	bad weather	no relay operated at our end	132kV Gal-Gol		Charging Code: BPSO-0329	
3	08.08.2021	01:00hrs	08.04.2021	04:10hrs	3.4	132kV Gal-Gol	132kV Gal-Gol	bad weather	Dist protection, REL 470 General trip, RYB phase, Dist. 05.93km towards Substation	Substation line		Charging Code: NLDC BTY-0307, NLDC IND-011 & NERLDC-215	
4. 132-33-22kV Tangle Substation 132kV and Above													
1.00	04/08/20	0:10	04/08/20	0:11	0.00	132kV Tangle-Nanglam	132kV Tangle-Nanglam	Temporary fault	Distance Protection Relay Trip phase ABC Fault Location 1.725KM, Fault Zone-1	132kV Tangle-Nanglam		Temporary	
1.00	04/08/20	0:44	04/18/20	0:45	0.00	-28.70	132kV Tangle-Agnering	132kV Tangle-Agnering	Temporary fault	Distance Protection Relay Trip phase ABC Fault Location 1.217KM, Fault Zone-1	132kV Tangle-Agnering		Temporary
1.00	04/08/20	0:47	04/18/20	0:48	0.00	21.13	132kV Tangle-Nanglam	132kV Tangle-Nanglam	Temporary fault	Distance Protection Relay Trip phase ABC Fault Location 1.095KM, Fault Zone-1	132kV Tangle-Nanglam		Temporary
1.00	04/08/20	0:48	04/18/20	0:50	0.00	4.10	132kV Tangle-Yarnoo	132kV Tangle-Yarnoo	Temporary fault	Distance Protection Relay Trip phase ABC Fault Location 2.756KM, Fault Zone-1	132kV Tangle-Nanglam		Temporary
5. 132-33kV Yarnoo Substation 0.66kV & Above													
1	30.04.2021	0:04:02S	30.04.2021	0:04:52S	0	4	132kV, Tangle Line Yarnoo Ss	0%	Distance relay tripped			Temporary	
6. 138-33kV Dagapola Substation 0.66kV & Above													
1	22.04.2021	12:47:49	22.04.2021	0:07:19	0	0.0	220kV Dagapola-132kV Dagapola Substation Over Voltage, 1A=1.96 A, 1B=, 1C=					Transient Fault	Overvoltage trip

May 2021

MONTHLY OUTAGE REPORT FOR THE MONTH OF MAY UNDER GRID BHOOTANG, TG, BPC.

Division: JAMB BHOOTANG
 Substation: 232/231/237 BHOOTANG Substation
 Month: May 21

Sl. No.	Name of Feeder	Voltage Level	Type of Change (Outage/Tripping)	Outage/ Tripping Time		Remediation Time		Duration of Outage		MVA Index Change (MW)	Tripping Details		Type/ Cause of Fault	Reason for Outage	Weather Condition During the Outage	Remarks
				Start	End	Start	Time	(Min)	(Max)		Protection Relay Tripped	Fault Details (As recorded by relay)				
STAT System																
1	Statok	132kV	Tripping	07/05/2021	07/27/2021	07/27/2021	07/27/2021	0	0	23.00	-	-	-	Tripping	Clearing	Wind hit tower. Protection relay Tripping due to over-current along with good fault from Statok.

Division: JAMB BHOOTANG
 Substation: 232/231/237 BHOOTANG Substation
 Month: May 21

Sl. No.	Name of Feeder	Voltage Level	Type of Change (Outage/Tripping)	Outage/ Tripping Time		Remediation Time		Duration of Outage		MVA Index Change (MW)	Tripping Details		Type/ Cause of Fault	Reason for Outage	Weather Condition During the Outage	Remarks
				Start	End	Start	Time	(Min)	(Max)		Protection Relay Tripped	Fault Details (As recorded by relay)				
1	Statok, Statok, Statok	132kV	Tripping	08/05/2021	08/05/2021	08/05/2021	08/05/2021	0	0	23.00	Distance protection relay 800.0% and 800K.0%	Tripping on 08/05/2021, Zone 1, Fault Location: 24.70% to 24.80% 70.0% to 70.10% 20.0% Fault Location: 23.00%	Protection Relay Tripped	NS	Clearing	Wind hit tower. Protection relay Tripping due to over-current along with good fault from Statok.
2	Statok, Statok, Statok	132kV	Tripping	08/05/2021	08/05/2021	08/05/2021	08/05/2021	0	0	0.00	Distance protection relay 800.0% and 800K.0%	Tripping on 08/05/2021, Zone 1, Fault Location: 24.70% to 24.80% 70.0% to 70.10% 20.0% Fault Location: 23.00%	Protection Relay Tripped	NS	Clearing	Wind hit tower. Protection relay Tripping due to over-current along with good fault from Statok.
3	Statok, Statok, Statok	132kV	Tripping	08/05/2021	08/05/2021	08/05/2021	08/05/2021	0	0	0.00	Distance protection relay 800.0% and 800K.0%	Tripping on 08/05/2021, Zone 1, Fault Location: 24.70% to 24.80% 70.0% to 70.10% 20.0% Fault Location: 23.00%	NS	NS	Clearing	Wind hit tower. Protection relay Tripping due to over-current along with good fault from Statok.
10	Statok	132kV	NS	27/05/2021	08/05/2021	27/05/2021	08/05/2021	0.04	0	22.70	NS	NS	NS	NS	Lightning & Switching	Lightning hit tower 800kV line. Protection relay Tripping due to over-current along with good fault from Statok.
10	Statok	132kV	NS	27/05/2021	08/05/2021	27/05/2021	08/05/2021	0.07	0	22.00	NS	NS	NS	NS	Lightning & Switching	Lightning hit tower 800kV line. Protection relay Tripping due to over-current along with good fault from Statok.

Division: JAMB BHOOTANG
 Substation: 232/231/237 BHOOTANG Substation
 Month: May 21

Sl. No.	Name of Feeder	Voltage Level	Type of Change (Outage/Tripping)	Outage/ Tripping Time		Remediation Time		Duration of Outage		MVA Index Change (MW)	Tripping Details		Type/ Cause of Fault	Reason for Outage	Weather Condition During the Outage	Remarks
				Start	End	Start	Time	(Min)	(Max)		Protection Relay Tripped	Fault Details (As recorded by relay)				
STAT System																
1	232/231/237, 232/231/237	132kV	Tripping	09/05/2021	09/09/2021	09/05/2021	09/09/2021	0	0	0.00	New directional STAT Protection Relay operated	09/05/2021, Zone 1, Fault Location: 24.70% to 24.80% 70.0% to 70.10% 20.0% Fault Location: 23.00%	Tripping due to feeder fault	-	Clearing	Tripping due to fault on STAT Feeder
2	232/231/237, 232/231/237	132kV	Tripping	09/05/2021	09/09/2021	09/05/2021	09/09/2021	0	0	0.00	New directional STAT Protection Relay operated	09/05/2021, Zone 1, Fault Location: 24.70% to 24.80% 70.0% to 70.10% 20.0% Fault Location: 23.00%	Tripping due to feeder fault	-	Clearing	Tripping due to fault on STAT Feeder
3	Statok, Statok, Statok	132kV	Tripping	09/05/2021	09/09/2021	09/05/2021	09/09/2021	0	0	0.00	Distance protection relay 800.0% and 800K.0%	Tripping on 09/05/2021, Zone 1, Fault Location: 24.70% to 24.80% 70.0% to 70.10% 20.0% Fault Location: 23.00%	Tripping due to feeder fault	-	Lightning & Switching	Lightning hit tower 800kV line. Protection relay Tripping due to over-current along with good fault from Statok.
6	232/231/237, 232/231/237	132kV	Tripping	09/05/2021	09/09/2021	09/05/2021	09/09/2021	0	0	0.00	New directional STAT Protection Relay operated	09/05/2021, Zone 1, Fault Location: 24.70% to 24.80% 70.0% to 70.10% 20.0% Fault Location: 23.00%	Tripping due to feeder fault	-	Lightning & Switching	Lightning hit tower 800kV line. Protection relay Tripping due to over-current along with good fault from Statok.
9	232/231/237, 232/231/237	132kV	Tripping	09/05/2021	09/09/2021	09/05/2021	09/09/2021	0	0	0.00	New directional STAT Protection Relay operated	09/05/2021, Zone 1, Fault Location: 24.70% to 24.80% 70.0% to 70.10% 20.0% Fault Location: 23.00%	Tripping due to feeder fault	-	Clearing	Tripping due to fault on STAT Feeder
4	232/231/237, 232/231/237	132kV	Tripping	09/05/2021	09/09/2021	09/05/2021	09/09/2021	0	0	0.00	New directional STAT Protection Relay operated	09/05/2021, Zone 1, Fault Location: 24.70% to 24.80% 70.0% to 70.10% 20.0% Fault Location: 23.00%	Tripping due to feeder fault	-	Clearing	Tripping due to fault on STAT Feeder
7	232/231/237, 232/231/237	132kV	Tripping	09/05/2021	09/09/2021	09/05/2021	09/09/2021	0	0	0.00	New directional STAT Protection Relay operated	09/05/2021, Zone 1, Fault Location: 24.70% to 24.80% 70.0% to 70.10% 20.0% Fault Location: 23.00%	Tripping due to feeder fault	-	Clearing	Tripping due to fault on STAT Feeder

Sl. No.	Year of Feeder	Voltage Level	Type of Change (Outage/Tripping)	Outage/Tripping Time		Description of Change		MVA Index Change (MW)	Outage/Tripping Details	Type of Cause of Fault	Reason for Outage	Weather Condition	Remarks
				Start	End	Start	End						
4	2021/2021	110KV	Tripping	01.11.2021	01:08:56	01.11.2021	01:07:56	0	New Overhead BSCOP PSCOP Relay operated New Overhead BSCOP PSCOP Relay operated	0KV	Relay-TRIP	Clear	Tripped while not charging, 1.001 Warning feeder
5	2021/2021	110KV	Tripping	01.11.2021	01:07:56	01.11.2021	01:08:56	0	New Overhead BSCOP PSCOP Relay operated	0KV	Relay-TRIP	Clear	Tripped due to fault on 110KV Trench feeder
10	2021/2021	110KV	Tripping	01.11.2021	01:07:56	01.11.2021	01:08:56	0	New Overhead BSCOP PSCOP Relay operated	0KV	Relay-TRIP	Clear	Tripped due to fault on 110KV Trench feeder
11	2021/2021	110KV	Tripping	01.11.2021	01:08:56	01.11.2021	01:07:56	0	New Overhead BSCOP PSCOP Relay operated	0KV	Relay-TRIP	Clear	Tripped due to fault on 110KV Warning feeder
16	2021/2021	110KV	Tripping	01.11.2021	01:08:56	01.11.2021	01:08:56	0	New Overhead BSCOP PSCOP Relay operated	0KV	Relay-TRIP	Clear	Tripped due to fault on 110KV Warning feeder
16	2021/2021	110KV	Tripping	01.11.2021	01:08:56	01.11.2021	01:08:56	0	New Overhead BSCOP PSCOP Relay operated	0KV	Relay-TRIP	Clear	Tripped due to fault on 110KV Warning feeder
17	2021/2021	110KV	Tripping	01.11.2021	01:08:56	01.11.2021	01:08:56	0	New Overhead BSCOP PSCOP Relay operated	0KV	Relay-TRIP	Clear	Tripped due to fault on 110KV Warning & Warning feeder

110KV Feeder:

Outage: 110KV 01.11.2021
 Substation: 110KV 110KV Warning Substation
 Mileage: 16.00

Sl. No.	Year of Feeder	Voltage Level	Type of Change (Outage/Tripping)	Outage/Tripping Time		Description of Change		MVA Index Change (MW)	Outage/Tripping Details	Type of Cause of Fault	Reason for Outage	Weather Condition	Remarks
				Start	End	Start	End						
1	2021/2021	110KV	Tripping	01.11.2021	01:08:56	01.11.2021	01:08:56	0	New Overhead BSCOP PSCOP Relay operated	0KV	Relay-TRIP	Clear	Tripped due to fault on 110KV Warning & Warning feeder
16	2021/2021	110KV	Tripping	01.11.2021	01:08:56	01.11.2021	01:08:56	0	New Overhead BSCOP PSCOP Relay operated	0KV	Relay-TRIP	Clear	Tripped due to fault on 110KV Warning & Warning feeder
17	2021/2021	110KV	Tripping	01.11.2021	01:08:56	01.11.2021	01:08:56	0	New Overhead BSCOP PSCOP Relay operated	0KV	Relay-TRIP	Clear	Tripped due to fault on 110KV Warning & Warning feeder

Outage: 110KV 01.11.2021
 Substation: 110KV 110KV Warning Substation
 Mileage: 16.00

Sl. No.	Year of Feeder	Voltage Level	Type of Change (Outage/Tripping)	Outage/Tripping Time		Description of Change		MVA Index Change (MW)	Outage/Tripping Details	Type of Cause of Fault	Reason for Outage	Weather Condition	Remarks
				Start	End	Start	End						
110KV													
1	2021/2021	110KV	Tripping	01.11.2021	01:08:56	01.11.2021	01:08:56	0	New Overhead BSCOP PSCOP Relay operated	0KV	Relay-TRIP	Clear	Tripped due to fault on 110KV Warning & Warning feeder
2	2021/2021	110KV	Tripping	01.11.2021	01:08:56	01.11.2021	01:08:56	0	New Overhead BSCOP PSCOP Relay operated	0KV	Relay-TRIP	Clear	Tripped due to fault on 110KV Warning & Warning feeder
3	2021/2021	110KV	Tripping	01.11.2021	01:08:56	01.11.2021	01:08:56	0	New Overhead BSCOP PSCOP Relay operated	0KV	Relay-TRIP	Clear	Tripped due to fault on 110KV Warning & Warning feeder
4	2021/2021	110KV	Tripping	01.11.2021	01:08:56	01.11.2021	01:08:56	0	New Overhead BSCOP PSCOP Relay operated	0KV	Relay-TRIP	Clear	Tripped due to fault on 110KV Warning & Warning feeder
5	2021/2021	110KV	Tripping	01.11.2021	01:08:56	01.11.2021	01:08:56	0	New Overhead BSCOP PSCOP Relay operated	0KV	Relay-TRIP	Clear	Tripped due to fault on 110KV Warning & Warning feeder

Substation: 220 KV/132 KV Substation Substation: 220 KV/132 KV Substation Substation: Mar 21																		
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Outage/ Tripping)	Outage Tripping		Normalisation Time		Duration of Outage		MW before Outage (MW)	Outgoing Breaker (Open)	Tripping Details		Type Cause of Fault	Reason for Outage	Outage Condition	Remarks	
				Time	Time	Time	Time	Time	Time			Feeder Breaker (As recorded by meter)	Feeder Breaker (As recorded by meter)					
1	Storage/Powerline Feeder	110KV	Tripping	11/03/2021	17:10	11/03/2021	09:20	0	0	0.00	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV
2	Storage/Powerline Feeder	110KV	Tripping	11/03/2021	17:10	11/03/2021	09:20	0	0	0.00	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV
3	Storage/Powerline Feeder	110KV	Tripping	11/03/2021	17:10	11/03/2021	09:20	0	0	0.00	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV
4	Storage/Powerline Feeder	110KV	Tripping	11/03/2021	17:10	11/03/2021	09:20	0	0	0.00	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV
5	Storage/Powerline Feeder	110KV	Tripping	11/03/2021	17:10	11/03/2021	09:20	0	0	0.00	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV
6	Storage/Powerline Feeder	110KV	Tripping	11/03/2021	17:10	11/03/2021	09:20	0	0	0.00	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV
7	Storage/Powerline Feeder	110KV	Tripping	11/03/2021	17:10	11/03/2021	09:20	0	0	0.00	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV
8	Storage/Powerline Feeder	110KV	Tripping	11/03/2021	17:10	11/03/2021	09:20	0	0	0.00	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV
9	Storage/Powerline Feeder	110KV	Tripping	11/03/2021	17:10	11/03/2021	09:20	0	0	0.00	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV
10	Storage/Powerline Feeder	110KV	Tripping	11/03/2021	17:10	11/03/2021	09:20	0	0	0.00	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV

Substation: 220 KV/132 KV Substation Substation: 220 KV/132 KV Substation Substation: Mar 21																		
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Outage/ Tripping)	Outage Tripping		Normalisation Time		Duration of Outage		MW before Outage (MW)	Outgoing Breaker (Open)	Tripping Details		Type Cause of Fault	Reason for Outage	Outage Condition	Remarks	
				Time	Time	Time	Time	Time	Time			Feeder Breaker (As recorded by meter)	Feeder Breaker (As recorded by meter)					
11	Storage/Powerline Feeder	110KV	Tripping	11/03/2021	17:10	11/03/2021	09:20	0	0	0.00	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV
12	Storage/Powerline Feeder	110KV	Tripping	11/03/2021	17:10	11/03/2021	09:20	0	0	0.00	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV

Substation: 220 KV/132 KV Substation Substation: 220 KV/132 KV Substation Substation: Mar 21																		
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Outage/ Tripping)	Outage Tripping		Normalisation Time		Duration of Outage		MW before Outage (MW)	Outgoing Breaker (Open)	Tripping Details		Type Cause of Fault	Reason for Outage	Outage Condition	Remarks	
				Time	Time	Time	Time	Time	Time			Feeder Breaker (As recorded by meter)	Feeder Breaker (As recorded by meter)					
1	Storage/Powerline Feeder	110KV	Tripping	11/03/2021	17:10	11/03/2021	09:20	0	0	0.00	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV
2	Storage/Powerline Feeder	110KV	Tripping	11/03/2021	17:10	11/03/2021	09:20	0	0	0.00	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV
3	Storage/Powerline Feeder	110KV	Tripping	11/03/2021	17:10	11/03/2021	09:20	0	0	0.00	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV
4	Storage/Powerline Feeder	110KV	Tripping	11/03/2021	17:10	11/03/2021	09:20	0	0	0.00	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV
5	Storage/Powerline Feeder	110KV	Tripping	11/03/2021	17:10	11/03/2021	09:20	0	0	0.00	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV
6	Storage/Powerline Feeder	110KV	Tripping	11/03/2021	17:10	11/03/2021	09:20	0	0	0.00	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV
7	Storage/Powerline Feeder	110KV	Tripping	11/03/2021	17:10	11/03/2021	09:20	0	0	0.00	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV
8	Storage/Powerline Feeder	110KV	Tripping	11/03/2021	17:10	11/03/2021	09:20	0	0	0.00	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV	110KV/132KV/132KV/132KV

1. 400-750-132-110KV Agneshing Substation													
Sl. No.	Date of Tripping	Time of Outage/ Time of Tripping	Date of Normalization	Time of Fault was Cleared	Duration of Outages (Hrs)	MW before Outage (MW)	Name of Feeder	Name of the Substation/Bus affected by the Fault	Reasons of Fault	Relay Operations	Fault Location(KM)	Type of outages	Remarks
11 40KV Agneshing													
1	05.05.2021	12:20hrs	05.05.2021	12:45hrs	0.25	~12,000	110KV Agneshing - Tawang feeder	Agneshing 05	Ground fault	Main 120 ph pick up, zone 1 trip / Main 200 ph pick up, zone 1 trip /	14.5km		heavy rainfall, thunder and lightning
2	05.05.2021	12:22hrs	05.05.2021	12:45hrs	0.23	1.20	110KV Agneshing - Dagapochha feeder	Dagapochha 05	Ground fault	Main 120 ph pick up, zone 1 trip / Main 200 ph pick up, zone 1 trip /	zone 1 - 15.9km zone 2 - 11.86km		heavy rainfall, thunder and lightning
3	05.05.2021	12:40hrs	05.05.2021	13:00hrs	2	~11,200	110KV Agneshing - Tawang feeder	Agneshing 05	Ground fault	Main 1 (R 400 ph pick up, z1 trip) / Main 200 R 0 ph pick up, z1 trip /	zone 1 - 4km zone 2 - 1.17km		heavy rainfall, thunder and lightning
4	05.05.2021	13:00hrs	05.05.2021	14:30hrs	0	1.33	110KV Agneshing - Dagapochha feeder	Dagapochha 05	Relay ground trip				heavy rainfall, thunder and lightning
5	28.05.2021	08:08 hrs	28.05.2021	08:12 hrs	0	10.40	110KV Agneshing - Tawang feeder	Tawang 05	Earthfault	Tphase pick up			No DFR and relay tripped null

2. 220kV-33kV Dajay Substation														
0 40kV and above														
1	01.05.2021	12.40kV	01.05.2021	12.06.40kV	2	17.02	Spending for Dajay 33kv to 11kv: 77EA, B=0.01EA, 86.1 EA, Distance relay Main B&T			Main 2-12, 3km, Main B-1; Tripped	whole Tracing in black			
0 33kV and below														
1	12.05.2021	2.50kV	12.05.2021	17.37kV	14	0.104	Dagapela-1	Dajay Substation	Ia=4.105A, B=452.8A, Ia=450.2A, Ia=1.371A	MCCOMP122	Line segment	Tripped	Feeder restored after O&M local ESD Dagapela confirmed line clearance	
2	14.05.2021	11.20kV	14.05.2021	12.40kV	1	0.079	Ranglungin	Dajay Substation	Ia=2.25A, B=1A, Ia=17.12A, Ia=14.52A	MCCOMP122	Line segment	Tripped	Feeder restored after O&M local ESD Tracing confirmed line clearance	
4. 132/33-11kV Tumbi Substation														
0 40 kV and Above														
1	5/3/2021	16.00	5/3/2021	16.05	0	16.2100	0	Tingbi-Nanglum	Tingbi-Nanglum	Temporary fault	Distance Protection Relay Trip phase ABC Fault Location: 11.80KM/Fault Zone 2	1100	Tingbi-Nanglum	Temporary
2	5/5/2021	18.5F	5/5/2021	24.01	0	12.0000	0	Tingbi-Nanglum	Tingbi-Nanglum	Temporary fault	Distance Protection Relay Trip phase ABC Fault Location: 14.7KM/Fault Zone 2	1100	Tingbi-Nanglum	Temporary
3	5/13/2021	18.5F	5/13/2021	18.07	0	4.5700	0	Tingbi-Nanglum	Tingbi-Nanglum	Temporary fault	Distance Protection Relay Trip phase ABC Fault Location: 13.9KM/Fault Zone 2	1100	Tingbi-Nanglum	Temporary
4	5/26/2021	18.0L	5/26/2021	23.30	0	20.0000	0	Tingbi-Nanglum	Tingbi-Nanglum	Temporary fault	Distance Protection Relay Trip phase ABC Fault Location: 11.94KM/Fault Zone 2	1100	Tingbi-Nanglum	Temporary
6. 220-33kV Dagapela Substation														
0 40kV & Above														
1	01.05.2021	0.582618889	01.05.2021	0.620118889	0	-0.94	220kV Dajay Dagapela No data recorded in Relay on 0 40 A, B&T			-	Transient Fault	No data on relay at 0		

June 2021

MONTHLY OUTAGE REPORT FOR THE MONTH OF JUNE UNDER AND BEYOND 100 MVA

Station:	330KV BPH/100KV
Substation:	330KV BPH/100KV
Month:	June 21

Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Disturbance/Triggering)	Disturbance/Triggering		Transmission Line		Percentage of Outage (%)	MVA Index Outage (MW)	Disturbance Status/Type	Outage Details (As recorded by index)	Type/Status of Feeder	Reason for Disturbance	Restoration Condition	Remarks
				Start	Clear	Start	Clear								
1	330KV Chongy Feeder	33KV	Tripping	06/06/2021	06/22	06/06/2021	06/20	0	0.75	Over current	330KV BPH/100KV 33KV Chongy Feeder	Tripping on fault	Over current	Restoring	Feeder restored on 06/22. All charges done after restoration with some fault cleared on Chongy control room.
2	330KV Tashir Feeder	33KV	Tripping	22/06/2021	22/09	22/06/2021	06/21	0	0.75	SW	330KV BPH/100KV 33KV Tashir Feeder	Tripping on fault	SW	Restoring	Disturbance cleared by remote Trip off, automatic reclosure, breaker re-close, protection also restored and 100% of 330KV BPH/100KV power on 06/22. Cleared the feeder after restoration by BPH/100KV.
3	330KV Chongy Feeder	33KV	Tripping	20/06/2021	20/20	20/06/2021	20/21	0	11.25	SW	330KV BPH/100KV 33KV Chongy Feeder	Tripping on fault	SW	Restoring	Disturbance cleared by remote Trip off, automatic reclosure, breaker re-close, protection also restored and 100% of 330KV BPH/100KV power on 06/22. Cleared the feeder after restoration by BPH/100KV.

Station:	330KV BPH/100KV
Substation:	330KV BPH/100KV
Month:	June 21

Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Disturbance/Triggering)	Disturbance/Triggering		Transmission Line		Percentage of Outage (%)	MVA Index Outage (MW)	Disturbance Status/Type	Outage Details (As recorded by index)	Type/Status of Feeder	Reason for Disturbance	Restoration Condition	Remarks
				Start	Clear	Start	Clear								
330KV Feeder															
1	330KV Chongy Feeder	33KV	Tripping	06/06/2021	06/22	06/06/2021	06/20	0	0.75	Over current	330KV BPH/100KV 33KV Chongy Feeder	Tripping on fault	Over current	Restoring	Feeder restored on 06/22. All charges done after restoration with some fault cleared on Chongy control room.
2	330KV Tashir Feeder	33KV	Tripping	22/06/2021	22/09	22/06/2021	06/21	0	0.75	SW	330KV BPH/100KV 33KV Tashir Feeder	Tripping on fault	SW	Restoring	Disturbance cleared by remote Trip off, automatic reclosure, breaker re-close, protection also restored and 100% of 330KV BPH/100KV power on 06/22. Cleared the feeder after restoration by BPH/100KV.
3	330KV Chongy Feeder	33KV	Tripping	20/06/2021	20/20	20/06/2021	20/21	0	11.25	SW	330KV BPH/100KV 33KV Chongy Feeder	Tripping on fault	SW	Restoring	Disturbance cleared by remote Trip off, automatic reclosure, breaker re-close, protection also restored and 100% of 330KV BPH/100KV power on 06/22. Cleared the feeder after restoration by BPH/100KV.
4	330KV BPH/100KV	33KV	Tripping	06/06/2021	06/27	06/06/2021	06/20	0	0.75	Non-Operational 330KV BPH/100KV Feeder	330KV BPH/100KV 33KV BPH/100KV	Tripping on fault	Non-Operational	Restoring	Feeder restored on 06/27. All charges done after restoration with some fault cleared on BPH/100KV control room.
5	330KV BPH/100KV	33KV	Tripping	06/06/2021	06/27	06/06/2021	06/20	0	0.75	Non-Operational 330KV BPH/100KV Feeder	330KV BPH/100KV 33KV BPH/100KV	Tripping on fault	Non-Operational	Restoring	Feeder restored on 06/27. All charges done after restoration with some fault cleared on BPH/100KV control room.
6	330KV BPH/100KV	33KV	Tripping	06/06/2021	06/27	06/06/2021	06/20	0	0.75	Non-Operational 330KV BPH/100KV Feeder	330KV BPH/100KV 33KV BPH/100KV	Tripping on fault	Non-Operational	Restoring	Feeder restored on 06/27. All charges done after restoration with some fault cleared on BPH/100KV control room.
7	330KV BPH/100KV	33KV	Tripping	06/06/2021	06/27	06/06/2021	06/20	0	0.75	Non-Operational 330KV BPH/100KV Feeder	330KV BPH/100KV 33KV BPH/100KV	Tripping on fault	Non-Operational	Restoring	Feeder restored on 06/27. All charges done after restoration with some fault cleared on BPH/100KV control room.
8	330KV BPH/100KV	33KV	Tripping	06/06/2021	06/27	06/06/2021	06/20	0	0.75	Non-Operational 330KV BPH/100KV Feeder	330KV BPH/100KV 33KV BPH/100KV	Tripping on fault	Non-Operational	Restoring	Feeder restored on 06/27. All charges done after restoration with some fault cleared on BPH/100KV control room.
9	330KV BPH/100KV	33KV	Tripping	06/06/2021	06/27	06/06/2021	06/20	0	0.75	Non-Operational 330KV BPH/100KV Feeder	330KV BPH/100KV 33KV BPH/100KV	Tripping on fault	Non-Operational	Restoring	Feeder restored on 06/27. All charges done after restoration with some fault cleared on BPH/100KV control room.

Annual Transmission System Performance Report | 2021

Section: 1000 BPH/1000V Sub-section: 1000 BPH/1000V Sheet: 206 of 211																
Sl. No.	Name of Feeder	Voltage Level	Type of Storage (Residence/Trapping)	Detection/Triggering		Transmission Time		Detection of Storage		MR Index (Storage (MR))	Trapping Results		Type/Case of Fault	Reason for Shutdown	Weather Condition	Remarks
				Start	Time	Start	Time	(min)	(min)		Protection Relay (Type)	Fault Results (As recorded by relay)				
1000V																
1	1000 BPH/1000V/Transformer-4	100V	Trapping	01.08.2021	19:34	01.08.2021	19:36	0	2	1.07	MMS & EMFT I/R & I/C relay	Earth Fault	Transformer Earth Fault	Clear		
2	1000 BPH/1000V/Transformer-4	100V	Trapping	02.08.2021	08:47	02.08.2021	08:54	0	7	0.97	MMS & EMFT I/R & I/C relay	Earth Fault	100V Over Voltage Under Load	Clear	Over voltage and subsequent overcurrent	
3	1000 BPH/1000V/Transformer-4B	100V	Trapping	02.08.2021	08:47	02.08.2021	08:55	0	7	0	MMS & EMFT I/R & I/C relay	Earth Fault	PGT operation for 100V only	Clear		
4	1000 BPH/1000V/Transformer-4B	100V	Trapping	04.08.2021	17:02	04.08.2021	17:08	0	6	0.80	MMS & EMFT I/R & I/C relay	Over Current	Trigger due to 100V Overload			Reasons & Description
5	1000 BPH/1000V/Transformer-4	100V	Trapping	06.08.2021	01:37	06.08.2021	01:40	0	3	0.80	MMS & EMFT I/R & I/C relay	Earth Fault	Trigger due to 100V Overloading Feeder	Clear		
6	Ngangin-Driglit	100V	Trapping	06.08.2021	01:21	06.08.2021	01:27	0	6	-07.12	Under-voltage Voltage Protection	Over Load		Short Circuit & Under-voltage		Transformer Feeder CB operated as Feeder not and Ngangin-Driglit CB operated as Feeder and overcurrent.
7	Ngangin-Driglit	100V	Trapping	06.08.2021	01:47	06.08.2021	01:51	0	4	-07.12	Under-voltage Voltage Protection	Over Current		Short Circuit & Under-voltage		Transformer Feeder CB operated as Feeder not and Ngangin-Driglit CB operated as Feeder and overcurrent.
8	Ngangin-Driglit	100V	Trapping	06.08.2021	01:39	06.08.2021	01:41	0	2	-07.12	Under-voltage Voltage Protection	Over Load		Short Circuit & Under-voltage		Transformer Feeder CB operated as Feeder not and Ngangin-Driglit CB operated as Feeder and overcurrent.
9	1000 BPH/1000V/Transformer-4	100V	Trapping	06.08.2021	10:04	06.08.2021	10:11	0	7	0.84	MMS & EMFT I/R & I/C relay	Earth Fault	100V Underloading Feeder	Clear		
10	Ngangin-Driglit	100V	Trapping	06.08.2021	10:29	06.08.2021	10:31	0	2	-06.58	Under-voltage Voltage Protection			Short Circuit & Under-voltage		
11	Ngangin-Driglit	100V	Trapping	07.08.2021	14:08	07.08.2021	14:08	0	0	-07.88	Under-voltage Voltage Protection	Earth Fault	Feeder Overload after combination with Driglit and 100V with closing code 100V Feeder by under Voltage Protection	Clear		Feeder changed after combination with Driglit and 100V with closing code 100V Feeder by under Voltage Protection.
12	1000 BPH/1000V/Transformer-4	100V	Trapping	04.08.2021	11:48	04.08.2021	11:59	0	1	0.91	MMS & EMFT I/R & I/C relay	Earth Fault	Over-voltage Underloading Feeder	Clear		
13	1000 BPH/1000V/Transformer-4	100V	Trapping	07.08.2021	02:37	07.08.2021	02:39	0	2	0.87	MMS & EMFT I/R & I/C relay	Earth Fault	Over-voltage Underloading Feeder	Reason		
14	DCT	100V	Trapping	04.08.2021	14:29	04.08.2021	14:30	0	1	12.76		N/A			Clear	Over the maximum capacity at site the main system has capacity nearly 100% but not lower for CB position indication lamp is abnormal not glowing. After switching the above position combination with 100V maximum Feeder Feederly CB trapped at site not.
15	Ngangin-Driglit	100V	Trapping	06.08.2021	17:08	06.08.2021	18:17	2	46	08.28	Under-voltage Voltage Protection			Clear		Feeder removed after completing for Over-voltage work at Driglit not and combination to 100V.
16	1000 BPH/1000V/Transformer-4	100V	Trapping	06.08.2021	17:21	06.08.2021	17:24	0	3	1.07	EMFT Earth Fault & Over-current relay	Over Current	100V Underloading Feeder	Short Circuit & Under-voltage		
17	1000 BPH/1000V/Transformer-4	100V	Underload	06.08.2021	18:28	06.08.2021	18:28	0	3	0.87	MMS & EMFT I/R & I/C relay		Abnormal closed Feeder	Clear		
Section: 1000 BPH/1000V Sub-section: 1000 BPH/1000V Sheet: 206 of 211																
Sl. No.	Name of Feeder	Voltage Level	Type of Storage (Residence/Trapping)	Detection/Triggering		Transmission Time		Detection of Storage		MR Index (Storage (MR))	Trapping Results		Type/Case of Fault	Reason for Shutdown	Weather Condition	Remarks
				Start	Time	Start	Time	(min)	(min)		Protection Relay (Type)	Fault Results (As recorded by relay)				
1	1000 BPH/1000V/Transformer-4	100V	Trapping	03.08.2021	0:44	03.08.2021	0:50	0	6	0.12	BAKCEP PROTECTIVE RELAY	Over Voltage	OC & EP		Normal	Informal MRPI and CB closed from site not at 10:00 hours
2	Storage Underloading Line	100V	Trapping	07.08.2021	0:08	07.08.2021	0:08	0	6	-05.84	BAKCEP PROTECTIVE RELAY	BAK & MR (EP) & MR (EP)	OC & EP		Normal	Informal MRPI and CB closed at 1:29 hrs from site not
3	Storage Range Feeder	100V	Trapping	07.08.2021	2:25	07.08.2021	2:27	0	27	-14.70	BAKCEP PROTECTIVE RELAY	BAK & MR (EP) & MR (EP) & MR (EP)	OC & EP		Normal	Informal MRPI and CB closed from site not at 1:29 hrs
4	Storage Underloading Line	100V	Trapping	07.08.2021	00:08	07.08.2021	00:08	0	0	-04.7	BAKCEP PROTECTIVE RELAY	BAK & MR (EP) & MR (EP)	OC & EP		Normal	Informal MRPI and CB closed from site not at 1:29 hrs
5	Storage Underloading Line	100V	Trapping	07.08.2021	00:08	07.08.2021	00:08	0	0	-04.96	BAKCEP PROTECTIVE RELAY	BAK & MR (EP) & MR (EP)	OC & EP		Normal	Informal MRPI and CB closed from site not at 1:29 hrs
6	Storage Range Feeder	100V	Trapping	07.08.2021	00:08	07.08.2021	00:08	0	0	0.17	BAKCEP PROTECTIVE RELAY	BAK & MR (EP) & MR (EP)	OC & EP		Normal	Informal MRPI and CB closed from site not at 1:29 hrs
7	Storage Range Feeder	100V	Trapping	07.08.2021	0:08	07.08.2021	0:07	0	0	0.10	BAKCEP PROTECTIVE RELAY	BAK & MR (EP) & MR (EP)	OC & EP		Normal	Informal MRPI and CB closed from site not at 1:29 hrs
8	Storage Range Feeder	100V	Trapping	07.08.2021	0:08	07.08.2021	0:07	0	0	0.10	BAKCEP PROTECTIVE RELAY	BAK & MR (EP) & MR (EP)	OC & EP		Normal	Informal MRPI and CB closed from site not at 1:29 hrs
9	Storage Range Feeder	100V	Trapping	07.08.2021	0:08	07.08.2021	0:07	0	0	0.10	BAKCEP PROTECTIVE RELAY	BAK & MR (EP) & MR (EP)	OC & EP		Normal	Informal MRPI and CB closed from site not at 1:29 hrs
10	Storage Range Feeder	100V	Trapping	07.08.2021	0:08	07.08.2021	0:07	0	0	0.10	BAKCEP PROTECTIVE RELAY	BAK & MR (EP) & MR (EP)	OC & EP		Normal	Informal MRPI and CB closed from site not at 1:29 hrs

Substation: 400/220/132/33kV Signalling Substation																	
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping		Normalization Time		Location of Outage (KM)		MW before Outage (MW)	Protection Relay Tripped	Outgoing Details		Type/Value of Fault	Reason for Shutdown	Weather Condition	Remarks
				Date	Time	Date	Time	Phase	Phase			Phase	Phase				
1	132/33V Distribution Feeder	132kV	Increasing supply fail	27/06/2021	20:00 hrs	27/06/2021	20:00 hrs	9	20	21.00	NO	There was an increasing supply fail to grid fail		NO	Other	Other	At 20:00 hrs increasing supply from 132kV substation fail and tripping substation was observed for no feeder tripping has occurred at 132kV substation

Substation: 400/220/132/33kV Signalling Substation																	
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping		Normalization Time		Location of Outage (KM)		MW before Outage (MW)	Protection Relay Tripped	Outgoing Details		Type/Value of Fault	Reason for Shutdown	Weather Condition	Remarks
				Date	Time	Date	Time	Phase	Phase			Phase	Phase				
1	Feeder (132/33V)	132kV	Grid fail	02/07/2021	08:00	02/07/2021	08:34		15	7.00	132kV Trip	Grid (132/33V) (132/33V) (132/33V) (132/33V)		NO	Not available	Other	Line dropped after after called receive from BPSO
2	Feeder (132/33V)	132kV	Grid fail	02/07/2021	08:00	02/07/2021	08:47		7	5.00	132kV Trip	Grid (132/33V) (132/33V) (132/33V) (132/33V)		NO	Not available	Other	Line dropped after after called receive from BPSO

1. 400/220/132/33kV Signalling Substation																
Sl. No.	Date of Tripping	Time of Outages/Time of Tripping	Date of Normalization	Time of Fault was Cleared	Description of Outages (Hrs)	MW before Outage (MW)	Name of Feeder	Name of the Substation on/lines Affected by the Fault	Reasons of Fault	Relay Operations	Fault Location(KM)	Type of outages	Remarks			
(i) 40kV Above																
	2-Jun-21	21:18 hrs	2-Jun-21	21:39 hrs	0	~205.00	40kV M2-2			Distance Relay: SPROTECT TMSU & SPROTECT TMSU1	Main-1: Tripped on RYB, Zone-1, Fault Location: 15.00km Main-2: Tripped on RYB, Fault Location: 16km	Transient				
	3-Jun-21	15:34hrs	3-Jun-21	15:44hrs	0	196.14	40kV M2-2			Distance Relay: SPROTECT TMSU & SPROTECT TMSU1	Fault Loop (L2L), Zone 1 trip, Fault distance (27.00km)	Transient				
	15-Jun-21	01:40 hrs	15-Jun-21	02:41 hrs	0	301.24	40kV Inverse to Algorithm (S0-1)			Distance Relay: SPROTECT TMSU & SPROTECT TMSU1	Main-1: Y1ph pick up and Z1 & Z1B trip, Fault distance 130.7km Main-2: Y1ph pick up and Z1 & Z1B trip, Fault distance 128.0km	Phase-Phase fault, Main-1, Is=0.45A, Ib=0.21AA, Ic=0.07kA Main-2, Is=0.44A, Ib=0.19A, Ic=1.00kA				
	15-Jun-21	01:40 hrs	15-Jun-21	02:21 hrs	0	301.24	40kV Inverse to Algorithm (S0-2)			Distance Relay: SPROTECT TMSU & SPROTECT TMSU1	Main-1: Y1ph pick up and Z1 & Z1B trip, Fault distance 130.0km Main-2: Y1ph pick up and Z1 & Z1B trip, Fault distance 130.0km	Phase-Phase fault, Main-1, Is=0.45A, Ib=0.21AA, Ic=0.07kA Main-2, Is=0.44A, Ib=0.19A, Ic=1.00kA				
	15-Jun-21	02:41 hrs	15-Jun-21	03:52 hrs	1		40kV M2-1 & M3			Distance Relay: SPROTECT TMSU & SPROTECT TMSU1	OV					
	19-Jun-21	16:42 hrs	19-Jun-21	17:13hrs	0	~242.31	40kV M3			Distance Relay: SPROTECT TMSU & SPROTECT TMSU1	Fault dist(8.0km)	Fault Loop(L4G)				
	28-Jun-21	19:50 hrs	28-Jun-21	19:50 hrs	0	204.25	40kV Quad inverse Algorithm Zone-2			Distance Relay: SPROTECT TMSU & SPROTECT TMSU1	Main-1, R1ph pick up and Z1 & Z1B trip, Fault distance 70.0km Main-2, Y1ph pick up and Z1 trip, Fault distance 74.0km	Is=1.00kA				

29-Jun-21	88.23 hrs	29-Jun-21	87.36 hrs	1	-11.81	400KV GCT		74002-74003-74004, SPROTECT 7/101	57.676 trip		
29-Jun-21	15.58 hrs	29-Jun-21	15.58 hrs	0	204.25	400KV Quad reclose Algorithm Line-2		Distance Relay SPROTECT 7MA2 & SPROTECT 7MA31	Main-1, Ypk pick, Fault distance 63.5km, Main-2, Ypk pick, Fault distance 63.5km		
6-Jun-21	11.53 hrs	7-Jun-21	12.17 hrs	0	0.64	220KV Dagaiphe Feeder		Distance Relay SPROTECT 7MA2 & REL670	Main-0, Ypk pick up and Z1 trip, Fault distance 7.0km, Main-2, Ypk pick up and Z1 trip, Fault distance 7.0km	Fault Loop (L2 & L1), Ia=0.02KA, Ib=2.05KA & Ic=2.05KA	
7-Jun-21	80.43 hrs	7-Jun-21	80.54 hrs	0	0.14	220KV Dagaiphe Feeder		Distance Relay SPROTECT 7MA2 & REL670	Main-0: Tripped on RYN, Zone-1, Fault Location: 7.0km, Main-2: Tripped on RYN, Zone-0 & 2, Fault Location: 7.0km	Fault Loop (L1 & L2), Ia=2.45KA, Ib=2.05KA & Ic=0.02KA	
7-Jun-21	88.27 hrs	7-Jun-21	88.41 hrs	0	1.14	220KV Dagaiphe Feeder		Distance Relay SPROTECT 7MA2 & REL670	Main 1 - Tripped on RYN, Zone 1, Distance: Distance Main-0=7.0km, Main-2=7.11 km	Ia=2.5KA, Ib=2.5KA, Ic=0.02KA	
7-Jun-21	88.11 hrs	8-Jun-21	11.15 hrs	28	1.31	220KV Dagaiphe Feeder		Distance Relay SPROTECT 7MA2 & REL670	Main 1 - Tripped on RYN, Zone 1, Main-0=7.0km, Main-2=7.4 km	Ia=2.5KA, Ib=2.5KA, Ic=0.02KA	
12-Jun-21	88.14 hrs	12-Jun-21	88.14 hrs			Bus-coupler			50.51N		
12-Jun-21	10.94 hrs	12-Jun-21	10.14 hrs	0	-13.34	400KV AICT-1		74002-74003-74004 & 740041-74006-74007CC	50.51N, WTI LV tripped	Over load	
12-Jun-21	10.59 hrs	12-Jun-21	11.13 hrs			Bus-coupler			50.51N		
12-Jun-21	11.47 hrs	12-Jun-21	12.21 hrs			Bus-coupler			50.51N		
18-Jun-21	17.00 hrs	18-Jun-21	17.21 hrs	0	21.89	400KV AICT 1 & 2		74002-74003-74004CC & 740041-74006-74007CC	LV SEF trip, 504-1 trip		
19-Jun-21	18.42 hrs	19-Jun-21	18.48 hrs	0	0.06	ICT-1, ICT-2, ICT-3, ICT-4		74002-74003-74004CC & 740041-74006-74007CC	Relay Des.trip, LV SEF trip		
28-Jun-21	85.15 hrs	28-Jun-21	85.72 hrs	0	1.1	220KV Dagaiphe Feeder		Distance Relay SPROTECT 7MA2 & REL670	Main-1, Ypk and Z1 trip, Fault distance 7.4km, Main-2, Ypk and Z1 trip, Fault distance 7.2km	Fault loop (L2,3)	
28-Jun-21	86.25 hrs	28-Jun-21	86.17 hrs	0	-1.76	220KV Dagaiphe Feeder		Distance Relay SPROTECT 7MA2 & REL670	Main-2 optd, Ypk pick up and Z1 trip, Fault distance 7.0km, Main-0 optd Ypk pick up and Z1 trip, Fault distance 7.0km	Fault loop (L2,3)	
3-Jun-21	18.39 hrs	3-Jun-21	18.44 hrs	0	13.76	220KV Galya Feeder		Distance Relay SPROTECT 7MA2 & 805.410	Fault loop (L2,3) Zone 1 trip, Fault dist=20.3km	Transient	
15-Jun-21	82.41 hrs	15-Jun-21	82.51 hrs	0	0	220KV Dagaiphe Feeder		Distance Relay SPROTECT 7MA2 & 805.410	Main 1, RYpk pick up		
18-Jun-21	17.39 hrs	18-Jun-21	18.07 hrs	2	40.67	220KV Dagaiphe Feeder			Main 1, Rpk pick up Fail (Dist=7.0km)	Fault Loop(L1,2) Fault current L1=1.3KA	
E. 120/66-110KV Dhaqay Substation											
0 400V and above											
1	11.06.2021	02.07hrs	11.06.2021	02.14hrs	0	6.33	Signaling from Dhaqay ST	Main 10- Ia=99.41A, L19, 27.66, 1 & 2, relay Main 8	Tripped	Whole Training in black	
2	16.06.2021	8.41-0700RS	16.06.2021	8.54-0700S	0	94.36	Dagaiphe Feed Dhaqay ST	Main 10- Ia=0.16A, 141.9C, 60.1 & 2, relay Main 8	Tripped	Whole Training in black	
E. 121/66-33-110KV Galya Substation											
0 400V and above											
1	01.06.2021	18.40hrs	01.06.2021	19.27	12	01-Sakati A Backout S	bad weather	No CB & relay operated at our end	Sakati line	Temporary	Auto reclosed from signaling on at 18.43hrs
3	04.06.2021	11.12hrs	04.06.2021	18.23hrs	0	5.4	132kv Gel-3rd bus	Shutdown by Sakati ss	ss	Temporary	Charging code NLDC BTN=1003,NLDC D02=215,NLDC=1094

4.132/110KV Tamhi Substation												
110KV and Above												
1	6/8/2021	2:20	6/9/2021	8:58	0	31.6600	110KV Tangli Nam Tangli No	Temporary fault	Distance Protection Relay Trip phase ABC Fault Location: 04.49KM Fault Zone: 2	110KV Tangli Namglun	Temporary	
2	6/11/2021	24:20	6/11/2021	01:40	0	17.5700	110KV Tangli Nam Tangli No	Temporary fault	Distance Protection Relay Start Phase B, Trip phase ABC, Fault Location: 20.14KM Fault Zone: 2	110KV Tangli Namglun	Temporary	
3	6/15/2021	1:46	6/15/2021	2:43	0	42.2600	110KV Tangli Nam Tangli No	Temporary fault	Distance Protection Relay Start Phase ABC, Trip phase ABC, Fault Location: 2.02KM Fault Zone: 1	110KV Tangli Namglun	Temporary	
4	6/15/2021	1:46	6/15/2021	2:38	0	44.5700	110KV Tangli Nam Tangli No	Temporary fault	Distance Protection Relay Start Phase ABC, Trip phase ABC, Fault Location: 6.70KM Fault Zone: 1	110KV Tangli Namglun	Temporary	
5	6/16/2021	17:01	6/16/2021	19:34	2	34.1300	110KV Tangli Nam Tangli No 210 Main Bus B phase insulator fail	Insulator fail	Distance Protection Relay Start Phase AN, Fault Location: 40.2 KM Fault Zone: 4	110KV Tangli Namglun	Insulator fail	
6	6/16/2021	17:01	6/16/2021	19:47	2	31.1200	110KV Tangli Nam Tangli No 210 Main Bus B phase insulator fail	Insulator fail	Distance Protection Relay Trip phase AN, Fault Location: 30.0 KM Fault Zone: 4	110KV Tangli Namglun	Insulator fail	
5.132/33KV Yarnoo Substation												
110KV & Above												
1	18.06.2021	0.711088889	18.06.2021	0.9747222	0	0.2	110KV Tangli Yarnoo 1 insulator fracture at Tangli No. N01	Tripping No				Restored after repair
6.120/33KV Dagapela Substation												
110KV & Above												
1	17.06.2021	0.06607556	17.06.2021	0.0972222	0	-0.64	120KV Dagapela over voltage	86 A, 802.0V-I			Transient Fault	Feeder tripped on over

July 2021

MONTHLY OUTAGE REPORT FOR THE MONTH OF JULY UNDER SMD DEOTHRANG, TD, BPC.													
1	Division:	SMD-DEOTHRANG											
	Substation:	132/33/110KV Yanglu Substation											
	Month:	Jul 21											
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping		Normalization Time		Outage Duration (hrs)	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time		Protection Relay Operd	Fault Details (As recorded by relay)			
132KV Feeders													
1	132/33KV, MFVA T1-F4	132KV	Tripping	7/2/2021	00:19 hrs	7/2/2021	00:23 hrs	0	Non-directional IDMT PROTN Relay operated	OC relay-50A & tripping relay R5 operated	Tripped due to feeder fault	+	Tripped due to fault on 33KV Tushar feeder
2	132/33KV, MFVA T1-F1	132KV	Tripping	7/2/2021	00:19 hrs	7/2/2021	00:24 hrs	0	Non-directional IDMT PROTN Relay operated	OC relay-50A & tripping relay R5 operated	Tripped due to feeder fault	+	Tripped due to fault on 33KV Tushar feeder
3	132/33KV, MFVA T1-F4	132KV	Tripping	7/2/2021	00:45 hrs	7/2/2021	00:55 hrs	8	Non-directional IDMT PROTN relay operated	OC relay-50C & tripping relay R5 operated	Tripped while test charging of 33KV Tushar feeder	+	Kept under shut down due to spark observation from LV side isolator
4	132/33KV, MFVA T1-F1	132KV	Tripping	7/2/2021	00:45 hrs	7/2/2021	01:50 hrs	1	Non-directional IDMT PROTN relay operated	OC relay-50C & tripping relay R5 operated	Tripped while test charging of 33KV Tushar feeder	+	Delayed in charging due to cascade.
5	132/33KV, MFVA T1-F4	132KV	Tripping	7/5/2021	09:39 hrs	7/5/2021	09:44 hrs	0	Non-directional IDMT PROTN relay operated	OC relay-50A & tripping relay R5 operated	Tripped due to feeder fault	+	Tripped due to fault on 33KV Tushar feeder
6	132/33KV, MFVA T1-F1	132KV	Tripping	7/13/2021	14:22 hrs	7/13/2021	14:27 hrs	0	Non-directional IDMT PROTN relay operated	OC relay-50A & tripping relay R5 operated	Tripped due to feeder fault	+	Tripped due to fault on 33KV Yarang feeder
7	132/33KV, MFVA T1-F1	132KV	Tripping	7/13/2021	15:14 hrs	7/13/2021	15:19 hrs	0	Non-directional IDMT PROTN relay operated	OC relay-50A & tripping relay R5 operated	Tripped due to feeder fault	+	Tripped due to fault on 33KV Yarang feeder

3		Division: SANDHUTRANG		Substation: 231/35/11kV Nganglam Substation		Month: Jul 21											
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown)	Shutdown/ Tripping		Normalization Time		Duration in (Hrs)	Protection Relay Oper	Tripping Details (As recorded by relay)	Type/Cause of Fault	Reason for Shutdown	Remarks				
				Date	Time	Date	Time										
11kV																	
1	Nganglam-Teigle	11kV	Tripping	07.07.2021	10:27	11.07.2021	12:34	07	Micro relay 9442	Fault Value (kV) 412.44 (k)-415.964, (C)-411.24 (k)-401.14	Earth Fault (k-PO to Ground)		Over charged cable causing conductor 1 (100) down both and not tripped on same fault. Fault was located towards TDP(2)-TDP(12) where dropping of DTR isolator has caused				
2	Nganglam-Teigle	11kV	Tripping	21.07.2021	12:00	21.07.2021	12:51	0	Micro relay 9442	100% trip. 0.8 stopped. Fault location: 137 (kV), Zone 1. Fault resistance: 1.750 ohm, System frequency: 50.00Hz. Fault direction: 70 (kV) 200- 10.47A, (k)- 885.44 (k)- 1405.6A, (kV)- 118.0V, (kV)- 51.84kV, (kV)- 115.9V	Over Current	Supply restored after coordination by BPSO and Teigle and with cable faulted (kV) conduct 1122 found by Mr. Teigle (BPSO) Teigle.					
3		Division: SANDHUTRANG		Substation: 132/35kV Mustang Substation		Month: Jul 21											
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown)	Shutdown/ Tripping		Normalization Time		Duration in (Hrs)	Protection Relay Oper	Tripping Details (As recorded by relay)	Type/Cause of Fault	Reason for Shutdown	Remarks				
				Date	Time	Date	Time										
1	132/35kV Trans	11kV	Tripping	5/8/2021	8:42	5/8/2021	8:50	0	BACKUP PROTN RELAY REF415	80A OPTD	OC & EF	-	CB closed at 09:50 hrs from our end.				
6	132/35kV Trans	11kV	Tripping	7/15/2021	8:32	7/15/2021	8:18		BACKUP PROTN RELAY REF415	80A OPTD, Protection tripped	OC & EF	-	CB closed at 6:18 hrs from our end.				
9	11kV Rangia B	11kV	Tripping	7/20/2021	12:16	7/20/2021	12:55		BCF1-REF415F PROTECTION RELAY	80A 80SD OPTD	OC & EF	-	CB closed at 12:55 hrs from our end.				
11	132/35kV Trans	11kV	Tripping	7/27/2021	12:59	7/27/2021	13:02		BACKUP PROTN RELAY REF415	80A OPTD	OC & EF	-	CB closed at 13:02 hrs from our end.				
4. 400/120/33/10kV Reporting Substation																	
Sl. No.	Date of Tripping	Time of Outages/ Time of Tripping	Date of Normalization	Time of Fault was Cleared	Duration of Outages (Hrs)	Duration of Outages (Min)	MVA before Outage (MVA)	Name of Feeder	Name of the Substation/Line Affected by the Fault	Reasons of Fault	Relay Operations	Fault Location(KM)	Type of outages	Remarks			
400kV																	
1	2-Ad-21	00:14 hrs	2-Ad-21	00:01 hrs	0	27	-78.01	300MVA ICT	-78.01	47.67 TDC A Pick-up: 47.67 TDC B Pick-up:	71000-11000-1PC000, SPROTECT T/2H1			ICT tripped along with tripping of 220kV Chagaple Line.			
2	2-Ad-21	01:34 hrs	2-Ad-21	07:40 hrs	0	14	-41.81	300MVA ICT	-41.81	47.67 TDC A Pick-up: 47.67 TDC B Pick-up: 300kV - 5.2 trip.	71000-11000-1PC000, SPROTECT T/2H1			ICT tripped along with tripping of 220kV Chagaple Line and ICT kept shuttles as per BPSO instruction.			
4	16-Ad-21	12:49 hrs	16-Ad-21	13:00 hrs	0	47	-78.31	300MVA ICT	-78.31	47.670 20V	71000-11000-1PC000, SPROTECT T/2H1						
7	16-Ad-21	12:49 hrs	16-Ad-21	12:49 hrs	0	0	MS-290.07 & MS-290.08	MSPA Line 1 & 2	MS-290.07 & MS-290.08	ICT1: High pick up. Fault distance 7.7 km. MS2: High pick up and 21.7 trip.	SPROTECT 76ACL SPROTECT 76A11			Line was restored at 1:20hr.			

120 kV														
1	2-M-21	00:14 hrs	2-M-21	00:22 hrs	00:14 hrs	0	0.01	220kV Dagaipela Feeder	Distance Relay: SIPROTECT *SA12 & REL470	Main-1, R1Yh pick up and Z1 Z1B trip. Fault distance 7.4km. Main-2, R1Yh pick up and Z1 trip. Fault distance 7.2km.	Feeder Loop-Z1 & L2, I=7.25kA, S=7.21kA & I=0.02kA			
2	2-M-21	00:47 hrs	2-M-21	00:07 hrs	00:00 hrs	0	0.01	220kV Dagaipela Feeder	Distance Relay: SIPROTECT *SA12 & REL470	Main-1, R1Yh pick up and Z1 Z1B trip. Fault distance 7.4km. Main-2, R1Yh pick up and Z1 trip. Fault distance 5.95km.	Feeder Loop-Z1 & L2, I=7.25kA, S=2.05kA & I=0.02kA			
3	2-M-21	01:00 hrs	2-M-21	01:20 hrs	01:00 hrs	0	0.07	220kV Dagaipela Feeder	Distance Relay: SIPROTECT *SA12 & REL470	Main-1, R1Yh pick up and Z1 Z1B trip. Fault distance 7.4km. Main-2, R1Yh pick up and Z1 trip. Fault distance 7.20km.	Feeder Loop-Z1 & L2, I=7.25kA, S=2.24kA & I=0.02kA			
4	2-M-21	01:04 hrs	0-M-21	14:00 hrs	01:00 hrs	43	0.07	220kV Dagaipela Feeder	Distance Relay: SIPROTECT *SA12 & REL470	Main-1, R1Yh pick up and Z1 Z1B trip. Fault distance 7.4km. Main-2, R1Yh pick up and Z1 trip. Fault distance 7.02km.	Feeder Loop-Z1 & L2, I=2.05kA, S=7.05kA & I=0.02kA	Line declared faulty		
5	20-M-21	04:01 hrs	20-M-21	04:02 hrs	04:01 hrs	0	0.07	220kV Dagaipela Feeder	Distance Relay: SIPROTECT *SA12 & REL470	Main-1, YR1Yh pick up and Z1 trip. Fault distance 7.4km. Main-2, YR1Yh pick up and Z1 trip. Fault distance 7.12km.	Feeder Loop-Z1 & L2, I=0.02kA, S=7.05kA & I=7.05kA			
6	20-M-21	08:54 hrs	20-M-21	17:23 hrs	10:59 hrs	0	49.52	220kV Taring Feeder	Distance Relay: SIPROTECT *SA12 & REL470	Main-1, SA1Yh pick up and Z1 trip. Fault distance 0.90km. Main-2, SA1Yh pick up and Z1 trip. Fault distance 0.20km.	Feeder Loop-Z1 & L2, I=1.05kA, S=0.30kA & I=4.00kA	Line changed as per BPSO code 1074, Push Zam		
7	20-M-21	08:59 hrs	20-M-21	17:29 hrs	10:59 hrs	0	0.01	220kV Dagaipela Feeder	Distance Relay: SIPROTECT *SA12 & REL470	Main-1, R1Yh pick up and Z1 trip. Fault distance 0.00km. Main-2, SA1Yh pick up and Z1 trip. Fault distance 0.12km.	Feeder Current I=3.02kA, S=0.01kA & I=1.70kA	Line changed as per BPSO code 1074, Push Zam		
8. 132/66/33/11kV Golepka Substation (0.6kV and above)														
1	21-07-2021	01:50hrs	22-07-2021	14:22hrs		32	30	to Golepka-Sigatung	none	Emergency call by Substation	No CB appeared at our end	Signaling line	Temporary	No CB appeared at our end
2	21-07-2021	01:27hrs	23-07-2021	13:06hrs		39	22.6	to Golepka-Subkati	none	handover-casting		Subkati line	Temporary	Charging code NLDC BTN=1344, NLDC IND=1204,NERLDC=0178
3	31-07-2021	06:19hrs	31-07-2021	18:10hrs	0	23	19.4	to Golepka-Subkati	None	V-Ph conductor sagged from main bus at Subkati Substation.	General trip,Line failZone 4,Y+ phase,D=6.61,2.0km,Differential relay,RY, ph, Fault current=I=520.4A,Y=1496.54A,S=142.65A,S=914.97A.	Subkati line	Temporary	Charging code NLDC BTN=1399, NLDC IND=1629,NERLDC=6461
6. 132/33/11kV Taring Substation (0.6kV and above)														
1	03/08/21	00:07	03/08/21	12:40	00	33	11.000	110kV Taring-Nangphel/110kV Taring-Nangphel	insulator failed	Distance Protection Relay Trip phase ABC,Start phase AB/ fault Location: 19.98km, fault Zone: 5.	110kV Taring-Nangphel	110kV Taring-Nangphel	Line fault	
2	03/08/21	01:08	03/08/21	12:53	0	34	10.400	110kV Taring-Nangphel/110kV Taring-Nangphel	Temporary fault	Distance Protection Relay Trip phase ABC,Start phase BC/ fault Location: 1.809km, fault Zone: 5.	110kV Taring-Nangphel	110kV Taring-Nangphel	Line fault	
7. 220/220kV Dagaipela Substation (0.6kV & above)														
1	15-06-2021	0:04:00	15-06-2021	0:07:22	0	19	-0.04	220kV Dagaipela-By Dagaipela Substation over voltage		at A, 140.7V=1	-	Transient Fault		Breaker tripped on over voltage

August 2021

Division: SMD-DEOTHRANG Substation: 131/35/11kV Kanglung Substation Month: Aug 21														
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown)	Shutdown/Tripping		Normalization Time		Duration of Outage		Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time	(Hrs)	(Min)	Protection Relay Oper	Fault Details (As recorded by relay)			
132kV Feeders														
1	112kV/Corbu	132kV	trip on fault	7.08.2021	12:39	7.08.2021	12:57	0	18	relay 85 operated	NA	Trip on fault	Faulty	132kV feeder trip due to outgoing feeder faulty
Division: SMD-DEOTHRANG Substation: 131/35/11kV Deothrang Substation Month: Aug 21														
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown)	Shutdown/Tripping		Normalization Time		Duration of Outage		Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time	(Hrs)	(Min)	Protection Relay Oper	Fault Details (As recorded by relay)			
1	NMEE 2	132/33kV	Trip	18.08.2021	11:28	18.08.2021	11:30	0	30		NA			Trip due to low air pressure & card issue.
2	NMEE 2	132/33kV	Trip	18.08.2021	12:17	18.08.2021	12:22	0	5	80				Trip by 5/7 feeder changed & found normal
Division: SMD-DEOTHRANG Substation: 132/35/11kV Nganglum Substation Month: Aug 21														
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown)	Shutdown/Tripping		Normalization Time		Duration of Outage		Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time	(Hrs)	(Min)	Protection Relay Oper	Fault Details (As recorded by relay)			
132kV														
1	gikhe-Ngum	132kV	Tripping	06.08.2021	12:39	06.08.2021	12:44	0	5	Micom relay P442	NA	Due to seepage of Rain water inside the CB box that might have caused lead to tripping of CB.		CB operated at our end only. Supply was restored after coordination to BPSO & Tingthi end.
2	nglum-Ting	132kV	Tripping	11.08.2021	02:58	11.08.2021	02:59	0	1	Micom relay P442	NA	Due to seepage of Rain water inside the CB box that might have caused lead to tripping of CB.		CB operated at our end only. Supply was restored after coordination to BPSO & Tingthi end.
3	nglum-Ting	132kV	Tripping	17.08.2021	04:00	17.08.2021	04:05	0	5	Micom relay P442	NA			CB operated at our end only. Supply was restored after coordination to BPSO & Tingthi end.
4	nglum-Ting	132kV	Tripping	17.08.2021	06:58	17.08.2021	07:05	0	7	Micom relay P442	NA	Due to seepage of Rain water inside the CB box that might have caused lead to tripping of CB.		CB operated at our end only. Supply was restored after coordination to BPSO & Tingthi end.
5	nglum-Ting	132kV	Tripping	17.08.2021	07:54	17.08.2021	09:31	1	17	Micom relay P442	NA			Supply restored after clearing and rectifying the seepage rain water from the CB box with vide Switch ON code# 1474 issued by Miss. Tshering Choden, BPSO.
6	nglum-Ting	132kV	Tripping	27.08.2021	12:31	27.08.2021	12:42	0	11	Micom relay P442	LA-84.05A IB=1.065KA IC=126KA Location 79.88km VAN= 75.51kV VBS= 81.02kV VCN= 37.72kV			Supply restored after coordinating to BPSO and Tingthi end with vide Switch ON code# 1523 issued by Mts. Pema Lhamo, BPSO.

Division:	SMD DEOTHRANG
Substation:	132/33kV Motang Substation
Month:	Aug-21

Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/ Tripping)	Shutdown/Tripping		Normalization Time		Duration of Outage		Tripping Details		Type Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time	(Hrs)	(Min)	Protection Relay Operd	Fault Details (As recorded by relay)			
1	132kV Ram	132kV	Tripping	8/5/2021	12:06	8/5/2021	13:04	1	10	MAIN DISTANCE PROT.N. RELAY-REL650	86A & 80B OPTD	OV&UV OPTD	-	Informed BPSO, as instructed to closed CB with code NLDC BH7-1408,NLDC India-208 and NERLDC-6689 at 13:14 hrs from our end.
2	132kV DM	132kV	Tripping	8/6/2021	15:40	8/6/2021	16:04		24	MAIN DISTANCE PROT.N. RELAY-REL650	86A OPTD,Protection tripped	OV&UV OPTD. BAY&B TRIP	-	CB closed at 16:04hrs from our end.
3	33kV POP I	33kV	Shutdown	8/8/2021	9:33	8/8/2021	10:06		33	HAND TRIPED	-	-	To replace fuse	Shutdown taken by ESD to replace fuses at their end and line charge at 10:06hrs from our end
4	132kV Des	132kV	Tripping	8/12/2021	5:23	8/12/2021	5:46		23	MAIN DISTANCE PROT.N. RELAY-REL650	86A & 80B OPTD	OV & UV OPTD	-	Tripped due to voltage shootup to 141.08kV informed BPSO and line charged at 5:46hrs from our end.
5	132kV Ram	132kV	Tripping	8/12/2021	5:23	8/12/2021	5:50		27	MAIN DISTANCE PROT.N. RELAY-REL650	86A & 80B OPTD	OV & UV OPTD	-	Tripped due to voltage shootup to 141.08kV informed BPSO and line charged at 5:50hrs from our end with code NLDC BH7-1449,NLDC India-372 and NERLDC-6962.
6	132kV DM	132kV	Tripping	8/12/2021	5:23	8/12/2021	6:24	1	1	MAIN DISTANCE PROT.N. RELAY-REL650	86A & 80B OPTD	OV & UV OPTD	-	Tripped due to voltage shootup to 141.08kV informed BPSO and line charged at 6:24hrs from our end.
7	132kV Phu	132kV	Tripping	8/12/2021	5:23	8/12/2021	6:27	1	4	MAIN DISTANCE PROT.N. RELAY-REL650	86A & 80B OPTD	OV & UV OPTD	-	Tripped due to voltage shootup to 141.08kV informed BPSO and line charged at 6:27hrs from our end.
8	33kV Azim	33kV	Shutdown	8/16/2021	16:11	8/16/2021	16:34		23	HAND TRIPED	-	-	To remove jumpering at their end.	CB closed at 16:34hrs from our end.
9	15MVA Tr	132/33kV	Tripping	8/26/2021	10:55	8/26/2021	10:54		1	Differential Relay RET 650 Operated	SEP proto opd.	-	-	CB closed at 10:54hr from our end.
10	Rangia Fee	132kV	Tripping	29-08-2021	14:06	29-08-2021	14:50		44	MAIN DISTANCE PROT.N. RELAY-REL650	86A & 80B OPTD	OV&UV	-	Informed BPSO, as instructed to closed CB with code NLDC BH7-1515,NLDC India-1797 and NERLDC-7627 at 14:50hrs from our end.
11	Rangia Fee	132kV	Tripping	29-08-2021	15:37	29-08-2021	16:51	1	14	MAIN DISTANCE PROT.N. RELAY-REL650	86A & 80B OPTD	OV&UV	-	Informed BPSO, as instructed to closed CB with code NLDC BH7-1516,NLDC India-1812 and NERLDC-7633 at 16:51hrs from our end.

Sl. No.	Date of Tripping	Time of Outages/ Time of Tripping	Date of Normalization	Time of Fault was Cleared	Duration of Outages (Hrs)	Duration of Outages (Min)	MW before Outage (MW)	Name of feeder	Name of the Substation/lines Affected by the Fault	Reasons of Fault	Relay Operations	Fault Location(KM)	Type of outages	Remarks
1) 66kV														
1	500MVA SC	600/220kV	Tripping	0:00	07:49 hrs	4420	37.55 hrs	8	-41.32	75J011-52890-IFCB DO, SPROTECT 7U781	No relay indication			
2	500MVA SC	400/220kV	Tripping	24-Aug-21	20:58 hrs	4432	21:04 hrs	8	-21.34	75J011-52890-IFCB DO, SPROTECT 7U781	50% 1/2 tripped			
3	500MVA SC	400/220kV	Tripping	0:00	22:47 hrs	4432	23:39 hrs	54		75J011-52890-IFCB DO, SPROTECT 7U781	50% 1/2 tripped			
4	500MVA SC	400/220kV	Tripping	0:00	23:54 hrs	4432	12:47 hrs			75J011-52890-IFCB DO, SPROTECT 7U781	50% 1/2 tripped			
5	400kV Quad	400kV	Tripping	0:00	01:59 hrs	4434	01:59 hrs	9	806.9	SPROTECT 7SA52, SPROTECT 7SA811	Main-1: Rph to ground pick. Main-2: Rph to ground pick	Fault distance 155.0km		
1	220kV Tans	220kV	Tripping	0:00	15:47 hrs	44415	16:37 hrs	50	-74.19	Distance Relay: SPROTECT 7SA52 & REL650	Main 1: Fault Loop Rph to Ground, Z1 x18 Trip. Fault dist: 21.94km. Main 2: Fault Loop Rph to Ground and Z1 & Z2 Trip.	current 1c: 0.26KA, 1b: 0.14KA & 1c: 4.20KA		
2	30 MVA SC	220kV	Tripping	0:00	04:40 hrs	44520	04:40 hrs	9	-21.89	36.1.96.2 operated	1/3 MTP			

E. 66kV and above													
1	11.08.2021 01:39 hrs	11.08.2021 02:00 hrs	0	21	76.42	Agarwala feeder	Dhagay SS	Main II Ia=15.4 kA, A.L. relay Main II	Tripped	bus coupler also tripped at a same time.			
2	11.08.2021 01:39 hrs	11.08.2021 2:12hrs	0	33	-83.06	Dagacha	Dhagay SS	Main II Ia=15.4 kA, A.L. relay Main II	Tripped	bus coupler also tripped at a same time.			

F. 132/66/33/11kV Gelephu Substation													
66kV and above													
1	11.09.2021	01.36hrs	11.09.2021	02.03hrs	00:00	16.8	By Gelephu-Salakat	25MVA(HV & LV)	bad weather	fail relay,B-ph.	Salakati line	Temporary	Charging code NLDC BFN-1442, IND-108 NERL(DC-093)

September 2021

Division: SMO DEOTHANG Substation: 132/66/33/11kV Yangtse Substation Month: 09/21															
M. No.	Name of Feeder	Voltage Level	STP/OT Outage	Shutdown/Tripping		Normalization Time		Duration of Outage		MW Index Outage (MW)	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time	(Hrs)	(Min)		Protection Relay Oper	Fault Details (As recorded by relay)			
110kV															
1	Corling-Kanglung Incomer	132KV	Tripping	02.09.2021	5:09	02.09.2021	6:11	0	17	-18.762	relay P1-CB1AACC040A operated.	Ia=411.3, Ib=80.3A, Ic=407.6	Earth fault	Tripped	Corling-Kanglung Incomer Breaker tripped indicating earth fault, test charge done at 6:40 but did not withstand, later again charged at 6:55.
2	Corling-Kanglung Incomer	132KV	Tripping	10.09.2021	17:30	10.09.2021	17:42	0	2	-21.204	relay P1-CB1AACC040A operated and P142(Distance Relay)	Ia=638.6, Ib=706.4, Ic=607.3 and Fault Location = 37.6KDM	Over current	Tripped	Corling-Kanglung Incomer Breaker tripped indicating Over current and test charge done and line withstood.
3	Phandolung	132KV	Tripping	10.09.2021	17:30	10.09.2021	17:39	0	20	20.324	BEF015	Ia=1.154 x IS, Ib=1.261 x IS, Ic=1.236 x IS	Over current	Tripped	132KV Phandolung line tripped on Over current and test charge done and line withstood.
4	Corling-Kanglung Incomer	132KV	Tripping	10.09.2021	17:39	10.09.2021	17:41	0	2	-21.204	relay P1-CB1AACC040A operated and P142(Distance Relay)	Ia=776.3, Ib=935, Ic=786.9 and Fault Location = 38.19KDM	Over current	Tripped	Corling-Kanglung Incomer Breaker tripped indicating Over current and test charge done and line withstood.
5	Phandolung	132KV	Tripping	10.09.2021	17:39	11.09.2021	12:43	19	6	20.324	BEF015	Ia=1.508 x IS, Ib=1.573 x IS, Ic=1.644 x IS	Over current	Tripped	132KV Phandolung line tripped on Over current and test charge done and line did not withstand. Line only faultily charged for feeder on dated (11.09.2021) Closing Code 1542 by Tibering Choden (BPSO Thimphu.)
6	Phandolung	132	Line Fault	20.09.2021	14:07	20.09.2021	14:15	0	19	10.974	Dist. Prot.	NA	Dist.	Line Fault	Tripped & indicates Distance Protection relay.
7	Phandolung	132	Shutdown	20.09.2021	16:32								Shutdown	Voltage checking at p. Thang m.	Opening code 0141, issued by BPSO Tibering Choden, Duty personal
8	Corling-Kanglung Incomer	132	Line Fault	20.09.2021	17:27	20.09.2021	18:06	0	39	-1.912	R.P	Ia=109.6A, Ib=712.8A, Ic=96.91A.	Earth fault	Line Fault	Tripped through fault relay.
Division: SMO DEOTHANG Substation: 132/66/33/11kV Yangtse Substation Month: 09/21															
M. No.	Name of Feeder	Voltage Level	STP/OT Outage	Shutdown/Tripping		Normalization Time		Duration of Outage		MW Index Outage (MW)	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks
110kV Feeders															
1	132/66KV, TMS.A. 33-9	132KV	Tripping	9/1/2021	18:51 hrs	9/1/2021	18:57 hrs	0	6	0.39	Exp relay operated	Tripping relay 30 operated	Tripped due to feeder fault	-	Tripped due to fault on 110V TMS.A feeder
1	Yangtse-Drooling Line	132KV	Tripping	9/28/2021	02:18 hrs	9/28/2021	02:34 hrs	0	18	64.7	MCCOP142	Directional -O/C & E/F Relay: Tripped 0 C/N, Inset 0'S, O/C inset 0- 1, E/F1 inset 0G1-1G, trip IN1=17.48=115.6KV, VBC=125.6KV, 3/CA=102.0KV, VAN=77.06KV, VBN=76.22KV, VCN=77.06KV, IA=187.7A, IB=190.2A, IC=170.7A, IDeltaI=4-017.0A, DV measured=0.14AA & tripping relay 30 operated at one end.	Tripped on fault	-	Information to BPSO & charged the feeder with the instruction from BPSO

Division: SMD DROTHANG Substation: CSJ-33 110kV Drothang Substation Month: 08/21														
Sl. No.	Name of Feeder	Voltage Level	OPSW Outage	Shutdown/Tripping		Normalization Time		Duration of Outage		MW before Outage (MW)	Tripping Details		Reason for Shutdown	Remarks
				Date	Time	Date	Time	(Hrs)	(Min)		Protection Relays Oper	Fault Details (As recorded by relay)		
1	132/10kV TMTVA Transformer MB	132/10kV	Tripped	02.09.2021	5:07	02.09.2021	5:20	0	0	0.67 & 0.65	NA	NA	NA	Both the Transformers got tripped due to fault at Sengkang-Drothang line. First capacitor bank not get reset.
2	132/10kV TMTVA Transformer MB	132/10kV	Tripped	03.09.2021	9:09	03.09.2021		0	0	0.08 & 0.077	NA	NA	NA	Both the Transformers got tripped due to over current earth fault of Bangor line. First charge was done and got reset till found ok.
3	132/10kV TMTVA Transformer MB	132/10kV	Tripped	03.09.2021	18:34	03.09.2021	18:09	0	0	06 and 05	Hi opt	NA	No Bangor life	Transformer was charged with isolating Bangor line and found normal. After the closing coil of Tr 2 13V side we kept life charge.
4	Sengkang-Drothang line	132kV	Tripped	28.09.2021	2:26	28.09.2021	2:31	0	11	-50.22	NA	NA	NA	Supply stopped at both end (Sengkang and Drothang). No backup supplied at Drothang end. At 2:31 hrs supply changed from Miranga and at 2:34 hrs supply synchronized from Sengkang substation.
Division: SMD DROTHANG Substation: T22-15 110kV Sengkang Substation Month: 08/21														
Sl. No.	Name of Feeder	Voltage Level	OPSW Outage	Shutdown/Tripping		Normalization Time		Duration of Outage		MW before Outage (MW)	Tripping Details		Reason for Shutdown	Remarks
				Date	Time	Date	Time	(Hrs)	(Min)		Protection Relays Oper	Fault Details (As recorded by relay)		
UNAV														
1	Sengkang-Tingthi	132kV	Tripping	01.09.2021	14:57	01.09.2021	15:08	0	44	-18.11	Missed relay P40	NA	Transient Fault	CB operated at Tingthi end only.
2	Sengkang-Tingthi	132kV	Tripping	09.09.2021	11:31	09.09.2021	11:42	0	0	10.7	Missed relay P40	IA= 107.8A IB= 155.0A IC= 164.5A D= 590.4A VAN= 113.3V VBN= 115.4V VCN= 128.4V A/B Insular Displacement	Earth Fault Transient Fault	Supply restored after coordination to BPSO and Tingthi end with vide Switch ON code# 1570, issued by Mahesh Kumar Choudh. BPSO
3	10kVA Transformer	132kV	Tripping	14.09.2021	14:51	14.09.2021	14:57	0	2	0.828	OTC & E/F Miscon-Relay	NA	Tripped cause due to 33kV Pushing feeder when Insular CB fail to operate	Charged after isolating 130V Pushing Feeder
4	10kVA Transformer	132kV	Tripping	22.09.2021	02:34	22.09.2021	02:18	0	0	0.876	BPO operated	Earth Fault	Earth Fault	Tripped due to 130V Pushing feeder fault
5	10kVA Transformer	132kV	Tripping	27.09.2021	12:17	27.09.2021	12:18	0	1	0.856	OTC & E/F Miscon-Relay	NA	Tripped cause due to 33kV Pushing feeder when Insular tripping coil has burnt up.	Charged after isolating 130V Pushing Feeder

Division		SMD BUDHANG		132 KV		Mangra Substation		CBET							
M. No.	Name of Feeder	Voltage Level	OPSW Outage	Shutdown Tripping Date	Time	Normalization Date	Time	Duration of Outage (Hrs)	(Min)	MW Index Outage (MW)	Processor Relays Oper	Tripping Details Fault Details (As recorded by relay)	Type/Cause of Fault	Reason for Shutdown	Remarks
1	132KV Doochang Feeder	132KV	Tripping	9/2/2021	5:58	9/2/2021	6:07	9		-17.9	MAIN DISTANCE PROTIN RELAY-RELEASE	SA & SB OPTD	OP&UV OPTD	-	Informed BPSO, as instructed to closed CB at 06:07 hrs from our end.
2	132KV Phamchohang I	132KV	Tripping	9/2/2021	5:58	9/2/2021	6:11	15		-18.8	MAIN DISTANCE PROTIN RELAY-RELEASE	SA & SB OPTD	OP&UV OPTD	-	Informed BPSO, as instructed to closed CB at 06:11 hrs from our end.
3	132KV Rangja Feeder	132KV	Tripping	9/2/2021	8:08	9/2/2021	8:18	20		18.38	MAIN DISTANCE PROTIN RELAY-RELEASE	SA & SB OPTD	OP&UV OPTD	-	Informed BPSO, as instructed to closed CB with code NLDC BBT-1417,NLDC India-04 and NERLDC-7737 charged at 8:08hrs from our end.
4	132KV Rangja Feeder	132KV	Tripping	9/8/2021	4:08	9/8/2021	9:42	1	20	49.27	MAIN DISTANCE PROTIN RELAY-RELEASE	SA & SB OPTD	OP & UV OPTD	-	Informed BPSO, as instructed to closed CB with code NLDC BBT-1734,NLDC India-202 and NERLDC-7961 line charged at 7:42hrs from our end.
5	132KV Doochang Feeder	132KV	Tripping	9/7/2021	5:28	9/7/2021	5:28	6		-41.71	MAIN DISTANCE PROTIN RELAY-RELEASE	SA & SB OPTD	OP & UV OPTD	-	Informed BPSO,as instructed to closed CB with code no. NLDC BBT-1561 charged at 5:28hrs from our end.
6	132KV DML Feeder	132KV	Tripping	9/7/2021	5:28	9/7/2021	5:38	18		0	SA & SB OPTD	OP & UV OPTD	-	Informed BPSO,as instructed to closed CB with code no. NLDC BBT-1564 charged at 5:38hrs from our end.	
7	132KV Rangja Feeder	132KV	Tripping	9/7/2021	5:38	9/7/2021	5:59	10		26.71	MAIN DISTANCE PROTIN RELAY-RELEASE	SA & SB OPTD	OP & UV OPTD	-	Informed BPSO, as instructed to closed CB with code NLDC BBT-1655,NLDC India-259 and NERLDC-8016 charged at 5:59hrs from our end.
8	132KV Doochang Feeder	132KV	Tripping	9/16/2021	3:58	9/16/2021	4:08	10		-60.22	MAIN DISTANCE PROTIN RELAY-RELEASE	SA & SB OPTD	OP & UV OPTD	-	Informed BPSO, as instructed to closed CB at 4:08hrs from our end.
9	132KV DML Feeder	132KV	Tripping	9/16/2021	3:58	9/16/2021	4:11	13		0	SA & SB OPTD	OP & UV OPTD,R,Y,B phase OPTD	-	Informed BPSO, as instructed to closed CB at 4:11hrs from our end.	
10	15MVA Transformer	132/10KV	Tripping	9/17/2021	8:23	9/17/2021	8:39	8		0.09	DIFFERENTIAL PROTIN RELAY-RELEASE	SA OPTD	OC & EF	-	CB closed at 8:39hrs from our end.
11	15MVA Transformer	132/10KV	Tripping	9/21/2021	16:07	9/21/2021	16:07	16		0.12	DIFFERENTIAL PROTIN RELAY-RELEASE	SA OPTD	EF	-	CB closed at 16:07hrs from our end.
12	15MVA Transformer	132/10KV	Tripping	9/21/2021	5:56	9/22/2021	5:58	2		0.27	DIFFERENTIAL PROTIN RELAY-RELEASE	SA OPTD,REF PROTIN OPTD	OC & EF	-	CB closed at 5:58hrs from our end.
13	15MVA Transformer	132/10KV	Tripping	9/22/2021	14:52	9/22/2021	14:54	2		0.08	DIFFERENTIAL PROTIN RELAY-RELEASE	SA OPTD,REF PROTIN OPTD	EF	-	CB closed at 14:54hrs from our end.
14	15MVA Transformer	132/10KV	Tripping	9/24/2021	1:07	9/26/2021	1:09	2		0.08	DIFFERENTIAL PROTIN RELAY-RELEASE	SA OPTD,REF PROTIN OPTD	OC & EF	-	CB closed at 1:09hrs from our end.
15	132KV Doochang Feeder	132KV	Tripping	9/24/2021	5:57	9/24/2021	6:07	10		-49.23	MAIN DISTANCE PROTIN RELAY-RELEASE	SA & SB OPTD	OP&UV Trip	-	Informed BPSO,as instructed to closed CB with code no. NLDC BBT-1617 at 6:07 hrs. line extend from our end.
16	132KV DML Feeder	132KV	Tripping	9/24/2021	5:57	9/24/2021	6:07	10		0	SA & SB OPTD,R,Y,B Trip	OP&UV Trip	-	Informed BPSO,as instructed to closed CB with code no. NLDC BBT-1618 at 6:07 hrs. line extend from our end.	
17	132KV Doochang Feeder	132KV	Tripping	9/28/2021	2:08	9/28/2021	2:29	11		-41.81	MAIN DISTANCE PROTIN RELAY-RELEASE	SA & SB OPTD	OC & EF	-	Informed BPSO, as instructed to closed CB at 2:29hrs from our end.
18	132KV Rangja Feeder	132KV	Tripping	9/28/2021	2:08	9/28/2021	3:12	38		10.08	MAIN DISTANCE PROTIN RELAY-RELEASE	SA & SB OPTD	OC & EF	-	Informed BPSO, as instructed to closed CB with code no. NLDC BBT-1476,NLDC India-1454,NERLDC-8188 at 3:12hrs line charge from our end.
19	132KV Doochang Feeder	132KV	Tripping	9/28/2021	2:56	9/28/2021	3:08	12		-41.81	MAIN DISTANCE PROTIN RELAY-RELEASE	SA & SB OPTD	OP&UV Trip	-	Informed BPSO, as instructed to closed CB at 3:08hrs from our end.
20	132KV DML Feeder	132KV	Tripping	9/28/2021	2:56	9/28/2021	3:10	14		0	SA & SB OPTD,R,Y,B Trip	OP&UV Trip	-	Informed BPSO, as instructed to closed CB at 3:10hrs from our end.	
21	132KV DML Feeder	132KV	Tripping	9/28/2021	4:08	9/28/2021	10:14	6	0	0	SA & SB OPTD,R,Y,B Trip	OP&UV Trip	-	Informed BPSO, as instructed to closed CB with code no. NLDC BBT-1674 at 11:14hrs line extend from our end.	
22	132KV Doochang Feeder	132KV	Tripping	9/28/2021	5:12	9/28/2021	6:40	1	28	-48.87	MAIN DISTANCE PROTIN RELAY-RELEASE	SA & SB OPTD	OP&UV Trip	-	Informed BPSO, as instructed to closed CB with code no. NLDC BBT-1672 at 08:40hrs CB closed. from our end.
23	132KV Phamchohang I	132KV	Tripping	9/29/2021	18:07	9/29/2021	18:11	6		-18.4	MAIN DISTANCE PROTIN RELAY-RELEASE	SA & SB OPTD	Zone-1 OPTD,R and Y phase Trip	-	Informed BPSO,as instructed to closed CB and CB closed at 18:11hrs from our end.
24	132KV Doochang Feeder	132KV	Tripping	9/29/2021	18:17	9/29/2021	18:25	6		-47.73	MAIN DISTANCE PROTIN RELAY-RELEASE	SA & SB OPTD	OP&UV Trip	-	Informed BPSO,as instructed to closed CB and CB closed at 18:25hrs from our end.
25	132KV Doochang Feeder	132KV	Tripping	9/29/2021	18:23	9/29/2021	18:49	20		-47.73	MAIN DISTANCE PROTIN RELAY-RELEASE	SA & SB OPTD	OP&UV Trip	-	Informed BPSO,as instructed to closed CB and CB closed at 18:49hrs from our end.
26	132KV Phamchohang I	132KV	Tripping	9/29/2021	18:37	9/29/2021	18:47	32		-19.84	MAIN DISTANCE PROTIN RELAY-RELEASE	SA & SB OPTD	OP&UV Trip	-	Informed BPSO,as instructed to closed CB and CB closed at 18:47hrs from our end.
27	132KV Rangja Feeder	132KV	Tripping	9/29/2021	18:37	9/29/2021	18:57	40		51.21	MAIN DISTANCE PROTIN RELAY-RELEASE	SA & SB OPTD	OP&UV Trip	-	Informed BPSO, as instructed to closed CB with code no. NLDC BBT-1461,NLDC India-1776,NERLDC-9083 at 18:57hrs line charge from our end.
28	132KV Doochang Feeder	132KV	Tripping	9/29/2021	17:37	9/29/2021	18:01	6		0	SA & SB OPTD	OP&UV Trip	-	Informed BPSO,as instructed to closed CB and CB closed at 18:01hrs from our end.	
29	132KV Phamchohang I	132KV	Tripping	9/29/2021	17:37	9/29/2021	18:04	7		0	SA & SB OPTD	OP&UV Trip	-	Informed BPSO,as instructed to closed CB and CB closed at 18:04hrs from our end.	
30	132KV Rangja Feeder	132KV	Tripping	9/29/2021	17:37	9/29/2021	18:29	28		0	SA & SB OPTD	OP&UV Trip	-	Informed BPSO, as instructed to closed CB with code no. NLDC BBT-1463,NLDC India-1767,NERLDC-9108 at 18:29hrs line charge from our end.	
31	132KV Doochang Feeder	132KV	Tripping	9/30/2021	10:58	9/30/2021	11:01	3		84.44	MAIN DISTANCE PROTIN RELAY-RELEASE	SA & SB OPTD	OP&UV Trip	-	Informed BPSO,as instructed to closed CB and CB closed at 11:01hrs from our end.
32	132KV Rangja Feeder	132KV	Tripping	9/30/2021	10:58	9/30/2021	11:27	28		42.73	MAIN DISTANCE PROTIN RELAY-RELEASE	SA & SB OPTD	OP&UV Trip	-	Informed BPSO, as instructed to closed CB with code no. NLDC BBT-1467,NLDC India-1819,NERLDC-9111 at 11:27hrs line charge from our end.

Division		AND BUTHANG													
Substation		110 KV Corling Substation													
Month		08/21													
M. No.	Name of Feeder	Voltage Level	TOPSW Outage	Shutdown/Tripping		Normalization Time		Duration of Outage		MW Index Outage (MFW)	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time	(Hrs)	(Min)		Protection Relay Oper	Fault Details (As recorded by relay)			
1	110 KV Khidiha Line	110 KV	No supply from Khidiha substation	05/09/2021	12:27 hrs	05/09/2021	12:34 hrs	0	7	2.040	Nil	Nil	There was no 110 KV supply from Khidiha substation		
2	110 KV Khidiha Line	110 KV	No supply from Khidiha substation	28/09/2021	17:29 hrs	29/09/2021	17:37 hrs	0	8	2.430	Nil	Nil	There was no 110 KV supply from Khidiha substation	110 KV Khidiha-Corling Line was tripped at Khidiha substation.	
3	110 KV Kanglung Line	110 KV	No supply from Khidiha substation	28/09/2021	17:29 hrs	29/09/2021	18:06 hrs	0	37	1.320	Relay SA and SB	VT line fail	There was no 110 KV supply from Khidiha substation	110 KV Kanglung Line Tripped at 17:37 hrs when Khidiha-Corling Line was changed from Khidiha end.	
Division		AND BUTHANG													
Substation		110 KV Phuntsokhang Substation													
Month		08/21													
M. No.	Name of Feeder	Voltage Level	TOPSW Outage	Shutdown/Tripping		Normalization Time		Duration of Outage		MW Index Outage (MFW)	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time	(Hrs)	(Min)		Protection Relay Oper	Fault Details (As recorded by relay)			
1	Phuntsokhang-Mitanga	110KV	Insulator Fail	9/2/2021	5:58	9/2/2021	9:15		17	18.62	REL650 Zone1	(DEF1)DEF1 Trip value: L1: 489.77A, L2: 414.7A, L3: 513.05A, L4: 597.68A.	Earth fault	Not available	110KV insulator failure trip at both end. Just changed from Kanglung end and did not withdrawn. Changed from Mitanga end and Normalized.
2	Kanglung	110KV	insulator Fail	9/10/2021	17:31	9/10/2021	17:33		32	20.15	ZONE 1 OPTD AND R,Y,B TRIP	ZONE1 OPTD AND R, Y,B Phase trip and fault distance 21.212KM Fault value:01:1477.81A,02:1898.30A,03:1911.80A,03:04.57A	R,Y and B phase trip	Not available	Test changed and line with stand.
3	Kanglung	110KV	trip on fault	9/10/2021	17:40	9/11/2021	12:40		19	20.15	ZONE 1 OPTD AND R,Y,B TRIP	ZONE1 OPTD AND R, Y,B Phase trip and fault distance 37.59KM Fault value:01:1241.55A,02:1337.37A,03:1219.54A,03:1.49	R,Y and B phase trip	Not available	Tripped upon after 7 minutes of test changing and RPSO has instructed for line parting line changed after TND cleared the fault with the switch ON code 1162 issued by area 3 clearing (Chokye/RPSO).
4	Kanglung (R,Y,A)	110KV	trip on fault	9/29/2021	18:08					18.76	ZONE 1 OPTD, RAB phase trip,FF BRG and OV/VT Trip	Trip value: L1: 1962.88A, L2: 1621.88A, L3: 20.81A, L4: 347.48A.	Over current	Not available	Test change line could not withdrawn line at Kanglung end due ZONE1 OPTD, RAB Phase trip,FF BRG and relay indicating OV/VT. Fault Distance: 19.87 km. Line under shutdown for fault finding by TLM. Durbang
5	Mitanga (R,Y,A)	110KV	trip	9/30/2021	07:59	9/30/2021	13:00		2	0.74	Nil	Nil	Nil	Not available	Trip at Kanglung and Durbang, both end CB are normal

I. 400/220/132/33kV Jigmeeling Substation													
Sr. No.	Date of Tripping	Time of Outages/ Time of Tripping	Date of Normalization	Time of Fault was Cleared	Duration of Outages (hrs)	MW before Outage (MW)	Name of feeder	Name of the Substation/lines Affected by the Fault	Reasons of Fault	Relay Operations	Fault Location(KM)	Type of outages	Remarks
0 66kV Above													
1	2-Sep-21	04:00 hrs	2-Sep-21	04:18 hrs	0	-185.42	400KV MU	400KV	Tripping	SIPROTECT 7SA52 & SIPROTECT 7SA511	R,Y,B Pickup, Ground Pickup, Zone 1 opfd.	Line-Ground fault	
2	7-Sep-21	07:00 hrs	7-Sep-21	07:04 hrs	0	-58.06	500MVA ICT	400/220KV	Tripping	7SM001-5EB00-1FC0-DD, SIPROTECT 7UT81	No relay indication		
3	7-Sep-21	07:06 hrs	7-Sep-21	12:22 hrs	5	-58.06	500MVA ICT	400/220KV	Tripping	7SM001-5EB00-1FC0-DD, SIPROTECT 7UT81	50% 1/2 tripped		
4	16-Sep-21	16:13 hrs	16-Sep-21	16:23 hrs	0	-185.42	400KV MU	400KV	Tripping	SIPROTECT 7SA52 & SIPROTECT 7SA511	Main 1 opfd, fault loop L2-3-G, Fault Dist. 41.3km, Main 2 opfd, L2-3-G, Fault Dist 41.2km	L2-3-Ground fault, (Main-1 Fault current Ia=0.07kA, Ib=0.58kA, Ic=6.34kA.) (Main-2 Fault current Ia=0.07kA, Ib=6.53kA, Ic=6.38kA.)	Line changed as per BPSO instruction
5	8-Sep-21	11:25hrs	8-Sep-21	11:38hrs	0	96.94	220KV Tawang feeder	220KV	Tripping	50/51M	Yph to Ground, Z1:1B Trip, Fault	Line-Ground fault	Western Grid fail
6	13-Sep-21	14:19hrs	13-Sep-21	14:23hrs	0	-45.25	220KV Tawang feeder	220KV	Tripping	Distance Relay: SIPROTECT 7SA52 & REL670	M	Line-Ground fault	Western Grid fail
7	13-Sep-21	14:20hrs	13-Sep-21	14:26hrs	0	1.1	220KV Duppela feeder	220KV	Tripping	Distance Relay: SIPROTECT 7SA52 & REL670	Main 1 opfd, Fault Loop(B to Ground) Fault dist(2km), Zone 1 opfd, Main 2 opfd, Fault Loop(B to Ground) Fault dist(3.55km), Zone 1 opfd.	Line-Ground fault	
8	17-Sep-21	16:14hrs	17-Sep-21	16:24hrs	0	-66.71	220KV Tawang feeder	220KV	Tripping	Distance Relay: SIPROTECT 7SA52 & REL671	Main 1: Yph trip, Z1:1B trip, Fault dist. 17.5km, Main 2: Yph trip, Z1 trip, Fault dist. 20.25km	Line-Ground fault	charged as per BPSO instruction
9	17-Sep-21	16:14hrs	17-Sep-21	16:43hrs	0	1.01	220KV Duppela feeder	220KV	Tripping	Distance Relay: SIPROTECT 7SA52 & REL670	Main 1: RYYph trip, Z1:1B trip, Fault dist. 28.9km, Main 2: Yph trip, Z1 trip, Fault dist. 18.2km	Line-Ground fault	charged and changed as per BP
10	28-Sep-21	13:37hrs	28-Sep-21	13:53hrs	0	-28.67	220KV Tawang feeder	220KV	Tripping	Distance Relay: SIPROTECT 7SA52 & REL671	Main 1 opfd, Fault Loop(L1-L3 to ground), Fault dist(1.1km), Fault Current Ia=0.45kA, Ib=1.25kA, Ic=1.82kA	Line-Ground fault	Closed tripped on same fault
11	28-Sep-21	13:37hrs	28-Sep-21	14:20hrs	0	1.87	220KV Duppela feeder	220KV	Tripping	Distance Relay: SIPROTECT 7SA52 & REL670	Main 1 opfd, Fault Loop(L2-L3 and ground), Fault dist(21.4km) Fault current Ia=0.02kA Ib=1.09kA Ic=1.22kA	Line-Ground fault	
12	28-Sep-21	13:51hrs	28-Sep-21	14:04hrs	0	-28.67	220KV Tawang feeder	220KV	Tripping	Distance Relay: SIPROTECT 7SA52 & REL671	Main 1 opfd, Fault Loop(L1-L3 to ground), Fault dist(21.1km), Fault Current Ia=0.45kA, Ib=1.25kA, Ic=1.82kA	Line-Ground fault	Closed tripped on same fault
13	28-Sep-21	14:04hrs	28-Sep-21	14:24hrs	0	-28.67	220KV Tawang feeder	220KV	Tripping	Distance Relay: SIPROTECT 7SA52 & REL671	Main 1 opfd, Fault Loop(L1-L3 to ground), Fault dist(21.1km), Fault Current Ia=0.45kA, Ib=1.25kA, Ic=1.82kA	Line-Ground fault	

3. 120/66/33kV Dhajay Substation													
@ 66kV and above													
1	13.09.2021	14:19:15hrs	13.09.2021	14:28:54hrs	0	78.54	Signaling feeder	Dhajay SS	Main 1 Ia=0.0186.1 &2. Distance re Main I=31.3KM, Main II=28.1	Tripped		Line restored as per BPSO	
2	17.09.2021	16:13hrs	17.09.2021	16:20hrs	0	86.5	Signaling feeder	Dhajay SS	Main 1 Ia=0.2086.1 &2. Distance re Main I=20.3KM, Main II=20.9	Tripped		Line restored as per BPSO	
3	29.09.2021	13:36hrs	29.09.2021	13:53hrs	0	29.54	Signaling feeder	Dhajay SS	Main 1 Ia=0.5386.1 &2. Distance re Main I=13.7KM, Main II=10.4	Tripped		Line restored as per BPSO	
4	29.09.2021	14:03hrs	29.09.2021	14:12hrs	0	0	Signaling feeder	Dhajay SS	Main 2. Ia86.1 &2. Distance relay Main II	Tripped		since the line couldn't restore	
5	29.09.2021	14:03hrs	29.09.2021	14:07hrs	0	1.62	ICT-II	Dhajay SS	ONLY 87 relay pick 86.1 &2. 87 relay	Tripped		Since Rarichu feeder was h	
6	29.09.2021	14:03hrs	29.09.2021	14:08hrs	0	0	ICT-I	Dhajay SS	DfT A=1.830, Ia0, Re 86.1 &2. 87 relay	Tripped		Since Rarichu feeder was h	
7	29.09.2021	14:03hrs	29.09.2021	14:21hrs	0	2.9	Dispatch	Dhajay SS	Main 2. Ia86.1 &2. Distance relay Main II	Tripped		Since Rarichu feeder was h	
3. 132/66/33/11kV Guelpha Substation													
@ 66kV and above													
1	14.09.2021	16:28hrs	14.09.2021	17:02hrs		21.8	132kv Gel-Sal Str	132kv Gel-Sal Str	General trip, YB-ph, Zone LID at 8.03km, Fault current, R=98.97A, Y= 2736.19A, B= 2618.54A, N= 19.05A			Charging code= NLDC BTN=1600, NLDC IND=767, NERLDC=8357	
4. 132/33/11kV Tingthi Substation													
@ 66 kV and Above													
1	9/1/2021	14:58	9/1/2021	15:38	0	18.7200	132kV Tingthi-Nangla	132kV Tingthi-Nangla	Temporary Fault	Distance Protection Relay: Trip phase ABC, Start phase AN, Fault Location: 39.82KM, Fault Zone-1.	132kV Tingthi-Nangla	Temporary	
2	9/9/2021	10:33	9/9/2021	10:42	0	31.6000	132kV Tingthi-Nangla	132kV Tingthi-Nangla	Temporary Fault	Distance Protection Relay: Trip phase ABC, Start phase AN, Fault Location: XY 17.4KM, Fault Zone-1.	132kV Tingthi-Nangla	Temporary	
3.00	44466.00	0.62	44466.00	0.62	0.00	14.49	132kV Tingthi- Agueling	132kV Tingthi- Agueling	Temporary Fault	Distance Protection Relay: Trip phase ABC, Fault Location: 19.12KM, Fault Zone- 1.	132kV Tingthi-Agueling	Temporary	

Division: SMO BHUTANI		Substation: 110/33KV Mangsa Substation		Month: 08/21											
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown)	Shutdown/Tripping		Normalization Time		Duration of Outage		MW before Outage (MW)	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time	(Hrs)	(Min)		Protection Relay Oper	Fault Details (As recorded by relay)			
1	110KV Range Feeder	110KV	Tripping	11/5/2021	20:25	11/5/2021	20:49		24	38.8	OC & EF	3L1=0.794E-2=0.185E-3=0.000	Tripped on fault	-	Informed BPSO, as instructed to closed CB with code no NSDC Bh-1792/NSDC India-120/NSDC/277 CB closed at 20:49hrs from our end.
3	110KV Transformer	110/33KV	Tripping	08/08/2021	8:00	08/08/2021	8:21		21	1.87	OC & EF, IAA & SSB OPTIM-PTD	Nil	Tripped on fault	-	CB closed at 18:21hrs from our end.
4	DME Factory Feeder	110KV	Tripping	08/08/2021	22:59	08/08/2021	23:03		4	0	OVUN,AVB TRIP, IAA & SSB OPTD	Nil	Tripped on fault	-	Informed BPSO, as instructed to closed CB with code no NSDC BH-1860 closed at 23:04hrs from our end.

Sl. No.	Date of Tripping	Time of Outage/Time of Tripping	Date of Normalization	Time of Fault was Cleared	Duration of Outage (Hrs)	Duration of Outage (Min)	MW before Outage (MW)	MT Lost During Outage	Name of Feeder	Name of the Substation Area Affected by the Fault	Reason of Fault	Relay Operations	Fault Location (KM)	Type of Outage	No. of Customers Affected	Customer Hours Affected	Remarks
3. 120/33KV Dagaqa Substation																	
0.66KV & Above																	
	2/28/11/2021	20:17hrs	28/11/2021	20:48hrs		11	13.88	2.514000007	Opening Feeder	Dagaqa Substation	over current	11.2 distance relay main-2, 1a=1161.11A	Tripped	Transient	Whole Dagaqa	0.18110	Entire area what are given supply from this feeder. Feeder restored after as per BPSO instruction.
	2/28/11/2021	20:17hrs	28/11/2021	20:48hrs		12	07.12	9.420	Dagaqa Feeder	Dagaqa Substation	over current	11.2 distance relay main-2, 1a=1161.11A	Tripped	Transient	Whole Dagaqa	0.2	Entire area what are given supply from this feeder. Feeder restored after as per BPSO instruction.
6. 120/33KV Dagaqa Substation																	
0.66KV & Above																	
1	04/11/2021	0.5:08:00	04/11/2021	0.5:03:00	0	19	2.8	2.8	120/33KV Transformer	Dagaqa	SEA	SEA	-	Transient	Whole Dagaqa	0.25118	Tripped while working inverter at 110V side.
2	04/11/2021	0.5:08:00	04/11/2021	0.5:03:00	0	19	2.8	2.8	120/33KV Transformer	Dagaqa	SEA	SEA	-	Transient	Whole Dagaqa	0.25118	Tripped while working inverter at 110V side.
3	05/11/2021	0.11:54:00	05/11/2021	0.14:09:00	5	19	5.58	5.74	120/33KV Transformer	Dagaqa	SEA	SEA	Relay set transient	Whole Dagaqa	0.25264	Tripped number of times in between due to higher load and low relay setting. Charged successfully after CNPD changed the setting.	
4	05/11/2021	0.11:54:00	05/11/2021	0.14:09:00	5	19	5.58	5.74	120/33KV Transformer	Dagaqa	SEA	SEA	Relay set transient	Whole Dagaqa	0.25264	Tripped number of times in between due to higher load and low relay setting. Charged successfully after CNPD changed the setting.	

December 2021

MONTHLY OUTAGE REPORT FOR THE MONTH OF DECEMBER 2021 SMO BHUTANI, SMO																	
Division: SMO BHUTANI		Substation: 110/33KV Mangsa Substation		Month: Dec 21													
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown)	Shutdown/Tripping		Normalization Time		Duration of Outage		MW before Outage (MW)	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks		
				Date	Time	Date	Time	(Hrs)	(Min)		Protection Relay Oper	Fault Details (As recorded by relay)					
1	110KV Feeder	110KV	Tripping	12/2/2021	09:05hrs	12/2/2021	09:17hrs		1	10.52	SEA	3L1=0.44A, 3L2=0.44A, 3L3=0.44A, 4=0.17A, 5=0.17A, 6=0.17A, 7=0.17A, 8=0.17A, 9=0.17A, 10=0.17A, 11=0.17A, 12=0.17A, 13=0.17A, 14=0.17A, 15=0.17A, 16=0.17A, 17=0.17A, 18=0.17A, 19=0.17A, 20=0.17A, 21=0.17A, 22=0.17A, 23=0.17A, 24=0.17A, 25=0.17A, 26=0.17A, 27=0.17A, 28=0.17A, 29=0.17A, 30=0.17A, 31=0.17A, 32=0.17A, 33=0.17A, 34=0.17A, 35=0.17A, 36=0.17A, 37=0.17A, 38=0.17A, 39=0.17A, 40=0.17A, 41=0.17A, 42=0.17A, 43=0.17A, 44=0.17A, 45=0.17A, 46=0.17A, 47=0.17A, 48=0.17A, 49=0.17A, 50=0.17A, 51=0.17A, 52=0.17A, 53=0.17A, 54=0.17A, 55=0.17A, 56=0.17A, 57=0.17A, 58=0.17A, 59=0.17A, 60=0.17A, 61=0.17A, 62=0.17A, 63=0.17A, 64=0.17A, 65=0.17A, 66=0.17A, 67=0.17A, 68=0.17A, 69=0.17A, 70=0.17A, 71=0.17A, 72=0.17A, 73=0.17A, 74=0.17A, 75=0.17A, 76=0.17A, 77=0.17A, 78=0.17A, 79=0.17A, 80=0.17A, 81=0.17A, 82=0.17A, 83=0.17A, 84=0.17A, 85=0.17A, 86=0.17A, 87=0.17A, 88=0.17A, 89=0.17A, 90=0.17A, 91=0.17A, 92=0.17A, 93=0.17A, 94=0.17A, 95=0.17A, 96=0.17A, 97=0.17A, 98=0.17A, 99=0.17A, 100=0.17A, 101=0.17A, 102=0.17A, 103=0.17A, 104=0.17A, 105=0.17A, 106=0.17A, 107=0.17A, 108=0.17A, 109=0.17A, 110=0.17A, 111=0.17A, 112=0.17A, 113=0.17A, 114=0.17A, 115=0.17A, 116=0.17A, 117=0.17A, 118=0.17A, 119=0.17A, 120=0.17A, 121=0.17A, 122=0.17A, 123=0.17A, 124=0.17A, 125=0.17A, 126=0.17A, 127=0.17A, 128=0.17A, 129=0.17A, 130=0.17A, 131=0.17A, 132=0.17A, 133=0.17A, 134=0.17A, 135=0.17A, 136=0.17A, 137=0.17A, 138=0.17A, 139=0.17A, 140=0.17A, 141=0.17A, 142=0.17A, 143=0.17A, 144=0.17A, 145=0.17A, 146=0.17A, 147=0.17A, 148=0.17A, 149=0.17A, 150=0.17A, 151=0.17A, 152=0.17A, 153=0.17A, 154=0.17A, 155=0.17A, 156=0.17A, 157=0.17A, 158=0.17A, 159=0.17A, 160=0.17A, 161=0.17A, 162=0.17A, 163=0.17A, 164=0.17A, 165=0.17A, 166=0.17A, 167=0.17A, 168=0.17A, 169=0.17A, 170=0.17A, 171=0.17A, 172=0.17A, 173=0.17A, 174=0.17A, 175=0.17A, 176=0.17A, 177=0.17A, 178=0.17A, 179=0.17A, 180=0.17A, 181=0.17A, 182=0.17A, 183=0.17A, 184=0.17A, 185=0.17A, 186=0.17A, 187=0.17A, 188=0.17A, 189=0.17A, 190=0.17A, 191=0.17A, 192=0.17A, 193=0.17A, 194=0.17A, 195=0.17A, 196=0.17A, 197=0.17A, 198=0.17A, 199=0.17A, 200=0.17A, 201=0.17A, 202=0.17A, 203=0.17A, 204=0.17A, 205=0.17A, 206=0.17A, 207=0.17A, 208=0.17A, 209=0.17A, 210=0.17A, 211=0.17A, 212=0.17A, 213=0.17A, 214=0.17A, 215=0.17A, 216=0.17A, 217=0.17A, 218=0.17A, 219=0.17A, 220=0.17A, 221=0.17A, 222=0.17A, 223=0.17A, 224=0.17A, 225=0.17A, 226=0.17A, 227=0.17A, 228=0.17A, 229=0.17A, 230=0.17A, 231=0.17A, 232=0.17A, 233=0.17A, 234=0.17A, 235=0.17A, 236=0.17A, 237=0.17A, 238=0.17A, 239=0.17A, 240=0.17A, 241=0.17A, 242=0.17A, 243=0.17A, 244=0.17A, 245=0.17A, 246=0.17A, 247=0.17A, 248=0.17A, 249=0.17A, 250=0.17A, 251=0.17A, 252=0.17A, 253=0.17A, 254=0.17A, 255=0.17A, 256=0.17A, 257=0.17A, 258=0.17A, 259=0.17A, 260=0.17A, 261=0.17A, 262=0.17A, 263=0.17A, 264=0.17A, 265=0.17A, 266=0.17A, 267=0.17A, 268=0.17A, 269=0.17A, 270=0.17A, 271=0.17A, 272=0.17A, 273=0.17A, 274=0.17A, 275=0.17A, 276=0.17A, 277=0.17A, 278=0.17A, 279=0.17A, 280=0.17A, 281=0.17A, 282=0.17A, 283=0.17A, 284=0.17A, 285=0.17A, 286=0.17A, 287=0.17A, 288=0.17A, 289=0.17A, 290=0.17A, 291=0.17A, 292=0.17A, 293=0.17A, 294=0.17A, 295=0.17A, 296=0.17A, 297=0.17A, 298=0.17A, 299=0.17A, 300=0.17A, 301=0.17A, 302=0.17A, 303=0.17A, 304=0.17A, 305=0.17A, 306=0.17A, 307=0.17A, 308=0.17A, 309=0.17A, 310=0.17A, 311=0.17A, 312=0.17A, 313=0.17A, 314=0.17A, 315=0.17A, 316=0.17A, 317=0.17A, 318=0.17A, 319=0.17A, 320=0.17A, 321=0.17A, 322=0.17A, 323=0.17A, 324=0.17A, 325=0.17A, 326=0.17A, 327=0.17A, 328=0.17A, 329=0.17A, 330=0.17A, 331=0.17A, 332=0.17A, 333=0.17A, 334=0.17A, 335=0.17A, 336=0.17A, 337=0.17A, 338=0.17A, 339=0.17A, 340=0.17A, 341=0.17A, 342=0.17A, 343=0.17A, 344=0.17A, 345=0.17A, 346=0.17A, 347=0.17A, 348=0.17A, 349=0.17A, 350=0.17A, 351=0.17A, 352=0.17A, 353=0.17A, 354=0.17A, 355=0.17A, 356=0.17A, 357=0.17A, 358=0.17A, 359=0.17A, 360=0.17A, 361=0.17A, 362=0.17A, 363=0.17A, 364=0.17A, 365=0.17A, 366=0.17A, 367=0.17A, 368=0.17A, 369=0.17A, 370=0.17A, 371=0.17A, 372=0.17A, 373=0.17A, 374=0.17A, 375=0.17A, 376=0.17A, 377=0.17A, 378=0.17A, 379=0.17A, 380=0.17A, 381=0.17A, 382=0.17A, 383=0.17A, 384=0.17A, 385=0.17A, 386=0.17A, 387=0.17A, 388=0.17A, 389=0.17A, 390=0.17A, 391=0.17A, 392=0.17A, 393=0.17A, 394=0.17A, 395=0.17A, 396=0.17A, 397=0.17A, 398=0.17A, 399=0.17A, 400=0.17A, 401=0.17A, 402=0.17A, 403=0.17A, 404=0.17A, 405=0.17A, 406=0.17A, 407=0.17A, 408=0.17A, 409=0.17A, 410=0.17A, 411=0.17A, 412=0.17A, 413=0.17A, 414=0.17A, 415=0.17A, 416=0.17A, 417=0.17A, 418=0.17A, 419=0.17A, 420=0.17A, 421=0.17A, 422=0.17A, 423=0.17A, 424=0.17A, 425=0.17A, 426=0.17A, 427=0.17A, 428=0.17A, 429=0.17A, 430=0.17A, 431=0.17A, 432=0.17A, 433=0.17A, 434=0.17A, 435=0.17A, 436=0.17A, 437=0.17A, 438=0.17A, 439=0.17A, 440=0.17A, 441=0.17A, 442=0.17A, 443=0.17A, 444=0.17A, 445=0.17A, 446=0.17A, 447=0.17A, 448=0.17A, 449=0.17A, 450=0.17A, 451=0.17A, 452=0.17A, 453=0.17A, 454=0.17A, 455=0.17A, 456=0.17A, 457=0.17A, 458=0.17A, 459=0.17A, 460=0.17A, 461=0.17A, 462=0.17A, 463=0.17A, 464=0.17A, 465=0.17A, 466=0.17A, 467=0.17A, 468=0.17A, 469=0.17A, 470=0.17A, 471=0.17A, 472=0.17A, 473=0.17A, 474=0.17A, 475=0.17A, 476=0.17A, 477=0.17A, 478=0.17A, 479=0.17A, 480=0.17A, 481=0.17A, 482=0.17A, 483=0.17A, 484=0.17A, 485=0.17A, 486=0.17A, 487=0.17A, 488=0.17A, 489=0.17A, 490=0.17A, 491=0.17A, 492=0.17A, 493=0.17A, 494=0.17A, 495=0.17A, 496=0.17A, 497=0.17A, 498=0.17A, 499=0.17A, 500=0.17A, 501=0.17A, 502=0.17A, 503=0.17A, 504=0.17A, 505=0.17A, 506=0.17A, 507=0.17A, 508=0.17A, 509=0.17A, 510=0.17A, 511=0.17A, 512=0.17A, 513=0.17A, 514=0.17A, 515=0.17A, 516=0.17A, 517=0.17A, 518=0.17A, 519=0.17A, 520=0.17A, 521=0.17A, 522=0.17A, 523=0.17A, 524=0.17A, 525=0.17A, 526=0.17A, 527=0.17A, 528=0.17A, 529=0.17A, 530=0.17A, 531=0.17A, 532=0.17A, 533=0.17A, 534=0.17A, 535=0.17A, 536=0.17A, 537=0.17A, 538=0.17A, 539=0.17A, 540=0.17A, 541=0.17A, 542=0.17A, 543=0.17A, 544=0.17A, 545=0.17A, 546=0.17A, 547=0.17A, 548=0.17A, 549=0.17A, 550=0.17A, 551=0.17A, 552=0.17A, 553=0.17A, 554=0.17A, 555=0.17A, 556=0.17A, 557=0.17A, 558=0.17A, 559=0.17A, 560=0.17A, 561=0.17A, 562=0.17A, 563=0.17A, 564=0.17A, 565=0.17A, 566=0.17A, 567=0.17A, 568=0.17A, 569=0.17A, 570=0.17A, 571=0.17A, 572=0.17A, 573=0.17A, 574=0.17A, 575=0.17A, 576=0.17A, 577=0.17A, 578=0.17A, 579=0.17A, 580=0.17A, 581=0.17A, 582=0.17A, 583=0.17A, 584=0.17A, 585=0.17A, 586=0.17A, 587=0.17A, 588=0.17A, 589=0.17A, 590=0.17A, 591=0.17A, 592=0.17A, 593=0.17A, 594=0.17A, 595=0.17A, 596=0.17A, 597=0.17A, 598=0.17A, 599=0.17A, 600=0.17A, 601=0.17A, 602=0.17A, 603=0.17A, 604=0.17A, 605=0.17A, 606=0.17A, 607=0.17A, 608=0.17A, 609=0.17A, 610=0.17A, 611=0.17A, 612=0.17A, 613=0.17A, 614=0.17A, 615=0.17A, 616=0.17A, 617=0.17A, 618=0.17A, 619=0.17A, 620=0.17A, 621=0.17A, 622=0.17A, 623=0.17A, 624=0.17A, 625=0.17A, 626=0.17A, 627=0.17A, 628=0.17A, 629=0.17A, 630=0.17A, 631=0.17A, 632=0.17A, 633=0.17A, 634=0.17A, 635=0.17A, 636=0.17A, 637=0.17A, 638=0.17A, 639=0.17A, 640=0.17A, 641=0.17A, 642=0.17A, 643=0.17A, 644=0.17A, 645=0.17A, 646=0.17A, 647=0.17A, 648=0.17A, 649=0.17A, 650=0.17A, 651=0.17A, 652=0.17A, 653=0.17A, 654=0.17A, 655=0.17A, 656=0.17A, 657=0.17A, 658=0.17A, 659=0.17A, 660=0.17A, 661=0.17A, 662=0.17A, 663=0.17A, 664=0.17A, 665=0.17A, 666=0.17A, 667=0.17A, 668=0.17A, 669=0.17A, 670=0.17A, 671=0.17A, 672=0.17A, 673=0.17A, 674=0.17A, 675=0.17A, 676=0.17A, 677=0.17A, 678=0.17A, 679=0.17A, 680=0.17A, 681=0.17A, 682=0.17A, 683=0.17A, 684=0.17A, 685=0.17A, 686=0.17A, 687=0.17A, 688=0.17A, 689=0.17A, 690=0.17A, 691=0.17A, 692=0.17A, 693=0.17A, 694=0.17A, 695=0.17A, 696=0.17A, 697=0.17A, 698=0.17A, 699=0.17A, 700=0.17A, 701=0.17A, 702=0.17A, 703=0.17A, 704=0.17A, 705=0.17A, 706=0.17A, 707=0.17A, 708=0.17A, 709=0.17A, 710=0.17A, 711=0.17A, 712=0.17A, 713=0.17A, 714=0.17A, 715=0.17A, 716=0.17A, 717=0.17A, 718=0.17A, 719=0.17A, 720=0.17A, 721=0.17A, 722=0.17A, 723=0.17A, 724=0.17A, 725=0.17A, 726=0.17A, 727=0.17A, 728=0.17A, 729=0.17A, 730=0.17A, 731=0.17A, 732=0.17A, 733=0.17A, 734=0.17A, 735=0.17A, 736=0.17A, 737=0.17A, 738=0.17A, 739=0.17A, 740=0.17A, 741=0.17A, 742=0.17A, 743=0.17A, 744=0.17A, 745=0.17A, 746=0.17A, 747=0.17A, 748=0.17A, 749=0.17A, 750=0.17A, 751=0.17A, 752=0.17A, 753=0.17A, 754=0.17A, 755=0.17A, 756=0.17A, 757=0.17A, 758=0.17A, 759=0.17A, 760=0.17A, 761=0.17A, 762=0.17A, 763=0.17A, 764=0.17A, 765=0.17A, 766=0.17A, 767=0.17A, 768=0.17A, 769=0.17A, 770=0.17A, 771=0.17A, 772=0.17A, 773=0.17A, 774=0.17A, 775=0.17A, 776=0.17A, 777=0.17A, 778=0.17A, 779=0.17A, 780=0.17A, 781=0.17A, 782=0.17A, 783=0.17A, 784=0.17A, 785=0.17A, 786=0.17A, 787=0.17A, 788=0.17A, 789=0.17A, 790=0.17A, 791=0.17A, 792=0.17A, 793=0.17A, 794=0.17A, 795=0.17A, 796=0.17A, 797=0.17A, 798=0.17A, 799=0.17A, 800=0.17A, 801=0.17A, 802=0.17A, 803=0.17A, 804=0.17A, 805=0.17A, 806=0.17A, 807=0.17A, 808=0.17A, 809=0.17A, 810=0.17A, 811=0.17A, 812=0.17A, 813=0.17A, 814=0.17A, 815=0.17A, 816=0.17A, 817=0.17A, 818=0.17A, 819=0.17A, 820=0.17A, 821=0.17A, 822=0.17A, 823=0.17A, 824=0.17A, 825=0.17A, 826=0.17A, 827=0.17A, 828=0.17A, 829=0.17A, 830=0.17A, 831=0.17A, 832=0.17A, 833=0.17A, 834=0.17A, 835=0.17A, 836=0.17A, 837=0.17A, 838=0.17A, 839=0.17A, 840=0.17A, 841=0.17A, 842=0.1					

Section 1.2016-2017 (2017-2018) - Ngazun Substation (See 1.2)														
Sl. No.	Name of Feeder	Voltage Level	MVA Rating	Operating Voltage (kV)	Transmission Line		Direction of Charge		MVA before Charge (MVA)	Feeding Details		Feeder loss at fault	Status	Remarks
					From	To	From	To		Feeder Details	Feeder Details (As recorded by relay)			
1.2016-2017 (2017-2018) - Ngazun Substation														
1	1021001	110kV	100MVA	110kV	1021001	1021002	0	0	0.02	Has directional protection relay	1021001-1021002 tripping relay M operated	Tripped due to feeder fault	-	Tripped due to fault on 1021002 Feeder
4	1021004	110kV	100MVA	110kV	1021004	1021005	0	0	0.03	Has directional protection relay	1021004-1021005 tripping relay M operated	Tripped due to feeder fault	-	Tripped due to fault on 1021005 Feeder
7	1021007	110kV	100MVA	110kV	1021007	1021008	0	0	0.03	Has directional protection relay	1021007-1021008 tripping relay M operated	Tripped due to feeder fault	-	Tripped while not charging 1021008 Feeder
8	1021008	110kV	100MVA	110kV	1021008	1021009	0	0	0.02	Has directional protection relay	1021008-1021009 tripping relay M operated	Tripped due to feeder fault	-	Tripped while not charging 1021009 Feeder
7	1021007	110kV	100MVA	110kV	1021007	1021010	0	0	0.03	Has directional protection relay	1021007-1021010 tripping relay M operated	Tripped due to feeder fault	-	Tripped while not charging 1021010 Feeder
4	1021004	110kV	100MVA	110kV	1021004	1021011	0	0	0.02	Has directional protection relay	1021004-1021011 tripping relay M operated	Tripped due to feeder fault	-	Tripped while not charging 1021011 Feeder
6	1021006	110kV	100MVA	110kV	1021006	1021012	0	0	0.03	Has directional protection relay	1021006-1021012 tripping relay M operated	Tripped due to feeder fault	-	Tripped due to fault on 1021012 Feeder
10	1021010	110kV	100MVA	110kV	1021010	1021013	0	0	0.03	Has directional protection relay	1021010-1021013 tripping relay M operated	Tripped due to feeder fault	-	Tripped due to fault on 1021013 Feeder
1.2016-2017 (2017-2018) - Ngazun Substation														
Sl. No.	Date of Feeder	Date of Charge	Date of Discharge	Direction of Charge	MVA before Charge (MVA)	Name of Feeder	Name of the Substation from which the Feeder is fed	Reason of Fault	Relay Operation	Feeder Loss at Fault	Type of outage	Remarks		
0 Fault - others														
1	10/11/2017	11/07/2017	10/11/2017	0	0.03	1021001	Ngazun sub station	Feeder fault	1021001-1021002 tripping relay M operated	Feeder Loss: 0.03 MVA	Feeder Outage			
1.2016-2017 (2017-2018) - Ngazun Substation														
0 Fault - others														
1	10/11/2017	11/07/2017	10/11/2017	0	0.03	1021001	Ngazun sub station	Feeder fault	1021001-1021002 tripping relay M operated	Feeder Loss: 0.03 MVA	Feeder Outage			
2	10/11/2017	11/07/2017	10/11/2017	0	0.03	1021001	Ngazun sub station	Feeder fault	1021001-1021002 tripping relay M operated	Feeder Loss: 0.03 MVA	Feeder Outage			
3	10/11/2017	11/07/2017	10/11/2017	0	0.03	1021001	Ngazun sub station	Feeder fault	1021001-1021002 tripping relay M operated	Feeder Loss: 0.03 MVA	Feeder Outage			
1.2016-2017 (2017-2018) - Ngazun Substation														
0 Fault - others														
1	10/11/2017	11/07/2017	10/11/2017	0	0.03	1021001	Ngazun sub station	Feeder fault	1021001-1021002 tripping relay M operated	Feeder Loss: 0.03 MVA	Feeder Outage			
1.2016-2017 (2017-2018) - Ngazun Substation														
0 Fault - others														
1	10/11/2017	11/07/2017	10/11/2017	0	0.03	1021001	Ngazun sub station	Feeder fault	1021001-1021002 tripping relay M operated	Feeder Loss: 0.03 MVA	Feeder Outage			
1.2016-2017 (2017-2018) - Ngazun Substation														
0 Fault - others														
1	10/11/2017	11/07/2017	10/11/2017	0	0.03	1021001	Ngazun sub station	Feeder fault	1021001-1021002 tripping relay M operated	Feeder Loss: 0.03 MVA	Feeder Outage			

Western Grid Outages
January 2021

Tripping for the month of January 2021, SMD Phasorholing												
Sl No.	Date of Tripping	Time of outages	Date of Normalization	Time of fault was cleared	Duration of Outages (Hrs)	MW before outage (MW)	Feeder Name	Name of the Substation/line affected by the fault	Reasons of fault	Relay operations	Exact location of fault [Line segment/ Substation]	Remarks
(A) 400/220/66/11 kV Malbasse Substation												
1	21.01.2021	1:35	21.01.2021	16:50	15	18	50/63MVA Transformer II	Malbasse S/S	-	OLTC BUCH trip, 27 trip	OLTC, OSR	Tripped on OLTC Buchline at 1:35 Hrs and issued shutdown to maintenance team, SMG vide PTW No. M55/01/2021 to rectify the OLTC OIR at 9:50 Hrs. Checked LV CR, the later tripping scheme of the transformer and charged the transformer at 16:50 Hrs.
2	22.01.2021	22:27	23.01.2021	12:18	13	20	50/63MVA Transformer II	Malbasse S/S	-	OLTC BUCH trip, 27 trip	OLTC, OSR	Tripped on OLTC Buchline at 22:27 Hrs dated 22.01.2021 and issued shutdown to maintenance team, SMG vide PTW No. M55/04/2021 to rectify the OLTC OIR at 9:30 Hrs. After rectifying the fault charged the transformer at 12:18 Hrs of 23.01.2021
(B) 220/66/11 kV Singhgisa Substation												
no tripping												
(C) 66/33/11 kV Phasorholing Substation												
1	10.01.2021	12:42	10.01.2021	12:47	0	0.51	5MVA transformer (66/11kV)	11kV fdr ILV and 11kV fdr VII	Tripped	OLTC trip, 06	Substation	5MVA transformer got tripped due to heavy fault on 11kV feeder VII(hospital). At 12:47hrs normalized the transformer.
2			11.01.2021	0:55	0	idle	66kV Malbasse-Fling feeder	66kV Malbasse-Fling feeder		Nil		At 08:55hrs charged 66kV Fling-Malbasse feeder which was under idle condition with charging code 1134 from BPSO, since 66kV Fling-Gedu section was taken shutdown by TMD/Fling for replacement of broken insulator at Kabreytar cluster area. On dated 12.01.2021 at 11:39hrs as per instruction from BPSO opened CR of 66kV Fling Malbasse feeder with opening code 0022 from BPSO at our end and feeder was kept under idle condition.
2	21.01.2021	9:13	23.01.2021	14:50	5	idle	66kV Malbasse-Fling feeder	66kV Malbasse-Fling feeder		Nil		At 09:13hrs 66kV Fling-Malbasse feeder (feeder under idle position) was taken shutdown by TMD/Fling with work permit no 604 for carrying out annual maintenance at location PS # 16 with opening code 0040 from BPSO. On dated 23.01.2021 at 14:50hrs normalized the feeder with charging code 1186 from BPSO.
3	23.01.2021	15:12				-2.49	66kV Malbasse-Fling feeder	66kV Malbasse-Fling feeder		Nil		At 15:21hrs 66kV Fling-Malbasse feeder CR was kept open from our end with opening code 0048 as per instruction from BPSO.
3			25.01.2021	0:36	0	idle	66kV Malbasse-Fling feeder	66kV Malbasse-Fling feeder		Nil	Line	At 08:36hrs charged 66kV Fling-Malbasse feeder which was under idle condition with charging code 1181 from BPSO, since 66kV Fling-Gantu feeder was taken shutdown by TMD/Fling for replacement of polymers insulator and RoW clearing.
4	25.01.2021	0:36					66kV Fling-Gantu feeder	66kV Fling-Gantu feeder		Nil	Line	At 08:36hrs 66kV Fling-Gantu feeder was taken shutdown by Parash, AE, TMD/Fling with work permit no. 609 opening code 0051 from BPSO for replacement of polymers insulators and RoW clearing.
(D) 66/33/11 kV Gedu Substation												
1	07.01.2021	20:35	07.01.2021	20:37	0	0.07	8MVA 66/33kV Tc.	33kV Gurunglara feeder-1	Differential fault on Transformer	1. Differential relay 2. Tripping relay 06	Line segment	Test charged and hold normal.
2	07.01.2021	20:43	07.01.2021	21:01	0	0.07	8MVA 66/33kV Tc.	33kV Gurunglara feeder-2	Differential fault on Transformer	1. Differential relay 2. Tripping relay 06	Line segment	Test charged and hold normal.
3	07.01.2021	21:20	07.01.2021	21:22	0	0.07	8MVA 66/33kV Tc.	33kV Gurunglara feeder-1	Differential fault on Transformer	1. Differential relay 2. Tripping relay 06	Line segment	Charged after opening breaker towards power house fdr from 33kV Gurunglara Substation.
4	07.01.2021	21:57	07.01.2021	22:03	0	0.07	8MVA 66/33kV Tc.	33kV Gurunglara feeder-2	Differential fault on Transformer	1. Differential relay 2. Tripping relay 06	Line segment	Charged after opening breaker towards power house fdr from 33kV Gurunglara Substation.
5	11.01.2021	0:57	12.01.2021	11:07	2	1.01	66kV Chakha-Phasorholing Line (Fling -Gedu section)	Nil	To replace broken insulator.	Nil	Line segment	Shutdown taken by TMD, BPC, Phasorholing for replacing of broken insulators at PC-1 to PC-6 at Kabreytar cluster area as per shutdown approval request on dt. 22.12.2020
6	12.01.2021	11:26	12.01.2021	11:28	0	0.54	8MVA 66/33kV Tc.	33kV Gurunglara feeder-1	Differential fault on Transformer	1. Differential relay 2. Tripping relay 06	Line segment	Test charged and hold normal.
7	26.01.2021	10:16	26.01.2021	10:18	0	0.51	8MVA 66/33kV Tc.	33kV Gurunglara feeder-1	Differential fault on Transformer	1. Differential relay 2. Tripping relay 06	Line segment	Test charged and hold normal.
8	26.01.2021	10:25	26.01.2021	10:28	0	0.51	8MVA 66/33kV Tc.	33kV Gurunglara feeder-2	Differential fault on Transformer	1. Differential relay 2. Tripping relay 06	Line segment	Test charged and hold normal.

06/33/11kV Gantu Substation												
1	25-01-2021	00:30				5.19	66KV P1ng feeder	Nil	Replacement of old insulator and ROW clearance	Nil	Location PP#20 to PP#40	Replacement of old disc with polymer and clearing RoW/location/bunch cutting. Line still under shutdown
(A) 66KV Chakha switching station												
1	18-01-2021	09:55hrs	18-01-2021	10:00hrs	15min	6-110.2MW	66KV Chakha 5tr	Fed from 66KV Jemara DC	Transient fault	CB open, G trip	Chakha PH	
(B) 66/33KV Water Substation												
1	15/01/2021	15:20hrs	15/01/2021	15:24hrs	4min	350MW	66KV SF6 Breaker	Fdr. I and II	OC, OCH, EF and EFH	OC, OCH, EF and EFH relay operated	Fdr. I wanakha	Test charge at 15:21hrs and line got hold and again after 1 min line got tripped and breaker charged after opening Fdr. Isolator.
2	18/01/2021	9:55hrs	18/01/2021	10:06hrs	11min	490MW	66KV Incomer	Fdr. I and II	Relay L23 got tripped at chakha end	Relay L23 got tripped at chakha end	66KV Incomer	66KV supply fail fro chakha end
3	21/01/2021	00:12hrs	21/01/2021	00:18hrs	6min	250MW	66KV SF6 Breaker	Fdr. I and II	OC, OCH and EF	OC, OCH and EF and EFH relay operated B phase	Fdr. II chapcha	Test charged at 00:12hrs but line could not hold, again test charged after keeping Fdr. I wanakha line open but line could not stand and finally line charged after opening isolator of Fdr. II chapcha
4	24/01/2021	11:45hrs	24/01/2021	11:46hrs	1min	430MW	66KV SF6 Breaker	Fdr. I and II	OC, OCH, EF and EFH	OC, OCH and EF and EFH relay operated B phase	Fdr. I wanakha	The breaker got tripped several times(Transient fault) and Fdr. I wanakha kept open to segregate fault and breaker had not tripped.
5	24/01/2021	12:20hrs	24/01/2021	12:21hrs	1min	190MW	66KV SF6 Breaker	Fdr. I and II	OC, OCH, EF and EFH	OC, OCH and EF and EFH relay operated B phase	Fdr. I wanakha	Breaker charged after opening of Fdr. I Wanakha and inform to ESD personal
6	24/01/2021	13:31hrs	24/01/2021	13:33hrs	2min	350MW	66KV SF6 Breaker	Fdr. I and II	OC, OCH, EF and EFH	OC, OCH and EF and EFH relay operated B phase	Fdr. I wanakha	Breaker tripped as ESD betikha had closed LBS of Betikha and breaker charged again after opening of Fdr. I Wanakha
7	27/1/2021	14:54hrs	27/1/2021	14:57hrs	3min	390MW	66KV SF6 Breaker	Fdr. I and II	OC, OCH, EF and EFH	OC, OCH and EF and EFH relay operated B phase	Fdr. I wanakha	As it was transient fault breaker had been tripped 3 times and Fdr. I kept open and charge the breaker
(C) 66/33KV Obakha Substation												
1	1/1/2021	4:13	1/11/2021	4:13	2	4.4	66/33KV 20MVA, Transformer I	All the 33KV Outgoing feeders got effected as the 33KV Incomer I&II got tripped on same time	Cable Flash Over	TRAF0 DIFFL-PROTN-RELAY 87-Indication : 1,3,4 & 5. 1. General Trip 3.DIFF Trip Ypk.4.DIFF Trip Bpk.5.DIFF Prot.Oper.DIR.OVC& E/F PROTN-RELAY 67- Trip Relay 86.	RICB Thimphu	The Transformer was tripped due to flash over of 11KV Incomer Cable at RICB Thimphu as confirmed by the ESD Personal. Test charged the Transformer & hold normal
2	1/11/2021	4:34	1/11/2021	4:35	1	4.4	66/33KV 20MVA, Transformer I	All the 33KV Outgoing feeders got effected as the 33KV Incomer I&II got tripped on same time	Cable Flash Over	TRAF0 DIFFL-PROTN-RELAY 87-Indication : 1,3,4 & 5. 1. General Trip 3.DIFF Trip Ypk.4.DIFF Trip Bpk.5.DIFF Prot.Oper.DIR.OVC& E/F PROTN-RELAY 67- Trip Relay 86.	RICB Thimphu	As per the information received from ESD Thimphu, The Incomer was tripped due to flash over of 11KV incomer cable at RICB Thimphu. Test charged the Transformer & hold normal
3	1/11/2021	4:50	1/11/2021	4:52	2	4.4	66/33KV 20MVA, Transformer I	All the 33KV Outgoing feeders got effected as the 33KV Incomer I&II got tripped on same time	Cable Flash Over	TRAF0 DIFFL-PROTN-RELAY 87-Indication : 1,3,4 & 5. 1. General Trip 3.DIFF Trip Ypk.4.DIFF Trip Bpk.5.DIFF Prot.Oper.DIR.OVC& E/F PROTN-RELAY 67- Trip Relay 86.	RICB Thimphu	As per the information received from ESD Thimphu, The Incomer was tripped due to flash over of 11KV incomer cable at RICB Thimphu. Test charged the Transformer & hold normal
4	1/21/2021	0:03	1/21/2021	0:05	2	-14.8	66KV Olakha-Sentokha	66KV Blackout as there is no supply from Changidaphu Substation		DISTANCE PROTN RELAY-21-Indication 1,2,4&12. 1.General trip. 2.Distance Operd. 4.Zone2 Operd. 12.LBB Operd. Trip relay-86	Line Segments	Reset the relay and test charge the 66KV incomer and stood normal
5	1/21/2021	8:56	1/21/2021	8:59	3	-22	66KV Olakha-Sentokha	66KV Blackout as there is no supply from Changidaphu Substation		DISTANCE PROTN RELAY-21-Indication 1,2,4&12. 1.General trip. 2.Distance Operd. 4.Zone2 Operd. 12.LBB Operd. Trip relay-86	Line Segments	Reset the relay and test charge the 66KV incomer and stood normal
6	1/21/2021	9:35	1/21/2021	9:39	4	-19	66KV Olakha-Sentokha	66KV Blackout as there is no supply from Changidaphu Substation		DISTANCE PROTN RELAY-21-Indication 1,2,4&12. 1.General trip. 2.Distance Operd. 4.Zone2 Operd. 12.LBB Operd. Trip relay-87	Line Segments	Reset the relay and test charge the 66KV incomer and stood normal with closing code 1167 from NLDC.

(F) 66/33/11kV Jemina Substation											
20.01.2021	8:58	20.01.2021	9:03	5	Chumdo: 3.78 C/daphu: -6.33	66 kV Chumdo line & 66 kV C/daphu line	Black out	Over Current	Start I>1	Line segment	Non directional O/C operated, Auto reclose lock out & distance protection optd. Indicated. Upon test charging at 09:03 Hrs, both the line stood normal.
20.01.2021	20:50	20.01.2021	20:54	4	Chumdo: 2.25 C/daphu: -6.72	66 kV Chumdo line & 66 kV C/daphu line	Black out	Over Current	Start I>1	Line segment	Non directional O/C operated, Auto reclose lock out & distance protection optd. Indicated. Upon test charging with system code: 1163 at 20:54 Hrs, both the line stood normal.
21.01.2021	9:36	21.01.2021	9:38	2	Chumdo: -3.03 C/daphu: 0.33	66 kV Chumdo line & 66 kV C/daphu line	Black out	Distance protection operated	Started phase BC	Line segment	Distance protection optd. & Auto reclose lockout, Started phase BC, Tripped phase ABC, Trip Zone I, fault location: 6.132 KM & 6.112 KM, Chumdo & C/daphu respectively. Upon test charging at 09:38 Hrs, both the line stood normal.
21.01.2021	11:25	20.01.2021	11:27	2	4:33	66 kV Chumdo line	Black out	Distance protection operated	Started phase AC	Line segment	Distance protection optd. & Auto reclose lockout, Started phase AC, Tripped phase ABC, Trip Zone I, fault location: 6.789 KM. Upon test charging at 11:27 Hrs with the code 1169, the line stood normal.
21.01.2021	11:25	20.01.2021	11:30	5	_ 5.31	66 kV C/daphu line	Black out	Distance protection operated	Started phase AC	Line segment	Distance protection optd. & Auto reclose lockout, Started phase AC, Tripped phase ABC, Trip Zone I, fault location: 6.616 KM. Upon test charging at 11:30 Hrs with the code 1170, the line stood normal.
(H) 66/11kV Haa Substation											
05.01.2021	13:33	05.01.2021	13:39	06minutes	-2.36	66kV Incomer	All the feeders	Unknown	O/C	Pangbesa s/s	Incomer tripped from Pangbesa substation on over current. Supply was resumed further,after informing the concern person.
21.01.2021	11:39	21.01.2021	11:52	14minutes	1.29	5MVA Tr- II	Incomer - II & Tr-II	To fill up the SF6 gas	Nil	Haa S/s	5MVA transformer - II was taken shutdown by substation Head to fill up the SF6 gas. The same was energised after completing the work.
(J) 66/33/11kV Pangbesa substation											
05.1.2021	13.36Hrs	05.1.2021	13:39Hrs	3	2.21	66kV OG to Haa	66kV OG to Haa	O/C	Distance relay	Pangbisa-Haa	
(K) 66/33kV Changidaphu Substation											
20.012.021	857hrs	20.012.021	1213hrs	16.00	1.017	66KV Cgangidaphu	66KV Cgangidaphu		Distance Protection. zone:1(R.Y.B phase)		
20.012.022	2050hrs	20.012.022	2059hrs	9.00	6.120	66KV Cgangidaphu	66KV		86trip(A and B)		
20.012.023	857hrs	20.012.023	1213hrs	16.00	1.017	66KV Cgangidaphu	66KV		Distance Protection.		

February 2021

Tripping report of 66kV and above feeders for the month of February, 2021

Sl No.	Date of Tripping	Time of outages	Date of Normalization	Time of fault was cleared	Duration of Outages (Hrs)	MW before outage (MW)	Feeder Name	Name of the Substation, lines affected by the fault	Reasons of fault	Relay operations	Exact location of fault [line segment/ Substation]	Remarks
(B66/13/11 kV Phuntsholing Substation)												
1	06.02.2021	14:40	06.02.2021	14:51	0	0.12	66KV Chokha-Phing feeder	66KV Chokha-Phing feeder		Dist Prot OPTD, Fault Imp- 6.80, fault angle- 54 deg, fault current- 0.359Amp, location- 5.730CM, 34.5% & 86 relay	Line	At 14:40hrs 66KV Chokha-Phing feeder got tripped on both the end. At 14:51hrs normalized the feeder.
(E7) 66/13/11 kV Gelela Substation												
1	06.02.2021	14:40	06.02.2021	14:53	0	2.34	66KV Chokha-Phuntsholing ltr.	Black out	Lightning and thundering		Line segment	Tripped from Chokha end.
2	06.02.2021	15:43	06.02.2021	15:44	0	0.49	800VA 66/11KV Tn.	11KV Gursunglara feeder-I	Differential fault on Transformer	1. Differential relay B-B phase Tripping relay 06	Line segment	Test charged and hold normal.
3	10.02.2021	12:31	10.02.2021	12:33	0	0.41	800VA 66/11KV Tn.	11KV Gursunglara feeder-I	Differential fault on Transformer	1. Differential relay B-B phase Tripping relay 06	Line segment	Test charged the transformer but it didn't hold. Informed to Mr. Tshering Penjor JE E333. Received information of tree fall on the 11KV Murching ltr of Gursunglara substation. The Murching ltr kept on tripped condition at Gursunglara substation and charged the 11KV Gursunglara ltr I at 12:44hrs and stood normal.
(E) 66/13/11 kV Gelela Substation												
1	04.02.2021	09:51	04.02.2021	10:34	3	2.90	66KV Gelela P/ling	N/A	Oil leakage from CT	N/A	Phuntsholing Sub-Station	Fire arresting oil leakage from CT Y phase
(F) 220/66/33 kV Thimphu Substation												
1	19.02.2021	0:00	21.02.2021	19:45	11		220KV Bursunglara	N/A	N/A	CB SF6 6/UCB TC Trouble, CB faulty	Outdoor yard, Breaker of 220KV Bursunglara.	Due to chattering sound on the breaker of 220KV Bursunglara, we have avail shutdown from the BPSO on the request of our substation head. The shutdown code No. 0167 is issued by Mrs. Phuljan. The breaker was charged at 19:50hrs against charging code 1329
(B) 66/13KV Wesa Substation												
1	14.2.2021	08:00hrs	14.2.2021	08:10hrs	10	212MW	Feeder 1 Wesa	Feeder 1 Wesa	O/C, OCH on ABC phase	O/C, OCH on ABC phase opened	Tree falls on 11KV line at Wesa as per BMD trouble	
(C) 66/33/11KV Bercha Substation												
1	2/9/2021	14:22hrs	2/10/2021	14:27hrs	71 Hrs	0.293	66KV Gasa ltr.	N/A	Tripped due to over current	O/C, B & C phase IA- 42.50A, IB-1.548KA & IC- 2.577KA, BA & 90B	not known	Fir tripped due to falling of large tree on the Y & B phase, and damage both the conductors. TMD Chokha site team modified it and recharged the ltr on dated 11.02.2021 at 14:27hrs.

March 2021

Tripping Report for the month of March 2021

Sl No.	Date of Tripping	Time of outages	Date of Normalization	Time of fault was cleared	Duration of Outages (Hrs)	MW before outage (MW)	Feeder Name	Name of the Substation, lines affected by the fault	Reasons of fault	Relay operations	Exact location of fault [line segment/ Substation]	Remarks
(A) 490/220/66/11 kV Malbasa Substation												
1	13.03.2021	16:50	13.03.2021	16:56	0	13	50/4.800VA Transformer III	Malbasa Substation	Tripped due to fault on Samsa Feeder	Differential trip		IL1-7.28A-126.4deg, IL2-141.65A--135.53deg, IL3-79.14A-134.40deg (Note, weather conditions were heavy rainfall, lightning, thundering and heavy wind)
2	13.03.2021	16:50	13.03.2021	16:57	0	18	220KV Malbasa -Samsa Feeder	Malbasa & Samsa Substation	Tripped due to Overcurrent and Earthfault	Distance protection operated and O/C protection operated		Fault data from EMTL Relay, G1 Phase A (FWD) EMTL-011-1A-3009A, Phase B (FWD)- IB-96.19A, Phase c (FWD)- IC - 3264A, Earthfault -REV-IE-2686A (Note, weather conditions were heavy rainfall, lightning, thundering and heavy wind)
(B) 220/66/11 kV Singhsigma Substation												
1	13.03.2021	16:50	13.03.2021	17:00	0	3	220KV Singhsigma -Samsa Feeder	Singhsigma GS & Samsa Feeder	Tripped due to Overcurrent and Earthfault	Distance protection operated and B6 operated		IL1-2803A, IL2-75.79A, IL3-2765A, IB-2042A
(B66/13/11 kV Phuntsholing Substation)												
1	05.03.2021	10:27	05.03.2021	10:33	0	0.14	66KV Chokha-Phing feeder	66KV Chokha-Phing feeder	Distance Protection	Dist Prot OPTD, Fault Imp- 7.9, fault angle- 51 deg, fault current- 2.617Amp, location- 40.7% & 86 relay.	Line	At 10:27hrs 66KV Chokha-Phing feeder got tripped on both the end. At 10:33hrs normalized the feeder. Weather condition was lightning and raining during the time of tripping.

G) 66/33kV Gonda Substation												
1	05.03.2021	10:26	05.03.2021	10:33	0	3.19	66kV Chukha-Phromcholing Wr	Black out	Lightning, thundering & raining		Line segment	Tripped from Chukha end.
H) 66/33kV Gomia Substation												
1	04.02.2021	09:51	04.02.2021	13:34	3	2.90	66kV Gomia-P/Sing	N/A	Oil leakage from CT	N/A	Phromcholing Sub-station	For arresting oil leakage from CT Y phase
I) 220/66/33 kV Dhamsum Substation												
1	13.03.2021	16:50	13.03.2021	17:04	0	-2.83	220kV Singhpoor	N/A	Over current	REL 670 MAIN 1- General trip, Zone 1, Band 3 phase fault	N/A	Trip values: E1- Fault mag- 207.78A, Fault angle- 08.76deg. IL2- Fault mag- 91.40A, Fault angle- -22.00deg. IL3- Fault mag- 347.06A, Fault angle- -0.6deg.
J) 66/33kV Waru Substation												
1	7/3/2021	09:10hr	7/3/2021	09:10hr	0	400kV	66kV Incomer	Ph. 1 and 2	Oil leak from Chukha end	Oil leak from Chukha end as Chukha Wr. Got tripped at Chukha end.		
K) 66/33kV Okaha Substation												
1	3/7/2021	8:40	3/7/2021	8:42	0	-26.6	66kV Sentsikka-Okaha line	Okaha substation	Line Fault	DISTANCE PROTN RELAY-21 Indication 1.2, 1&12. 1.General trip 2.Distance Opnd. 4.Zone2 Opnd. 12.LBD Opnd. Trip relay-08		66kV Sentsikka-Okaha line was tripped on distance protection relay Zone 2.Reset the relay and changed the 66kV incommr and stand normal.
2	3/7/2021	8:54	3/7/2021	8:55	0	-13.1	66kV Sentsikka-Okaha line	Okaha substation	Line Fault	DISTANCE PROTN RELAY-21 Indication 1.2, 1&12. 1.General trip 2.Distance Opnd. 4.Zone2 Opnd. 12.LBD Opnd. Trip relay-08		66kV Sentsikka-Okaha line was again tripped on distance protection relay Zone 2.Reset the relay and changed the 66kV incommr and stand normal.
3	3/7/2021	9:20	3/7/2021	9:22	0	-21.1	66kV Sentsikka-Okaha line	Okaha substation	Line Fault	DISTANCE PROTN RELAY-21 Indication 1.2, 1&12. 1.General trip 2.Distance Opnd. 4.Zone1 Opnd. 12.LBD Opnd. Trip relay-08		66kV Sentsikka-Okaha line was tripped on distance protection relay Zone 1.Reset the relay and changed the 66kV incommr as per the instruction received from DPSO and stand normal.
4	3/7/2021	10:24	3/7/2021	10:29	0	-27.7	66kV Sentsikka-Okaha line	Okaha substation	Line Fault	DISTANCE PROTN RELAY-21 Indication 1.2, 1&12. 1.General trip 2.Distance Opnd. 4.Zone2 Opnd. 12.LBD Opnd. Trip relay-08		66kV Sentsikka-Okaha line was tripped on distance protection relay Zone 2.Reset the relay and changed the 66kV incommr as per the instruction received from DPSO and stand normal.
5	3/7/2021	14:26	3/7/2021	14:31	0	-28.3	66kV Sentsikka-Okaha line	Okaha substation	Line Fault	DISTANCE PROTN RELAY-21 Indication 1.2, 1&12. 1.General trip 2.Distance Opnd. 4.Zone2 Opnd. 12.LBD Opnd. Trip relay-07		66kV Sentsikka-Okaha line was tripped on distance protection relay Zone 2.Reset the relay and changed the 66kV incommr as per the instruction received from DPSO and stand normal.
6	3/08/2021	21:11	30/3/2021	21:13	0	12.2	20MVA Transformer I	All the Outgoing feeders got effected as the 33kV Incomer I & II was tripped.	Due to tripping of 33kV DP#1 B feeder	Differential Protection Operated. Indication 1,3,4 A.5. 1.General trip. 3. Differential trips on Y Phase 4.Differential tripped on B Phase. 7. Differential protection operated		The 66/33kV 20MVA Transformer I was tripped due to tripping of 33kV O/G feeder V1 (DP#1 B)
7	3/08/2021	21:20	30/3/2021	21:21	0	12.2	20MVA Transformer I	All the Outgoing feeders got effected as the 33kV Incomer I & II was tripped.	Due to tripping of 33kV DP#1 B feeder	Differential Protection Operated. Indication 1,3,4 A.5. 1.General trip. 3. Differential trips on Y Phase 4.Differential tripped on B Phase. 7. Differential protection operated		The 66/33kV 20MVA Transformer I was tripped due to tripping of 33kV O/G feeder V3 (DP#1 B)

66/33/11kV Laksya Substation											
1	18.03.2021	09:16hrs	31.09.2021	17:00hrs	1791	2.140	66kV LSA-SEM	NA	NA	NA	66kV LSA -SEM isolator shutdown as per the shutdown approval No 10A/BPC/SPHO/PSOD/16/171 to carry out the re-conducting HTLS Project from Sentshika to Doshika Supply an interruption incident from Sentshika.
66/33/11kV Pore Substation											
1	3/7/2021	10:16	3/7/2021	10:17	0	0.28	66kV Line 04	Tripped from Chanda	Tripped from Chanda		
66/33/11kV Jemina Substation											
1	07.03.2021	8:14	07.03.2021	8:45	0	3.89	66 kV Chanda	Black out	Distance relay operated, Phase ABC, Zone 1	Dist. Relay, Ph. ABC, Zone 1	Both the 66 kV lines, Chanda & Changdaphu tripped on Phase ABC, Zone 1 as shown by operated Distance relay at 08:14 hrs, the Chanda line charged at 08:07 hrs with charging code 1194.
2	07.03.2021	8:14	07.03.2021	8:47	0	-5.27	66 kV Changdaphu	Black out till 08:47 hrs	Distance relay operated, Phase ABC, Zone 1	Dist. Relay, Ph. ABC, Zone 1	Both the 66 kV lines, Chanda & Changdaphu tripped on Phase ABC, Zone 1 as shown by operated Distance relay at 08:14 hrs, the Changdaphu line charged at 08:47 hrs with charging code 1194.
3	07.03.2021	8:50	07.03.2021	9:00	0	3.09	66 kV Chanda	Black out	Distance relay operated, Phase ABC, Zone 1	Dist. Relay, Ph. ABC, Zone 1	Both the 66 kV lines, Chanda & Changdaphu tripped on Phase ABC, Zone 1 as shown by operated Distance relay at 08:50 hrs after charging the Changdaphu line at 08:47 hrs, the Chanda line charged at 09:00 hrs after instruction from BPSO.
4	07.03.2021	8:50	07.03.2021	10:10	1	-5.27	66 kV Changdaphu	Black out till 09:00 hrs	Distance relay operated, Phase ABC, Zone 1	Dist. Relay, Ph. ABC, Zone 1	Both the 66 kV lines, Chanda & Changdaphu tripped on Phase ABC, Zone 1 as shown by operated Distance relay at 08:50 hrs, after charging the Changdaphu line at 08:47 hrs, the Changdaphu line was kept open, however, again at 09:10 hrs, with the charging code 1191 from BPSO, the Changdaphu line was charged, but the line couldn't hold and tripped along with 66 kV Chanda. Therefore, the Changdaphu line kept open.
5	07.03.2021	10:10	07.03.2021	10:16	0	-1.97	66 kV Chanda	Black out	Distance relay operated, Phase ABC, Zone 1	Dist. Relay, Ph. ABC, Zone 1	Both the 66 kV lines, Chanda & Changdaphu tripped on Phase ABC, Zone 1 as shown by operated Distance relay at 10:10 hrs after charging the Changdaphu line at 10:10 hrs, the Chanda line charged at 10:16 hrs after instruction from BPSO.
66/33/11kV Sentshika Substation											
1	5/18/2021	09:15hrs				-2.040		Short down taken by Mr. Kishay Wangchuk (project manager) for re-conducting HTLS line for new lay at Sentshika S/S.			
66/33/11kV Pangbasa substation											
Nil											
66/33kV Changdaphu Substation											
1	3/7/2021	81hrs	3/7/2021	85hrs	0.00	3.230	66kV Jemina to Changdaphu	Changdaphu	Covering of insulator by Storm-1st	Distance Protection	
2	3/7/2021	110hrs	3/18/2021	103hrs	263.30	3.230	66kV Jemina to Changdaphu	Changdaphu	Covering of insulator by Storm-1st	Distance Protection	
3	3/7/2021	95hrs	3/7/2021	110hrs	2.00	-0.990	66kV Olakha to Changdaphu	Olakha	Covering of insulator by Storm-1st	Only 3rd Relay Operated	

April 2021

Tripping report of 66kV and above feeders for the month of April, 2021

M No.	Date of Tripping	Time of outages	Rate of Normalization	Time of fault was cleared	Duration of Outages (hrs)	MW before outage (MW)	Feeder Name	Name of the Substation/Line affected by the fault	Reasons of fault	Relay operations	Exact location of fault [Line segment/ Substation]	Type of outages	Remarks
66/33/11kV Malhawa Substation													
1	22.04.2021	12:40	22.04.2021	13:00	0	27	66kV Silguri Feeder	Silguri Substation	Transformer fault	Main 1 & 6A B-apt.	IL1-376-NA-100 10kg, IL2-256A-47 17kg, IL3-54134-90 29kg, IL4- 43416- 87 05kg		(Note: weather conditions were light rainfall with lightning)
2	22.04.2021	12:40	22.04.2021	12:48	0	0	220kV Bus coupler	Malhawa Substation	Transformer fault	6A- trip, 6B apt.			Earthfault. [Note: weather conditions were light rainfall with lightning]
66/33/11kV Singhiqawa Substation													
1	22.04.2021	12:40	22.04.2021	12:47	0	5.1	66kV Gromat Circuit Br.	Singhiqawa GIS	Tripped due to Overcurrent	Directional overcurrent trip, 1Pg Trip, 3B apt.			IL1-0 114A, IL2-0 02NA, IL3-0 08AA
2	22.04.2021	12:40	22.04.2021	12:48	0	0	66kV Main Bus 1	Singhiqawa GIS	Tripped due to Overcurrent	4/C Trip, General Trip, 6B apt.			IL1-0 23AA, IL2-0 26AA, IL3-0 04AA
66/33/11kV Phuntsholing Substation													
1			13.04.2021	9:00	9	0	66kV Malhawa-Phing feeder	66kV Malhawa-Phing feeder					In 09:05hrs charged 66kV Phing-Malhawa feeder which was under idle condition with charging code 1708 from BPSO [for supply reliability at Phing S/S], since 66kV Chokha-Gada section was taken shutdown by TMO, Thimshaling for carrying out annual maintenance on 66kV Chokha-Gada section (1a replacement of insulator with glass and polymer). On dated 10/04/2021 at 17:05hrs opened CB of 66kV Phing-Malhawa feeder with opening code 0413 from BPSO and again the feeder was kept under idle condition.
2	22.04.2021	3:07	22.04.2021	3:30	0	9.00	66kV Phing-Gromat feeder	66kV Phing-Gromat feeder	Tripped	DITH OPTD, 06A&B	Line		In 03:07hrs 66kV Phing-Gromat feeder got tripped at end end and 66kV Chokha-Phing feeder got tripped at Chokha end causing black out at Phuntsholing. Weather condition was raining with lightning during the time of tripping, in 03:10hrs charged 66kV Malhawa-Phing feeder after informing BPSO. At 03:14hrs re-normalized 66kV Phing-Gromat feeder after getting clearance from BPSO. In 03:30hrs opened CB of 66kV Phing-Malhawa feeder with opening code 0413 from BPSO and again the feeder was kept under idle condition.

01 66/33/11kV County Substation													
Sl. No.	Date of Tripping	Time of outages	Date of Normalization	Time of fault was cleared	Duration of Outages (Hrs)	MW before outages (MW)	Feeder Name	Name of the Substation/lines affected by the fault	Reason of fault	Relay operations	Exact location of fault (Line segment/ Substation)	Type of outages	Remarks
1	22/04/2021	03:09	22/04/2021	03:39	0	-7.33	66KV Incomer Dandim & Gema-Phonsholing	Gema Substation	Transient fault	General trip Zone-4 trip B ph. Fault	Line segment	Transient Fault	66KV Phonsholing supply resumed at 3:18 hrs. 66KV Dandim feeder charged after returning to BPSO and Dandim Substation.
02 20MVA/01kV Dhandim Substation													
Tripping Report for the month of APRIL, 2021													
1	22/04/2021	3:07	22/04/2021	03:10	0	7.7	66-33 Gema-06	N/A	Tripped	N/A	N/A	N/A	66KV Gema-06 tripped on B phase fault at 3:07:00.
1	08/04/2021	10:40	08/04/2021	12:43	0	7.7	66KV Ghalda-Changshing Line	Ghalda substation	Due to fault at Dechencholing line	Distance protection relay J1 operated. Indication (Ground trip)	66KV Gema line from Dechencholing	Transient Fault	The supply was led from Sonakha due to fault at 66KV Dechencholing to Gema Line as information received from BPSO and shift duty of Sonakha Substation.
4	18/04/2021	11:38	18/04/2021	12:39	0	7	66KV Ghalda-Changshing Line	Ghalda Substation	Under voltage	Only Trip relay 04 Operated	Ghalda Substation	Temporary	The supply was led due to under voltage. Reset all the relays and changed the feeder, held normal.
7	4/22/2021	1:40	4/22/2021	2:42	0	3.0	20MVA Transformer 1	Only 33KV Chabacks feeder IV was affected as the other feeders was fed from Transformer II	Due to tripping of 33KV Chabacks feeder (F4-FV)	TRAF0-DIFFL, PROTIN, RELAY 07 Indication : L, L1 & 3, 1 General Trip, 5 DIF Trip Yph 4 DIF Trip Dph 5 DIF Post-Opd, DIB, OVC & EF PROTIN-RELAY 07 Trip Relay 06	Line segment	Transient Fault	The 66/33KV 20MVA Transformer 1 was tripped due to tripping of 33KV OVC feeder IV (Chabacks) Changed the feeder and held normal.
8	4/22/2021	11:07	4/22/2021	13:37	0	8.80	20MVA Transformer 1	Only 33KV Chabacks feeder IV was affected as the other feeders was fed from Transformer II	Due to tripping of 33KV Chabacks feeder (F4-FV)	TRAF0-DIFFL, PROTIN, RELAY 07 Indication : L, L1 & 3, 1 General Trip, 5 DIF Trip Yph 4 DIF Trip Dph 5 DIF Post-Opd, Trip Relay 06	Line segment	Transient Fault	66/33KV 20MVA Transformer 1 tripped due to tripping of 33KV OVC IV (Chabacks feeder) Changed the feeder after confirmation and clearance received from ESD personnel and held normal.
03 66/33/11KV Lobsaze Substation													
1	26/04/2021	20:15hrs	26/04/2021	21:45hrs	1	-0.450	66KV LSA-Bancho	Lobsaze substation	Bancho machine tripped	NA	Bancho Plant	NA	66KV LSA-Bancho feeder tripped at 20:15hrs from Bancho end and the relay breaker operated at our end supply resumed at 21:45hrs from Bancho end.
2	26/04/2021	23:05hrs	27/04/2021	00:21hrs	1	-7.020	66KV LSA-Bancho	Lobsaze substation	Bancho machine tripped	NA	Bancho Plant	NA	66KV LSA-Bancho feeder tripped at 23:05hrs from Bancho end and the relay breaker operated at our end supply resumed at 00:21hrs from Bancho end on 27/04/2021.
04 66/33/11KV Pema Substation													
No													
05 66/33/10KV Ananta Substation													
No													
06 66/33/10KV Dechencholing substation													
1	4/8/2021	10:47hrs	4/8/2021	11:00hrs	0	3.113	Sub 10MVA Tr.	Whole org. line	Due to insulation Puncture/leakage	only B1 relay	Opposite of DIBing S/S, 66KV line Sonakha to DIBing Incomer line	Tripped	Sound came out like boom blast from opposite of our substation from double circuit tower, later we have found out that one side of double stringing insulator was puncture/leakage due to low rating. 66KV Incomer line tripped from sonakha end. However both 10MVA Tr. are tripped at our end.
07 66/11KV Haas Substation													
1	01/04/2021	03:28	01/04/2021	03:38	0	-4.28	66KV Incomer, along with all the feeders.	unknown	OVC	Painghwa substation, Para	66KV Incomer tripped from Painghwa substation on occurrence. The same was investigated further.		
2	08/04/2021	1:07	08/04/2021	01:08	0	-1.8	66KV Incomer, along with all the feeders.	unknown	OVC	Painghwa substation, Para	66KV Incomer tripped from Painghwa substation on occurrence. The same was investigated further.		

(G) 220kV Substation Samskha												
1	08.04.2021	10.40hrs	08.04.2021	10.52hrs	0.00	21.500	30MVA Transformer 1	220kV Samskha Substation	B phase isolator operational above De-energizing	BT and LV Backing protection Optd. (BT: Is=247.2A, Ib=61.27A, Ic=61.11A); (LV: Is= 97% 7A, Ib=397.2A, Ic= 105.0A)	220kV Samskha Substation	Transient
2	08.04.2021	10.40hrs	08.04.2021	10.47hrs	0.00	21.810	30MVA Transformer 2	220kV Samskha Substation	B phase isolator operational above De-energizing	BT and LV Backing protection Optd. (BT: Is=150.1A, Ib= 125.5A, Ic=84.06A); (LV: Is= 500.5A, Ib=380.5A, Ic= 231.0A)	220kV Samskha Substation	Transient
3	28.04.2021	12.10hrs	28.04.2021	12.18hrs	0.00	17.870	30MVA Transformer 1	220kV Samskha Substation	One thunder and lightning De-energizing has tripped and automatically fault (not tripped)	Differential protection optd. BT and LV Backing protection Optd.	220kV Samskha Substation	Transient
4	28.04.2021	12.10hrs	28.04.2021	12.18hrs	0.00	17.800	30MVA Transformer 2	220kV Samskha Substation	One thunder and lightning De-energizing has tripped and automatically fault (not tripped)	Differential protection optd. BT and LV Backing protection Optd.	220kV Samskha Substation	Transient
5	08.04.2021	10.40hrs	08.04.2021	10.50hrs	0.00	8.850	66kV Samskha-De-energizing Feeder	220kV Samskha Substation & 66kV De-energizing Substation	B phase isolator operational above De-energizing	Is= Trip Is= 1.051A, Ib=56.87A, Ic=45.11A		Permanent
6	28.04.2021	12.10hrs	28.04.2021	12.21hrs	0.00	7.620	66kV Samskha-De-energizing Feeder	220kV Samskha Substation & 66kV De-energizing Substation	B phase isolator operational above De-energizing	Distance Protection Optd. Is= Trip Is= 2.108A, Ib=74.8A, Ic=61.66A		Transient
(H) 66-33/11kV Panglusa substation												
1	02.04.2021	11.30hrs	02.04.2021	11.39hrs	0	2.21	66kV OC-Has feeder	Has	OC			Transient
2	08.04.2021	14.07hrs	08.04.2021	14.08hrs	0	1.74	66kV OC-Has feeder	Has	OC			Transient
(I) 66-33kV Chongphu Substation												
(J) 66-33kV Dhang Substation												
1	08.04.2021	10.40hrs	11.04.2021	9.40hrs	76	-0.29	6.10kV incoming line		Failure of insulator	NA		66kV incoming line was tripped at 10:44 hrs and line at Dhang Substation had been back feed from Panglusa at 14:07 hrs. 66kV line changed at 17:00 hrs as per the clearing code (M) from BPSO.
2	28.04.2021	12.10hrs	28.04.2021	12.27hrs	0	-0.29	6.10kV incoming line		Hand trip	NA		66kV line breakdown (Hand trip) from Samskha.

2021 MAY/2021 LV Grids, Substation													
1	01.05.2021	13:27	01.05.2021	14:05	0	1.73	0007 Chabha-Phuntsholing	Black out	Due to bad weather		Line segment	Weather condition: Heavy Rainfall. 0007 line was changed from Chabha after improving the weather condition.	
2	01.05.2021	15:10	01.05.2021	15:10	0	1.74	0007 Chabha-Phuntsholing	Black out	Due to bad weather		Line segment	Weather condition: Heavy Rainfall. 0007 line was changed from Chabha after improving the weather condition.	
3	06.05.2021	10:11	10.05.2021	10:33	10	0.04	0004 Gyangtse-1 and 2	0007 Gyangtse breaker 1 and 2	0007 supply extended from 0007 Gyangtse to 0007 Gyangtse-1		Substation	1000v shutdown for installation and commissioning of LV's line section-0 parallel with main line. 50 second to hrs. (Kanchi Zangmo, to 0007-0007)	
4	10.05.2021	9:28	10.05.2021	9:40	0	0.0	0004 Gyangtse-1	0007 Gyangtse breaker 1	Bad weather	Differential fault on R phase	Line segment	Weather Condition: Thundering and Raining. Line changed after weather got clear and wind normal.	
5	10.05.2021	0:02	10.05.2021	0:06	0	1.04	0007 Chabha-Phuntsholing line	Black out	Due to bad weather		Line segment	Weather condition: Raining and Thundering. 0007 line changed from Phuntsholing rail.	
6	10.05.2021	16:45	10.05.2021	16:53	0	0.03	0004 Gyangtse-1	0007 Gyangtse breaker 1 & 2	0007	0007	Line segment	Test changed and held normal.	
7	10.05.2021	15:33	10.05.2021	15:42	0	0.03	0004 Gyangtse-1	0007 Gyangtse breaker 1	0007	0007	Line segment	Test changed and held normal.	
2021 MAY/2021 LV Grids, Substation													
1	01.05.2021	15:11	01.05.2021	15:18	0	-0.004	0007 Dhanochu	Control Substation	Nil	Nil	Malfunction Substation	0007 supply tripped from Malfunction Sub Station.	
2	04.05.2021	12:31	04.05.2021	14:54	7	-7.029	0007 Dhanochu	Nil	Over Current	General trip, Zone-1, R ph fault, 2 ph fault, 3 ph fault V F from fault	0007 Inance-Gangto Line	Tripped on Fault	0007 Dhanochu tripped due to maintenance and supply could not withdrawn from the fault and thereby over charged following to 0007 at 07:54 hours and the line withdrawn.
3	05.05.2021	13:09	05.05.2021	14:00	0	-0.739	0007 Dhanochu & Inance-Phuntsholing	Whole Inance	Over Current/Treatment Fault	General trip, Zone-1, R ph fault, 2 ph fault, 3 ph fault	0007 Inance-Gangto Line	Tripped on Fault	0007 Dhanochu tripped due to maintenance, supply changed with coordination from 0007 at 14:00 hours. 0007 Gangto-Phuntsholing supply resumed at 15:43 hrs.
2021 LV Transmission Substation													
1	01.05.2021	13:11	01.05.2021	13:04	0	-0.19	Empowering Dhanochu Feeder	Dhanochu V/F	Transformer fault	0004/0003/11-041	4.3.04	Line fault	V/F fault. Fault distance 0.5 km, Zone-1 fault.
2	04.05.2021	8:21	04.05.2021	0:35	0	-1.93	Empowering Dhanochu Feeder	Dhanochu V/F	Transformer fault	0004/0003/11-041	24.00	Line fault	Line tripped due to heavy rainfall and lightning and thunder. Line fault record as under: Zone 1, 4Phase to phase fault(R to B) (Distance, fault location, 30.100/30.34%)
2021													
1	04.05.2021	0:36	04.05.2021	7:20	0	7.32	Gangto feeder	Nil	Heavy rainfall and lightning and thunder	0004/0003/11	NA	Line fault	Line tripped due to heavy rainfall and lightning and thunder. Line fault record as under: Zone 1, 02C on R ph fault, 1.10km from 19.00 27 fault location: 00.000%, 27 fault long 1.51.
2	05.05.2021	13:54	05.05.2021	14:06	0	12.33	Gangto feeder	Nil	Heavy rainfall and lightning and thunder	0004/0003/11	NA	Line fault	Line tripped due to heavy rainfall and lightning and thunder. Line fault record as under: Zone 2(R) started 1 (Fault long type: L2 with N, 27 fault location: 1.500/1.00%)
Tripping Report for the month of MAY 2021													
Sl. No.	Date of Tripping	Time of outage	Date of Resumption	Time of fault was cleared	Duration of Outage (Min)	MW before outage (MW)	Feeder Name	Name of the Substation from affected by the fault	Reason of fault	Relay operation	Exact location of fault (Line segment/ Substation)	Type of outage	Remarks
2(A) 0007 Chabha switching station													
1	01.05.2021	13:27	01.05.2021	14:05	38	1.73	0007 Chabha 1	Phuntsholing	Weather condition	OC & CB open	Chabha	Dip	
2	01.05.2021	15:10	01.05.2021	15:10	0	1.74	0007 Chabha 2	Phuntsholing	Weather condition	OC & CB open	Chabha	Dip	
2(B) 0004 Gyangtse-1 and 2													
1	06.05.2021	10:11	10.05.2021	10:33	22	0.04	0004 Gyangtse-1 and 2	0007 Gyangtse	0007 supply extended from 0007 Gyangtse to 0007 Gyangtse-1		Substation	Shutdown	1000v shutdown for installation and commissioning of LV's line section-0 parallel with main line. 50 second to hrs. (Kanchi Zangmo, to 0007-0007)
2	10.05.2021	9:28	10.05.2021	9:40	12	0.0	0004 Gyangtse-1	0007 Gyangtse	Bad weather	Differential fault on R phase	Line segment	Line segment	Weather Condition: Thundering and Raining. Line changed after weather got clear and wind normal.
3	10.05.2021	0:02	10.05.2021	0:06	4	1.04	0007 Chabha-Phuntsholing line	0007 Chabha-Phuntsholing line	Due to bad weather		Line segment	Line segment	Weather condition: Raining and Thundering. 0007 line changed from Phuntsholing rail.
4	10.05.2021	16:45	10.05.2021	16:53	8	0.03	0004 Gyangtse-1	0007 Gyangtse	0007	0007	Line segment	Line segment	Test changed and held normal.
5	10.05.2021	15:33	10.05.2021	15:42	9	0.03	0004 Gyangtse-1	0007 Gyangtse	0007	0007	Line segment	Line segment	Test changed and held normal.
2(C) 0007 Dhanochu													
1	01.05.2021	15:11	01.05.2021	15:18	7	-0.004	0007 Dhanochu	Control Substation	Nil	Nil	Malfunction Substation	Tripped on Fault	0007 supply tripped from Malfunction Sub Station.
2	04.05.2021	12:31	04.05.2021	14:54	142	-7.029	0007 Dhanochu	Nil	Over Current	General trip, Zone-1, R ph fault, 2 ph fault, 3 ph fault V F from fault	0007 Inance-Gangto Line	Tripped on Fault	0007 Dhanochu tripped due to maintenance and supply could not withdrawn from the fault and thereby over charged following to 0007 at 07:54 hours and the line withdrawn.
3	05.05.2021	13:09	05.05.2021	14:00	51	-0.739	0007 Dhanochu & Inance-Phuntsholing	Whole Inance	Over Current/Treatment Fault	General trip, Zone-1, R ph fault, 2 ph fault, 3 ph fault	0007 Inance-Gangto Line	Tripped on Fault	0007 Dhanochu tripped due to maintenance, supply changed with coordination from 0007 at 14:00 hours. 0007 Gangto-Phuntsholing supply resumed at 15:43 hrs.
2(D) 0004 Gyangtse-1													
1	10.05.2021	9:28	10.05.2021	9:40	12	0.0	0004 Gyangtse-1	0007 Gyangtse	Bad weather	Differential fault on R phase	Line segment	Line segment	Weather Condition: Thundering and Raining. Line changed after weather got clear and wind normal.
2	10.05.2021	0:02	10.05.2021	0:06	4	1.04	0007 Chabha-Phuntsholing line	0007 Chabha-Phuntsholing line	Due to bad weather		Line segment	Line segment	Weather condition: Raining and Thundering. 0007 line changed from Phuntsholing rail.
3	10.05.2021	16:45	10.05.2021	16:53	8	0.03	0004 Gyangtse-1	0007 Gyangtse	0007	0007	Line segment	Line segment	Test changed and held normal.
4	10.05.2021	15:33	10.05.2021	15:42	9	0.03	0004 Gyangtse-1	0007 Gyangtse	0007	0007	Line segment	Line segment	Test changed and held normal.

3(C) 66/33 KV Chhalla Substation													
No.	Date	Time	Start	End	Duration	Severity	Equipment	Location	Remarks	Impact			
1	03/2021	10:49	03/2021	10:51	0	0.7	22 KV's transformer 1	Chhalla substation and all outgoing feeders		Supply shut from Chhalla (not full) supply fed from Chhalla at 11:05hrs and change at 11:05hrs.			
2	09/2021	16:21				0.7	66KV Chhalla-Changphela Line	66KV Chhalla-Changphela Line	On Relay 7(N+1) Distance Protection Relay 21.1 General Trip 1 Distance Operated 3 Zone One Operated along with Tripping relay 00 operated. On Relay 7(N+1) General Trip 2 Distance Operated 3 Zone One Operated along with Tripping relay 00 operated. On Relay 7(N+1) Over Current and Earth Fault Protection Relay 20/21.1 General Trip 2 Earth Fault Operated 4.1000 used along with Tripping relay 00 operated.	IT part near Jorshing	The 66KV Chhalla-Changphela was tripped on distance relay, so the 66KV line was not changed owing to the indication and operation of relay. Operational personnel have seen that there was spark near the entry of 3 phase conductors during tripping happened. Shortcircuit followed to BPHO in this regard. Since parking could not proceed due to rain constraint, the 66KV line was kept under shut down. The next day following by TMSD line power.		
3	09/2021	16:21	09/2021	17:24	1		66KV Bus Coupler	Chhalla Substation	On Relay 7(N+1) Distance Protection Relay 21.1 General Trip 2 Distance Operated 3 Zone One Operated along with Tripping relay 00 operated.		Supply shut from 66KV Sonawala Line and 66KV Changphela Line		
4	09/2021	16:52	09/2021	17:21	0	14.8	66KV Sonawala-Chhalla Line	Chhalla substation and all outgoing feeders	On Relay 7(N+1) Distance Protection Relay 21.1 General Trip 2 Distance Operated 3 Zone One Operated along with Tripping relay 00 operated.		Supply shut from 66KV Sonawala Line and 66KV Changphela Line		
5	01/2021	16:52	01/2021	16:53	0	4.7	66KV Chhalla-Sonawala	Chhalla substation and all outgoing feeders	1100 operated		Feeder was tripped while Test charging of 66KV Chhalla-Changphela feeder which was under shutdown for changing of 3 phase conductors between dead and source and 66KV gentry at Chhalla substation. After receiving all relevant change the feeder and held normal.		
6	01/2021	16:52	01/2021	17:08	20	0.7	66KV Chhalla-Changphela Line	66KV Chhalla-Changphela Line	On DISTANCE PROTECT Relay 21.1 General Trip 2 Distance Operated 3 Zone 1 Operated along with Tripping relay 00 operated.	IT part	Shutdown taken by Durgale Wangchuk to provide routine string for long span ratio crossing and removal. As per Approval request no. 002/2020 for 18 7500/7500KVA/33KV/11KV-100 and approved on 05/08/2020. BPHO/PHO/VA/2021/115 Breaker open, line and bus insulator open and work started close at both Chhalla and Changphela and BPHO. Shutdown code 007/Shutdown was returned by Mr. Chhalla/Chhalla of 7500/Chhalla after changing of 3 phase conductors between dead and source and 66KV gentry at Chhalla substation. After receiving code no.2100 from BPHO/VA/2021/115 feeder was test charged but could not hold and tripped again. Feeder was kept shutdown for further line panning by line staff. After completion of work, changed the feeder with BPHO code no.2107 and held normal.		
7	01/2021	16:52	01/2021	16:59	0		66KV Bus Coupler	Chhalla Substation	DCASEE and Distance protection	Tripping relay 00	Chhalla-Changphela feeder	Temporary	Feeder was tripped while Test charging of 66KV Chhalla-Changphela feeder which was under shutdown for changing of 3 phase conductors between dead and source and 66KV gentry at Chhalla substation. After receiving all relevant change the feeder and held normal.
3(D) 66/33 KV S. Jorshing Substation													
1	07/07/2021	12:43hrs	07/07/2021	13:06hrs		-7.100	66KV LAA-Sonawala	NA	NA	NA	NA	NA	Feed fed from Sonawala (Phase/sequence inverter)
2	24/07/2021	00:15hrs	24/07/2021	01:23hrs		0.000	66KV Sonawala LAA	NA	Feed fed	NA	NA	NA	66KV LAA-Chhalla feeder tripped at 00:15hrs with one phase breaker is operated at 00:15hrs. Chhalla feeder tripped at 00:15hrs with one phase breaker is operated at 00:15hrs.
3	15/07/2021	11:45hrs	15/07/2021	11:48hrs		0.000	66KV LAA-Chhalla	NA	Control problem at	On 07/07/2021, 11:45hrs, 66KV LAA-Chhalla feeder tripped at 11:45hrs. Chhalla feeder tripped at 11:45hrs.	NA	NA	66KV LAA-Chhalla feeder tripped at 11:45hrs. Chhalla feeder tripped at 11:45hrs.
4	15/07/2021	10:00hrs	15/07/2021	17:00hrs		0.000	66KV LAA-Chhalla	NA	Control problem at	On 07/07/2021, 10:00hrs, 66KV LAA-Chhalla feeder tripped at 10:00hrs. Chhalla feeder tripped at 10:00hrs.	NA	NA	66KV LAA-Chhalla feeder tripped at 10:00hrs. Chhalla feeder tripped at 10:00hrs.
5	21/07/2021	11:15hrs	21/07/2021	11:17hrs		10.100	66KV LAA-Chhalla	NA	NA	On 07/07/2021, 11:15hrs, 66KV LAA-Chhalla feeder tripped at 11:15hrs. Chhalla feeder tripped at 11:15hrs.	NA	NA	66KV LAA-Chhalla feeder tripped at 11:15hrs. Chhalla feeder tripped at 11:15hrs.
6	24/07/2021	00:15hrs	24/07/2021	01:23hrs		0.000	66KV LAA-Chhalla	NA	Feed fed	NA	NA	NA	66KV LAA-Chhalla feeder tripped at 00:15hrs with one phase breaker is operated at 00:15hrs. Chhalla feeder tripped at 00:15hrs with one phase breaker is operated at 00:15hrs.
7	17/07/2021	08:00hrs	17/07/2021	14:10hrs		20.000	66KV LAA-Chhalla	NA	Shutdown	NA	NA	NA	66KV LAA-Chhalla feeder tripped at 08:00hrs. Chhalla feeder tripped at 08:00hrs.
3(E) 66/33 KV S. Jorshing Substation													
1	03/2021	13:07hrs	03/2021	13:07hrs	0	2.2	66KV Chhalla Line in	Chhalla all incoming and outgoing feeders	Tripped from chhalla				Feed failure from chhalla
2	09/2021	13:07hrs	09/2021	16:28hrs	0	2	66KV Chhalla Line in	Chhalla all incoming and outgoing feeders	Tripped from chhalla				
3(F) 66/33 KV Sonawala Substation													
1	01/07/2021	11:47	01/07/2021	14:30	0	-1.24	66 KV Changphela		Distance relay operated with auto reclose lock out.	Distance relay			TR 01 operation, TR 02 operation, TR 03 in broken, TR 04 not, TR 05 broken, TR 06 not, TR 07 broken, TR 08 not, TR 09 broken, TR 10 not, TR 11 not, TR 12 not, TR 13 not, TR 14 not, TR 15 not, TR 16 not, TR 17 not, TR 18 not, TR 19 not, TR 20 not, TR 21 not, TR 22 not, TR 23 not, TR 24 not, TR 25 not, TR 26 not, TR 27 not, TR 28 not, TR 29 not, TR 30 not, TR 31 not, TR 32 not, TR 33 not, TR 34 not, TR 35 not, TR 36 not, TR 37 not, TR 38 not, TR 39 not, TR 40 not, TR 41 not, TR 42 not, TR 43 not, TR 44 not, TR 45 not, TR 46 not, TR 47 not, TR 48 not, TR 49 not, TR 50 not, TR 51 not, TR 52 not, TR 53 not, TR 54 not, TR 55 not, TR 56 not, TR 57 not, TR 58 not, TR 59 not, TR 60 not, TR 61 not, TR 62 not, TR 63 not, TR 64 not, TR 65 not, TR 66 not, TR 67 not, TR 68 not, TR 69 not, TR 70 not, TR 71 not, TR 72 not, TR 73 not, TR 74 not, TR 75 not, TR 76 not, TR 77 not, TR 78 not, TR 79 not, TR 80 not, TR 81 not, TR 82 not, TR 83 not, TR 84 not, TR 85 not, TR 86 not, TR 87 not, TR 88 not, TR 89 not, TR 90 not, TR 91 not, TR 92 not, TR 93 not, TR 94 not, TR 95 not, TR 96 not, TR 97 not, TR 98 not, TR 99 not, TR 100 not, TR 101 not, TR 102 not, TR 103 not, TR 104 not, TR 105 not, TR 106 not, TR 107 not, TR 108 not, TR 109 not, TR 110 not, TR 111 not, TR 112 not, TR 113 not, TR 114 not, TR 115 not, TR 116 not, TR 117 not, TR 118 not, TR 119 not, TR 120 not, TR 121 not, TR 122 not, TR 123 not, TR 124 not, TR 125 not, TR 126 not, TR 127 not, TR 128 not, TR 129 not, TR 130 not, TR 131 not, TR 132 not, TR 133 not, TR 134 not, TR 135 not, TR 136 not, TR 137 not, TR 138 not, TR 139 not, TR 140 not, TR 141 not, TR 142 not, TR 143 not, TR 144 not, TR 145 not, TR 146 not, TR 147 not, TR 148 not, TR 149 not, TR 150 not, TR 151 not, TR 152 not, TR 153 not, TR 154 not, TR 155 not, TR 156 not, TR 157 not, TR 158 not, TR 159 not, TR 160 not, TR 161 not, TR 162 not, TR 163 not, TR 164 not, TR 165 not, TR 166 not, TR 167 not, TR 168 not, TR 169 not, TR 170 not, TR 171 not, TR 172 not, TR 173 not, TR 174 not, TR 175 not, TR 176 not, TR 177 not, TR 178 not, TR 179 not, TR 180 not, TR 181 not, TR 182 not, TR 183 not, TR 184 not, TR 185 not, TR 186 not, TR 187 not, TR 188 not, TR 189 not, TR 190 not, TR 191 not, TR 192 not, TR 193 not, TR 194 not, TR 195 not, TR 196 not, TR 197 not, TR 198 not, TR 199 not, TR 200 not, TR 201 not, TR 202 not, TR 203 not, TR 204 not, TR 205 not, TR 206 not, TR 207 not, TR 208 not, TR 209 not, TR 210 not, TR 211 not, TR 212 not, TR 213 not, TR 214 not, TR 215 not, TR 216 not, TR 217 not, TR 218 not, TR 219 not, TR 220 not, TR 221 not, TR 222 not, TR 223 not, TR 224 not, TR 225 not, TR 226 not, TR 227 not, TR 228 not, TR 229 not, TR 230 not, TR 231 not, TR 232 not, TR 233 not, TR 234 not, TR 235 not, TR 236 not, TR 237 not, TR 238 not, TR 239 not, TR 240 not, TR 241 not, TR 242 not, TR 243 not, TR 244 not, TR 245 not, TR 246 not, TR 247 not, TR 248 not, TR 249 not, TR 250 not, TR 251 not, TR 252 not, TR 253 not, TR 254 not, TR 255 not, TR 256 not, TR 257 not, TR 258 not, TR 259 not, TR 260 not, TR 261 not, TR 262 not, TR 263 not, TR 264 not, TR 265 not, TR 266 not, TR 267 not, TR 268 not, TR 269 not, TR 270 not, TR 271 not, TR 272 not, TR 273 not, TR 274 not, TR 275 not, TR 276 not, TR 277 not, TR 278 not, TR 279 not, TR 280 not, TR 281 not, TR 282 not, TR 283 not, TR 284 not, TR 285 not, TR 286 not, TR 287 not, TR 288 not, TR 289 not, TR 290 not, TR 291 not, TR 292 not, TR 293 not, TR 294 not, TR 295 not, TR 296 not, TR 297 not, TR 298 not, TR 299 not, TR 300 not, TR 301 not, TR 302 not, TR 303 not, TR 304 not, TR 305 not, TR 306 not, TR 307 not, TR 308 not, TR 309 not, TR 310 not, TR 311 not, TR 312 not, TR 313 not, TR 314 not, TR 315 not, TR 316 not, TR 317 not, TR 318 not, TR 319 not, TR 320 not, TR 321 not, TR 322 not, TR 323 not, TR 324 not, TR 325 not, TR 326 not, TR 327 not, TR 328 not, TR 329 not, TR 330 not, TR 331 not, TR 332 not, TR 333 not, TR 334 not, TR 335 not, TR 336 not, TR 337 not, TR 338 not, TR 339 not, TR 340 not, TR 341 not, TR 342 not, TR 343 not, TR 344 not, TR 345 not, TR 346 not, TR 347 not, TR 348 not, TR 349 not, TR 350 not, TR 351 not, TR 352 not, TR 353 not, TR 354 not, TR 355 not, TR 356 not, TR 357 not, TR 358 not, TR 359 not, TR 360 not, TR 361 not, TR 362 not, TR 363 not, TR 364 not, TR 365 not, TR 366 not, TR 367 not, TR 368 not, TR 369 not, TR 370 not, TR 371 not, TR 372 not, TR 373 not, TR 374 not, TR 375 not, TR 376 not, TR 377 not, TR 378 not, TR 379 not, TR 380 not, TR 381 not, TR 382 not, TR 383 not, TR 384 not, TR 385 not, TR 386 not, TR 387 not, TR 388 not, TR 389 not, TR 390 not, TR 391 not, TR 392 not, TR 393 not, TR 394 not, TR 395 not, TR 396 not, TR 397 not, TR 398 not, TR 399 not, TR 400 not, TR 401 not, TR 402 not, TR 403 not, TR 404 not, TR 405 not, TR 406 not, TR 407 not, TR 408 not, TR 409 not, TR 410 not, TR 411 not, TR 412 not, TR 413 not, TR 414 not, TR 415 not, TR 416 not, TR 417 not, TR 418 not, TR 419 not, TR 420 not, TR 421 not, TR 422 not, TR 423 not, TR 424 not, TR 425 not, TR 426 not, TR 427 not, TR 428 not, TR 429 not, TR 430 not, TR 431 not, TR 432 not, TR 433 not, TR 434 not, TR 435 not, TR 436 not, TR 437 not, TR 438 not, TR 439 not, TR 440 not, TR 441 not, TR 442 not, TR 443 not, TR 444 not, TR 445 not, TR 446 not, TR 447 not, TR 448 not, TR 449 not, TR 450 not, TR 451 not, TR 452 not, TR 453 not, TR 454 not, TR 455 not, TR 456 not, TR 457 not, TR 458 not, TR 459 not, TR 460 not, TR 461 not, TR 462 not, TR 463 not, TR 464 not, TR 465 not, TR 466 not, TR 467 not, TR 468 not, TR 469 not, TR 470 not, TR 471 not, TR 472 not, TR 473 not, TR 474 not, TR 475 not, TR 476 not, TR 477 not, TR 478 not, TR 479 not, TR 480 not, TR 481 not, TR 482 not, TR 483 not, TR 484 not, TR 485 not, TR 486 not, TR 487 not, TR 488 not, TR 489 not, TR 490 not, TR 491 not, TR 492 not, TR 493 not, TR 494 not, TR 495 not, TR 496 not, TR 497 not, TR 498 not, TR 499 not, TR 500 not, TR 501 not, TR 502 not, TR 503 not, TR 504 not, TR 505 not, TR 506 not, TR 507 not, TR 508 not, TR 509 not, TR 510 not, TR 511 not, TR 512 not, TR 513 not, TR 514 not, TR 515 not, TR 516 not, TR 517 not, TR 518 not, TR 519 not, TR 520 not, TR 521 not, TR 522 not, TR 523 not, TR 524 not, TR 525 not, TR 526 not, TR 527 not, TR 528 not, TR 529 not, TR 530 not, TR 531 not, TR 532 not, TR 533 not, TR 534 not, TR 535 not, TR 536 not, TR 537 not, TR 538 not, TR 539 not, TR 540 not, TR 541 not, TR 542 not, TR 543 not, TR 544 not, TR 545 not, TR 546 not, TR 547 not, TR 548 not, TR 549 not, TR 550 not, TR 551 not, TR 552 not, TR 553 not, TR 554 not, TR 555 not, TR 556 not, TR 557 not, TR 558 not, TR 559 not, TR 560 not, TR 561 not, TR 562 not, TR 563 not, TR 564 not, TR 565 not, TR 566 not, TR 567 not, TR 568 not, TR 569 not, TR 570 not, TR 571 not, TR 572 not, TR 573 not, TR 574 not, TR 575 not, TR 576 not, TR 577 not, TR 578 not, TR 579 not, TR 580 not, TR 581 not, TR 582 not, TR 583 not, TR 584 not, TR 585 not, TR 586 not, TR 587 not, TR 588 not, TR 589 not, TR 590 not, TR 591 not, TR 592 not, TR 593 not, TR 594 not, TR 595 not, TR 596 not, TR 597 not, TR 598 not, TR 599 not, TR 600 not, TR 601 not, TR 602 not, TR 603 not, TR 604 not, TR 605 not, TR 606 not, TR 607 not, TR 608 not, TR 609 not, TR 610 not, TR 611 not, TR 612 not, TR 613 not, TR 614 not, TR 615 not, TR 616 not, TR 617 not, TR 618 not, TR 619 not, TR 620 not, TR 621 not, TR 622 not, TR 623 not, TR 624 not, TR 625 not, TR 626 not, TR 627 not, TR 628 not, TR 629 not, TR 630 not, TR 631 not, TR 632 not, TR 633 not, TR 634 not, TR 635 not, TR 636 not, TR 637 not, TR 638 not, TR 639 not, TR 640 not, TR 641 not, TR 642 not, TR 643 not, TR 644 not, TR 645 not, TR 646 not, TR 647 not, TR 648 not, TR 649 not, TR 650 not, TR 651 not, TR 652 not, TR 653 not, TR 654 not, TR 655 not, TR 656 not, TR 657 not, TR 658 not, TR 659 not, TR 660 not, TR 661 not, TR 662 not, TR 663 not, TR 664 not, TR 665 not, TR 666 not, TR 667 not, TR 668 not, TR 669 not, TR 670 not, TR 671 not, TR 672 not, TR 673 not, TR 674 not, TR 675 not, TR 676 not, TR 677 not, TR 678 not, TR 679 not, TR 680 not, TR 681 not, TR 682 not, TR 683 not, TR 684 not, TR 685 not, TR 686 not, TR 687 not, TR 688 not, TR 689 not, TR 690 not, TR 691 not, TR 692 not, TR 693 not, TR 694 not, TR 695 not, TR 696 not, TR 697 not, TR 698 not, TR 699 not, TR 700 not, TR 701 not, TR 702 not, TR 703 not, TR 704 not, TR 705 not, TR 706 not, TR 707 not, TR 708 not, TR 709 not, TR 710 not, TR 711 not, TR 712 not, TR 713 not, TR 714 not, TR 715 not, TR 716 not, TR 717 not, TR 718 not, TR 719 not, TR 720 not, TR 721 not, TR 722 not, TR 723 not, TR 724 not, TR 725 not, TR 726 not, TR 727 not, TR 728 not, TR 729 not, TR 730 not, TR 731 not, TR 732 not, TR 733 not, TR 734 not, TR 735 not, TR 736 not, TR 737 not, TR 738 not, TR 739 not, TR 740 not, TR 741 not, TR 742 not, TR 743 not, TR 744 not, TR 745 not, TR 746 not, TR 747 not, TR 748 not, TR 749 not, TR 750 not, TR 751 not, TR 752 not, TR 753 not, TR 754 not, TR 755 not, TR 756 not, TR 757 not, TR 758 not, TR 759 not, TR 760 not, TR 761 not, TR 762 not, TR 763 not, TR 764 not, TR 765 not, TR 766 not, TR 767 not, TR 768 not, TR 769 not, TR 770 not, TR 771 not, TR 772 not, TR 773 not, TR 774 not, TR 775 not, TR 776 not, TR 777 not, TR 778 not, TR 779 not, TR 780 not, TR 781 not, TR 782 not, TR 783 not, TR 784 not, TR 785 not, TR 786 not, TR 787 not, TR 788 not, TR 789 not, TR 790 not, TR 791 not, TR 792 not, TR 793 not, TR 794 not, TR 795 not, TR 796 not, TR 797 not, TR 798 not, TR 799 not, TR 800 not, TR 801 not, TR 802 not, TR 803 not, TR 804 not, TR 805 not, TR 806 not, TR 807 not, TR 808 not, TR 809 not, TR 810 not, TR 811 not, TR 812 not, TR 813 not, TR 814 not, TR 815 not, TR 816 not, TR 817 not, TR 818 not, TR 819 not, TR 820 not, TR 821 not, TR 822 not, TR 823 not, TR 824 not, TR 825 not, TR 826 not, TR 827 not, TR 828 not, TR 829 not, TR 830 not, TR 831 not, TR 832 not, TR 833 not, TR 834 not, TR 835 not, TR 836 not, TR 837 not, TR 838 not, TR 839 not, TR 840 not, TR 841 not, TR 842 not, TR 843 not, TR 844 not, TR 845 not, TR 846 not, TR 847 not, TR 848 not, TR 849 not, TR 850 not, TR 851 not, TR 852 not, TR 853 not, TR 854 not, TR 855 not, TR 856 not, TR 857 not, TR 858 not, TR 859 not, TR 860 not, TR 861 not, TR 862 not, TR 863 not, TR 864 not, TR 865 not, TR 866 not, TR 867 not, TR 868 not, TR 869 not, TR 870 not, TR 871 not, TR 872 not, TR 873 not, TR 874 not, TR 875 not, TR 876 not, TR 877 not, TR 878 not, TR 879 not, TR 880 not, TR 881 not, TR 882 not, TR 883 not, TR 884 not, TR 885 not, TR 886 not, TR 887 not, TR 888 not, TR 889 not, TR 890 not, TR 891 not, TR 892 not, TR 893 not, TR 894 not, TR 895 not, TR 896 not, TR 897 not, TR 898 not, TR 899 not, TR 900 not, TR 901 not, TR 902 not, TR 903 not, TR 904 not, TR 905 not, TR 906 not, TR 907 not, TR 908 not, TR 909 not, TR 910 not, TR 911 not, TR 912 not, TR 913 not, TR 914 not, TR 915 not, TR 916 not, TR 917 not, TR 918 not, TR 919 not, TR 920 not, TR 921 not, TR 922 not, TR 923 not, TR 924 not, TR 925 not, TR 926 not, TR 927 not, TR 928 not, TR 929 not, TR 930 not, TR 931 not, TR 932 not, TR 933 not, TR 934 not, TR 935 not, TR 936 not, TR 937 not, TR 938 not, TR 939 not, TR 940 not, TR 941 not, TR 942 not, TR 943 not, TR 944 not, TR 945 not, TR 946 not, TR 947 not, TR 948 not, TR 949 not, TR 950 not, TR 951 not, TR 952 not, TR 953 not, TR 954 not, TR 955 not, TR 956 not, TR 957 not, TR 958 not, TR 959 not, TR 960 not, TR 961 not, TR 962 not, TR 963 not, TR 964 not, TR 965 not, TR 966 not, TR 967 not, TR 968 not, TR 969 not, TR 970 not, TR 971 not, TR 972 not, TR 973 not, TR 974 not, TR 975 not, TR 976 not, TR 977 not, TR 978 not, TR 979 not, TR 980 not, TR 981 not, TR 982 not, TR 983 not, TR 984 not, TR 985 not, TR 986 not, TR 987 not, TR 988 not, TR 989 not, TR 990 not, TR 991 not, TR 992 not, TR 993 not, TR 994 not, TR 995 not, TR 996 not, TR 997 not, TR 998 not, TR 999 not, TR 1000 not, TR 1001 not, TR 1002 not, TR 1003 not, TR 1004 not, TR 1005 not, TR 1006 not, TR 1007 not, TR 1008 not, TR 1009 not, TR 1010 not, TR 1011 not, TR 1012 not, TR 1013 not, TR 1014 not, TR 1015 not, TR 1016 not, TR 1017 not, TR 1018 not, TR 1019 not, TR 1020 not, TR 1021 not, TR 1022 not, TR 1023 not, TR 1024 not, TR 1025 not, TR 1026 not, TR 1027 not, TR 1028 not, TR 1029 not, TR 1030 not, TR 1031 not, TR 1032 not, TR 1033 not, TR 1034 not, TR 1035 not, TR 1036 not, TR 1037 not, TR 1038 not, TR 1039 not, TR 1040 not, TR 1041 not, TR 1042 not, TR 1043 not, TR 1044 not, TR 1045 not, TR 1046 not, TR 1047 not, TR 1048 not, TR 1049 not, TR 1050 not, TR 1051 not, TR 1052 not, TR 1053 not, TR 1054 not, TR 1055 not, TR 1056 not, TR 1057 not, TR 1058 not, TR 1059 not, TR 1060 not, TR 1061 not, TR 1062 not, TR 1063 not, TR 1064 not, TR 1065 not, TR 1066 not, TR 1067 not, TR 1068 not, TR 1069 not, TR 1070 not, TR 1071 not, TR 1072 not, TR 1073 not, TR 1074 not, TR 1075 not, TR 1076 not, TR 1077 not, TR 1078 not, TR 1079 not, TR 1080 not, TR 1081 not, TR 1082 not, TR 1083 not, TR 1084 not, TR 1085 not, TR 1086 not, TR 1087 not, TR 1088 not, TR 1089 not, TR 1090 not, TR 1091 not, TR 1092 not, TR 1093 not, TR 1094 not, TR 1095 not, TR 1096 not, TR 1097 not, TR 1098 not, TR 1099 not, TR 1100 not, TR 1101 not, TR 1102 not, TR 1103 not, TR 1104 not, TR 1105 not, TR 1106 not, TR 1107 not, TR 1108 not, TR 1109 not, TR 1110 not, TR 1111 not, TR 1112 not, TR 1113 not, TR 1114 not, TR 1115 not, TR 1116 not, TR 1117 not, TR 1118 not, TR 1119 not, TR 1120 not, TR 1121 not, TR 1122 not, TR 1123 not, TR 1124 not, TR 1125 not, TR 1126 not, TR 1127 not, TR 1128 not, TR 1129 not, TR 1130 not, TR 1131 not, TR 1132 not, TR 1133 not, TR 1134 not, TR 1135 not, TR 1136 not, TR 1137 not, TR 1138 not, TR 1139 not, TR 1140 not, TR 1141 not, TR 1142 not, TR 1143 not, TR 1144 not, TR 1145 not, TR 1146 not, TR 1147 not, TR 1148 not, TR 1149 not, TR 1150 not, TR 1151 not, TR 1152 not, TR 1153 not, TR 1154 not, TR 1155 not, TR 1156 not, TR 1157 not, TR 1158 not, TR 1159 not, TR 1160 not, TR 1161 not, TR 1162 not, TR 1163 not, TR 1164 not, TR 1165 not, TR 1166 not, TR 1167 not, TR 1168 not, TR 1169 not, TR 1170 not, TR 1171 not, TR 1172 not, TR 1173 not, TR 1174 not, TR 1175 not, TR 1176 not, TR 1177 not, TR 1178 not, TR 1179 not, TR 1180 not, TR 1181 not, TR 1182 not, TR 1183 not, TR 1184 not, TR 1185 not, TR 1186 not, TR 1187 not, TR 1188 not, TR 1189 not, TR 1190 not, TR 1191 not, TR 1192 not, TR 1193 not, TR 1194 not, TR 1195 not, TR 1196 not, TR 1197 not, TR 1198 not, TR 1199 not, TR 1200 not, TR 1201 not, TR 1202 not, TR 1203 not, TR 1204 not, TR 1205 not, TR 12

DZAK/ST/11V Paogha substation										
1	20.05.2021	16.05/06	20.05.2021	16.22/06	9	2.2	98KV DG Bus Breaker	Bus	04V	Transmission
(A) 98.7KV 4 Core High Voltage Substation										
1	09.05.2021	16.23/06	12.05.2021	17.08/06	71	-1.82	98KV Challa-Changdaphu Line	Changdaphu and Challa in	Right conductor sagged and got contact with Tyle conductor	Revised near IT park
2	04.05.2021	08.18/06	04.05.2021	14.05/06	10.00	-0.88	98KV Challa-Changdaphu Line	Changdaphu and Challa in	No indication	Prevention
3	08.05.2021	14.18/06	11.05.2021	17.18/06	09.00	-1.91	98KV Challa-Changdaphu Line	98KV Challa-Changdaphu Line	Shortcircuit near to TMSD in vicinity Right conductor near IT park Station	
4	11.05.2021	08.17/06	11.05.2021	17.18/06	8.00	-1.02	98KV Challa-Changdaphu Line	98KV Challa-Changdaphu Line	Annual Maintenance of the line to TMSD	
5	14.05.2021	08.18/06	14.05.2021	14.05/06	10.00	0.61	98KV Challa-Changdaphu Line	98KV Challa-Changdaphu Line	Annual Maintenance of the line to TMSD	
6	17.05.2021	08.17/06	17.05.2021	14.27/06	10.00		98KV Challa-Changdaphu Line	98KV Challa-Changdaphu Line	Annual Maintenance of the line to TMSD	None Available
(B) 98.7KV Busbar Substation										
1	01.05.2021	11.18/06	01.05.2021	11.05/06	0	-0.8	98.7KV Incoming Line		Changes	Changes of 98KV line from 230kg ACSR to 98KV ACSR from the system

June 2021

Sl No.	Date of Tripping	Time of outages	Date of Normalization	Time of fault was cleared	Duration of Outages (Hrs)	MW before outage (MW)	Feeder Name	Name of the Substation/lines affected by the fault	Reasons of fault	Relay operations	Exact location of fault [Line segment/ Substation]	Type of outages	Remarks
(A) 400/220/66/11 KV Malhae Substation													
66kV & Above													
1	01.06.2021	22:50	02.06.2021	1:42	1	21	50/63MVA Transformer I	Malhae s/s	Overcurrent	General trip, LBB trip, BK opnd, S1 trip.	66KV Piling line	Overcurrent fault	IL1-750.97A--1.97 deg, IL2-750.2A--129.4deg, IL3-733.86A--114.7deg,IL4-22.13A--127.04deg, Note: Due to permanent fault in piling line, Feeders connected to the same bus of it could not withstand while test changed. After knowing the fault and isolating piling line only we could charged rest of the feeders.
2	01.06.2021	22:50	02.06.2021	1:45	1	21	66KV Pasakha Feeder 1	Malhae S/S	Overcurrent	SB trip, BK opnd, General trip.	66KV Piling line	Overcurrent fault	IL1-991.76A--0.99 deg, IL2-1326A--134deg, IL3-1164A--135.43deg,IL4-435.4A-5.36deg
3	01.06.2021	22:50	02.06.2021	1:45	23	-	66KV Bus Coupler	Malhae S/S	Earth fault	-	66KV Piling line	E/C & E/F	IL1-7491.81A--04.3 deg, IL2-140.5A-135.9deg, IL3-138.67A--91.5deg,IL4-7437.5A--84.27deg
4	05.06.2021	20:37	05.06.2021	20:42	0	81	200MVA ICT	Malhae S/S	Earth fault	67/67N opnd and BK opnd	-	E/C & E/F	4I PHASE A(FW0)-L5- 05MT1, 5A-1062A, PHASE B (FW0) 51.66A, PHASE (FW0) C- 112.7A, E/F (FW0) 05MT1, 5E-974.5A
5	05.06.2021	20:37	05.06.2021	20:45	0	21	50/63MVA Transformer III	Malhae S/S	Overcurrent	OLTC-BOCH trip	-	-	IL1-29.1A--99.23 deg, IL2-69.09A--176.79deg, IL3-321.28A--126.75deg,IL4-189.78A-139.8deg
6	06.06.2021	23:20	06.06.2021	23:29	0	20	50/63MVA Transformer I	Malhae S/S	Overcurrent	LBB trip, General trip, BK B opnd	66KV Piling line	Overcurrent fault	IL1-748A--3.29 deg, IL2-694.51A-133.45deg, IL3-393A-137.94deg,IL4-614A-117.75deg
7	06.06.2021	23:20	06.06.2021	23:31	0	20	66 KV Pasakha Feeder 1	Malhae S/S	Overcurrent	General trip, KOC SB trip, BK trip	66KV Piling line	Overcurrent fault	IL1-549A-10.19deg, IL2-175.3A-139.15deg, IL3-209.96A-136.42deg,IL4-171.57A--130.2deg
8	06.06.2021	23:20	06.06.2021	23:26	0	-	220KV Bus Coupler	Malhae S/S	Overcurrent	SPA1 140C relay opnd I- trip.	66KV Piling line	Overcurrent fault	Bus coupler tripped due to arch from 66KV side.
9	06.06.2021	23:20	06.06.2021	23:30	0	-	66KV Bus Coupler	Malhae S/S	E/F	KOC trip, General trip, IEF 50N trip	66KV Piling line	Overcurrent fault	IL1-7695.44A--21.75deg, IL2-290.56A--17.36deg, IL3-68.15A--33.43deg,IL4-7695A--21.75deg
10	12.06.2021	9:19	12.06.2021	9:24	0	24	66 KV Pasakha Feeder IV	Malhae S/S	E/F	General trip, HF 50N trip, BK opnd.	66KV Pasakha IV line	E/F	IL1-2427.31A--45.6deg, IL2-271.05A--74.9deg, IL3-346.6A-96.27deg,IL4-2538.37A-133.02deg
11	12.06.2021	9:19	12.06.2021	9:24	0	24	66 KV Pasakha Feeder II	Malhae S/S	Overcurrent	General trip, HF 50N trip, BK opnd.	66KV Pasakha II line	Overcurrent fault	IL1-8.27A-40.72deg, IL2-1231.4A--5.79deg, IL3-768.96A-56.09deg
12	12.06.2021	9:19	12.06.2021	9:24	0	25	66 KV Pasakha Feeder IV	Malhae S/S	Overcurrent	General trip, HF 50N trip, BK opnd., KOC 50-trip.	66KV Pasakha IV line	Overcurrent fault	IL1-3111.43A--51.27deg, IL2-601.95A-166.54deg, IL3-279.73A-120.4deg
13	19.06.2021	21:18	19.06.2021	21:25	0	23	66 KV Pasakha Feeder I	Malhae S/S	E/F	General trip, HF 50N trip, BK opnd.	66 KV Pasakha Feeder I line	E/F	IL1-2592.88A--47.93deg, IL2-299.68A--94.45deg, IL3-151.76A-127.77deg,IL4-2651.87A-127.77deg
14	19.06.2021	21:18	19.06.2021	21:25	0	23	66 KV Pasakha Feeder II	Malhae S/S	Overcurrent	General trip, HF 50N trip, BK opnd.	66 KV Pasakha Feeder II line	Overcurrent fault	IL1-8.32A--140.09deg, IL2-1299.73A--147.96deg, IL3-848.96A--131.43deg
15	19.06.2021	21:18	19.06.2021	21:25	0	24	66 KV Pasakha Feeder IV	Malhae S/S	Overcurrent	General trip, HF 50N trip, BK opnd.	66KV Pasakha IV line	Overcurrent fault	IL1-911.37A--31.23deg, IL2-304.4A-146.04deg, IL3-613.75A-104.45deg
16	19.06.2021	21:18	19.06.2021	21:25	0	-	66KV Bus Coupler	Malhae S/S	E/F	General trip.	-	E/F	IL1-1437.31A--46.94deg, IL2-467.77A--31.36deg, IL3-330.93A--66.28deg,IL4-2226.45A-31.4deg
17	22.06.2021	20:30	22.06.2021	20:39	0	79	200MVA ICT	Malhae S/S	Overcurrent	67/67N opnd and BK opnd.	-	-	PHASE A(FW0)-L5- 30MT1, 3A-1190A, PHASE B (FW0) 50- 346.3A, PHASE (FW0) C- 141.8A, E/F (FW0) 30MT1, 3E-923.4A, IL3-21A-371.66deg, IL2-121.64A-133.83deg, IL3-59.47A--175.64deg,IL4-106.2A--130.46deg
18	22.06.2021	20:30	22.06.2021	20:43	0	27	50/63MVA Transformer III	Malhae S/S	-	Dfll trip	-	-	IL3-59.47A--175.64deg,IL4-106.2A--130.46deg
19	22.06.2021	20:30	22.06.2021	20:53	0	51	220KV Bixpara Feeder	Malhae S/S & Bixpara line	Overcurrent	Zone 1 trip, BK-OPTD.	18.77 km	Overcurrent fault	IL1-4413kA, IL2-379.7A, IC -5.197kA
(B) 220/66/11 kV Singhiqeen Substation													
1	05.06.2021	20:37	05.06.2021	21:07	0	7	220KV Samshe Feeder	GS, Singhiqeen s/s	E/F	O/C trip, BK trip.	Samshe line	E/F	IL1-5006 A, IL2-64.75A, IL3-61.95A, IL4-8066A
2	12.06.2021	9:19	12.06.2021	9:29	0	5	66KV Bhoten Concept & Drak Lamsat Feeder	GS, Singhiqeen s/s	Overcurrent	General trip, E/C trip, IE-- trip, E-- Directional trip, BEP Directional Trip.	-	Overcurrent Fault	IL1-5.24kA, IL2-6.42kA, IL3-6.22kA
3	19.06.2021	21:18	19.06.2021	21:27	0	1	66KV Bhoten Concept & Drak Lamsat Feeder	GS, Singhiqeen s/s	Overcurrent	I--O Directional trip, General trip.	-	Overcurrent Fault	IL1-5.20kA, IL2-6.42kA, IL3-6.20kA

B) 66/33/11 kV Phuntsholing Substation													
1			04.06.2021	9:00	9	idle	66kV Malhaase-Fling feeder	66kV Malhaase-Fling feeder			In 09:00hrs issued shutdown to Signe Gyelag, Sr Engineer, TMD Fling with work permit no 822 for re-string snapped conductor between location PS-3 & PS-4. After completion of work at 10:30hrs CE closed from Malhaase end and 66kV Malhaase-Fling feeder kept under idle position.		
2			05.06.2021	11:27	11	idle	66kV Malhaase-Fling feeder	66kV Malhaase-Fling feeder			At 11:27hrs charged 66kV Fling-Malhaase feeder which was under idle condition with charging code 3835 as per instruction from BPSO for supply reliability at Fling to [] since 66kV Chokha Fling feeder taken shutdown by Gentsu substation for rectification of insulators at Gentsu substation. At 13:45hrs opened CE of 66kV Fling-Malhaase feeder after getting clearance from BPSO with opening code 0008 and again the feeder was kept under idle condition.		
			08.06.2021	10:00			66kV Malhaase-Fling feeder	66kV Malhaase-Fling feeder	Line		66kV Malhaase Fling feeder test charged with charging code 3279 for checking the healthiness of line as per instructions from BPSO. At 10:30hrs opened CE of said feeder as per instruction from BPSO with opening code 0017.		
##			20.06.2021	17:37	17	idle	66kV Malhaase-Fling feeder	66kV Malhaase-Fling feeder	Line		66kV Malhaase Fling feeder test charged with charging code 1733 from from BPSO, since there was shutdown on 66kV Chokha-Fling feeder. At 18:44hrs opened CE of said feeder as per instruction from BPSO with opening code 0075.		
##	30.06.2021	2.06	30.06.2021	12:00	19	0.90	66kV Fling-Gentsu feeder	66kV Fling-Gentsu feeder		DSTN OPTD, 186404	Gentsu substation	66kV Fling-Gentsu feeder tripped at our end and 66kV Chokha-Fling feeder got tripped at their end causing blackout at Fling. At 02:09hrs supply was extended from Malhaase substation after informing to BPSO. At 02:25hrs 66kV Chokha-Fling feeder normalised from chokha end. 66kV Fling-Gentsu fbr taken shutdown by Gentsu substation since jumper conductor got snapped at Gentsu as end. After completion rectification works at Gentsu at 12:00hrs 66kV Fling-Gentsu feeder normalised with charging code 1283 from Gentsu substation. Opened CE of 66kV Malhaase-Fling with opening code 0186 from BPSO and feeder was kept under idle charged.	
C) 66/33/11 kV Gentsu Substation													
1	03.06.2021	13:29	03.06.2021	13:32	0	0.17	66/33/11kV SMYA Tr III	33kV Goringlana-II		REF	Substation	Charged the Transformer after isolating the out going feeder. 33kV Goringlana feeder-II was charged from 33kV Goringlana feeder-I.	
2	04.06.2021	9:35	20.06.2021	22:00	12	0.13	66/33/11kV SMYA Tr III	Nil	Insulator alignment problem and oil filtration.		Substation	Shutdown	Work permit No. 71 issued to Mrs. Rinchen Zangmo, Sr. Engineer of SMD Fling to carry out HV insulator alignment problem and to perform oil filtration.
3	05.06.2021	11:36	05.06.2021	13:50	2	0.18	66/33/11kV SMYA Tr III	Nil	Insulator alignment problem.		Substation	Shutdown	Work permit No. 72 issued to Mrs. Rinchen Zangmo, Sr. Engineer of SMD Fling to carry out HV insulator alignment problem on TMVA 66/33kV transformer-II.
4	07.06.2021	18:30	07.06.2021	20:33	2	1.16	66kV Chokha -Fling Line	Black out	Rectification of insulator alignment.		Substation		For rectification of TMVA transformer-II HV side insulator alignment.
5	08.06.2021	10:17	08.06.2021	12:33	0	1.30	66kV Chokha -Fling Line	Black out	Rectification of insulator alignment.		Substation		For rectification of TMVA transformer-II HV side insulator alignment.
6	17.06.2021	12:52	23.06.2021	11:30	372	1.6	SMYA 66/11kV Tr-II	Nil	Oil filtration		Substation	Shutdown	Work permit No. 76 issued to Mrs. Rinchen Zangmo Sr. Engineer of SMD Fling for transformer oil filtration.
7	20.06.2021	18:00	20.06.2021	18:40	0	1.40	66kV Chokha -Fling Line	Black out	Rectification of insulator alignment.		Substation		For rectification of SMVA transformer-II HV side insulator alignment.
8	21.06.2021	12:27	26.06.2021	14:05	122	0.34	SMVA 66/33kV Tr-I	Nil	Oil filtration		Substation	Shutdown	Work permit No. 77 issued to Mrs. Rinchen Zangmo Sr. Engineer of SMD Fling for transformer oil filtration.
9	23.06.2021	11:17	27.06.2021	16:57	101	0.79	SMYA 66/11kV Tr-I	Nil	Oil filtration		Substation	Shutdown	Work permit No. 78 issued to Mrs. Rinchen Zangmo Sr. Engineer of SMD Fling for transformer oil filtration.
10	26.06.2021	14:30	27.06.2021	11:54	21	0.43	66/33/11kV SMYA Tr III	Nil	Oil filtration		Substation	Shutdown	Work permit No 79 issued to Mrs Rinchen Zangmo, Sr Engineer for oil filtration on O/L DC.
11	30.06.2021	2:06	30.06.2021	2:10	0	0.51	66kV Chokha -Fling Line	Black out			Line		Supply charged from Phuntsholing end.
D) 66/33/11kV Gentsu Substation													
1	30.06.2021	2:06	30.06.2021	02:41	0	-0.301	Shutdown	Whole Gentsu	NA	NA	Gentsu Sub Station		Supply failed from Obasendum Sub Station.
2	30.06.2021	2:06	30.06.2021	12:00	10	0.24	Gentsu P/Ling	Nil	Over Current	ISWTL Over Current 0144.5180.21CX	Gentsu Sub Station		T phase conductor between Ware trap and Line insulator burned to dead.
E) 220/66/33 kV Obasendum Substation 220kV													
1	05.06.2021	20:37	05.06.2021	20:44	0	-4.74	220kV Nagayagan	N/A	Transient fault	REL670 General trip, Zone-L, B, Ph	N/A	N/A	220kV Nagayagan feeder tripped from both the end and charge at 20:44hrs as per the clearance given by BPSO, T/yjts. Dist. Showing 19.56kva and 48.90% and C/R closed from Malhaase end at 21:07 hrs.
2	30.06.2021	2:06	30.06.2021	2:41	0	0.25	66kV Gentsu feeder	Gentsu	Transient fault	REF615-DRO/C67 Trip, R,Y,B Ph fault	N/A	N/A	66kV Gentsu Feeder feeder tripped at both the ends at 02:00hrs and charged at 02:41 hrs as per the charging code No 1280 by Phub Zangmo, BPSO Thimphu.

July 2021

Sl No.	Date of Tripping	Time of outages	Date of Normalization	Time of fault was cleared	Duration of Outages (Hrs)	MW before outage (MW)	Feeder Name	Name of the Substation/Lines affected by the fault	Reasons of fault	Relay operations	Exact location of fault (Line segment/ Substation)	Type of outages	Remarks
(A) 400/220/66/11 kV Malhaese Substation													
66kV & Above													
1	24.07.2021	18:28	24.07.2021	21:49	3	22	50 MVA Transformer EI	Malhaese S/S	Inter Tripped as 400kV sagged and touched on the 66kV Multicircuit feeder going towards Industrial State	86, RET 670	fault on 66kV multicircuit Line.	Overcurrent	I1=469.31A, I2=58.87A, I3=92.20A, I4=309.75A
2	28.07.2021	18:28	24.07.2021	18:42	0	40	200MVA ICT	Malhaese S/S		87/67N,86	fault on 66kV multicircuit Line.	Overcurrent	I1=1629A, I2=184.573A, I3=400A, I4=576.68A
3	24.07.2021	18:28	30.07.2021	12:44	130	20	66 kV Pasakha I	Malhaese S/S		86 operated, ROC-50- trip, IEF-50N-TRIP	fault on 66kV multicircuit Line.	Overcurrent	I1=6075A, I2=322.2A, I3=124.71A, I4= 137.63.
4	24.07.2021	18:28	30.07.2021	12:44	130	20	66 kV Pasakha II	Malhaese S/S		86 operated, ROC-50- trip, IEF-50N-TRIP	fault on 66kV multicircuit Line.	Overcurrent	I1=0.16A, I2=454.65A, I3=166.36A,
5	24.07.2021	18:28	30.07.2021	12:45	130	20	66 kV Pasakha IV	Malhaese S/S		86 operated, General trip IEF directional trip	fault on 66kV multicircuit Line.	Overcurrent	I1=1048.38A, I2=239.34A, I3=511.47A,
(B) 66/33/11 kV Phoocholing Substation													
1	24.07.2021	15:30	24.07.2021	18:54	3	0.75	66kV Plog-Gonets feeder	66kV Plog-Gonets feeder		DITN OPTD, 106686 fault imp= 34.3, fault angle=27, fault current=2.07A, fault location=49.0	Line		66kV Plog-Gonets feeder tripped at our end. At 18:34hrs test charged after getting clearance from BP50 but got tripped on same fault. Informed to BP50. At 18:54hrs charged after getting clearance from BP50 after opening CB from Gonets end and stand normal.
(C) 66/33/11 kV Gonets Substation													
1	24.07.2021	18:30	24.07.2021	18:55	0	-0.81	66kV Gonets-F/ling	Whole Gonets	Grid failed	Distance and over current	Malhaese		Distance relay and over current relay opnd. at F/ling Substation.
2	24.07.2021	18:30	24.07.2021	18:59	0	-3.765	66kV Dhandum	Whole Gonets	Grid failed	NA	Malhaese		Charged after the given instruction from BP50.
(D) 220/66/33 kV Dhandum Substation													
220kV													
1	24.07.2021	18:30	24.07.2021	19:05	0	-7.33	220kV Malhaese	220kV Malhaese	Line fault	NA	Malhaese	N/A	220kV Malhaese-Dhandum line 220 kV singeygnas-Dhandum feeder got tripped from Malhaese substation. We were informed that the Conductor has snap and fallen on the Multicircuit at Malhaese substation causing tripping of 220 kV (bus coupler and ICT). After isolating the fault, line was reconnected at 2:08 pm from Malhaese substation.
2	24.07.2021	18:30	24.07.2021	19:05	0	-0.6	220kV Singeygnas	220kV Singeygnas	Line fault	NA	Singeygnas	N/A	Since 220 kV (Malhaese and Singeygnas) feeder was tripped from Malhaese end, there was power interruption from 66 kV Dhandum to Gonets. 66 kV Plog-Gonets ring system could not be charged from Plog SS. At 18:56 hrs Plog-gonets and Gonets-Dhandum charged. No tripping of CB was encountered in Dhandum substation.
3	24.07.2021	18:30	24.07.2021	18:56	0	3.95	66 kV Gonets	66 kV Gonets	Line fault	NA	Gonets	N/A	

(C) 66/33kV Olakha Substation													
1	7/7/2021	8:08	7/7/2021	8:10	0	7.8	66/33kV 20MVA Transformer I	All the out going feeders was effected as both the 20 MVA I & II transformer was tripped.	Due to tripping of 33kV Chabacha feeder IV, the transformer got tripped.	TRAF0 DIFFL. PROT.N. RELAY RT Indication : L,J,A & S. 1. General Trip J.DIFF Trip Ypk.4.DIFF Trip Bpk.5.DIFF Prot.Oper. Trip Relay 86.	Olakha	Transformer Fault	The 66/33kV 20MVA Transformer I was tripped due to tripping of 33kV O/G Feeder IV (Chabacha).Charged the feeder and hold normal.
2	7/7/2021	8:08	7/7/2021	8:10		7.7	66/33kV 20MVA Transformer II	All the out going feeders was effected as both the 20 MVA I & II transformer was tripped.	Due to tripping of 33kV Chabacha feeder IV, the transformer got tripped.	DER.Over current and Earth fault Protection relay 86 Indication: 1 & 5. 1 General Trip & 5 O/C & E/F operated.	Line Segments	Transformer Fault	The 66/33kV 20MVA Transformer II was tripped due to tripping of 33kV O/G Chabacha feeder IV.
3	7/9/2021	14:18	7/9/2021	14:31	0	7.0	66/33kV 20MVA Transformer I	The supply was not effected as the feeders was fed from 66/33kV 20MVA Transformer II	Temporary Fault	TRAF0 DIFFL. PROT.N. RELAY RT Indication : L,J,A & S. 1. General Trip J.DIFF Trip Ypk.4.DIFF Trip Bpk.5.DIFF Prot.Oper. Trip Relay 86.	Olakha	Transformer Fault	Reset the relays, charged the Transformer I and hold normal.
4	7/12/2021	8:48	7/12/2021	10:27	4	5.7	66/33kV 20MVA Transformer I	Only 33kV DPH II Feeders VI was effected as the feeders was fed from 66/33kV 20MVA Transformer II	The transformer was tripped due to tripping of 33kV DPH II Feeders VI	TRAF0 DIFFL. PROT.N. RELAY RT Indication : L,J,A & S. 1. General Trip J.DIFF Trip Ypk.4.DIFF Trip Bpk.5.DIFF Prot.	33kV DPH II Feeders VI line	Transformer Fault	The transformer was tripped on differential. Issued the work permit no 1059 to Sr. Engineer SMD and TCCD Sherab Dorji for checking the relay coordination between Transformer and outgoing feeders. Charged the feeder after checking relays and hold normal.
5	7/16/2021	7:02	7/16/2021	10:07	8	6.5	66/33kV 20MVA Transformer I	Only 33kV Chabacha feeders IV was effected as the feeders was fed from 66/33kV 20MVA Transformer II	The transformer was tripped due to tripping of Chabacha feeders IV	TRAF0 DIFFL. PROT.N. RELAY RT Indication : L,J,A & S. 1. General Trip J.DIFF Trip Ypk.4.DIFF Trip Bpk.5.DIFF Prot.	33kV Chabacha Feeders IV line	Transformer Fault	The transformer was tripped on differential. Issued the work permit no 1060 to Engineer SMD and TCCD Sherab Dorji for checking the relay coordination between Transformer and outgoing feeders. Charged the 20MVA Transformer I after checking relays setting and hold normal.
7	7/19/2021	20:45	7/19/2021	20:48		10.2	66/33kV 20MVA Transformer II	All the out going feeders was effected as both the 20 MVA I & II transformer was tripped.	O/C & E/F	DER.Over current and Earth fault protection relay 67 Indication: 7 O/C & E/F operated.	Line Segments	Transformer Fault	The 66/33kV 20MVA Transformer II was tripped and test charged the feeder and hold normal.
10	7/28/2021	18:34	7/28/2021	19:22	0	7.3	66/33kV 20MVA Transformer I	The supply was not effected as the feeders was fed from 66/33kV 20MVA Transformer II	Transformer Differential Protection relay Operated	TRAF0 DIFFL. PROT.N. RELAY RT Indication : L,J,A & S. 1. General Trip 4.DIFF Trip Bpk.5.DIFF Prot.	Olakha	Temporary	20MVA Transformer I tripped on differential protection, informed to maintenance engineers for test charging of the Transformer. Charged the transformer after confirmation received and hold normal.
11	7/28/2021	19:06	7/28/2021	19:30		20.2	66/33kV 20MVA Transformer II	All the out going feeders was effected as both the 20 MVA I & II transformer was tripped.	O/C & E/F	DER.Over current and Earth fault protection relay 67 Indication: 1,2,3 O/C & E/F operated.	Olakha Substation	Over load	Due to overload, transformer II was tripped as Transformer I and 33kV busbar I was in trip position due to differential protection indication.
(E) 220kV Substation Samsikha													
1	21.07.2021	15:50hrs	21.07.2021	15:55hrs		31.030	50MVA-II	Samsikha SS	Over Current	RET318 relay opd.	-	Transformer	
2	21.07.2021	16:35hrs	21.07.2021	18:40hrs		0.130	66kV Samsikha-Dechula Line	SCADA data validation at both Samsikha and BPSO end.				Transformer	No customer affected

August 2021

Sl.No.	Date of Tripping	Time of outages	Date of Normalization	Time of fault was cleared	Duration of Outages (Hrs)	MW before outage (MW)	Feeder Name	Name of the Substation/Line affected by the fault	Reasons of fault	Relay operations	Exact location of fault (Line segment/ Substation)	Type of outage	Remarks
(A) 400/720/36/11 kV Malhae Substation													
66kV & Above													
1	17.08.2021	1:34	17.08.2021	1:34	0	410	800V Tala-Malhae line	Malhae S/S	Tripped due to OC on Y phase at Tala end.	A-B start, A/B 1/2ops	Line fault	Overcurrent fault	No fault displayed, B6 did not operate but both Main and Tie breaker open/tripped.
2	17.08.2021	3:40	17.08.2021	3:56	0	-133	220kV Chokha feeder	Malhae S/S	Tripped due to OC on B phase	Bus trip, Zone 1, AR lockout start.	Distance=18.2km	Overcurrent fault	SL1-288AA, SL2-5513A, SL3-5.417KA
3	17.8.2021	3:40	17.08.2021	4:20	0	24	30 MVA Transformer on B6	Malhae S/S	Tripped due to chokha feeder	Ms operated, DSR Trip.	Switch Yard	Tripped	SL1-71.85A--88.85Adeg, SL2-171.5A--199.62deg, SL3-74.87A--115.64deg, SL4-279.28A--79.63deg
4	25.08.2021	1:21	25.08.2021	14:00	12	73	200 MVA KCT	Malhae S/S	Backhole trip	66kV phase BOCBS trip.	transformer yard	Tripped	SL1-0.121A--56.21deg, SL2-0.032A--133.6 deg, SL3-307A--68.2deg.
5	25.08.2021	9:30	25.08.2021	10:13	3	73	200 MVA KCTP 1 S) phase	Malhae S/S	Shutdown	-	-	Shutdown	PTW no. T1 was issued by Mr. Paro Ram Wakes, SMC plng, for rectification of Backhole trip.
(B) 220/36/11 kV Singhaeom Substation													
1	18.08.2021	14:44	20.08.2021	20:00	29	0.078	22kV Feeder 1	GIS, Singhaeom S/S	Overcurrent on R, Y phase	Op trip, O/C trip, D=> Trip.General trip.	Pole washed away by flood at Chawanghae (2 span conductor damaged)	Tripped	SL1-0.73A, SL2-0.32A, SL3-0.51AA
(C) 66/11/11 kV Phomcholing Substation													
1	06.08.2021	14:05	06.08.2021	15:42	6	0.34	66kV Pling-Gemto feeder	66kV Pling-Gemto feeder		DCN OPTS, DMK6	Line	Tripped on Fault	66kV Pling-Gemto feeder tripped at our end and 66kV Chokha-Ping from their end running back out, at 14:05hrs 66kV Chokha-Ping feeder normalized from chokha end and at 15:42hrs test cleared after getting clearance from BPSO and started normal.
2			06.08.2022	14:40	14	nil	66kV Malhae-Ping feeder	66kV Malhae-Ping feeder					At 14:40hrs charged 66kV Malhae-Ping feeder after getting approval from BPSO with charging code 1414 which was under site charged condition, at 15:42hrs opened CR of 66kV Malhae-Ping feeder with opening code 0145 from BPSO after normalizing 66kV (Inkha-Ping and 66kV Pling-Gemto feeder.
3			06.08.2022	21:30	21	nil	66kV Malhae-Ping feeder	66kV Malhae-Ping feeder					At 21:30hrs charged 66kV Malhae-Ping feeder with charging code 1418 from BPSO which was under site charged condition, since at Gemto and B phase conductor got snapped, at 15:42hrs opened CR of 66kV Malhae-Ping feeder with opening code 0145 from BPSO after normalizing 66kV Chokha-Ping and 66kV Pling-Gemto feeder.
4	07.08.2021	11:01			06:00	0.75	66kV Malhae-Ping feeder	66kV Malhae-Ping feeder					At 11:01hrs opened CR of 66kV Malhae-Ping feeder with opening code 0197 from BPSO and feeder kept under site condition.
(D) 66/11/11 kV Gorta Substation													
1	06.08.2021	14:57	06.08.2021	16:40	6	1.29	66kV Chokha-Phomcholing line	Shut out	Bad weather		Line segment		Charged from Chokha end.
(E) 66/33/11 kV Gemto Substation													
1	06.08.2021	14:39	06.08.2021	14:39	0	0.42	66kV (Thamdon/P/S) NE	Gemto	Grid Fail	Nil	Line segment		Both supply failed from (Thamdon and Phomcholing).
2	06.08.2021	21:24	07.08.2021	08:56	18	0.42	66kV P/Sing	Nil	B Phase conductor snapped	Nil	Gemto Substation		Hand tripped the breaker against shutdown Code No. 0194 and charged against charging Code No. 1420
(F) 220/66/33 kV (Thamdon Substation													
1	06.08.2021	14:38	06.08.2021	14:54	0	0.71	66kV Gemto	Gemto	Transient fault	BSP#(15-09R0/197) TRP-RYB @ fault	Gemto line	N/A	Relay indication, [67 - Direction over current, [Earth fault relay] SL1 - 1.73A, SL2 - 1.54A, SL3 1.73A [3 phase fault]. There weather condition was bad, BPSO has informed us to charge the line.

Tripping Report for the month of AUGUST 2021													
Sl. No.	Date of Tripping	Time of outages	Date of Normalization	Time of fault was cleared	Duration of Outages (hrs)	MW before outages (MW)	Feeder Name	Name of the Substation/Buses affected by the fault	Reasons of fault	Relay operations	Exact location of fault (Line segment/Substation)	Type of outages	Remarks
040V LSA - Dochula Feeder													
1	07.08.2021	17:47hrs	07.08.2021	17:55hrs	0	17.400	040V LSA-Dochula	NA	Line fault	OCR EF with 40 relay	NA	NA	040V LSA -Dochula feeder tripped at 17:47hrs operating breaker at our end & Dochula end and informed to BPNL at 17:55hrs with the clearing code 1422 breaker towards closed towards Dochula and line stand thereafter
2	01.08.2021	01:27hrs	11.08.2021	01:35hrs	0	09.176	040V LSA-Dochula	NA	Line fault	OCR EF with 40 relay	NA	NA	040V LSA -Dochula feeder tripped at 01:27hrs operating breaker at our end & Dochula end and informed to BPNL at 01:35hrs the breaker towards closed towards Dochula and Bhawche and line stand thereafter
3	01.08.2021	01:40hrs	11.08.2021	01:57hrs	2	22.199	040V LSA-Dochula	NA	Line fault	NA	NA	NA	040V LSA -Dochula feeder tripped at 01:40hrs without any relay or breakers operated at our end and at 01:57hrs supply restored from Bhawche
4	04.08.2021	03:40hrs	04.08.2021	04:10hrs	0	09.240	040V LSA-Dochula	NA	Line fault	OCR EF with 40 relay	NA	NA	040V LSA -Dochula feeder tripped at 03:40hrs due to under voltage at Dochula and closed the breaker with the clearing code from BPNL at 04:10hrs and line stand thereafter
040V LSA - Dzongkhag Bhawche Feeder													
1	01.08.2021	01:27hrs	11.08.2021	01:35hrs	0	09.176	040V LSA-Bhawche	NA	Line fault	OCR EF with 40 relay	NA	NA	040V LSA -Bhawche feeder tripped at 01:27hrs operating breaker at our end & Bhawche end and informed to BPNL at 01:35hrs the breaker towards closed towards Bhawche and line stand thereafter
2	01.08.2021	01:40hrs	11.08.2021	01:57hrs	2	22.199	040V LSA-Bhawche	NA	Line fault	NA	NA	NA	040V LSA -Bhawche feeder tripped at 01:40hrs without any relay or breakers operated at our end and at 01:57hrs supply restored from Bhawche
040-040V Bha Substation													
1	08.08.2021	4:01	08.08.2021	8:22	2hr	45.5	All the feeders	Due to Dzongkhag feeder	E-F & O/C	Tripping, Fuse			Incident report along with all the supporting details due to the fault on the Dzongkhag Feeder. Incident supply was changed from Panglha end with the clearing code 1427 from BPNL but failed to start, so, after isolating the faulty feeder (Dzongkhag) MW incident was start again was changed side clearing code 1428 and it was found normal. The faulty feeder was kept isolated as to carry out the panning by PSL. Bha.
040-120kV Substation Sonatkhola													
1	01.08.2021	00:20hrs	11.08.2021	00:40hrs		40.770	120kV Sonatkhola-Bhawche Line	120kV Sonatkhola-Bhawche Line	Over Voltage	Main-C Dis. Oper. (Over Voltage Trip)		Temporary	
2	09.08.2021	09:10hrs	09.08.2021	09:10hrs		36.470	220kV/110kV SONIMVA-2	Sonatkhola and Dochula Substation	Over Current (Tripped while opening Dochula to Intra-Sub)	Over Current and Intra (Over current Trip)		Temporary	
3	01.08.2021	00:50hrs	11.08.2021	00:51hrs		07.420	220kV/110kV SONIMVA-2	Sonatkhola and Dochula Substation	Over Current (Tripped while opening Dochula to Intra-Sub)	Over Current and Intra (Over current Trip)		Temporary	
4	01.08.2021	00:20hrs	11.08.2021	00:17hrs		33.470	040V Sonatkhola-Dochula Line	Sonatkhola and Dochula Substation	Broken Conductor	Dis. Relay Oper. Broken conductor trip		Temporary	
5	09.08.2021	00:17hrs	09.08.2021	00:50hrs	1.00	0.730	040-110V SONVA_2	Sonatkhola Substation	Thermal trip to control station supply from SONVA-1				
6	01.08.2021	08:59hrs	11.08.2021	12:50hrs	4.00	41.000	040V Sonatkhola-Dochula Line	040V Dochula Substation	Hardware failure by Mr. Kaley Wangchuk, Project Manager to make jumper connection on tower location. Thermal jumper opening at tower 32			Transient	No customer affected
120kV/110V Panglha substation													
1	07.08.2021	07:12	07.08.2021	07:04	0	0.00	040V OG-1has		Tripped on O/C	Distance Relay		Transient	
2	08.08.2021	4:02	08.08.2021	6:23	2	0.50	040V OG-4has		Tripped on O/C & E-F	Distance Relay		Long	Depth Test charging in coordination with BPNL the line without stand. Lastly it was found out that the end one of 110kV line had a problem where the line was changed after isolating 110V feeder

September 2021

Sl No.	Date of Tripping	Time of outages	Date of Normalization	Time of fault was cleared	Duration of Outages (hrs)	MW before outage (MW)	Feeder Name	Name of the Substation/Times affected by the fault	Reasons of fault	Relay operations	Exact location of fault (Line segment/ Substation)	Type of outages	Remarks
(A) 400/77.5/11 kV Malhaan Substation													
88KV & Above													
1	02.09.2021	4:30	02.09.2021	4:45	0	5.75	20KV Malhaan-Dhanchon feeder	Malhaan S/E end Dhanchon	DC trip on 1 phase Earth fault	none 1 trip,Zone 1 trip,20 optd	30.8 km	Overcurrent fault	SL-102.64-358.10kg,SL-276.64-103.40kg,SL-75.8364-100.70kg,SL-6-2794.6-16.50kg
2	06.09.2021	2:00	06.09.2021	15:20	13	22	50/33KV transformer I	Malhaan Substation	Trip due to fault on 88KV p/line feeder	LBB optd	88KV p/line	88KV p/line	SL-972.70 A-2.20kg,SL-2-944.210-121.92kg,SL-3-947.40-117.92kg
3	06.09.2021	15:09	06.09.2021	15:25	0	22	88KV Pasakha feeder I	Malhaan Substation	Trip due to fault on 88KV p/line feeder	SingleLOC tripping	88KV p/line	88KV p/line	SL-1132.190-05.00kg,SL-2-1707.25A-151.75kg,SL-3-090.50A-37.40kg
4	06.09.2021	15:09	06.09.2021	15:20	0	-	88KV bus coupler	Malhaan Substation	Trip due to fault on 88KV p/line feeder	30 optd, IEF300 trip	88KV p/line	88KV p/line	SL-1213.49A-34.70kg,SL-2-1305.93A-101.00kg,SL-3-1201.05A-77.90kg,SL-4-530.29A-30.00kg
5	12.09.2021	0:20	12.09.2021	04:30	14	-	88KV p/line feeder		O/C 8E/F	30 optd,201-trip	88KV p/line	88KV p/line	SL-1409.032-84.02kg,SL-3-1255.00-04270A
6	12.09.2021	0:20	12.09.2021	10:44	13	-	88KV bus coupler	Malhaan Substation	O/C 8E/F	0/C 30trip,IEF300 trip,general trip	88KV p/line	88KV p/line	SL-1446.11A-130.91kg,SL-2-1276.21A-145.50kg,SL-3-176.10A-71.12kg,SL-4-1202.97A-145.00kg
7	12.09.2021	14:30	12.09.2021	14:33	0	17	88KV Pasakha feeder I	Malhaan Substation	O/C 8E/F	IEF 300 trip,30 optd	88KV pasakha line	88KV pasakha line	SL-555.61A-179.60kg, SL-2-1310.29A-25.33kg,SL-3-277.12A-06.45kg,SL-4-1050.95A-127.45kg
8	12.09.2021	14:30	12.09.2021	14:32	0	-	88KV bus coupler	Malhaan Substation	O/C 8E/F	IEF 300 trip,30 optd	88KV pasakha line	88KV pasakha line	SL-2401.340-21.33kg,SL-2-1243.61A-146.10kg,SL-3-301.39A-07.03kg,SL-4-1004.10A-126.05kg
9	12.09.2021	14:30	12.09.2021	14:34	0	19	88KV Pasakha feeder IV	Malhaan Substation	O/C	IEF 300 trip,30 optd	88KV pasakha line	88KV pasakha line	SL-567.06A-42.45kg,SL-2-1434.29A-15.41kg,SL-3-109.93A-03.00kg
10	13.09.2021	13:02	13.09.2021	13:20	0	44	22KV Begawa feeder	Malhaan Substation	O/C on B Phase	30 optd, 8E lockout start, 200M1 trip	fault location -24.00km	88KV p/line	SL-114.50SL-2-313.90SL-3-0205A
11	13.09.2021	13:02	13.09.2021	13:30	0	23	50/33KV transformer III	Malhaan Substation	tripped due to Begawa feeder	Differential trip	24.00km	88KV p/line	SL-09.820-32.26kg,SL-2-122.49A-100.09kg,SL-3-77.90A-121.95kg,SL-4-37.71A-126.02kg
12	16.09.2021	13:36	16.09.2021	13:44	0	24	50/33KV transformer III	Malhaan Substation	88KV support feeder			88KV p/line	SL-136.19A-64.03kg,SL-2-07.19A-8.07kg,SL-3-00.39A-00.25kg,SL-4-217.20A-19.97kg
13	17.09.2021	10:54	17.09.2021	20:03	1	-1	88KV support feeder	Malhaan Substation	O/C 8E/F	Zone 1 trip,zone 1 trip	44.0 km	88KV p/line	SL-240.60-00.07kg,SL-2-205.20-20.07kg,SL-3-1370A-30.00kg,SL-4-3121A-30.00kg
(B) 220KV/33 kV Singhaeev Substation													
1	01.09.2021	6:30	01.09.2021	6:30	29	0.4	Singha- ramcha feeder	Singhaeev	Overcurrent	30 optd	22KV overhead line	O/C tripped	SL-96.044,SL-2-2556A,SL-00.7A,SL-0170A
2	16.09.2021	13:35	16.09.2021	16:14	1	1.36	Singha- ramcha feeder	Singhaeev	Overcurrent	30 optd	22KV overhead line	O/C tripped	SL-102.2A,SL-2-35.35A,SL-04.02A
(C) 66/33 kV Phuntsholing Substation													
1	21.09.2021	14:47	21.09.2021	17:13	2	-	88KV Chukka and Gentsa feeder	88KV Chukka and Gentsa feeder	Tripped		Chukka and Gentsa end	88KV p/line	Both 88KV feeder got tripped at their end causing blackout at Phuntsholing. Informed to BPSO and supply was extended from 88KV Malhaan
2			21.09.2021	14:50	14	0.0	88KV Malhaan-Ping feeder	88KV Malhaan-Ping feeder				88KV p/line	At 14:50hrs charged 88KV Malhaan-Ping feeder since both 88KV Chukka and Gentsa feeder got tripped at their end. At 17:10hrs opened CB of 88KV Malhaan-Ping feeder with opening order 9120 from BPSO and feeder kept under safe condition.
(D) 66/33 kV Gedu Substation													
1	21.09.2021	14:47	21.09.2021	16:50	0	1.00	88KV Chukka-Phuntsholing line	Blackout			Line segment	88KV p/line	Supply restored from Chukka, CTP
(E) 66/33 kV Gentsa Substation													
1	21.09.2021	15:54	21.09.2021	18:36	0	-7.30T	88KV Dhanchon	Bus	General tripped		Dhanchon	General	Test charged from Dhanchon and supply stood normal
2	21.09.2021	15:40	21.09.2021	15:47	0	-7.30T	88KV Dhanchon	Gentsa substation	General tripped		Dhanchon	General	Test charged from Dhanchon and supply stood normal
3	21.09.2021	15:40	21.09.2021	15:43	0	5.32	88KV P/Line	Gentsa substation	General tripped		P/Line	General	Test charged from Dhanchon and supply stood normal
Tripping Report for the month of SEPTEMBER 2021													
Sl No.	Date of Tripping	Time of outages	Date of Normalization	Time of fault was cleared	Duration of Outages (hrs)	MW before outage (MVA)	Feeder Name	Name of the Substation/Times affected by the fault	Reasons of fault	Relay operations	Exact location of fault (Line segment/ Substation)	Type of outages	Remarks
(A) 88KV Chukka switching station													
1	20.09.2021	14:00hrs	20.09.2021	14:00hrs	0	4.00MVA	88KV busbar	fed from 88KV Chukka feeder	Transient fault	0-trip, 30-trip, CB 200	Chukka	Tripping	
2	20.09.2021	14:00hrs	20.09.2021	14:00hrs	0	11.05MVA	88KV Chukka Feeder	Par, Pengsum, Gentsa	Wind failure	No operation at Chukka end	Gentsa end	Wind failure	
(B) 88/33KV Wates Substation													
1	20/9/2021	14:25hrs	20/9/2021	14:53hrs	0	250MVA	88KV M/S	F/A, I and F/A, II	O/C, O/C & E/F	O/C, O/C & E/F	F/A, II/Coupler	88KV p/line	Test failure on 88KV line at Gentsa
2	20/9/2021	13:30hrs	20/9/2021	13:43hrs	0	200MVA	88KV busbar	F/A, I and F/A, II	88KV supply fed from source	88KV supply fed from source	88KV supply fed from source	Tripping	
3	20/9/2021	13:30hrs	20/9/2021	13:33hrs	0	200MVA	88KV busbar	F/A, I and F/A, II	88KV supply fed from source	88KV supply fed from source	88KV supply fed from source	Tripping	

(C) 66/33KV Chukha Substation													
1	03/2021	2:30	03/2021	3:07	1	2.83	20MVA Transformer II	All the 11KV Outgoing feeders got effected as the 11KV busbar I & E was tripped.	Over current and Earth fault,	Directional Over current and Earth fault protection relay and tripping relay 86.	Chukha substation	DC Supply failed	20MVA Transformer II could not charged due to failure of DC. Charged the Transformer after the DC supply was restored.
2	03/2021	2:30	03/2021	3:21	1	2.9	20MVA Transformer I	All the Outgoing feeders got effected as the 11KV busbar I & E was tripped.	Over current and Earth fault, the Transformer could not charged due to failure of DC.	Directional Over current and Earth fault protection relay-47 and tripping relay 86.	Chukha substation	DC line blown out	Charged the Transformer after the DC supply was restored. The line blown at charges and was replaced with new one.
3	08/2021	10:27	08/2021	11:07	0	-16.61	66KV Busbar- Chukha line	All the 11KV Outgoing feeders was effected due to Grid failure.	Grid fail	NO	Line segment	Grid fail	As confirmed by the shift duty of Inservice Substation, the 66KV supply was tripped from Kharikhu end.
4	08/2021	10:27	08/2021	11:07	0	4.32	66KV Chukha - Changrappa line	All the 11KV Outgoing feeders was effected due to Grid failure.	Grid fail	NO	Line segment	Grid fail	As confirmed by the shift duty of Inservice Substation, the 66KV supply was tripped from Kharikhu end. The 66KV busbar was charged after information received from BPSO.
5	09/12/2021	12:10	09/12/2021	12:07	0	3.46	66KV Chukha - Changrappa line	All the 11KV Outgoing feeders was effected due to Grid failure.	Grid fail	NO	Line segment	Grid fail	As confirmed by the shift duty of Inservice Substation, the 66KV supply was tripped from Kharikhu end. The 66KV busbar was charged after information received from BPSO.
6	09/12/2021	12:10	09/12/2021	12:07	0	-18.9	66KV Busbar- Chukha line	All the 11KV Outgoing feeders was effected due to Grid failure.	Grid fail	NO	Line segment	Grid fail	As confirmed by the shift duty of Inservice Substation, the 66KV supply was tripped from Kharikhu end.
7	02/28/2021	13:00	02/28/2021	13:34	0	-6.67	66KV Busbar- Chukha line	All the 11KV Outgoing feeders was effected due to failure of Inservice line.	Supply failed from the Inservice.	NO	Line segment	Grid fail	As confirmed by the shift duty of Inservice Substation, the 66KV supply was tripped from Kharikhu end.
8	02/28/2021	13:30	02/28/2021	14:23	0	0	66KV Chukha - Changrappa line	All the 11KV Outgoing feeders was effected due to Grid failure.	Grid fail	NO	Line segment	Grid fail	As confirmed by the shift duty of Inservice Substation, the 66KV supply was tripped from Kharikhu end. The 66KV busbar was charged after information received from BPSO.
9	02/28/2021	13:30	02/28/2021	14:23	0	5.50	20MVA Transformer I	All the Outgoing feeders got effected as the 11KV busbar I & E was tripped.	Grid fail	NO	Line segment	Line segment	Charged the 20MVA Transformer I and manual normal.
10	02/28/2021	13:30	02/28/2021	14:23	0	5.50	20MVA Transformer II	Chukha substation	Grid fail	NO	Line segment	Grid fail	Charged the 20MVA Transformer and hold normal.
(D) 66/33/11KV Lohrysa Substation													
66KV L.A. - Breaker Breaker													
1	29/09/2021	13:50hrs	29/09/2021	14:20hrs	0	20.050	66KV L.A. - Breaker	Lohrysa Substation	Grid fail	NA	NA	NA	66KV L.A. - Breaker breaker grid fail at 13:50hrs without any relay or breakers operation at one end and supply.
66KV L.A. - Breaker Breaker													
1	29/09/2021	13:50hrs	29/09/2021	14:20hrs	0	-24.520	66KV L.A. - Breaker	Lohrysa Substation	Grid fail	NA	NA	NA	66KV L.A. - Breaker breaker grid fail at 13:50hrs without any relay or breakers operation at one end and supply.
(E) 66/33/11KV Pura Substation													
1	15/08/2021	20:27	20/08/2021	20:52	0	7.41	66KV Chukha - Line In	Black out at pure	Tripped from Chukha end.				
2	20/08/2021	13:30	20/08/2021	13:42	0	4.95	66KV Chukha - Line In	Black out at pure	Tripped from Chukha				
2	20/08/2021	14:00	20/08/2021	14:13	0	4.95	66KV Chukha - Line In	Black out at pure again	Tripped from Chukha				
(F) 66/33/11KV Jambha Substation													
1	12/08/2021	12:00	12/08/2021	12:19	0	0.60 Chukha & 2.51 Changrappa	66 KV Lines, Chukha & Changrappa	Blackout	Earth Fault	Earth fault & Auto reclose lockout	Line segment		In 11.47 A, B, 11.62 A, C, 11.05 A, In measured 13.10 A, Ycb 04.13 Y, Ycb 05.24 V & Y for Chukha & B, 11.17 A, In 7.6 A In measured 12.24 A, Ycb 10.15 V, Ycb 14.05 Y & Ycb 05.24 V for Changrappa.
2	20/08/2021	13:05	20/08/2021	13:16	0	1.91 C-400 & 4.51 Chukha	66 KV Lines, Chukha & Changrappa	Blackout	Supply failed from Chukha	NO	Chukha breaking station end, above general trip.		-
3	20/08/2021	13:37	20/08/2021	13:40	0	1.15 C-400 & 4.62 Chukha	66 KV Lines, Chukha & Changrappa	Blackout	Distance protection operated at Changrappa end.	NO	Changrappa end, Distance relay operated.		-
4	20/08/2021	13:50	20/08/2021	14:17	0	1.15 C-400 & 4.62 Chukha	66 KV Lines, Chukha & Changrappa	Blackout	Supply failed from Bartschi, at Bus line from - Chukha end.	NO	Source		-

100-66.22.110KV Dechencholing substation											
1	08.08.2021	11.200hrs	08.08.2021	11.37hrs	0		66KV DC Sensibha	Whole line	Supply failed from source		
2	12.08.2021	12.000hrs	12.08.2021	12.23hrs	0		66KV DC Sensibha	Whole line	Supply failed from source		
3	13.08.2021	14.190hrs	13.08.2021	14.27hrs	0		66KV DC Sensibha	Whole line	Supply failed from source		
4	28.08.2021	10.000hrs	28.08.2021	10.17hrs	0		66KV DC Sensibha	Whole line	Supply failed from source. Tripped from Basochi end.		
5	28.08.2021	11.29hrs	28.08.2021	14.18hrs	0		66KV DC Sensibha	Whole line	Supply failed from source. Tripped from Basochi end.		
66KV side Main down											
1	01.09.2021	13.000hrs	01.09.2021	16.00hrs	3hrs	---	10MVA T-4		supply feed from 10MVA T-4 66KV side CT Having annual inspection.		
2	02.09.2021	08.02hrs	02.09.2021	08.37hrs	0	---	10KV O-G-01	Only O-G-01	Short down taken by ENO-Offical for phase sequence correction.		
3	11.09.2021	21.240hrs	11.09.2021	23.38hrs	2hrs	---	10MVA T-4	supply feed from 10MVA T-4	System observed low spot on 10V side of 10MVA T-4. MFO breaker of phase removed, as to prevent to our equipment we requested Taha end to reduce the load, as they permitted us to load support the 10KV O-G-1. Taha-1: Same night our crew team had notified the faultage point and changed 10MVA T-4 and changed Taha O-G-1 and informed them to increase the load as normal. Same night maintenance Engineer had started. This		
4	15.09.2021	11.130hrs	15.09.2021	10.02hrs	1hrs	---	10MVA T-4	supply feed from 10MVA T-4	Short down caused to MFO team to access the flat spot at 1.1V side 10MVA T-4 TCB breaker terminal in Y phase.		
100-66.110KV Dha Substation											
1	29.08.2021	1400	29.08.2021	1611	1hr	+1.34	66 kv busbar	Due to tripping of 110KV Tanning - Spreading bar	Supply failed due to tripping of Spreading - Tanning bar. The same was normalised after reworking the supply from 110KV Tanning to RDP power plant.		
110KV Substation Sensibha											
1	08.08.2021	10.17hrs	08.08.2021	11.37hrs		-17.740		Supply failed from both 110KV source. No tripping at our end	Temporary		
2	28.08.2021	13.04hrs	28.08.2021	13.14hrs		-77.140		Grid Failed. No tripping at our end	Temporary		
3	29.08.2021	13.79hrs	29.08.2021	-77.18		-77.180		Grid Failed. No tripping at our end	Temporary		
4	02.09.2021	12.000hrs	02.09.2021	12.23hrs		59.800	66KV Sensibha	Dechenla Substation	Busbar Combustion Dist. Relay Oper. Supply complete Dist. Relay Oper.	Tripped	
5	02.09.2021	08.00hrs	02.09.2021	08.14hrs	0:00	59.530	66KV Sensibha	Dechenla Substation	Fault Layer 1-1-1 Ground Trip Ground Trip. Right Dist. Relay Oper.	Tripped	
6	08.09.2021	09.47hrs	08.09.2021	10.24hrs	2:00	64.970	66KV Sensibha	Dechenla Substation	Fault Layer 1-1-1 Ground Trip Ground Trip. Right Dist. Relay Oper.	Tripped	
7	11.09.2021	19.23hrs	11.09.2021	19.36hrs	0:00	61.890	66KV Sensibha	Dechenla Substation	Fault Layer 1-1-1 Ground Trip. Right Dist. Relay Oper.	4.0 Tripped	
8	13.09.2021	10.13hrs	13.09.2021	10.25hrs	0:00	62.900	66KV Sensibha	Dechenla Substation	Fault Layer 1-1-1 Ground Trip Dist. Relay Oper.	1.0 Tripped	
9	16.09.2021	16.13hrs	16.09.2021	16.33hrs	0:00	63.840	66KV Sensibha	Dechenla Substation	Fault Layer 1-1-1 Ground Trip Dist. Relay Oper.	0 Tripped	
10	17.09.2021	16.14hrs	17.09.2021	16.34hrs	0:00		66KV Sensibha	Dechenla Substation	Fault Layer 1-1-1 Ground Trip Dist. Relay Oper.	0 Tripped	
11	21.09.2021	15.09hrs	21.09.2021	15.17hrs	0:00	64.070	66KV Sensibha	Dechenla Substation	Fault Layer 1-1-1 Ground Trip Dist. Relay Oper.	0 Tripped	
12	13.09.2021	16.13hrs	13.09.2021	16.27hrs	0:00	17.170	66KV Sensibha	Dechencholing Substation	Under Voltage trip Dist. Relay Oper.	Tripped	
13	28.08.2021	13.04hrs	28.08.2021	13.09hrs	0:00	19.840	66KV Sensibha	Dechencholing Substation	Under Voltage trip Grid failed	Tripped	
14	02.09.2021	11.09hrs	02.09.2021	12.05hrs	1:00	16.040	66KV Sensibha Transformer		No notice the oil leakage on Yth Bushing	Tripped	
110-66.22.11KV Pangbasa substation											
1	29.08.2021	13.08	29.08.2021	13.42	0	1.6	66KV Channel Line 3b		Black out at pang	Tripped from chubha	
2	29.08.2021	14.00	29.08.2021	14.11	0	1.6	66KV Channel Line 3b		Black out at pang again	Tripped from chubha	
100-66.110KV Changdaphu Substation											
1	28.08.2021	11.37hrs	28.08.2021	13.43hrs			66KV Changdaphu- Animes Line	66KV Changdaphu-Dechen Line	Grid Failed	Dist. Relay Oper. RT Trip. Power Swing	Tripped
2	08.08.2021	11.27hrs	08.08.2021	11.42hrs			66KV Changdaphu- Yibha Line	Changdaphu Substation	Grid Failed	Dist. Relay Oper. Dph Trip. Power Swing	Tripped

XL146-15KV Busing Substation												
1	08.08.2021	1129 hrs	08.08.2021	1130 hrs	0	+0.27	30 KV Incoming line	46 KV Thimphu-Cross Line, Dangi Substation & all outgoing Feeders	Trip	NA	NA	Line Trip from Sengkha Substation
2	12.08.2021	1209 hrs	12.08.2021	1215 hrs	0	-1.07	30 KV Incoming line	47 KV Thimphu-Cross Line, Dangi Substation & all outgoing Feeders	Trip	NA	NA	Line Trip from Sengkha Substation, i.e. 220 KV CBP-DEM Feeder Trip on B Phase Fault (Earth Fault)
3	13.08.2021	1419 hrs	13.08.2021	1428 hrs	0	-0.71	30 KV Incoming line	48 KV Thimphu-Cross Line, Dangi Substation & all outgoing Feeders	Trip	NA	NA	Line Trip from Sengkha Substation, i.e. 220 KV CBP-DEM Feeder Trip
4	28.08.2021	1307 hrs	28.08.2021	1314 hrs	0	+0.81	30 KV Incoming line	48 KV Thimphu-Cross Line, Dangi Substation & all outgoing Feeders	Trip	NA	NA	Line Trip from Sengkha Substation, i.e. 220 KV Bardshe Feeder Trip at Bardshe end
5	28.08.2021	1408 hrs	28.08.2021	1414 hrs	0	+0.30	30 KV Incoming line	48 KV Thimphu-Cross Line, Dangi Substation & all outgoing Feeders	Trip	NA	NA	Western Grid Blackout due to 220 KV Yaring-Syngteling Line
6	30.08.2021	1727 hrs	30.08.2021	1732 hrs	0	0.22 & 0.18	over Transformer	busbar II & all outgoing feeders	Trip	30 % & 80 OPTD		Tripped due to earth fault & recirculation of Outgoing Feeder

October 2021

Tripping Report for the month of OCTOBER 2021														
Sl. No.	Date of Tripping	Time of Tripping	Date of Normalization	Time of fault was cleared	Duration of Outages (hrs)	Duration of Outages (mins)	MW before outage (MW)	Feeder Name	Name of the Substation line affected by the fault	Reasons of fault	Relay operations	Exact location of fault (if the upstream substation)	Type of outage	Remarks
(A) 40KV Chukha substation														
NA														
(B) 40-KV Wang Substation														
1	10/10/2021	17:04	10/10/2021	17:05	01:00	00:45	4000	40KV 100 feeder	14, 1 and 14, 2	40KV 100 A, B	40KV 100 A, B relay operated	14, 1 & 14, 2	DC Failure	Line Trip on 100 A & B circuit
2	10/10/2021	17:05	10/10/2021	17:05	00:00	00:00	2000	40KV 100 feeder	14, 1 and 14, 2	40KV 100 A, B	40KV 100 A, B relay operated	14, 1 & 14, 2	DC Failure	Line Trip on 100 A & B circuit
(C) 40-KV Sengkha Substation														
1	09/9/2021	4:01	09/9/2021	4:10	0	31	0	20MVA Transformer II	All the Outgoing feeders got affected as both the transformer was tripped.	Due to Failure of DC, The transformer got tripped.	NO	Chukha Substation	DC Failure	After rectification of the DC circuit, Reset the relay and test charged, the transformer and hold normal.
2	09/9/2021	3:34	09/9/2021	4:10	0	39	2.0	20MVA Transformer I	All the Outgoing feeders got affected as both the transformer was tripped.	Due to Failure of DC, The transformer got tripped.	NO	Chukha Substation	DC Failure	After rectification of the DC circuit, Reset the relay and test charged, the transformer and hold normal.
3	09/9/2021	03:37	09/9/2021	03:40	0	0	4.04	20MVA Transformer II	All the Outgoing feeders got affected, as both the 20MVA Transformer was tripped.	Transformer was tripped while charging of 33KV busbar II.	DC: Over current and Earth fault probe relay #7 open Control trip 2 UN operated, Indication, Bus under Voltage and Over current and earth fault operated.	Line Segments	Transient Fault	Reset the relay and test charged, Transformer hold normal.
4	09/9/2021	01:05	09/9/2021	03:17	0	04	0	20MVA Transformer II	All the Outgoing feeders got affected, as both the 20MVA Transformer was tripped.	Spring discharged due to tripping of 33KV busbar I and II.	NO	Substation	Breaker Spring Discharging	Due to repeated tripping of the 33KV busbar I & II, the 01 st breaker of 20MVA I & II had got spring discharged, due to that charging of transformer could not operated normally from local and remote from control room. The other spring was charged from on-site panel, Charged the Transformer and stand normal.
5	09/9/2021	04:19	09/9/2021	04:25	0	1	4.51	20MVA Transformer II	All the Outgoing feeders got affected, as both the 20MVA Transformer was tripped.	Transformer was tripped while charging of 33KV busbar II.	DC: Over current and Earth fault probe relay #7 open Control trip 2 UN operated, Indication, Bus under Voltage and Over current and earth fault operated.	Line Segments	Transient Fault	Transformer was tripped while charging of 33KV busbar II. After isolating all the feeders, Charged the Transformer and stand normal.
7	09/9/2021	02:22	09/9/2021	02:30	04	04	3.68	40KV Chukha busbar line	All the 33KV charging line was affected.	To Change the Tap Position on off load Condition at Chukha end.	NO	At Chukha end	Shutdown	The supply was held tripped from Chukha end to change the Tap position on DC load condition as to boost the voltage on line as per information received from BPSO.
8	09/9/2021	02:32	09/9/2021	02:36	0	4	4.21	20MVA Transformer I	All the Outgoing feeders got affected, as both the 20MVA Transformer was tripped.	Transformer was tripped while charging of 33KV busbar II.	Under Voltage Operated along with 40 th Tripping relay.	Line Segments	Under Voltage	The Transformer was Tripped, while charging of 33KV busbar II.
9	09/9/2021	01:05	09/9/2021	03:17	0	04	0	20MVA Transformer I	All the Outgoing feeders got affected, as both the 20MVA Transformer was tripped.	Spring discharged due to tripping of 33KV busbar I and II.	Only 80 th Tripping Relay Operated.	Substation	Breaker Spring Discharging	Due to repeated tripping of the 33KV busbar I & II, the 01 st breaker of 20MVA I & II had got spring discharged, due to that charging of transformer could not operated normally from local and remote from control room. The other spring was charged from on-site panel, Charged the Transformer and stand normal.

10	10/9/2021	10:16	10/9/2021	11:07	0	29	1	110KV DPH I Feeder 7	All the 110KV outgoing feeders affected	Due to Change over the supply from Chhokha line	Over Current and Earth Fault along with Master relay Trip, Indication 14-1	Substation	Voltage profile	Due to Voltage boost, the feeders was tripped, Reset the relays and test change the feeders and stand normal.	
11	10/9/2021	11:24	10/9/2021	11:27	0	1	3.38	20MVA Transformer I	All the outgoing feeders get affected as both the transformer was tripped	Transformer was tripped while charging of 110V Incomer II	Only 40 Tripping Relay Operated	Line Segment	Transformer Fault	The Transformer was Tripped while charging of 110V Incomer II , Reset the relay and re-energized Transformer hold normal.	
12	00000000	7:16	00000000	7:21	07	0.36	20MVA Transformer I	All the outgoing feeders get affected as both the transformer was tripped	Due to Under Voltage	Indication: Bus under voltage signal, O/C and E/F along with tripping relay 40	Line Segment	Transformer Fault	Reset the relay and not changed Transformer hold normal.		
13	00000000	10:13	00000000	11:11	29	1.08	20MVA Transformer I	All the outgoing feeders get affected as both the transformer was tripped	Due to Under Voltage	Indication: Bus under voltage signal, O/C and E/F along with tripping relay 40	Line Segment	Transformer Fault	Reset the relay and not changed Transformer hold normal.		
14	00000000	11:21	00000000	11:40	22	0	20MVA Transformer I	The feeders was not effected as the supply was fed from Transformer II	Hand Tripped	Nil	Line Segment	Hand Tripped	The Transformer was tripped after instruction from BPSO for testing of voltage changed the transformer with charging code 1417 from BPSO and hold normal		
15	00000000	11:08	00000000	11:08	1	3.49	20MVA Transformer II	The feeders was not effected as the supply was fed from 20MVA Transformer I	Tap Changing of Transformer	Nil	Substation	Due to under voltage	20MVA II hand tripped after getting clearance from BPSO to increase the tap position from 11 to 9 with opening code no 0176 Charged the transformer with closing code no 1080 and stand normal.		
16	00000000	10:46	00000000	10:56	10	0.62	20MVA Transformer II	The feeders was not effected as the supply was fed from 20MVA Transformer I	Tap Changing of Transformer	Nil	Substation	Due to under voltage	20MVA II hand tripped after getting order from BPSO to decrease the tap position from 11 to 9 with opening code no 0176 and charged the transformer with closing code no 1192 and stand normal.		
(F) 66-33/11KV Lobshe Substation															
1	02.10.2021	06:08hr	02.10.2021	06:08hr	0	22	24.820	66KV LAA-Duchula	NA	Under voltage at Duchula end	BPMI UNDER relay	NA	NA	66KV LAA -Duchula tripped at 06:08 hrs operating breaker open at our end and informed BPSO and line was charged at 06:11hrs with the charging code 1476	
2	04.10.2021	20:52hr	04.10.2021	20:56hr	0	4	25.090	66KV LAA-Duchula	NA	NA	Dist relay operated with 40 relay	NA	NA	66KV LAA -Duchula tripped at 20:52 hrs operating breaker open at our end and informed BPSO and line was charged at 20:56hrs with the charging code 1476 and DR submitted to BPSO & C&PD	
3	04.10.2021	21:02hr	04.10.2021	21:03hr	0	9	22.900	66KV LAA-Duchula	NA	NA	Dist relay operated with 40 relay	NA	NA	66KV LAA -Duchula tripped at 21:02 hrs operating breaker open at our end and informed BPSO and line was charged at 21:11hrs with the charging code 1477 and DR submitted to BPSO & C&PD	
4	04.10.2021	21:10hr	04.10.2021	21:10hr	0	12	22.900	66KV LAA-Duchula	NA	NA	Dist relay operated with 40 relay	NA	NA	66KV LAA -Duchula tripped at 21:10 hrs operating breaker open at our end and informed BPSO and line was charged at 21:11hrs with the charging code 1479 and DR submitted to BPSO & C&PD	
5	04.10.2021	03:54hr	04.10.2021	04:56hr	0	4	-25.200	66KV LAA-Bharchu	NA	NA	Master operated	NA	NA	66KV LAA -Bharchu feeder tripped at 03:54hrs operating breaker one end and was breaker closed at 04:56hrs supply was fed back for Duchula at time of tripping LAA-Bharchu feeder	
(F) 66-33/11 KV Pasa Substation															
1	08.10-2021	11:18hr	08.10-2021	11:12hr	0	0	0.47	66KV Chhokha Line to	No outages	Tripped from Chhokha	-				
(F) 66-33/11KV Animes Substation															
1	04.10.2021	11:23	04.10.2021	11:27	0	4	06.72	Chhokha B - 11.70 Chhokha	66KV lines, Chhokha & Changdaphu	Blackout	Supply failed from Chhokha		Line segment	Supply failed from the source	
1	01.10.2021	06:08hr	01.10.2021	06:08hr	0.00	172.120	220KV Sumbhuwa-Bharchu Line	220KV Sumbhuwa-Bharchu Line and Sumbhuwa	220KV Sumbhuwa-Bharchu Line and Sumbhuwa	220KV Sumbhuwa-Bharchu Line and Sumbhuwa	220KV Sumbhuwa-Bharchu Line and Sumbhuwa	220KV Sumbhuwa-Bharchu Line and Sumbhuwa	220KV Sumbhuwa-Bharchu Line and Sumbhuwa	220KV Sumbhuwa-Bharchu Line and Sumbhuwa	220KV Sumbhuwa-Bharchu Line and Sumbhuwa
2	01.10.2021	06:07hr	01.10.2021	06:07hr	1.00	45.190	220KV Sumbhuwa-Bharchu Line	220KV Sumbhuwa-Bharchu Line and Sumbhuwa	220KV Sumbhuwa-Bharchu Line and Sumbhuwa	220KV Sumbhuwa-Bharchu Line and Sumbhuwa	220KV Sumbhuwa-Bharchu Line and Sumbhuwa	220KV Sumbhuwa-Bharchu Line and Sumbhuwa	220KV Sumbhuwa-Bharchu Line and Sumbhuwa	220KV Sumbhuwa-Bharchu Line and Sumbhuwa	220KV Sumbhuwa-Bharchu Line and Sumbhuwa
3	01.10.2021	21:34hr	01.10.2021	21:32hr	14.00	38.310	220KV Sumbhuwa-Bharchu Line	220KV Sumbhuwa-Bharchu Line and Sumbhuwa	220KV Sumbhuwa-Bharchu Line and Sumbhuwa	220KV Sumbhuwa-Bharchu Line and Sumbhuwa	220KV Sumbhuwa-Bharchu Line and Sumbhuwa	220KV Sumbhuwa-Bharchu Line and Sumbhuwa	220KV Sumbhuwa-Bharchu Line and Sumbhuwa	220KV Sumbhuwa-Bharchu Line and Sumbhuwa	220KV Sumbhuwa-Bharchu Line and Sumbhuwa
4	01.10.2021	11:43hr	01.10.2021	11:44hr	0.00	63.730	220KV Sumbhuwa-Bharchu Line	220KV Sumbhuwa-Bharchu Line and Sumbhuwa	220KV Sumbhuwa-Bharchu Line and Sumbhuwa	220KV Sumbhuwa-Bharchu Line and Sumbhuwa	220KV Sumbhuwa-Bharchu Line and Sumbhuwa	220KV Sumbhuwa-Bharchu Line and Sumbhuwa	220KV Sumbhuwa-Bharchu Line and Sumbhuwa	220KV Sumbhuwa-Bharchu Line and Sumbhuwa	220KV Sumbhuwa-Bharchu Line and Sumbhuwa
5	24.09.2021	10:03hr	24.09.2021	12:55hr	1.00	52.00	66KV Chhokha Line	66KV Chhokha Line and Sumbhuwa	66KV Chhokha Line and Sumbhuwa	66KV Chhokha Line and Sumbhuwa	66KV Chhokha Line and Sumbhuwa	66KV Chhokha Line and Sumbhuwa	66KV Chhokha Line and Sumbhuwa	66KV Chhokha Line and Sumbhuwa	66KV Chhokha Line and Sumbhuwa
6	01.10.2021	09:15hr	01.10.2021	10:20hr	414.00	17.710	66KV Chhokha Line	66KV Chhokha Line and Sumbhuwa	66KV Chhokha Line and Sumbhuwa	66KV Chhokha Line and Sumbhuwa	66KV Chhokha Line and Sumbhuwa	66KV Chhokha Line and Sumbhuwa	66KV Chhokha Line and Sumbhuwa	66KV Chhokha Line and Sumbhuwa	66KV Chhokha Line and Sumbhuwa
7	01.10.2021	10:27hr	01.10.2021	10:30hr	0.00	10.00	66KV Chhokha Line	66KV Chhokha Line and Sumbhuwa	66KV Chhokha Line and Sumbhuwa	66KV Chhokha Line and Sumbhuwa	66KV Chhokha Line and Sumbhuwa	66KV Chhokha Line and Sumbhuwa	66KV Chhokha Line and Sumbhuwa	66KV Chhokha Line and Sumbhuwa	66KV Chhokha Line and Sumbhuwa
8	01.10.2021	09:03hr	01.10.2021	09:03hr	1.00	11.00	66KV Chhokha Line	66KV Chhokha Line and Sumbhuwa	66KV Chhokha Line and Sumbhuwa	66KV Chhokha Line and Sumbhuwa	66KV Chhokha Line and Sumbhuwa	66KV Chhokha Line and Sumbhuwa	66KV Chhokha Line and Sumbhuwa	66KV Chhokha Line and Sumbhuwa	66KV Chhokha Line and Sumbhuwa
9	24.09.2021	09:13hr	24.09.2021	09:12hr	1.00	27.00	66KV Chhokha Line	66KV Chhokha Line and Sumbhuwa	66KV Chhokha Line and Sumbhuwa	66KV Chhokha Line and Sumbhuwa	66KV Chhokha Line and Sumbhuwa	66KV Chhokha Line and Sumbhuwa	66KV Chhokha Line and Sumbhuwa	66KV Chhokha Line and Sumbhuwa	66KV Chhokha Line and Sumbhuwa

November 2021

Sl No	Date of Tripping	Time of outage	Date of Normalization	Time of fault re-occurred	Duration of Outage (hrs)	WPP Index outage (WPP)	Feeder Name	Name of the Substation, When affected by the fault	Reasons of Fault	Relay operations	Exact location of fault (Line segment/ Substation)	Type of outage	Remarks
131-000-101/04-11 KV Western Substation													
131-000-101-01 KV Western Substation													
1	15.11.2021	16:08	18.11.2021	16:08	0	33	100 MW KT	-	Tripped	PRO (P)W(1)KT tripped (M open)	100 MW KT	Tripped	KT got tripped due to on-going maintenance work on upper phase WCT while resuming the connection of PRO of Upper Phase-KT.
2	16.11.2021	9:49	16.11.2021	16:01	0	49	100 MW KT	-	Tripped	WCT surge relay open (M open) (M open)	100 MW KT	Tripped	KT got tripped due to on-going maintenance work on upper phase WCT while resuming the connection of PRO of Upper Phase-KT.
131-000-101-02 KV Western Substation													
1	14.11.2021	8:02hr	14.11.2021	8:16hr		450W	40KV WCT feeder	131-1 and 131-2	4VC, 4VCL, 4F & 4FO	4VC, 4VCL, 4F & 4FO relay operated	40KV WCT feeder (changed after mounting relay and supply feed normal for the 131-1 Substation get developmental problem as it could not lock on high for some WCT off after consulting with Maintenance team	Tripped	
131-000-101-03 KV Western Substation													
1	11.07.2021	19:38	11.07.2021	19:50	0	14.06	40-13KV (2)KV WCT Transformer 2	All bus charging and busbar feeders get affected as the Transformer 1 & 2 was tripped	Due to three (3) phase and earth fault	Three circuit breakers with both along with its trip relay	Chattis Substation	Transient	Reset the relay and changed the transformer individually and feed normal
2	11.07.2021	19:38	11.07.2021	19:50	0	14.06	40-13KV (2)KV WCT Transformer 2	All bus charging and busbar feeders get affected as the Transformer 1 & 2 was tripped	Due to three (3) phase and earth fault	Three circuit breakers with both along with its trip relay	Chattis Substation	Transient	Reset the relay and changed the transformer individually and feed normal
3	11.08.2021	20:54	11.08.2021	21:02	0	01.76	40KV Chattis Substation Line	Chattis substation	Load Shed	Not	Line Segment	Line Protection	As per the information received from the franchisee and the supply was not there because of the 131-1 Substation. Therefore, the franchisee has been provided a 10hr.
131-000-101-04 KV Western Substation													
1	15.11.2021	11:47hr	15.11.2021	11:59hr	0	27.17%	40KV Chattis Substation	NA	NA	NA relay operated	NA	NA	40KV L.A. Chattis tripped at 11:47 hr, operating breaker open at 11:59
2	16.11.2021	20:59hr	16.11.2021	21:09hr	0	23.20%	40KV Chattis Substation	NA	NA	47 relay operated	NA	NA	40KV L.A. Chattis tripped at 20:59 hr, operating breaker open at 21:09
3	16.11.2021	21:02hr	16.11.2021	21:20hr	12	4.56%	40KV L.A. Chattis	NA	NA	NA	NA	NA	40KV L.A. Chattis feed relay tripped at 21:02 hr, open at 21:20
4	16.11.2021	20:59hr	16.11.2021	21:09hr	1	32.03%	40KV L.A. Chattis	NA	NA	47 relay operated	NA	NA	40KV L.A. Chattis breaker tripped at 20:59 hr, operating breaker open at 21:09
131-000-101-05 KV Western Substation													
1	26.11.2021	20:46hr	26.11.2021	20:46hr	0		40KV Chattis Substation	Chattis-NA	Supply feeded from source				
2	26.11.2021	20:47hr	26.11.2021	21:06hr	0		40KV Chattis Substation	Chattis-NA	Supply feeded from source				
131-000-101-06 KV Western Substation													
1	26.11.2021	20:56hr	26.11.2021	19:02hr		40.00%	22KV Chattis Substation Chattis Line	Chattis Substation		Chattis and Chattis opened during the test change of 22KV Chattis Chattis Line		Transient	
2	26.11.2021	20:42hr	27.11.2021	19:46hr	22.04	40.00%	22KV Chattis Substation Chattis Line and Chattis Substation	22-0 Chattis (2)KV at Chattis (2)KV	Chattis L.A. High Trip, Fault (2)KV L.A.		1.0hr	Permanent	
131-000-101-07 KV Western Substation													
1	26.11.2021	20:42hr	26.11.2021	20:06hr	0	4.75	40KV Chattis Substation Chattis Line	40KV Chattis Chattis Line	Load Fault	Chattis relay open, High Trip		Transient	
131-000-101-08 KV Western Substation													
1	06.11.2021	00:01hr	06.11.2021	00:02hr	0	0.07	Transformer 2	Chattis Substation & all charging Feeder	Tripping	40KV	NA		Tripped due to earth fault on Chattis Feeder (2)KV (2) Phase Trip)
2	06.11.2021	07:01hr	06.11.2021	07:02hr	0	0.1	Transformer 2	Chattis Substation & all charging Feeder	Tripping	40KV	NA		Tripped due to earth fault on Chattis Feeder (2)KV (2) Phase Trip)
3	06.11.2021	02:01hr	06.11.2021	02:02hr	0	0	Transformer 1	NA	Tripping	NA	NA		Transformer 1 (2)KV was tripped due to earth fault on the 22KV (2) Phase Trip
4	06.11.2021	02:01hr	06.11.2021	02:02hr	0	0.07	Transformer 2	Chattis Substation & all charging Feeder	Tripping	40KV	NA		Tripped due to earth fault on Chattis Feeder
5	06.11.2021	02:01hr	06.11.2021	02:02hr	0	0	Transformer 1	NA	Tripping	40KV	NA		Line change Feeder 1 (2)KV (2) Phase Trip
6	06.11.2021	02:01hr	06.11.2021	02:02hr	0	0	Transformer 1	NA	Tripping	40KV	NA		Line change Feeder 1 (2)KV (2) Phase Trip
7	07.11.2021	02:01hr	07.11.2021	02:02hr	0	0.06	Transformer 1	Chattis Substation & all charging Feeder	Tripping	40KV	NA		Tripped due to earth fault on Chattis Feeder
8	07.11.2021	02:01hr	07.11.2021	02:02hr	0	0	Transformer 1	Chattis Substation & all charging Feeder	Tripping	40KV	NA		Tripped due to earth fault on Chattis Feeder
9	07.11.2021	02:01hr	07.11.2021	02:02hr	0	0	Transformer 1	Chattis Substation & all charging Feeder	Tripping	40KV	NA		Tripped due to earth fault on Chattis Feeder
10	07.11.2021	02:01hr	07.11.2021	02:02hr	0	0.08	Transformer 2	NA	Tripping	40KV	NA		Transformer 2 (2)KV (2) Phase Trip, after refueling, all load given to 10KV, changed and the 10KV (2) Phase Trip
11	07.11.2021	02:01hr	07.11.2021	02:02hr	0	0.08	Transformer 1	NA	Tripping	40KV	NA		Line change Feeder 1 (2)KV (2) Phase Trip, after refueling, all load given to 10KV, changed and the 10KV (2) Phase Trip
12	07.11.2021	02:01hr	07.11.2021	02:02hr	0	0	Transformer 1	Chattis Substation & all charging Feeder	Tripping	40KV	NA		Tripped due to earth fault on Chattis Feeder
13	07.11.2021	02:01hr	07.11.2021	02:02hr	0	0	Transformer 1	Chattis Substation & all charging Feeder	Tripping	40KV	NA		Tripped due to earth fault on Chattis Feeder
14	07.11.2021	02:01hr	07.11.2021	02:02hr	0	0	Transformer 1	Chattis Substation & all charging Feeder	Tripping	40KV	NA		Tripped due to earth fault on Chattis Feeder
15	07.11.2021	02:01hr	07.11.2021	02:02hr	0	0	Transformer 1	Chattis Substation & all charging Feeder	Tripping	40KV	NA		Tripped due to earth fault on Chattis Feeder
16	07.11.2021	02:01hr	07.11.2021	02:02hr	0	0	Transformer 1	Chattis Substation & all charging Feeder	Tripping	40KV	NA		Tripped due to earth fault on Chattis Feeder
17	07.11.2021	02:01hr	07.11.2021	02:02hr	0	0	Transformer 1	Chattis Substation & all charging Feeder	Tripping	40KV	NA		Tripped due to earth fault on Chattis Feeder
18	07.11.2021	02:01hr	07.11.2021	02:02hr	0	0	Transformer 1	Chattis Substation & all charging Feeder	Tripping	40KV	NA		Tripped due to earth fault on Chattis Feeder
131-000-101-09 KV Western Substation													
1	26.11.2021	20:56hr	26.11.2021	20:56hr			Substation (2)KV Line	All (2)KV Line	Load Fault	Chattis relay open			22KV Line

