



Table of Contents

1. INTRODUCTION	2
2. NATIONAL PEAK DEMAND.....	2
2.1. POWER (MW) CONSUMED BY COUNTRY	2
3. ENERGY AVAILABILITY AND REQUIREMENT FOR THE COUNTRY.....	3
3.1. ENERGY (MU) CONSUMED BY COUNTRY	3
4. PERFORMANCE OF GENERATING PLANTS.....	4
4.1. POWER AND ENERGY GENERATION	4
4.2. PLANT CAPACITY FACTOR.....	5
5. EXPORT AND IMPORT OF ELECTRICITY.....	5
6. FREQUENCY PROFILE.....	6
6.1. FREQUENCY FOR THE MONTH OF JULY, 2022	6
6.2. FREQUENCY FOR THE MONTH OF AUGUST, 2022	7
6.3. FREQUENCY FOR THE MONTH OF SEPTEMBER, 2022.....	8
6.4. FREQUENCY SUMMARY FOR THE MONTH OF JULY TO SEPTEMBER, 2022.....	9
7. VOLTAGE PROFILE OF SELECTED SUBSTATION	9
7.1. VOLTAGE PROFILE FOR THE JULY, 2022	10
7.2. VOLTAGE PROFILE FOR MONTH OF AUGUST, 2022	11
7.3. VOLTAGE PROFILE FOR THE MONTH OF SEPTEMBER, 2022.....	12
7.4. VOLTAGE SUMMARY FOR THE MONTH OF JULY TO SEPTEMBER, 2022.....	13
8. MAJOR OUTAGES OF FEEDERS AND EQUIPMENT	14
8.1. MAJOR OUTAGES IN EASTERN GRID	14
8.2. MAJOR OUTAGES IN WESTERN GRID	14
9. ANNEXURES	14



1. Introduction

The electricity transmission network in Bhutan is solely owned by Bhutan Power Corporation limited (BPC) and electricity generation is solely owned by Druk Green Power Corporation Limited (DGPC). The Office of the Bhutan Power System Operator (BPSO) under Ministry of Energy and Natural Resources is responsible for safe, secure and efficient operation of Bhutan transmission network and generation.

This quarterly report is prepared in compliance to the Grid Code Regulation (GCR) 2008, clause 6.14.1, and “System Operator has to submit a quarterly report covering the performance of the Transmission System to all Licensees, Authority and Ministry”. This transmission performance report contains summary of growth of peak demand, performance of generating stations (power and energy generation), energy availability and requirement for the country, export and import of electricity to/ from India, frequency profile of selected substation and voltage profile of few important substations.

All the index and other calculations in this report have been executed based on the data received from substations and generating plants.


2. National Peak Demand

The national peak demand till now is recorded at **435.35MW** which was occurred on December 26, 2021 at 18:00 hours. This is calculated by summation of Feeder Loading at Plants minus Export.

Table 2.1. The National Peak Demand since 2007

Year	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021
Peak Load (MW)	157.36	187.05	237.17	256.95	276.24	282.44	313.94	333.41	336.52	335.87	362.09	399.35	387.66	374.53	435.35
% Growth over previous Year	-	18.87	26.79	8.34	7.51	2.24	11.15	6.20	0.93	-0.19	7.81	10.29	-2.93	-3.39	16.24

Graph 2.1. The growth in National Peak Demand since 2007



2.1. Power (MW) consumed by country

Following methods are used to calculate peak demand for the Eastern Grid, Western Grid and National demand.

1. **National Demand** = (Sum of all total generation)-(Sum of all Export or Import)
2. **National Demand** = (Sum of all feeders loading at hydropower station) – (Sum of all Export/Import)
3. **National Demand** = (Sum of all substation loading)


For this report, the National Demand was calculated using method-1



Table 2.1.2. Domestic demand for Eastern Grid, Western Grid and National using method- 1

Grid	Eastern Grid Load (MW)		Western Grid Load (MW)		National Load (MW)	
	Max	Min	Max	Min	Max	Min
July	143.03	126.00	487.45	99.30	540.67	114.15
August	198.09	112.00	430.26	60.24	527.18	138.29
September	196.43	112.90	400.75	113.86	530.45	102.27

Graph 2.1.2. Domestic demand for Eastern Grid, Western Grid and National using method- 1



The national load pattern for the month of July to September, 2022 calculated using method-1 is attached as **Annexure-II**

3. Energy Availability and Requirement for the country

3.1. Energy (MU) consumed by Country

The total energy consumed within Bhutan is computed from the total energy DGPC had sold to BPC including the royalty energy.

Table 3.1.1. Total Energy (MU) consumed

Month	Total Ex-bus (MU)	Total Export/Import (MU)	Total energy sold to BPC (MU)
July	1466.27185885	1165.18020988	302.86886546
August	1687.51443064	1368.19948924	321.19551127
September	1647.27563936	1332.65091566	316.52998178

Graph 3.1.1. Total Energy (MU) consumed







Table 3.1.2. Energy (MU) consumed

Grid	Eastern Grid Consumption	Western Grid Consumption	Total Consumption
Month	(MU)	(MU)	(MU)
July	59.728885600	224.844968	284.5738535
August	61.584417200	240.532610	302.1170268
September	60.13601145	238.081376	298.2173871

Graph 3.1.2. Energy (MU) consumed



4. Performance of generating plants

4.1. Power and Energy Generation


The maximum total generation for the third quarter of year 2022 was 2,465.02 MW in month of September and minimum generation was 884.67 MW in the July month.

Table: 4.1.1 Summary of maximum and minimum generation by various hydropower plant

Generation By	BHP (MW)		CHP (MW)		THP (MW)		KHP (MW)		DHP (MW)		MHPA (MW)		TOTAL (MW)	
Month	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min
July	66.40	10.70	369.99	79.47	1,122.00	557.00	66.00	0.00	127.03	44.31	594.19	193.19	2,345.61	884.67
August	66.58	33.34	353.00	259.79	1,122.00	830.00	66.00	0.00	127.07	57.38	729.82	393.37	2,464.47	1,576.08
September	66.39	21.10	353.39	165.59	1,122.00	734.00	66.00	0.00	127.32	63.57	729.92	232.07	2,465.02	1,216.13

Source: Hydropower Plants (DGPC)

Graph: 4.1.1 Summary of maximum and minimum generation by various hydropower plant





Daily maximum, minimum and average generation by each generating plant for the month of July to September, 2022 is attached as Annexure-I.

4.2.Plant Capacity Factor

The capacity factor of each generating plant was calculated as below:


$$Capacity\ factor = \frac{Total\ energy\ plant\ has\ produce\ over\ a\ period}{Total\ energy\ plant\ would\ produce\ when\ operated\ at\ full\ capacity}$$

Table 4.2.1: Total generation and capacity factor of various hydropower plants

Month	BHP (MU)	BHP (CF)	CHP (MU)	CHP (CF)	THP (MU)	THP (CF)	KHP (MU)	KHP (CF)	DHP (MU)	DHP (CF)	MHP (MU)	MHP (CF)
July	43.83676	95.13%	217.85103	90.05%	692.638545	94.31%	47.016469	108.83%	62.04	68.39%	1,466.27	282.85%
August	47.02880	98.77%	68.64779	27.46%	220.88800	29.11%	134.037818	300.26%	30.752396	32.80%	0	0.00%
September	46.97590	101.94%	63.49768	26.25%	225.46300	30.70%	185.114909	428.51%	27.62	30.45%	0.00	0.00%

Source: ID, BPC

Graph 4.2.1: Capacity factor of various hydropower plants



5. Export and Import of Electricity

Maximum export for the third quarter of year 2022 was 1,280.73 MW in the month of August to Binaguri substation in India. The minimum export recorded was 2 MW to Salakoti & Rangia substation in India during the month of July.

Table 5.1. Export of electricity to India

Export To	Binaguri (MW)		Birpara (MW)		Salakoti and Rangia (MW)	
	Max	Min	Max	Min	Max	Min
July	1,209.00	571.03	232.88	51.30	77.24	2.00
August	1,280.73	727.27	260.74	52.32	77.91	13.79
September	1,136.36	559.00	281.22	4.30	95.51	0.50

Graph 5.1. Export of electricity to India





Table 5.2. Import of electricity from India.

Import From	Binaguri (MW)		Birpara (MW)		Salakoti and Rangia (MW)	
	Max	Min	Max	Min	Max	Min
July	0.00	0.00	0.00	0.00	20.02	1.29
August	0.00	0.00	0.00	0.00	10.24	10.24
September	0.00	0.00	24.16	24.16	15.60	0.06

Graph 5.3. Import of electricity to India



6. Frequency profile

The nominal allowed frequency range shall be 50Hz ± 1% in Bhutan. The system is normally managed such that frequency is maintained within operational limit of 49.5 Hz to 50.5 Hz. However, frequency may move outside these limit under faulty condition.

As per the Grid Code 2008, clause 6.4.1 the frequency is classified into three different bands as follows:

- Normal state
The transmission System frequency is within the limit of 49.5Hz to 50.5Hz.
- Alert state
The Transmission System frequency is beyond the normal operating limit but within 49.0Hz to 50.0Hz.
- Emergency state
There is generation deficiency and frequency is below 49.0Hz.

The frequency at 220kV Bus at 220/66/11kV Semtokha substation in the western grid and 132kV Bus at 60MW Kurichhu Hydropower Plant in the eastern grid is considered.

6.1. Frequency for the month of July, 2022

Table 6.1.1. Bus Frequency profile of Semtokha Substation

Sl. No.	Operating State	Frequency
1	Normal State	100.00%
2	Alert State	0.00%
3	Emergency State	0.00%
4	Blackout/Other	0.00%

Graph 6.1.1. Bus Frequency of Semtokha Substation





Table 6.1.2. Bus frequency of Kurichhu Hydro Power Plant

Sl. No.	Operating State	Frequency
1	Normal State	98.79%
2	Alert State	0.00%
3	Emergency State	0.00%
4	Blackout/Other	1.21%

Graph 6.1.2. Bus frequency of Kurichhu Hydro Power Plant



In the month of July, 2022, the Western grid has maintained the frequency within the normal operating limit of 100% and Eastern grid has maintained the normal operating limit of 98.79% and deviated 1.21% to blackout/others.

6.2.Frequency for the month of August, 2022

Table 6.2.1. Bus frequency of Semtokha Substation

Sl. No.	Operating State	Frequency
1	Normal State	99.87%
2	Alert State	0.13%
3	Emergency State	0.00%
4	Blackout/Other	0.00%

Graph 6.2.1. Bus frequency of Semtokha Substation





Table 6.2.2. Bus frequency of Kurichhu Hydro Power Plant

Sl. No.	Operating State	Frequency
1	Normal State	100.00%
2	Alert State	0.00%
3	Emergency State	0.00%
4	Blackout/Other	0.00%

Graph 6.2.2. Bus frequency of Kurichhu Hydro Power Plant



In the month of August, 2022, the western grid frequency was maintained at normal operating range of 99.87% and deviated 0.13% to Alert state whereas Eastern grid was maintained at maintained at normal operating range of 100%

6.3. Frequency for the month of September, 2022

Table 6.3.1. Bus frequency of Semtokha Substation

Sl. No.	Operating State	Frequency
1	Normal State	96.51%
2	Alert State	0.00%
3	Emergency State	0.00%
4	Blackout/Other	3.49%

Graph 6.3.1. Bus frequency of Semtokha Substation







Table 6.3.2. Bus frequency of Kurichhu Hydro Power Plant

Sl. No.	Operating State	Frequency
1	Normal State	96.37%
2	Alert State	0.40%
3	Emergency State	0.00%
4	Blackout/Other	3.23%

Graph 6.3.2. Bus frequency of Kurichhu Hydro Power Plant




In the month of September, 2022, western grid frequency had maintained at 96.51% within the normal operating range and deviated 3.49% to blackout/other state. The eastern also maintain within normal operating range of 96.37 %, deviated 0.40% to alert state and 3.23 % to blackout/other state.

6.4.Frequency Summary for the month of July to September 2022

Table 6.4.1. Frequency summary for the month of July to September, 2022.

Substation/Plant	Bus Frequency at Semtokha Substation (Hz)		Bus Frequency at Kurichhu Hydropower Plant (Hz)	
	Max	Min	Max	Min
July	50.20	49.60	50.25	49.60
August	50.20	49.40	50.25	49.49
September	50.10	49.80	50.50	49.59

Graph 6.4.1. Frequency summary for the month of July to September, 2022



Daily maximum, minimum and average Frequency of Malbase substation in western grid and Kurichhu Hydro Power Plant in eastern grid for the month of July to September, 2022 is attached as **Annexure-III**

7. Voltage Profile of selected substation

As per the Grid Code 2008, clause 6.4.1 the voltage at all connection point is classified into three different bands as follows:

1. *Normal State*
The voltage at all connection points are within the limits of 0.95 times and 1.05 times of the normal values
2. *Alert State*
The voltage at all connection points are outside the normal limit but within the limits of 0.9 times and 1.1 times of the nominal values.
3. *Emergency State*



Transmission system voltages are outside the limit of 0.9 times and 1.1 times of nominal values.

Due to the location of 400/22/66/11kV Malbase substation in western grid and 132/33/11kV Nangkhor substation in the eastern grid, the voltage profile of these substations are considered.

7.1.Voltage profile for the July, 2022

Table 7.1.1. Voltage Profile for 400/220/66kV Malbase Substation

Sl. No.	Operating State	400kV Bus Voltage	220kV Bus Voltage	66kV Bus Voltage
1	Normal State	99.73%	99.73%	99.87%
2	Alert State	0.00%	0.00%	0.00%
3	Emergency State	0.27%	0.27%	0.13%
4	Blackout/Other	0.00%	0.00%	0.00%

Graph 7.1.1. Voltage Profile for 400/220/66kV Malbase Substation




Table 7.1.2. Voltage Profile of 220/66/11kV Semtokha Substation

Sl. No.	Operating State	220kV Bus Voltage	66kV Bus Voltage
1	Normal State	99.87%	100.00%
2	Alert State	0.00%	0.00%
3	Emergency State	0.13%	0.00%
4	Blackout/Other	0.00%	0.00%

Graph 7.1.2. Voltage Profile of 220/66/11kV Semtokha Substation





Table 7.1.3. Voltage Profile of 132/33/11kV Nangkhor Substation

Sl. No.	Operating State	132kV Bus Voltage
1	Normal State	99.73%
2	Alert State	0.13%
3	Emergency State	0.00%
4	Blackout/Other	0.13%

Graph 7.1.3. Voltage Profile of 132/33/11kV Nangkhor Substation



7.2.Voltage Profile for month of August, 2022

Table 7.2.1. Voltage Profile for 400/220/66kV Malbase Substation

Sl. No.	Operating State	400kV Bus Voltage	220kV Bus Voltage	66kV Bus Voltage
1	Normal State	99.87%	99.87%	97.04%
2	Alert State	0.00%	0.00%	2.69%
3	Emergency State	0.00%	0.00%	0.13%
4	Blackout/Other	0.13%	0.13%	0.13%

Graph 7.2.1. Voltage Profile for 400/220/66kV Malbase Substation





Table 7.2.2. Voltage Profile of 220/66/11kV Semtokha Substation

Sl. No.	Operating State	220kV Bus Voltage	66kV Bus Voltage
1	Normal State	100.00%	100.00%
2	Alert State	0.00%	0.00%
3	Emergency State	0.00%	0.00%
4	Blackout/Other	0.00%	0.00%

Graph 7.2.2. Voltage Profile of 220/66/11kV Semtokha Substation







Table 7.2.3. Voltage Profile of 132/33/11kV Nangkhor Substation

Sl. No.	Operating State	132kV Bus Voltage
1	Normal State	100.00%
2	Alert State	0.00%
3	Emergency State	0.00%
4	Blackout/Other	0.00%

Graph 7.2.3. Voltage Profile of 132/33/11kV Nangkhor Substation



7.3. Voltage Profile for the month of September, 2022

Table 7.3.1. Voltage Profile for 400/220/66kV Malbase Substation

Sl. No.	Operating State	400kV Bus Voltage	220kV Bus Voltage	66kV Bus Voltage
1	Normal State	96.77%	96.64%	95.97%
2	Alert State	0.00%	0.00%	0.40%
3	Emergency State	0.00%	0.13%	0.00%
4	Blackout/Other	3.23%	3.23%	3.63%

Graph 7.3.1. Voltage Profile for 400/220/66kV Malbase Substation








Table 7.3.2. Voltage Profile of 220/66/11kV Semtokha Substation

Sl. No.	Operating State	220kV Bus Voltage	66kV Bus Voltage
1	Normal State	96.37%	96.51%
2	Alert State	0.00%	0.00%
3	Emergency State	0.13%	0.00%
4	Blackout/Other	3.49%	3.49%

Graph 7.3.2. Voltage Profile of 220/66/11kV Semtokha Substation





Table 7.3.3. Voltage Profile of 132/33/11kV Nangkhon Substation

Sl. No.	Operating State	132kV Bus Voltage
1	Normal State	96.77%
2	Alert State	0.00%
3	Emergency State	0.00%
4	Blackout/Other	3.23%

Graph 7.3.3. Voltage Profile of 132/33/11kV Nangkhon Substation




7.4. Voltage Summary for the Month of July to September, 2022

Table 7.4.1. Voltage Summary for the month of July to September, 2022

Substation	Malbase Substation						Nangkhon Substation	
	400kV Bus Voltage (kV)		220kV Bus Voltage (kV)		66kV Bus Voltage (kV)		132kV Bus Voltage (kV)	
Month	Max	Min	Max	Min	Max	Min	Max	Min
July	414.00	405.00	224.00	221.00	66.35	63.10	139.87	126.34
August	414.50	402.00	222.50	209.50	68.00	60.01	136.31	129.04
September	415.50	399.00	223.00	214.50	68.00	62.00	136.10	129.45

Graph 7.4.1. Voltage Summary for the month of July to September, 2022





Daily maximum, minimum and average bus voltage of Malbase substation in western grid and Nangkhor substation in eastern grid for the month of July to September, 2022 is attached as **Annexure-IV**

8. Major Outages of Feeders and Equipment

The transmission lines and equipment which were shut down for annual maintenance and hand/force trip are not considered in the report.

8.1. Major Outages in Eastern Grid

It had been observed that there was multiple major tripping occurred during the third quarter of the year compare to the previous quarter. Generally, all the tripping occurred are of transient in nature but the maximum restoration time 38hr.

The feeders and equipment outages for the Eastern grid is attached as **Annexure-V**.

8.2. Major Outages in Western Grid

It had been observed that there was major tripping occurred during the third quarter year as compared to the previous quarter the restoration time was ranging from 2hrs-1847hrs.

The detail tripping report of any element is compiled and circulated to relevant stakeholder every month.

The feeders and equipment outages for the Western grid is attached as **Annexure-VI**.

9. Annexures

Annexure-I

Table: Generation of July, 2022

Jul-22 Date	BHP (MW)			CHP (MW)			THP (MW)			KHP (MW)			DHP (MW)			MHP (MW)			
	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	
1	66.33	63.72	66.12	369.32	277.26	331.03	1,122.00	1,122.00	1,122.00	0.00	0.00	0.00	126.83	93.27	104.11	593.64	591.70	592.83	
2	66.34	66.08	66.20	369.56	275.58	332.38	1,122.00	1,122.00	1,122.00	65.77	64.90	65.31	126.89	95.39	110.76	594.19	592.01	593.21	
3	66.24	65.97	66.09	369.97	268.82	368.16	1,122.00	935.00	1,114.21	66.00	64.59	65.33	105.31	45.00	86.29	594.06	193.19	568.54	
4	0.00	65.73	66.05	369.99	367.63	368.52	1,122.00	871.00	1,001.33	66.00	66.00	66.00	97.46	82.12	81.18	593.67	394.26	580.42	
5	0.00	62.10	64.52	369.40	367.05	368.26	1,021.00	777.00	887.92	66.00	66.00	66.00	74.37	66.27	70.71	593.59	591.95	593.04	
6	0.00	22.05	38.83	369.07	366.70	366.26	1,078.00	699.00	867.83	66.00	66.00	66.00	87.31	82.28	64.92	593.59	538.15	578.57	
7	63.33	58.20	60.87	369.26	79.47	352.51	867.00	557.00	783.63	66.00	66.00	66.00	62.33	57.46	60.36	573.08	479.48	521.21	
8	60.48	40.52	57.96	277.29	272.65	275.42	747.00	557.00	707.00	66.00	65.71	65.92	63.64	56.88	58.44	540.75	358.22	304.46	
9	66.11	56.12	61.80	274.55	272.84	273.87	837.00	717.00	752.13	66.00	66.00	66.00	126.41	38.41	84.76	378.26	392.50	517.33	
10	57.08	51.25	55.06	274.63	272.71	273.88	817.00	617.00	722.67	66.00	66.00	66.00	64.35	55.46	59.55	538.40	460.68	497.25	
11	55.84	10.70	49.75	277.00	273.82	275.00	790.00	670.00	730.00	66.00	66.00	66.00	56.46	33.37	54.83	569.55	470.83	521.93	
12	54.50	49.71	50.80	276.72	275.56	276.23	824.00	630.00	721.21	66.00	66.00	66.00	53.93	51.36	52.37	585.00	479.36	526.85	
13	49.69	48.05	49.13	276.98	274.87	276.04	1,122.00	690.00	890.08	66.00	66.00	66.00	52.46	48.94	51.33	566.06	300.53	533.02	
14	48.15	44.26	47.05	276.82	274.69	276.15	1,122.00	774.00	1,016.34	66.00	66.00	66.00	30.52	48.00	49.70	592.90	429.05	569.19	
15	48.69	45.10	46.17	276.79	275.01	276.13	921.00	607.00	829.21	66.00	65.69	65.95	39.94	48.99	50.74	593.08	465.49	531.90	
16	44.94	44.20	44.59	277.22	275.32	276.39	764.00	607.00	712.88	66.00	65.34	65.70	45.77	44.32	45.28	479.92	420.70	461.43	
17	44.55	43.10	43.65	277.41	275.34	276.05	1,071.00	674.00	789.13	65.91	64.99	65.42	45.77	44.32	45.28	479.91	435.43	465.55	
18	46.59	43.37	44.45	276.67	275.62	276.19	940.00	680.00	747.92	66.00	63.00	62.86	45.59	44.31	45.07	473.53	419.53	443.96	
19	62.06	19.71	49.93	277.11	275.52	276.22	790.00	680.00	710.00	66.00	66.00	66.00	63.23	47.01	54.87	591.99	420.93	542.59	
20	66.09	45.87	56.92	277.03	274.87	276.06	1,061.00	710.00	840.79	66.00	65.81	65.95	123.30	55.86	80.97	593.89	309.47	553.59	
21	66.33	66.07	66.17	277.04	274.78	276.16	1,122.00	851.00	1,002.92	65.14	47.71	63.93	126.94	88.35	113.84	593.89	591.39	592.67	
22	66.30	65.71	66.17	276.74	272.85	276.00	1,122.00	1,122.00	1,122.00	65.12	31.46	62.38	126.98	107.06	122.22	593.62	591.74	593.01	
23	66.33	66.08	66.22	277.19	275.42	276.03	1,122.00	955.00	1,084.29	65.04	59.45	61.83	127.03	124.40	126.56	593.65	592.53	593.27	
24	66.29	66.07	66.20	277.22	274.94	275.93	1,122.00	561.00	1,075.25	66.00	29.81	59.26	124.40	86.44	101.25	593.61	592.84	593.33	
25	66.26	66.05	66.17	277.00	274.66	275.95	1,122.00	935.00	1,083.04	65.83	65.03	65.40	133.33	86.57	99.88	593.68	387.51	567.37	
26	66.33	66.11	66.21	276.79	274.96	276.22	1,122.00	1,122.00	1,122.00	65.50	63.41	64.40	126.95	118.33	123.40	593.13	292.10	571.52	
27	66.33	24.79	43.21	276.79	275.51	276.05	1,122.00	1,122.00	1,122.00	66.00	32.00	54.03	126.95	118.33	123.40	593.62	591.09	592.53	
28	66.40	66.22	66.31	277.07	275.82	276.03	1,122.00	1,122.00	1,122.00	66.00	66.00	66.00	126.90	110.28	121.40	594.01	341.68	310.19	
29	66.53	66.17	66.26	276.44	274.94	275.88	1,122.00	1,122.00	1,122.00	66.00	66.00	66.00	121.40	104.38	114.26	594.16	591.49	593.16	
30	66.30	66.14	66.21	276.85	274.96	276.04	1,122.00	1,122.00	1,122.00	66.00	66.00	66.00	126.89	108.30	119.79	594.12	591.69	593.54	
31	66.34	66.03	66.24	277.06	184.25	272.26	1,122.00	1,122.00	1,122.00	66.00	66.00	66.00	126.93	115.38	122.98	593.73	575.48	592.44	
Max	66.40			369.99			1,122.00			66.00			127.03			594.19			
Min		10.70			79.47			557.00			0.00			44.31			193.19		

Graph: Generation for the month July, 2022




Table: Generation for the month of August, 2022

Aug-22	BHP (MW)			CHP (MW)			THP (MW)			KHP (MW)			DHP (MW)			MHP (MW)			
Date	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	
1	66.33	66.18	66.28	276.73	274.73	276.11	1,122.00	1,122.00	1,122.00	66.00	66.00	66.00	126.98	126.62	126.86	593.81	393.37	373.70	
2	66.38	66.16	66.28	276.76	275.14	276.03	1,122.00	1,122.00	1,122.00	66.00	66.00	66.00	126.95	126.64	126.82	593.88	392.89	393.50	
3	66.38	66.15	66.29	276.85	274.89	276.16	1,122.00	1,122.00	1,122.00	66.00	66.00	66.00	126.98	126.78	126.86	593.79	392.12	393.45	
4	0.00	66.21	66.28	276.75	275.64	276.38	1,122.00	1,122.00	1,122.00	66.00	66.00	66.00	127.87	110.80	123.63	593.90	393.38	393.58	
5	0.00	66.18	66.25	277.09	275.09	276.31	1,122.00	1,122.00	1,122.00	66.00	66.00	66.00	126.95	106.46	113.28	638.83	392.15	399.72	
6	0.00	66.13	66.27	276.98	275.62	276.20	1,122.00	1,122.00	1,122.00	66.00	66.00	66.00	126.98	80.60	121.13	729.83	638.39	706.26	
7	66.58	66.24	66.42	276.98	275.81	276.24	1,122.00	1,122.00	1,122.00	66.00	66.00	66.00	127.03	113.46	122.81	729.72	361.21	721.00	
8	66.29	66.10	66.19	276.62	274.67	276.06	1,122.00	1,122.00	1,122.00	66.00	66.00	66.00	127.48	97.42	107.23	729.07	726.71	728.08	
9	66.29	66.07	66.17	276.89	275.58	276.24	1,122.00	1,122.00	1,122.00	66.00	66.00	66.00	110.49	97.41	102.44	729.04	728.37	728.75	
10	66.31	66.06	66.17	276.99	275.86	276.41	1,122.00	1,122.00	1,122.00	66.00	66.00	66.00	88.44	88.33	93.93	728.98	727.26	728.69	
11	66.21	66.03	66.10	276.87	275.91	276.34	1,122.00	1,122.00	1,122.00	66.00	66.00	66.00	95.39	86.38	91.18	729.02	661.36	721.04	
12	66.43	66.10	66.32	276.80	275.76	276.41	1,122.00	1,122.00	1,122.00	66.00	66.00	66.00	87.40	80.90	84.27	661.56	605.27	633.13	
13	66.34	66.01	66.18	277.13	275.53	276.32	1,122.00	1,122.00	1,122.00	66.00	66.00	66.00	87.48	78.37	80.72	726.80	375.01	613.28	
14	66.18	66.00	66.08	277.13	275.55	276.28	1,122.00	1,122.00	1,122.00	66.00	66.00	66.00	127.03	87.41	116.81	729.55	721.28	727.68	
15	66.27	43.82	65.34	309.45	275.71	282.15	1,122.00	1,122.00	1,122.00	66.00	66.00	66.00	126.84	94.38	118.53	728.75	727.45	728.17	
16	66.19	66.00	66.08	333.41	309.38	324.48	1,122.00	1,122.00	1,122.00	66.00	66.00	66.00	118.48	87.41	96.89	729.82	625.66	689.27	
17	66.25	33.54	55.66	344.07	331.55	340.85	1,122.00	1,122.00	1,122.00	66.00	66.00	66.00	90.52	88.38	84.63	644.42	356.14	391.75	
18	66.14	33.82	50.99	343.89	342.14	342.78	1,122.00	958.00	1,075.18	66.00	66.00	66.00	80.39	75.30	77.87	709.22	550.99	570.07	
19	65.36	64.38	64.81	349.08	342.40	347.10	1,122.00	958.00	1,105.67	66.00	66.00	66.00	87.41	63.50	76.15	729.28	530.92	653.70	
20	64.42	57.94	62.81	348.88	275.75	332.67	1,122.00	978.00	1,073.25	66.00	66.00	66.00	86.36	71.81	76.35	729.36	676.31	714.60	
21	63.39	60.23	60.84	348.93	347.40	348.15	1,122.00	961.00	1,008.75	66.00	66.00	66.00	76.30	68.38	71.83	728.33	391.25	663.81	
22	61.61	56.52	60.04	352.20	347.44	349.10	1,122.00	998.00	1,097.25	66.00	66.00	66.00	82.70	68.69	73.12	729.22	643.69	715.48	
23	61.13	58.93	59.60	352.59	350.67	351.62	1,122.00	948.00	1,046.54	66.00	66.00	66.00	106.40	67.39	76.19	728.96	621.39	707.42	
24	58.77	40.82	57.09	352.39	350.95	351.68	1,105.00	948.00	1,039.29	66.00	66.00	66.00	96.41	68.15	76.49	621.53	576.13	390.00	
25	57.73	54.85	55.73	352.35	348.52	351.70	948.00	884.00	917.96	66.00	65.82	65.99	71.38	63.34	66.43	630.43	541.22	581.51	
26	57.25	54.41	55.53	352.27	351.45	351.92	994.00	830.00	809.13	66.00	65.76	65.94	67.15	62.29	64.08	630.52	516.16	564.18	
27	66.07	51.15	54.68	352.68	351.37	351.83	870.00	830.00	845.00	66.00	33.00	61.81	63.38	57.38	61.10	625.13	529.88	553.33	
28	66.25	65.48	66.07	353.00	348.99	352.01	1,122.00	830.00	1,065.04	66.00	65.71	65.99	126.90	61.45	67.99	729.09	628.90	704.37	
29	66.29	66.01	66.14	352.88	351.37	351.85	1,122.00	1,122.00	1,122.00	66.00	65.74	65.96	127.05	80.37	95.29	729.04	725.98	727.99	
30	66.20	64.88	65.91	352.46	349.13	351.66	1,122.00	1,122.00	1,122.00	65.91	65.60	65.78	104.51	61.14	83.57	728.92	726.95	728.14	
31	66.17	64.79	65.58	352.47	259.79	310.04	1,122.00	1,122.00	1,122.00	65.57	65.02	65.36	126.93	78.42	91.81	728.90	727.45	728.40	
Max	66.58			353.00			1,122.00			66.00			127.07			729.82			
Min		33.54			259.79			830.00			0.00			57.38				395.37	

Source: THP, CHP, BHP, KHP, MHP (DGPC)

Graph: Generation for the month of August, 2022




Table: Generation for the month of September, 2022

Date	BHP (MW)			CHP (MW)			THP (MW)			KHP (MW)			DHP (MW)			MHP (MW)		
	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava
1	21.24	21.10	21.16	352.46	259.18	325.36	1,122.00	1,122.00	1,122.00	16.70	0.00	15.12	101.31	78.91	86.53	729.05	726.82	727.88
2	66.17	65.99	66.10	352.29	259.43	323.44	1,122.00	1,122.00	1,122.00	66.00	66.00	66.00	101.51	78.91	86.53	729.07	726.67	728.35
3	66.28	66.02	66.12	352.58	351.71	352.08	1,122.00	1,122.00	1,122.00	66.00	66.00	66.00	106.41	79.44	86.15	729.26	727.56	728.66
4	0.00	65.94	66.05	352.35	351.80	351.98	1,122.00	1,122.00	1,122.00	66.00	65.82	65.98	101.42	79.28	86.43	729.23	728.10	728.90
5	0.00	64.21	65.28	352.62	351.77	352.12	1,122.00	1,122.00	1,122.00	66.00	66.00	66.00	85.39	74.38	78.75	729.55	725.61	727.87
6	0.00	66.05	66.13	352.27	351.67	352.18	1,122.00	961.00	1,005.54	66.00	65.82	65.98	126.88	74.38	86.19	729.11	725.65	728.31
7	66.23	66.03	66.12	352.49	351.11	352.03	1,122.00	1,122.00	1,122.00	66.00	65.33	65.86	95.48	75.38	83.61	728.67	628.36	724.23
8	66.28	66.01	66.13	352.56	351.53	352.03	1,122.00	1,122.00	1,122.00	65.81	61.11	64.48	127.01	74.86	86.22	729.17	728.06	728.56
9	66.39	64.87	66.17	352.50	351.22	351.99	1,122.00	1,122.00	1,122.00	64.27	30.81	60.63	127.52	126.74	126.87	729.25	726.63	728.45
10	66.26	66.06	66.16	352.61	351.21	351.83	1,122.00	1,122.00	1,122.00	66.00	33.00	62.35	127.02	100.57	118.90	729.92	727.28	728.83
11	66.39	66.05	66.19	352.61	351.39	352.12	1,122.00	1,122.00	1,122.00	66.00	66.00	66.00	106.46	84.98	100.54	729.55	727.94	728.90
12	66.27	65.99	66.16	352.52	350.67	352.04	1,122.00	1,122.00	1,122.00	66.00	66.00	66.00	96.47	87.12	90.23	729.81	727.16	728.97
13	66.22	66.03	66.11	352.45	350.63	351.81	1,122.00	1,122.00	1,122.00	66.00	66.00	66.00	121.27	85.36	95.46	729.71	726.63	728.68
14	66.20	65.90	66.09	352.49	350.53	351.83	1,122.00	1,122.00	1,122.00	66.00	66.00	66.00	118.47	82.36	100.70	729.53	726.89	728.43
15	66.18	65.85	66.06	352.61	350.84	351.91	1,122.00	1,122.00	1,122.00	66.00	30.00	57.44	109.50	88.33	96.88	729.24	728.30	728.74
16	66.16	65.98	66.06	352.44	351.11	351.79	1,122.00	1,122.00	1,122.00	66.00	66.00	66.00	127.01	80.42	100.21	729.05	728.37	728.65
17	66.26	54.37	65.53	352.53	273.56	348.41	1,122.00	1,122.00	1,122.00	66.00	66.00	66.00	127.02	85.45	111.70	729.31	728.15	728.77
18	66.23	45.84	65.29	352.51	351.20	351.93	1,122.00	1,122.00	1,122.00	66.00	66.00	66.00	100.49	81.48	89.49	729.00	631.32	704.23
19	66.27	66.10	66.17	352.58	351.60	352.08	1,122.00	1,122.00	1,122.00	66.00	66.00	66.00	92.40	78.82	81.93	631.55	586.47	612.42
20	66.17	65.93	66.09	352.22	351.29	351.93	1,122.00	1,122.00	1,122.00	66.00	66.00	66.00	84.40	75.08	78.98	588.55	541.08	558.14
21	66.06	65.14	65.57	352.81	350.26	352.14	1,122.00	935.00	1,067.46	66.00	66.00	66.00	79.38	73.01	75.36	570.25	496.22	530.94
22	66.28	24.53	64.00	353.30	165.59	324.54	1,122.00	771.00	973.33	66.00	66.00	66.00	80.87	71.88	77.00	695.90	358.29	538.95
23	66.22	65.05	65.66	353.09	351.14	352.29	1,122.00	928.00	1,029.83	66.00	66.00	66.00	98.43	74.64	86.62	676.20	438.32	625.85
24	65.54	64.49	65.04	352.90	351.20	352.09	1,122.00	968.00	1,096.33	66.00	66.00	66.00	114.18	83.37	94.36	729.48	232.07	505.56
25	66.19	64.35	65.36	352.56	351.59	352.14	1,122.00	908.00	1,041.79	66.00	66.00	66.00	84.39	80.34	84.93	727.95	530.32	715.27
26	66.25	64.34	65.52	352.89	351.47	352.20	1,078.00	988.00	1,016.75	66.00	66.00	66.00	80.35	73.34	77.31	727.14	616.61	651.79
27	66.19	64.23	65.37	352.71	261.38	345.14	1,105.00	938.00	1,033.33	66.00	49.50	65.31	74.88	70.86	72.84	726.57	555.97	618.64
28	66.12	63.16	64.71	352.53	323.43	350.69	938.00	734.00	919.75	66.00	66.00	66.00	71.33	68.30	69.90	600.41	566.17	581.52
29	66.19	64.33	65.31	353.02	331.78	351.27	908.00	834.00	887.75	66.00	66.00	66.00	96.49	82.48	76.22	728.26	556.24	638.33
30	65.53	59.86	62.80	353.39	351.50	352.19	854.00	790.00	805.54	66.00	49.50	65.31	70.55	66.33	67.89	580.52	540.40	557.11
31	63.78	58.92	60.65	0.00	No Generation	Error	820.00	820.00	820.00	0.00	No Generation	Error	89.03	89.03	89.03	0.00	No Generation	Error
Max	66.39			353.39			1,122.00			66.00			127.32			729.92		
Min		21.10			165.59			734.00			0.00				63.37			232.07

Source: THP, CHP, BHP, KHP, MHP (DGPC)

Graph: Generation for the month of September, 2022





Table: National demand for July, 2022

Jul-22	Max	Min	Ava
0:00	503.95	140.28	319.37
1:00	446.84	127.90	311.02
2:00	447.61	143.74	307.12
3:00	480.90	169.46	327.89
4:00	439.26	169.23	313.08
5:00	447.58	185.74	336.40
6:00	474.43	199.90	368.67
7:00	510.34	211.01	389.22
8:00	540.67	218.82	381.79
9:00	536.16	114.15	373.17
10:00	532.18	160.49	365.54
11:00	517.90	220.66	367.17
12:00	483.64	242.61	372.29
13:00	479.54	246.46	353.12
14:00	490.60	159.46	345.17
15:00	462.87	162.55	338.45
16:00	477.06	158.15	353.68
17:00	502.37	174.69	368.08
18:00	499.42	173.29	380.47
19:00	519.85	169.29	392.14
20:00	529.99	138.54	389.31
21:00	507.27	123.07	376.58
22:00	518.04	157.12	343.66
23:00	503.47	146.00	328.86
	540.67		
		114.15	

Graph: National Demand for July, 2021



Annexure-II



Table: National Demand for August, 2022

Aug-22	Max	Min	Ava
0:00	503.57	279.43	392.16
1:00	466.40	256.11	388.51
2:00	501.55	138.29	381.48
3:00	500.49	269.10	389.96
4:00	433.90	273.91	386.85
5:00	437.96	224.61	387.44
6:00	461.42	313.43	417.62
7:00	485.66	345.36	441.02
8:00	474.33	342.46	426.55
9:00	490.41	336.28	429.08
10:00	467.82	152.08	415.66
11:00	468.04	226.36	417.91
12:00	482.51	230.31	413.43
13:00	456.99	254.76	415.96
14:00	495.80	249.62	408.14
15:00	452.70	283.77	405.96
16:00	462.41	281.94	401.88
17:00	464.29	285.62	403.97
18:00	498.11	309.35	428.43
19:00	527.18	340.93	460.61
20:00	521.26	368.90	463.12
21:00	489.76	338.75	439.40
22:00	474.56	318.77	417.32
23:00	455.99	286.47	399.24
	527.18		
		138.29	

Graph: National Demand for August, 2022





Table: National Demand for September, 2022

Sep-22	Max	Min	Ava
0:00	442.41	142.30	388.69
1:00	441.11	132.15	370.59
2:00	434.44	102.27	371.84
3:00	433.11	181.40	369.33
4:00	434.56	248.17	376.22
5:00	440.04	150.40	380.01
6:00	462.90	197.33	409.10
7:00	498.32	277.54	438.39
8:00	474.02	310.33	423.20
9:00	495.38	290.65	422.79
10:00	470.99	304.65	415.50
11:00	471.77	284.91	410.21
12:00	462.91	322.87	411.04
13:00	466.36	316.18	401.62
14:00	466.06	289.16	396.31
15:00	454.37	299.55	396.72
16:00	498.30	314.96	398.16
17:00	519.22	309.51	415.07
18:00	525.39	300.49	428.69
19:00	530.45	353.81	460.48
20:00	514.96	348.60	448.61
21:00	473.99	287.97	418.56
22:00	461.76	107.09	402.53
23:00	453.39	146.49	390.91
	530.45		
		102.27	

Graph: National Demand for September, 2022





Annexure-III

Table: Daily maximum, minimum and average frequency for the month of July, 2022

Date	Bus Frequency at Semtokha Substation			Bus Frequency at Kurichhu Hydropower Plant		
	Max	Min	Ava	Max	Min	Ava
1	50.00	49.70	49.95	50.14	49.81	50.01
2	50.00	49.70	49.92	50.15	49.79	49.97
3	50.20	49.80	49.97	50.15	49.84	50.02
4	50.00	49.70	49.91	50.08	49.74	49.96
5	50.10	49.80	49.96	50.10	49.87	49.99
6	50.00	49.60	49.95	50.06	49.77	50.00
7	50.00	49.80	49.94	50.13	49.79	50.00
8	50.00	49.60	49.96	50.13	49.84	50.01
9	50.10	49.90	49.98	50.12	49.93	50.02
10	50.10	49.80	49.98	50.11	49.76	50.01
11	50.00	49.90	49.95	50.15	49.76	50.00
12	50.00	49.80	49.96	50.10	49.90	50.01
13	50.10	49.80	49.98	50.14	49.88	50.02
14	50.10	49.80	49.97	50.10	49.84	50.01
15	50.00	49.70	49.92	50.25	49.70	49.98
16	50.00	49.70	49.95	50.08	49.81	50.01
17	50.00	49.80	49.95	50.12	49.87	50.02
18	50.00	49.80	49.93	50.05	49.60	49.95
19	50.00	49.80	49.95	50.13	49.79	50.00
20	50.00	49.70	49.95	50.15	49.74	50.01
21	50.10	49.90	49.98	50.08	49.90	50.02
22	50.10	49.90	49.97	50.13	49.94	50.02
23	50.00	49.80	49.95	50.09	49.87	50.02
24	50.10	49.70	49.98	50.09	49.79	50.01
25	50.00	49.80	49.98	50.10	49.92	50.04
26	50.00	49.80	49.97	50.06	49.84	50.00
27	50.00	49.80	49.96	50.08	49.83	50.00
28	50.00	49.60	49.94	50.08	49.69	50.00
29	50.10	49.80	49.96	50.12	49.85	50.00
30	50.10	49.90	49.99	50.12	49.94	50.04
31	50.00	49.90	49.98	50.17	49.97	50.04
Max	50.20			50.25		
Min		49.60			49.60	

Source: TD (BPC), KHP (DGPC)

Graph: Daily maximum, minimum and average frequency for the month of July, 2022






Table: Daily maximum, minimum and average frequency for the month of August, 2022

Aug-22 Date	Bus Frequency at Semtokha Substation			Bus Frequency at Kurichhu Hydropower Plant		
	Max	Min	Ava	Max	Min	Ava
1	50.00	49.80	49.95	50.08	49.88	50.02
2	50.00	49.80	49.96	50.07	49.73	50.00
3	50.00	49.60	49.92	50.07	49.60	49.97
4	50.00	49.80	49.94	50.10	49.80	49.99
5	50.00	49.80	49.97	50.08	49.96	50.02
6	50.00	49.80	49.95	50.08	49.76	49.99
7	50.00	49.90	49.97	50.21	49.91	50.02
8	50.00	49.70	49.95	50.12	49.76	50.01
9	50.00	49.70	49.95	50.11	49.86	50.01
10	50.00	49.80	49.95	50.23	49.87	50.01
11	50.00	49.70	49.95	50.19	49.83	50.03
12	50.00	49.80	49.93	50.07	49.80	49.99
13	50.00	49.80	49.93	50.05	49.85	49.98
14	50.00	49.80	49.96	50.08	49.73	50.00
15	50.20	49.80	49.97	50.25	49.81	50.03
16	50.00	49.40	49.92	50.09	49.67	50.01
17	50.00	49.80	49.94	50.05	49.86	49.99
18	50.00	49.60	49.94	50.08	49.59	50.00
19	50.00	49.90	49.97	50.19	49.96	50.04
20	50.00	49.90	49.97	50.07	49.89	50.01
21	50.00	49.70	49.95	50.14	49.80	50.01
22	50.00	49.90	49.97	50.10	49.90	50.02
23	50.00	49.80	49.95	50.08	49.90	50.02
24	50.00	49.70	49.92	50.14	49.81	49.99
25	50.00	49.60	49.94	50.09	49.59	49.98
26	50.00	49.60	49.91	50.08	49.74	49.97
27	50.00	49.80	49.91	50.12	49.86	49.98
28	50.00	49.80	49.95	50.12	49.90	49.99
29	50.00	49.70	49.92	50.03	49.82	49.95
30	50.00	49.80	49.93	50.09	49.81	49.99
31	50.00	49.80	49.93	50.09	49.81	50.00
Max	50.20			50.25		
Min		49.40			49.59	

Source: TD (BPC), KHP (DGPC)

Graph: Daily maximum, minimum and average frequency for the month of August, 2021




Table: Daily maximum, minimum and average frequency for the month of September, 2022



Date	Bus Frequency at Semtokha Substation			Bus Frequency at Kurichhu Hydropower Plant		
	Max	Min	Ava	Max	Min	Ava
1	50.00	49.80	49.94	50.09	49.90	50.00
2	50.00	49.80	49.93	50.30	49.84	50.00
3	50.00	49.80	49.95	50.06	49.89	49.99
4	50.00	49.80	49.96	50.13	49.95	50.02
5	50.00	49.90	49.96	50.06	49.88	49.99
6	50.00	49.80	49.95	50.06	49.70	49.97
7	50.00	49.70	49.93	50.04	49.85	49.98
8	50.00	49.70	49.93	50.05	49.73	49.97
9	50.00	49.80	49.91	50.09	49.83	49.98
10	50.00	49.80	49.93	50.05	49.84	49.99
11	50.00	49.80	49.94	50.13	49.85	50.01
12	50.00	49.80	49.92	50.06	49.78	49.98
13	50.00	49.80	49.96	50.13	49.49	50.00
14	50.00	49.80	49.95	50.11	49.49	49.98
15	50.00	49.80	49.97	50.13	49.78	49.99
16	50.10	49.90	49.98	50.12	49.92	50.01
17	50.00	49.70	49.96	50.11	49.91	50.01
18	50.00	49.90	49.94	50.05	49.91	50.00
19	50.00	49.80	49.95	50.05	49.87	49.99
20	50.00	49.80	49.98	50.06	49.95	50.02
21	50.00	49.80	49.97	50.08	49.89	50.01
22	50.00	49.90	49.95	50.08	49.90	50.01
23	50.00	49.90	49.97	50.06	49.94	50.01
24	50.10	49.90	49.98	50.06	49.85	50.02
25	50.00	49.70	49.96	50.10	49.85	50.02
26	50.00	49.50	49.94	50.07	49.84	50.00
27	50.00	49.70	49.95	50.09	49.94	50.02
28	50.00	49.90	49.97	50.06	49.90	50.01
29	50.00	49.80	49.96	50.06	49.49	50.00
30	50.00	49.80	49.97	50.08	49.92	50.02
31	0.00	Error	Error	0.00	Error	Error
Max	50.10			50.30		
Min		49.50			49.49	

Source: TD (BPC), KHP (DGPC)

Graph: Daily maximum, minimum and average frequency for the month of September 2022




Table: Daily maximum, minimum and average Voltage for the month of July, 2022



Jul-22 Date	Malbase Substation									Nangkhor Substation		
	400kV Bus Voltage (kV)			220kV Bus Voltage (kV)			66kV Bus Voltage (kV)			132kV Bus Voltage (kV)		
	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava
1	412.50	402.00	404.06	218.00	214.00	216.00	66.00	64.00	64.96	134.23	130.29	132.64
2	406.00	401.50	404.17	219.00	213.00	215.77	66.00	64.00	65.03	134.65	130.70	132.83
3	406.00	401.00	404.35	217.50	213.50	216.04	65.90	64.00	64.84	135.28	130.50	132.91
4	406.00	402.50	404.33	218.00	121.00	211.91	65.50	64.00	64.92	134.44	131.23	132.65
5	405.50	403.50	404.63	217.00	213.50	215.31	65.25	64.00	64.69	135.48	130.08	132.99
6	407.50	402.50	404.52	218.00	212.00	215.38	65.10	63.10	64.60	134.20	131.32	132.85
7	408.50	402.50	405.50	218.50	212.50	215.81	65.20	63.68	64.55	134.44	131.12	132.82
8	406.50	404.50	405.65	217.50	213.00	215.42	65.00	64.00	64.65	134.44	131.74	133.08
9	409.00	404.50	406.81	219.50	213.00	215.85	66.00	64.00	64.70	135.69	132.57	134.33
10	410.50	406.00	408.79	218.50	214.00	216.73	66.00	64.00	65.15	136.31	131.57	134.38
11	410.00	407.00	408.46	219.00	215.50	217.23	66.00	64.00	65.36	135.90	130.29	132.99
12	411.50	405.00	407.77	219.00	213.50	216.35	66.00	63.65	64.78	135.69	129.66	132.88
13	407.00	405.00	406.56	219.00	213.50	216.92	66.00	63.65	64.95	134.21	130.29	132.63
14	411.00	406.00	407.65	219.00	214.00	216.90	66.00	64.50	65.01	134.03	131.12	132.42
15	411.00	405.00	407.78	220.00	217.00	218.21	66.00	65.00	65.48	135.48	130.02	132.34
16	411.00	405.00	408.50	220.00	216.50	218.49	65.25	64.00	64.95	134.86	130.29	132.20
17	414.00	405.00	394.46	223.00	218.00	219.00	65.23	65.00	65.04	135.27	130.08	132.73
18	413.00	405.00	408.79	222.50	216.00	218.63	65.23	64.00	64.74	134.03	130.70	132.45
19	410.50	406.00	407.10	220.50	216.50	218.08	65.45	64.75	64.99	135.69	130.49	132.42
20	409.00	402.00	406.60	220.50	217.00	218.56	66.00	64.00	65.12	134.65	130.29	132.77
21	409.50	404.00	407.33	220.50	217.00	218.88	66.35	64.50	65.56	136.31	130.49	132.82
22	407.50	404.00	405.88	219.50	216.00	217.73	66.00	64.00	65.07	134.65	130.08	132.22
23	411.00	403.00	405.67	219.00	216.00	217.60	66.00	64.00	65.09	134.23	130.50	132.22
24	408.50	402.50	405.25	218.50	215.00	216.77	65.00	64.00	64.63	135.28	129.25	132.64
25	410.00	404.50	405.98	219.33	122.00	213.51	66.00	64.55	65.01	135.90	131.32	133.35
26	408.00	405.00	405.96	222.00	216.00	219.23	66.00	64.00	64.96	139.87	129.87	133.31
27	413.50	406.00	410.39	222.50	218.50	220.94	66.00	65.00	65.24	134.10	126.34	131.76
28	413.00	405.00	408.54	224.00	216.00	219.69	66.00	64.00	65.29	135.48	129.90	132.96
29	408.50	405.50	406.94	219.50	216.00	218.15	66.00	64.00	64.94	138.39	131.12	132.85
30	408.00	405.50	406.96	220.00	217.00	218.27	65.00	64.88	64.99	135.07	131.12	133.32
31	410.00	406.00	407.67	220.75	217.00	219.30	65.87	64.50	65.10	135.69	131.53	133.13
Max	414.00			224.00			66.35			139.87		
Min		401.00			121.00			63.10			126.34	

Source: TD, BPC

Graph: Daily maximum, minimum and average Voltage for the month of July, 2022




Table: Daily maximum, minimum and average Voltage for the month of August, 2022



Aug-22 Date	Malbase Substation									Nangkhor Substation		
	400kV Bus Voltage (kV)			220kV Bus Voltage (kV)			66kV Bus Voltage (kV)			132kV Bus Voltage (kV)		
	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava
1	409.50	405.50	407.56	221.00	213.00	218.42	66.00	64.00	64.95	134.23	130.89	132.58
2	408.50	404.00	406.71	219.50	215.00	217.98	65.50	64.00	64.74	134.86	130.08	132.50
3	410.00	404.00	406.73	219.50	215.50	217.67	65.00	64.00	64.67	135.28	129.04	132.24
4	410.50	404.50	407.02	220.50	214.50	217.52	65.75	63.00	64.31	135.07	131.32	132.62
5	408.50	404.50	406.83	218.50	215.00	216.98	65.13	64.00	64.48	134.44	130.08	132.30
6	410.00	404.50	407.40	219.50	215.50	217.25	65.00	63.00	64.32	135.48	130.98	132.76
7	410.00	404.50	407.45	219.00	215.00	217.21	65.00	64.00	64.57	133.89	129.10	132.68
8	409.50	406.00	407.77	219.00	216.00	217.60	65.28	64.00	64.77	135.07	130.56	132.82
9	410.50	405.50	408.13	220.50	215.50	217.65	66.01	64.25	65.04	133.82	131.16	132.61
10	412.00	405.50	408.85	219.00	216.00	217.75	65.00	64.00	64.56	134.86	129.66	132.88
11	413.00	404.00	408.50	219.50	213.50	217.25	66.00	63.00	64.53	135.69	131.12	133.06
12	413.00	405.00	407.67	218.50	216.00	217.15	65.30	63.89	64.66	135.27	131.53	132.96
13	409.00	406.00	407.79	219.00	216.50	217.46	65.00	64.15	64.79	134.65	131.45	132.73
14	412.00	407.00	409.88	220.50	217.00	218.81	65.45	64.00	64.96	133.82	131.42	132.91
15	410.50	404.00	407.90	221.00	216.00	218.54	66.00	64.00	65.13	134.03	130.80	132.89
16	408.50	403.50	405.81	219.50	215.50	217.44	66.00	64.00	64.93	134.44	129.66	132.35
17	406.50	403.00	404.54	219.00	215.00	216.79	65.30	64.00	64.59	134.86	130.08	132.49
18	408.00	404.00	405.81	219.50	214.50	217.17	66.00	62.70	64.51	134.44	130.29	132.35
19	407.50	404.50	405.89	216.00	209.50	214.67	64.00	60.01	62.81	134.65	130.80	132.25
20	409.00	403.00	406.25	217.50	213.50	215.71	63.45	62.00	62.93	134.65	130.70	132.90
21	409.00	404.00	406.63	222.50	215.00	217.63	68.00	62.70	64.15	136.31	130.45	133.60
22	406.50	402.50	405.31	220.00	216.50	217.58	65.00	64.00	64.34	135.07	130.19	132.52
23	407.50	402.00	405.31	218.50	216.00	217.65	65.00	63.00	64.04	135.90	130.70	132.87
24	409.00	404.50	406.60	219.50	215.50	218.05	65.00	63.00	64.11	133.82	130.49	132.36
25	408.00	405.00	406.24	218.00	214.00	215.90	64.45	61.00	62.94	135.48	131.32	133.19
26	409.80	405.00	406.87	218.00	215.00	216.53	65.00	62.65	63.75	133.00	130.49	131.92
27	410.00	407.00	408.63	219.50	215.50	217.52	65.25	63.00	64.42	134.80	129.10	132.24
28	414.50	404.50	410.17	221.50	215.00	218.25	65.85	65.00	63.43	135.07	130.70	133.27
29	407.50	405.00	405.77	218.00	214.00	216.33	65.00	63.00	63.97	135.48	130.25	132.99
30	408.50	403.50	405.48	219.00	215.00	217.23	65.00	62.60	64.38	134.44	130.08	133.00
31	406.00	403.50	404.98	218.50	215.50	217.19	65.50	63.50	64.55	135.27	132.16	133.17
Max	414.50			222.50			68.00			136.31		
Min		402.00			209.50			60.01			129.04	

Source: TD, BPC

Graph: Daily maximum, minimum and average Voltage for the month of August, 2022







Table: Daily maximum, minimum and average Voltage for the month of September, 2022

Date	Malbase Substation									Nangkhor Substation		
	400kV Bus Voltage (kV)			220kV Bus Voltage (kV)			66kV Bus Voltage (kV)			132kV Bus Voltage (kV)		
	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava
1	408.00	399.00	405.13	218.50	215.00	217.15	65.00	64.00	64.53	135.69	129.45	133.41
2	407.00	404.00	405.54	218.00	215.00	216.69	65.00	63.50	64.20	135.07	131.10	132.99
3	408.50	405.50	407.56	219.50	215.50	217.77	65.85	63.50	64.65	134.03	130.08	132.88
4	409.00	403.50	407.17	218.50	214.50	217.39	65.25	63.00	64.31	135.28	132.00	133.58
5	407.50	405.00	406.98	312.00	215.00	220.69	65.00	63.00	63.95	135.48	132.16	133.89
6	412.00	404.50	408.13	220.00	215.00	217.33	65.00	63.65	64.12	133.82	131.12	132.63
7	408.50	404.00	406.29	219.50	215.00	217.52	65.00	64.00	64.55	133.61	131.32	132.60
8	408.50	404.50	406.67	217.50	215.50	216.52	65.00	63.75	64.34	134.03	130.10	132.28
9	408.50	404.50	406.17	218.00	215.00	216.29	64.65	63.00	63.96	133.82	131.50	132.58
10	409.50	405.00	407.25	218.50	215.50	217.38	65.00	63.45	64.47	134.03	131.50	132.79
11	409.50	405.00	407.75	219.50	216.00	218.02	65.05	63.00	64.40	134.44	130.40	132.89
12	411.00	406.50	408.90	220.00	217.50	218.69	65.15	64.00	64.79	134.65	131.75	133.20
13	409.00	406.00	407.60	219.00	216.00	217.59	65.00	63.00	64.14	135.10	132.37	133.47
14	409.50	406.00	408.04	219.50	216.50	217.55	65.00	63.90	64.35	135.07	131.79	133.53
15	409.00	406.50	407.69	219.00	215.00	217.38	65.00	63.00	64.36	134.86	129.45	132.55
16	411.00	406.00	408.33	219.50	216.00	217.81	65.00	63.00	64.53	134.23	132.50	133.17
17	410.00	404.50	407.96	219.50	215.00	218.19	66.00	63.00	64.43	135.69	131.10	133.47
18	409.00	404.50	407.23	219.50	215.50	217.79	65.00	63.00	64.21	134.24	131.30	132.87
19	408.50	404.50	406.82	219.50	216.00	217.73	65.35	64.00	64.55	134.86	131.53	133.18
20	409.00	404.50	407.83	219.00	215.50	217.67	65.00	64.00	64.77	134.52	131.32	132.82
21	411.50	405.50	408.52	220.00	215.50	218.04	66.00	64.00	64.74	134.00	131.12	132.49
22	415.50	406.00	409.88	221.00	216.00	217.79	65.00	64.00	64.51	136.10	130.29	132.49
23	410.00	405.50	407.88	220.00	216.50	218.17	67.60	64.00	65.31	134.86	131.30	132.88
24	411.00	407.00	409.19	223.00	217.00	220.31	68.00	65.25	67.01	135.48	130.49	133.64
25	410.50	405.00	408.88	221.00	215.50	218.85	66.00	64.00	65.08	135.69	132.70	134.47
26	408.50	403.50	406.50	220.50	214.50	217.19	64.69	62.00	63.66	135.69	132.16	133.55
27	412.00	405.00	408.19	221.00	215.00	218.69	68.00	63.00	64.79	135.48	131.12	133.55
28	410.50	406.00	408.21	219.00	214.50	217.38	65.00	63.00	64.30	134.56	131.80	133.28
29	412.50	406.00	408.67	219.00	216.00	217.60	65.00	62.90	64.04	134.65	131.89	133.13
30	410.50	406.00	408.46	219.50	215.00	217.67	65.00	63.50	64.10	134.86	131.60	132.99
31	0.00	Error	Error	0.00	Error	Error	0.00	Error	Error	0.00	Error	Error
Max	415.50			312.00			68.00			136.10		
Min		399.00			214.50			62.00			129.45	

Source: TD, BPC

Graph: Daily maximum, minimum and average Voltage for the month of September, 2022



Annexure-V



Transmission System Performance Report

Third Quarterly Report-2022

Sl. No.	Date of Tripping	Time of Outage/Time of Tripping	Date of Normalization	Time of Fault was Cleared	Direction of Outage (Dir)	MW before Outage (MW)	Name of Feeder	Name of the Substation where Affected by the Fault	Reasons of Fault	Relay Operations	Fault Location(KM)	Type of outage	Remarks
1. 400/220/112 KV, Dighring Substation													
9 112kV Above													
1	29.07.2022	3:48 hrs	29.07.2022	8:14 hrs	0	4.05	400/220 kV ICT	Agriwading Substation		91970LV			
2	01.07.2022	11:40 hrs	01.07.2022	10:30 hrs	0	28.258	112kV KCT-4	Agriwading Substation		Main 1&2 R, 1&2 Wp and RY Wp	Main 1 Fault Current Is = 2.90KA, Fault distance = 11.8km; Main 2 Fault distance = 10.48km		
3	07.07.2022	08:17 hrs	07.07.2022	08:23 hrs	0	11.188	112kV Dighring Feeder	Dighring Substation	Earth fault(Y to Ground)	Main 1 & 2 (Y to G Trip) Trip and ZI Wp, Zone1 Wp	Main 1 & 2 Fault Current Is = 10.1KA, Is=1.4KA, Is=2.1KA, Fault distance = 1.2km		
4	08.07.2022	19:48 hrs	08.07.2022	19:39 hrs	0	13.788	112kV Torang Feeder	Agriwading Substation	Earth fault(L1L2 - Ground)	Main 1 & 2 (L1L2 to Trip), Zone1 Wp	Main 1 & 2 Fault Current Is = 3.7KA, Is=1.4KA, Is=1.7KA, Fault distance = 11.17 km		
5	08.07.2022	18:50 hrs	08.07.2022	20:00 hrs	0	12.470	112kV Dighring Feeder	Dighring Substation	Earth fault(L1L2 - Ground)	Main 1 & 2 (L1L2 to Trip), Zone1 Wp	Main 1 & 2 Fault Current Is = 1.80 KA, Is=0.11KA, Is=0.1 KA, Fault distance = 1.8km, Is=0.78(KI, 1.2)		
6	09.07.2022	02:18 hrs	09.07.2022	02:33 hrs	0	48.380	112kV Torang Feeder	Agriwading Substation	Earth fault(B phase to Ground)	Main 1 (R, Y & B phase Wp, Zone1 Wp; Main 2 (R, Y & B phase Wp, Zone1 Wp)	Main 1 Fault distance = 17.8km; Main 2 Fault distance = 17.58km		
7	09.07.2022	02:26 hrs	09.07.2022	02:34 hrs	0		112kV Dighring Feeder	Dighring Substation	Earth fault(Y phase to Ground)	Main 1 (R, Y & B phase Wp, Zone1 Wp; Main 2 (R, Y & B phase Wp, Zone1 Wp)	Main 1 Fault distance = 10.8km; Main 2 Fault distance = 14.88km		
8	09.07.2022	19:34 hrs	09.07.2022	20:01 hrs	0	81.480	112kV Torang Feeder	Agriwading Substation	R,B phase to ground loop	R,B phase (ZI Wp, Is=1.8KA, Is=0.7KA, Is=1.6KA, Is=0.52KA Wp, Is=0.62 KA Wp)	Fault Dist = 11.8km		
9	20.07.2022	19:54 hrs	20.07.2022	20:01 hrs	0	44.170	112kV Dighring Feeder	Dighring Substation	R,B phase to ground loop	R,B phase Wp (ZI Wp, Is=1.47KA, Is=0.7KA, Is=1.6KA, Is=0.52KA Wp) main 1 and 2 Is=1.81 KA Wp	Fault Dist = 9.4KM		
10	21.07.2022	19:19 hrs	21.07.2022	20:29 hrs	1		112kV Bus Coupler	Agriwading Substation	Over Current	91 Wp			
11	22.07.2022	19:08 hrs	22.07.2022	19:15 hrs			112kV Bus Coupler	Agriwading Substation	Over Current	91 Wp			
12	01.07.2022	14:05 hrs	01.07.2022	14:12 hrs	0	41.68	112kV Tugphi Feeder	Tugphi Substation	R,Y phase Wp	Main 1&2 R, 1&2 Wp, R,Y phase Wp, ZI Wp	Fault Current Is=1.7KA, Is=1.9KA, Is=1.21 KA, Distance=10.8km	Transient	
13	01.07.2022	11:40 hrs	01.07.2022	16:20	0	39.49	112kV KCT-4	Agriwading Substation		Main 1&2 R, 1&2 Wp and RY Wp		Transient	
14	08.07.2022	20:18 hrs	08.07.2022	20:30 hrs	0	10.17	112kV Tugphi Feeder	Tugphi Substation	Earth fault (L1L2L3-G)	Main 1 optd, L1L2L3-G Trip, Zone1 Wp	Main 1 Current Is = 0.17KA, Is=0.21KA, Is=1.18KA, Fault distance = 8.88km (Z1, 1)	Transient	
15	08.07.2022	20:30 hrs	08.07.2022	20:33 hrs	0	20.94	112kV Golepha Feeder	Golepha Substation	Earth fault (L1L2L3-G)	Main 1&2 optd, L1L2L3-G Trip, Zone1 Wp	Fault distance = 21.137.58km	Transient	
16	24.07.2022	10:06 hrs	24.07.2022	08:39 hrs	0	10.68	112kV Tugphi Feeder	Tugphi Substation	Earth fault (L1L2L3-G)	Main 1&2 optd, L1L2L3-G Trip, Zone1 Wp	Fault distance = 1.88km	Transient	
17	24.07.2022	10:11 hrs	24.07.2022	10:17 hrs	0	18.97	112kV Golepha Feeder	Golepha Substation	Earth fault (L1L2L3-G)	Main 1&2 optd, L1L2L3-G Trip, Zone1 Wp	Fault distance = 6.48km	Transient	



Transmission System Performance Report

Third Quarterly Report-2022

2. 220kV/33kV Dhajji Substation 30kV and above														
1	08.07.2022	19.50hrs	08.07.2022	19.50hrs	0	20.82	Tripping- Spreading	Dhaji Substati a	Main 1- Ia=1.59kA, Ib=0.01kA, Ic=1.87kA with distance 30.1KM. Main 2- Ia=1.745 kA, Ib=1.01 kA, Ic=1.873 kA with distance 30.18KM.	Distance relay Main 1&2(21.1R 21.2)	Line segment	Tripped	Feeder restored after BPSO instructions.	
2	08.07.2022	23.05hrs	09.07.2022	23.30hrs	0	20.82	Tripping- Spreading	Dhaji Substati a	Main 1- Ia=2.01kA, Ib=1.25kA, Ic=2.09kA with distance 30KM. Main 2- Ia=2.043 kA, Ib=1.029 kA, Ic=2.093 kA with distance 17KM.	Distance relay Main 1&2(21.1R 21.2)	Line segment	Tripped	Feeder restored after BPSO instructions.	
3	20.07.2022	19.52hrs	20.07.2022	20.00hrs	0	61.55	Tripping- Spreading	Dhaji Substati a	Main 1- Ia=2.24kA, Ib=0.01kA, Ic=0.01kA with distance 87.21KM. Main 2- Ia=2.051 kA, Ib=1.77 kA, Ic=1.661 kA, Ia=1.663 kA with distance 33KM.	Distance relay Main 1&2(21.1R 21.2)	Line segment	Tripped	Feeder restored after BPSO instructions.	
3. 132kV/33kV Gelephu Substation 30kV and above														
1	08.07.2022	20.29hrs	08.07.2022	21.39hrs	1	24	132kv Gal-Ge	Gelephu a	line lightning	on on ABC - phase Ia=1.613kA, Ib=1.595kA, Ic=1.44 kA			Temporary	- Changing Code NLDC BTN=1009, NLDC DND=030 & NERLDC=4125. At the same time 132kv Gal-Ge line also tripped from Spreading end and under was heavy raining, structure & splitting.
2	24.07.2022	16.09hrs	24.07.2022	16.59hrs	15	12	132kv Gal-Ge	Gelephu a	line lightning	on on ABC - phase Ia=1.613kA, Ib=1.595kA, Ic=1.44 kA			Temporary	- Changing Code NLDC BTN=1009, NLDC DND=1275 & NERLDC=4011. At the same time 132kv Gal-Ge line also tripped from Spreading end & charged back at 16.09hrs.
3	24.07.2022	17.12hrs	24.07.2022	19.25hrs	2	12	132kv Gal-Ge	New	Insulator clamp burnt	Bar down taken by		Gelephu a	Temporary	Due to burnt (spark) on R phase bar insulator. Opening code-NLDC BTN=0804 & Changing code/NLDC BTN=0110. Substation was normal as the customer were not affected during that emergency situation.
4	24.07.2022	19.40hrs	24.07.2022	20.50hrs	1	12	132kv Gal-Ge	New	Insulator clamp burnt	Bar down taken by		Gelephu a	Temporary	Due to burnt (spark) on Y phase bar insulator. Opening code-NLDC BTN=0804 & Changing code/NLDC BTN=0115. customer was not affected as substation was there.



Transmission System Performance Report

Third Quarterly Report-2022

4. 132/33kV Yarehi Substation

0.66kV @ Ahara

1	03/07/2022	14.04	03/07/2022	14.13	0	-44.57	Tagphi-3p/Tagphi-3p	Temporary Fault	Distance Relay Start Phase ABCN, Tri P Phase ABC, Fault zone-1 trip, Fault location: 11.84KM	13.84KM	Temporary
2	03/07/2022	16.14	03/07/2022	16.18	0	14.90	Tagphi-3p/Tagphi-3p	Temporary Fault	Distance Relay Start Phase ABCN, Tri P Phase ABC, Fault zone-1 trip, Fault location: 55.81KM	55.18KM	Temporary
3	06/07/2022	7.50	06/07/2022	8.05	4	2.16	Tagphi-3p/Tagphi-3p	Temporary Fault	Distance Relay Start Phase ABCN, Tri P Phase ABC, Fault zone-1 trip, Fault location: 55.81KM	55.81KM	Temporary
4	08/07/2022	20.28	08/07/2022	20.28	0	-23.54	Tagphi-3p/Tagphi-3p	Temporary Fault	Distance Relay Start Phase ABCN, Trip Phase ABC, Fault zone-1 trip, Fault location: 22.88KM	22.88KM	Temporary
5	08/07/2022	22.16	08/07/2022	22.26	0	22.26	Tagphi-3p/Tagphi-3p	Temporary Fault	Distance Relay Start Phase ABCN, Tri P Phase ABC, Fault zone-1 trip, Fault location: 12.17KM	12.17KM	Temporary
6	08/07/2022	22.34	08/07/2022	22.43	0	15.54	Tagphi-3p/Tagphi-3p	Temporary Fault	Distance Relay Start Phase ABCN, Trip Phase ABC, Fault zone-1 trip, Fault location: 10.28KM	10.28KM	Temporary
7	08/07/2022	22.47	08/07/2022	22.59	0	14.54	Tagphi-3p/Tagphi-3p	Temporary Fault	Distance Relay Start Phase ABCN, Trip Phase ABC, Fault zone-1 trip, Fault location: 11.47KM	11.47KM	Temporary
8	08/07/2022	15.15	08/07/2022	15.31	0	32.44	Tagphi-3p/Tagphi-3p	Temporary Fault	Distance Relay Start Phase ABCN, Trip Phase ABC, Fault zone-1 trip, Fault location: 17.14KM	17.14KM	Temporary
9	08/07/2022	15.32	08/07/2022	16.21	0	-32.2	Tagphi-3p/Tagphi-3p	Temporary Fault	Distance Relay Start Phase ABCN, Trip Phase ABC, Fault zone-1 trip, Fault location: 17.70KM	17.70KM	Temporary
10	24/07/2022	2.10	24/07/2022	2.20	0	19.66	Tagphi-3p/Tagphi-3p	Temporary Fault	Distance Relay Start Phase ABCN, Trip Phase ABC, Fault zone-1 trip, Fault location: 19.88KM	19.88KM	Temporary
11	24/07/2022	14.36	24/07/2022	14.47	0	13.61	Tagphi-3p/Tagphi-3p	Temporary Fault	Distance Relay Start Phase ABCN, Trip Phase ABC, Fault zone-1 trip, Fault location: 19.70KM	19.70KM	Temporary
12	24/07/2022	14.68	24/07/2022	14.19	0	30.01	Tagphi-3p/Tagphi-3p	Temporary Fault	Distance Relay Start Phase ABCN, Tri P Phase ABC, Fault zone-1 trip, Fault location: 24.48KM	24.48KM	Temporary

5. 132/33kV Yarema Substation

0.66kV @ Ahara

1	08/07/2022	10.49	08/07/2022	10.56	0	28.8	132kV Tagphi 1-C Yarema S1	Broken conductor optd	00 relay	Nil	Tripped Fault
2	09/07/2022	12.23	09/07/2022	12.26	0	28.8	132kV Tagphi 1-C Yarema S1	Broken conductor optd	00 relay	Nil	Tripped Fault
3	18/07/2022	12.99	18/07/2022	12.11	0	-33.7	132kV Tagphi 1-C Yarema S1	Broken conductor optd	00 relay	Nil	Tripped Fault
4	19/07/2022	19.55	19/07/2022	19.57	0	-31.8	132kV Tagphi 1-C Yarema S1	Broken conductor optd	00 relay	Nil	Tripped Fault
5	23/07/2022	23.44	23/07/2022	23.54	0	-31.1	132kV Tagphi 1-C Yarema S1	Broken conductor optd	00 relay	Nil	Tripped Fault
6	24/07/2022	2.10	24/07/2022	2.17	0	-36.5	132kV Tagphi 1-C Yarema S1	Broken conductor optd	00 relay	Nil	Tripped Fault
7	24/07/2022	10.69	24/07/2022	10.10	0	-32	132kV Tagphi 1-C Yarema S1	Broken conductor optd	00 relay	Nil	Tripped Fault

6. 132/33kV Dagapola Substation

0.66kV @ Ahara

1	07/07/2022	08:35hrs	7/07/2022	08:27hrs	0	34.80	220kV Feeding Dagapola Substation H	Earth fault	Master trip relay optd	zone-1 at the distance of 7.2 km(YARD phase)	Grid fail	Tripped from ignoring and due to 0%
2	8/07/2022	17:08hrs	8/07/2022	20:02hrs	1	32.13	220kV Feeding Dagapola Substation H	L1 L2 phase to ground(Earth fault)	Master trip relay optd		Grid fail	Tripped from ignoring and due to 0%
3	9/07/2022	02:23hrs	9/07/2022	02:14hrs	0	34.43	220kV Feeding Dagapola Substation H	R&Y phase	Master trip relay optd	zone	Grid fail	Tripped from ignoring and due to 0%
4	20/07/2022	19:37hrs	20/07/2022	20:04hrs	0	41.84	220kV Feeding Dagapola Substation H	R&B to ground	Master trip relay optd	distance at 9.0km	Grid fail	Tripped from ignoring and due to 0%



Transmission System Performance Report

Third Quarterly Report-2022

Month of August 2021

110KV													
Sl. No.	Name of Feeder	Voltage Level	Type of Feeder	Outage Reason	Location	Tripping Date & Time	Normalization Date & Time	Customers affected (Yes/No)?	Remarks	Outage Duration(hh:mm:ss)	Outage in Minutes(mi)	No. of Customers Interrupted (NI)	Remarks
02	Nganglam	132KV	Transmission Line	Fault	Transmission Line	01-08-2022 05:11:00	01-08-2022 05:14:00	Yes	Tripped on Overcurrent & Earth Fault (50A & 50C)	00:03:00		1	
03	Nganglam	132KV	Transmission Line	Fault	Transmission Line	01-08-2022 07:14:00	01-08-2022 07:26:00	Yes	Tripped on Overcurrent & Earth Fault (50A & 50C)	00:12:00		130	
09	Nganglam	132KV	Transmission Line	Fault	Transmission Line	01-08-2022 10:44:00	03-08-2022 10:53:00	No	Tripped on Earth Fault. Fault details: IA= 447.5A IB= 7.227A IC= 6.750A IN= 437.4A VAN= 111.8KV VRN= 131.5KV VCN= 125.2KV	00:09:00		0	
14	Nganglam	132KV	Transmission Line	Fault	Transmission Line	06-08-2022 12:10:00	06-08-2022 12:22:00	No	Tripped on over current. Relay acted B6. Fault Zone= 1 Fault Duration= 76.74ms. Relay tripped time= 00.00ms. Fault loc= 25.23km. IA= 1.570KA IB= 1.607KA IC= 137.7A VAN= 137.7A VRN= 9.001KV VCN= 83.07KV Fault Resistance= 160.5ms	00:12:00		0	
15	Nganglam	132/33KV	SMVA Transformer-1	Fault	Substation	06-08-2022 12:10:00	06-08-2022 12:14:00	Yes	Tripped due to 132 KV Nganglam-Tingthi	00:04:00		3244	
29	Nganglam	132/33KV	SMVA Transformer-1	Fault	Distribution Line	14-08-2022 14:24:00	14-08-2022 14:27:00	Yes	Tripped on Overcurrent	00:03:00		3244	
30	Nganglam	132/33KV	SMVA Transformer-1	Fault	Substation	14-08-2022 14:27:00	14-08-2022 14:30:00	Yes	Tripped on overcurrent due to 33KV Druk GYP feeder (Feeder CB not Operated)	00:03:00		3244	
36	Nganglam	132/33KV	SMVA Transformer-1	Fault	Substation	15-08-2022 15:16:00	15-08-2022 15:18:00	Yes	SMVA tra (LV) side tripped due to 33KV DGCL. fbr on R/F	00:02:00		3244	
37	Nganglam	132/33KV	SMVA Transformer-1	Fault	Distribution Line	18-08-2022 06:45:00	18-08-2022 06:47:00	Yes	SMVA tra-1 (HV & LV) tripped due to 33KV Decharging feeder	00:02:00		1458	
42	Nganglam	132/33KV	SMVA Transformer-1	Fault	Distribution Line	20-08-2022 07:18:00	20-08-2022 07:22:00	Yes	Tripped on Overcurrent due to 33KV Pathang feeder fault while extending supply from Thimlegang LBS	00:04:00		339	
51	Nganglam	132/33KV	SMVA Transformer-1	Fault	Distribution Line	23-08-2022 11:41:00	23-08-2022 11:52:00	Yes	Tripped due to 33KV Decharging Feeder Fault	00:11:00		3244	
52	Nganglam	132/33KV	SMVA Transformer-1	Fault	Distribution Line	23-08-2022 22:12:00	23-08-2022 22:13:00	Yes	Tripped on Overcurrent. The SMVA Tr-1 is kept in idle charged and SMVA Transformer is put inservice	00:01:00		3244	
55	Nganglam	132/33KV	SMVA Transformer-2	Shutdown	Distribution Line	23-08-2022 18:25:00	23-08-2022 18:26:00	No	SMVA Transformer was put in Parallel with TMVA transformer after the installation of 2Nos. of CB Interrupter at SMVA Tr-1 LV side and SMVA Transformer was kept in idle charged	00:01:00		0	
67	Nganglam	132KV	Transmission Line	Shutdown	Transmission Line	31-08-2022 04:02:00	31-08-2022 05:50:00	No	CB could not Closed at Nanghor and after tripping, EPSSO instructed us to Open CB at our end and Closed first at Nanghor end.	01:48:00		0	
68	Nganglam	132KV	Transmission Line	Shutdown	Transmission Line	31-08-2022 13:30:00	31-08-2022 15:05:00	No	To do CB maintenance at Nanghor 2/3.	01:35:00		0	



Transmission System Performance Report

Third Quarterly Report-2022

Month of September 2022

Sl. No.	Name of Feeder	Voltage Level	Type of Feeder (Overhead/Underground)	Maximum Supply Type		Transmission Data		Distance of Feeder		MVA Load (Peak/Min)	Transmission Loss (%)	Voltage Drop (%)	Remarks
				From	To	From	To	From	To				
1
2

Sl. No.	Name of Feeder	Voltage Level	Type of Feeder (Overhead/Underground)	Maximum Supply Type		Transmission Data		Distance of Feeder		MVA Load (Peak/Min)	Transmission Loss (%)	Voltage Drop (%)	Remarks
				From	To	From	To	From	To				
1
2

Sl. No.	Feeder Name (Under Feeder)	Feeder Name (Over Feeder)	Supply Source (Under/Over)	Feeder Length (km)	Supply From & To (MVA/Min)	Transmission Data & Type (MVA/Min)	Capacity (MVA/Min)	Remarks	Range (km)	Percentage (MVA/Min)	No. of Customers (MVA/Min)
1	
2	

Sl. No.	Name of Feeder	Voltage Level	Type of Feeder (Overhead/Underground)	Maximum Supply Type		Transmission Data		Distance of Feeder		MVA Load (Peak/Min)	Transmission Loss (%)	Voltage Drop (%)	Remarks
				From	To	From	To	From	To				
1
2

Sl. No.	Name of Feeder	Voltage Level	Type of Feeder (Overhead/Underground)	Maximum Supply Type		Transmission Data		Distance of Feeder		MVA Load (Peak/Min)	Transmission Loss (%)	Voltage Drop (%)	Remarks
				From	To	From	To	From	To				
1

Sl. No.	Name of Feeder	Voltage Level	Type of Feeder (Overhead/Underground)	Maximum Supply Type		Transmission Data		Distance of Feeder		MVA Load (Peak/Min)	Transmission Loss (%)	Voltage Drop (%)	Remarks
				From	To	From	To	From	To				
1

Sl. No.	Date of Feeding	Type of Feeder	Date of Feeding	Date of Feeding	Distance of Feeder (km)	MVA Load (Peak/Min)	Name of the Substation (Under/Over)	Remarks of Feeder	Supply Operation	Feeder Location (km)	Type of Feeder	Remarks
1	08.09.2022	...	08.09.2022	08.09.2022
2	22.09.2022	...	22.09.2022	22.09.2022
3	22.09.2022	...	22.09.2022	22.09.2022
4	22.09.2022	...	22.09.2022	22.09.2022
5	24.09.2022	...	24.09.2022	24.09.2022
6	24.09.2022	...	24.09.2022	24.09.2022
7	24.09.2022	...	24.09.2022	24.09.2022
8	24.09.2022	...	24.09.2022	24.09.2022
9	24.09.2022	...	24.09.2022	24.09.2022
10	22.09.2022	...	22.09.2022	22.09.2022
11	22.09.2022	...	22.09.2022	22.09.2022
12	08.09.2022	...	08.09.2022	08.09.2022
13	22.09.2022	...	22.09.2022	22.09.2022
14	22.09.2022	...	22.09.2022	22.09.2022
15	22.09.2022	...	22.09.2022	22.09.2022
16	24.09.2022	...	24.09.2022	24.09.2022



Transmission System Performance Report

Third Quarterly Report-2022

2.20047017 Thimphu Substation													
2.20047017 and above													
1	22.09.2022	01.10m	22.09.2022	01.10m			220KV Bus, Coupler	Shunt Substation		High Voltage	Substation	Trigger	Feeder restored after O&M work. SPD Testing conducted for January
2	24.09.2022	01.10m	24.09.2022	01.10m			10.72	Transfer Switching Feeder	Shunt Substation	over current	Substation	Trigger	Feeder restored after O&M work. SPD Testing conducted for January
3.11040311101 Galkha Substation													
3.11040311101 and above													
1	07.09.2022	00.00m	08.09.2022	00.00m	11	11		Transfer Switching Feeder	None	Substation	Substation		Disturbance taken to shift the Operating Point towards Substation Feeder due to Substation operational work.
2	24.09.2022	01.00m	24.09.2022	01.00m		10	over current & Trip	Transfer Switching Feeder	Over Heat	Substation	Substation		Supply interrupted from 24.09.2022
4.1000017 Thimphu Substation													
4.10001 & above													
1	08.09.2022	11.20m	08.09.2022	11.40m	0	12.01	AV Tapchhi sagging	20V Tapchhi sagging F	Temporary Fault	Disturbance: Phase ABC, Tap Phase ABC, Fault over 1 sq. Feet location: 11.20.22	21.10.22		Trigger
2	08.09.2022	12.00m	08.09.2022	12.20m	0	11.74	AV Tapchhi sagging	20V Tapchhi sagging F	Temporary Fault	Disturbance: Phase ABC, Tap Phase ABC, Fault over 1 sq. Feet location: 11.74.22	21.10.22		Trigger
3	22.09.2022	00.00m	22.09.2022	00.00m	0	11.70	AV Tapchhi sagging	20V Tapchhi sagging F	Temporary Fault	Disturbance: Phase ABC, Tap Phase ABC, Fault over 1 sq. Feet location: 11.20.22	20.22		Trigger
4	22.09.2022	00.20m	22.09.2022	00.20m	0	11.70	AV Tapchhi sagging	20V Tapchhi sagging F	Temporary Fault	Disturbance: Phase ABC, Tap Phase ABC, Fault over 1 sq. Feet location: 11.20.22	21.09		Trigger
5	22.09.2022	00.00m	22.09.2022	00.00m	0	11.70	AV Tapchhi sagging	20V Tapchhi sagging F	Temporary Fault	Disturbance: Phase ABC, Tap Phase ABC, Fault over 1 sq. Feet location: 11.20.22	17.09		Trigger
6	22.09.2022	00.00m	22.09.2022	00.00m	0	11.70	AV Tapchhi sagging	20V Tapchhi sagging F	Temporary Fault	Disturbance: Phase ABC, Tap Phase ABC, Fault over 1 sq. Feet location: 11.20.22	20.22		Trigger
7	24.09.2022	00.00m	24.09.2022	00.00m	0	11.41	AV Tapchhi sagging	20V Tapchhi sagging F	Temporary Fault	Disturbance: Phase ABC, Tap Phase ABC, Fault over 1 sq. Feet location: 11.20.22	11.20		Trigger
8	24.09.2022	00.00m	24.09.2022	00.00m	0	11.41	AV Tapchhi sagging	20V Tapchhi sagging F	Temporary Fault	Disturbance: Phase ABC, Tap Phase ABC, Fault over 1 sq. Feet location: 11.20.22	11.20		Trigger
9	24.09.2022	00.00m	24.09.2022	00.00m	0	11.41	AV Tapchhi sagging	20V Tapchhi sagging F	Temporary Fault	Disturbance: Phase ABC, Tap Phase ABC, Fault over 1 sq. Feet location: 11.20.22	11.20		Trigger
10	24.09.2022	00.00m	24.09.2022	00.00m	0	11.27	AV Tapchhi sagging	20V Tapchhi sagging F	Temporary Fault	Disturbance: Phase ABC, Tap Phase ABC, Fault over 1 sq. Feet location: 11.20.22	10.1		Trigger
5.1103017 Yarrow Substation													
5.11031 & above													
1	08.09.2022	00.00m	08.09.2022	00.00m	0	11.5	110KV Tapchhi TC	Yarrow TC	AVC Trip	11.09.2022	Yarrow TC		Checked as per the SF
2	17.09.2022	00.00m	17.09.2022	00.00m	0	11.5	110KV Tapchhi TC	Yarrow TC	Under-voltage	10.09.2022	Yarrow TC		Checked as per the SF
3	21.09.2022	00.00m	21.09.2022	00.00m	0	11.5	110KV Tapchhi TC	Yarrow TC	AVC Trip	10.09.2022	Yarrow TC		Checked as per the SF
4	21.09.2022	00.00m	21.09.2022	00.00m	0	11.5	110KV Tapchhi TC	Yarrow TC	Under-voltage	10.09.2022	Yarrow TC		Checked as per the SF
5	21.09.2022	00.00m	21.09.2022	00.00m	0	11.5	110KV Tapchhi TC	Yarrow TC	AVC Trip	10.09.2022	Yarrow TC		Checked as per the SF
6	21.09.2022	00.00m	21.09.2022	00.00m	0	11.5	110KV Tapchhi TC	Yarrow TC	Under-voltage	10.09.2022	Yarrow TC		Checked as per the SF
6.20047017 Diphra Substation													
6.20047 & above													
1	24.09.2022	00.00m	24.09.2022	00.00m	0	10.20	Transformer 2	Diphra SA	Over-voltage	24.09.2022	Diphra SA	Under-voltage	Transformer 2 removed



Transmission System Performance Report

Third Quarterly Report-2022

Western grid Outages

July 2021

Sl. No.	Date of Tripping	Time of outages	Date of Normalization	Time of fault was cleared	Duration of Outages (Hrs)	MW before outage (MW)	Feeder Name	Name of the Substation/lines affected by the fault	Reasons of fault	Relay operations	Exact location of fault [Line segment/ Substation]	Type of outages	Remarks
66kV & Above													
(A) 400/220/66/11 kV Malhae Substation													
1	01.07.22	7:46	01.07.22	8:06	0	551.37	400kV Malhae- Siliguri fdr.	Malhae St	O/C & E/F	Phase 1 trip, Main II CAR-RCV, 2M1 trip, fuse fail	193km		IL1=1677A, I2=303.7deg, IL2=748.2A, I2=255.3deg, IL3=718.4A, I3=133.1deg, IL4=1599A, I4=278.9deg
2	03.07.22	17:20	03.07.22	17:27	0	151.9	200kV Malhae- Chukha feeder	Malhae St	O/C & E/F	Zone 1 trip, AB lock out shut	Zone 1= 8.001km		IA=5679A, I2=3967A, I3=3733A
**	18.07.22	3:06	18.07.22	4:25	1	5.6	200kV Malhae- Gantaa feeder	Dhamsam St.	O/C on B phase	86 opnd.			IL1=75.95A, I2=220.7deg, IL2=118.5A, I2=235.1deg, IL3=2538A, I3=41.95deg, IL4=2347A, I4=58deg
**	20.07.22	8:20	20.07.22	9:09	0	236	400kV Malhae- Siliguri fdr.	Malhae St & Siliguri St	O/C on T & B phase	Zone 1 trip	38.33km		IL1=780A, I2= 2999A, I3=3623A
**	23.07.22	17:11	23.07.22	17:32	0		66kV Bus Coupler	Malhae St	O/C				R=1377.24A, Y=11481.83A, B=14715.27A
**	23.07.22	17:11	23.07.22	17:25	0	22	66kV Pasakha feeder I	Malhae St	O/C				R=129.11A, I=103.18deg, Y=1786.66A, I=139.38deg, B=1230.18A, I=17.55A
**	23.07.22	17:11	23.07.22	18:24	1	0	66kV pling feeder	Malhae St	O/C				R=11.26kA, Y=11.72kA, B=1.32kA
**	28.07.22	11:30	28.07.22	13:35	2	20	66kV Pasakha feeder I	Malhae St	IEF SON trip, 86 opnd, general trip				IL1=210.56A, I2=82.05deg, IL2=925.15A, I2=198.3deg, IL3=129.19A, I3=90.05deg, IL4=976.52A, I4=156.08 deg
**	28.07.22	11:58	28.07.22	23:47	12	21	66kV Pasakha feeder II	Malhae St	S1 Trip, 86 opnd, General trip				IL1=0.19A, I2=0.05deg, IL2=656.02A, I2=156.79deg, IL3=662.70A, I3=23.20deg, IL4=0.19A, I4=0.9 deg
**	28.07.22	11:58	28.07.22	23:47	12	23	66kV Pasakha feeder IV	Malhae St	IEF SON trip, 86 opnd, general trip				IL1=809.15A, I2=18.74deg, IL2=1607.84A, I2=17.40deg, IL3=200.51A, I3=53.29deg, IL4=809.15A, I4=14.74 deg
**	28.07.22	11:58	28.07.22	23:47	12		66kV Bus Coupler	Malhae St	IEF SON trip, 86 opnd, general trip, IEF-50, trip				IL1=648.07A, I2=115.40deg, IL2=1246.10A, I2=131.21deg, IL3=238.83A, I3=98.24deg, IL4=12947.19A, I4=131.26deg
**	28.07.22	11:58					66kV pling feeder	Malhae St	O/C	Trip phase N, Earth Fault I, Trip D1>3			IL1= 8.397A, IL2= 9.497A, IL3= 3.560kA, IL4= 9.690kA. The feeder will undergo breakdown due to 400kV Tala feeder 1 conductor got snapped and touched on transmission line of said feeder.
(B) 220/66/11 kV Singyeigan Substation													
1	17.07.22	3:52	17.07.22	3:45	0	0.897	220kV Singyeigan Feeder	Singyeigan st					avoided download fault due to Ifigi software communication problem.
**	28.07.22	23:39	28.07.22	23:44	0	4	66kV B/Coupler feeder	Singyeigan st					IL1=11.84kA, IL2= 58.92kA, IL3= 95.53kA
(B) 66/33/11 kV Phuentsholing Substation													
1	03.07.2022	17:19	03.07.2022	17:26	0	3.70	66kV Chukha-Pling feeder	66kV Chukha-Pling fdr		DSTN OPTD, 106406	Tripped at both end		At 17:19hrs 66kV Chukha-Pling feeder got tripped from both end. At 17:26hrs normalised the above feeder after getting clearance from BPSO with charging code 1A52.
**	12.07.2022	6:30	12.07.2022	6:34	0	1.15	10MVA Voltamps TRF (66/33kV)	10MVA Voltamps TRF (66/33kV)	Tripped		Substation		10 MVA Transformer and 33kV Incomer II got tripped due to fault on 33kV fdr IV/Verina Bonakha.
**	14.07.2022	17:09	14.07.2022	17:24	0	3.27	66kV Chukha-Pling feeder and 66kV Pling-Gomtu feeder	Black out at Pling st	Tripped at their end	Nil	Tripped at their end		66kV Chukha-Pling and 66kV Pling-Gomtu feeder got tripped at their end, no breaker operation at our end. At 17:09hrs normalised 66kV Chukha-Pling feeder from Chukha end and at 17:27hrs normalised 66kV Gomtu feeder from Gomtu end.
**	15.07.2022	15:42	15.07.2022	15:44	0	1.93	10MVA Voltamps TRF (66/33kV)	10MVA Voltamps TRF (66/33kV)	Tripped	Nil	Substation		10 MVA Transformer and 33kV Incomer II got tripped due to fault on 33kV fdr IV/Verina Bonakha.
(D) 66/33/11 kV Gedu Substation													
1	03.07.2022	17:20	03.07.2022	17:28	0	1.72	66kV Gedu- Chukha	Blackout	Bad weather		Line segment		66kV supply failed from CHF. At 17:27hrs 66kV supply charged from Phuentsholing Substation.
	06.07.2022	9:02	06.07.2022	9:45	0	1.33	66/11kV 5MVA Tr-1	Nil	Tighten transformer NCT		Substation		Work permit to TR issued to Substation Head for NCT tightening work.
2	16.07.2022	18:58	16.07.2022	19:10	0	1.49	66kV Gedu- Chukha	Blackout			Line segment		66kV supply failed from CHF. At 19:10hrs 66kV supply restored from Chukha.
3	31.07.2022	9:12	31.07.2022	9:27	0	1.5	66kV Gedu-Phuentsholing	Nil	Emergency shutdown at Phuentsholing end		Line segment		Emergency shutdown taken at Phuentsholing substation to verify the faulting sound from the isolator.
(E) 66/33/11 kV Gomtu Substation													
1	11.07.2022	17:30	12.07.2022	10:50	17	0.01	66/33kV 3 MVA Transformer	Nil	over current	O/C with IDMT highest 30y and trip relay R8	Gomtu st	Fault	Penetrated line insulator
2	14.07.2022	17:09	14.07.2022	17:29	0	4.824	66kV Dhamsam feeder	Gomtu Substation	Transient fault	Distance Relay Operated	Line segment	Transient fault	Charged the feeder as per the instruction given by BPSO
3	14.07.2022	17:09	14.07.2022	17:27	0	2.66	66kV Phuentsholing feeder	Gomtu Substation	Earth fault	IDMT EF operated	Line segment	Transient fault	Charged the feeder as per the instruction given by BPSO
3	16.07.2022	19:01	16.07.2022	19:11	0	5.362	66kV Dhamsam feeder	Gomtu Substation	Tripped from Dhamsam end	Nil	Line segment	Transient fault	Tripped from Dhamsam end and supply resumed at 19:11hrs
3	16.07.2022	19:01	16.07.2022	19:14	0	3.61	66kV Phuentsholing feeder	Phuentsholing substation	Earth fault	E/F 37N3	Line segment	Transient fault	Tripped on earthfault and charged the line as requested by BPSO and charge withstand
4	19.07.2022	09:13	19.07.2022	10:29	1	2.82	66kV Phuentsholing feeder	Nil	Spark on B phase CB terminal	Nil	Gomtu substation	Emergency Shutdown	Availed emergency shutdown by Substation Head against Work Permit No. 07A, opening code 6868 and closing code 1751 from BPSO.
4	20.07.2022	18:56	20.07.2022	18:56	0	7.634	66kV Dhamsam feeder	Nil	B-Phase fault	Distance Relay Operated & A/R Operated, General trip, Zone Out, trip, 2: Cou trip & B-Phase fault	Line segment	Transient fault	Auto recloser operated and charged from Dhamsam end at 19:07hrs of date 20.07.2022 against closing code 1854 from BPSO
(F) 220/66/33kV Dhamsam Substation													
1	14.7.2022	17:10	14.7.2022	17:29	0	3.09	66kV Gomtu fdr	Gomtu	Heavy thundering/lightning, windy and raining at Gomtu area.	General trip, Zone 2 trip, Y phase faulty, vt fuse fail.		Line fault	Feeder not after stopping the weather at gomtu area and consult with D060 for next charging.
2	28.07.2022	18:56	28.07.2022	19:09	0	7.41	66kV Gomtu fdr	Gomtu	thundering, high lightning, windy and raining at Gomtu	General trip, Zone 1 trip, Y phase faulty		Line fault	BPSO General trip Zone 1/O/C on YR Abs Dur: 2.29 R=1 Dist: 15.91% Fault loop - L2N e Charged the feeder based upon the charging Code:1054, BPSO Y/phis, moreover after normalization of rain fall
Sl. No.	Date of Tripping	Time of outages	Date of Normalization	Time of fault was cleared	Duration of Outages (Hrs)	MW before outage (MW)	Feeder Name	Name of the Substation/lines affected by the fault	Reasons of fault	Relay operations	Exact location of fault [Line segment/ Substation]	Type of outages	Remarks
(A) 66kV Chukha switching station													
1	01.07.2022	18:18hrs	01.07.2022	19:14hrs		0.11.12MW	66kV Chukha Feeder	Puro substation.	E-fault	Due to E/F SA 111-4A, B1 661.6A, IC 137.5A.	66kV Transmission Line	Trip	
2				19:25hrs		7.63MW	66kV Pangtara Feeder	Pangtara Substation	Transient fault	1PH and General trip	66kV Transmission Line	Trip	
3				19:25hrs		7.1.94MW	66kV Semaia Feeder	Puro and Pangtara	Transient fault	1PH and General trip	66kV Transmission Line	Trip	Expn feeder open as per BPSO
4	28.07.2022	10:18hrs	28.07.2022	23:33hrs	06hs	0.0.35MW	66kV Semaia Feeder	Fed from 66kV Chukha Feeder	Sidewalk	CB open, Lock/Bus isolator open, E-ventch closed	Ismaia substation	Sidewalk	System by CNPD for checking the operation of Line and bus isolator electrically as SCADA installation is in progress at Ismaia.
(B) 66/33kV Watsa Substation													
1	07-01-22	18:19hrs	07-01-22	18:47hrs		620MW	66kV IC	Fdr I and II	66kV IC tripped at chukha end	66kV IC tripped at chukha end	66kV IC tripped at chukha end	Tripped	WTI tripped and reset the temperature to 75 with consultation with Mr. Head SMD, and the line charged.
(C) 66/33kV Olakha Substation													
1	21-07-22	17:15	21-07-22	17:15	0	6.19	66/33kV 20MVA, Transformer I	Only 66/33kV 20MVA, Transformer I was affected	Over current and earth fault	Earth Fault Over Current Operated	Line Segment	Taken Shut down	The 66kV Olakha-Changdaga was taken shut down by Massage Chukha Oystertech of TMSD, with work permit no 2507 and also with the shutdown approval from BPSO. Thanks for removal of the pole located at the line area Daga. Ea jumps area with breaker opening code 0220. The line was charged after completion of the work with closing code 1617 at 17:38hrs and stood normal.
(D) 66/33/11kV Loberna Substation													
66kV LSA - Grewathang feeder													
1	07.07.2022	06:15hrs	07.07.2022	06:20hrs	0	20.620	66kV LSA - Grewathang feeder	66/33/11kV Loberna substation		NA			66kV LSA - Grewathang feeder tripped at 06:15hrs and supply resumed at 06:20hrs and at the time of tripping No breaker or relay operated at Loberna end.
2	08.07.2022	19:49hrs	08.07.2022	19:50hrs	0	17.970	66kV LSA - Grewathang feeder	66/33/11kV Loberna substation		NA			66kV LSA - Grewathang feeder tripped at 19:49hrs informed to BPSO and line charged at 19:50hrs from Grewathang st and line extended to Dochula at 19:53hrs.
3	09.07.2022	02:18hrs	09.07.2022	02:18hrs	0	18.720	66kV LSA - Grewathang feeder	66/33/11kV Loberna substation		Dist relay operated, Zone 3 opnd.			66kV LSA - Grewathang feeder tripped at 02:18hrs informed to BPSO and line charged at 02:18hrs from Grewathang st and line extended to Dochula at 02:33hrs.
4	09.07.2022	12:23hrs	09.07.2022	12:20hrs	0	20.240	66kV LSA - Grewathang feeder	66/33/11kV Loberna substation		Dist relay operated, Zone 3 opnd.			66kV LSA - Grewathang feeder tripped at 12:23hrs informed to BPSO and line charged at 12:20hrs from Grewathang st and line extended to Dochula at 12:30hrs.
5	20.07.2022	19:53hrs	20.07.2022	19:50hrs	0	21.000	66kV LSA - Grewathang feeder	66/33/11kV Loberna substation		Dist relay operated, Trip B & C, Zone 3 opnd, IA-119 KA, B-415.3, IC-666 IA)			66kV LSA - Grewathang feeder tripped at 19:53hrs informed to BPSO and line charged at 19:50hrs from Grewathang st and line extended to Dochula at 20:03hrs.
66kV LSA - Dochula feeder													
1	07.07.2022	06:15hrs	07.07.2022	06:20hrs	0	13.470	66kV LSA - Dochula feeder			NA			66kV LSA - Dochula feeder tripped at 06:15hrs and supply resumed at 06:20hrs and at the time of tripping No breaker or relay operated at Loberna end.
2	08.07.2022	19:49hrs	08.07.2022	19:53hrs	0	13.840	66kV LSA - Dochula feeder			NA			66kV LSA - Dochula feeder tripped at 19:49hrs informed to BPSO and line charged at 19:50hrs from Grewathang st and line extended to Dochula at 19:53hrs.
3	09.07.2022	02:18hrs	09.07.2022	02:18hrs	0	16.120	66kV LSA - Dochula feeder			NA			66kV LSA - Dochula feeder tripped at 02:18hrs informed to BPSO and line charged at 02:18hrs from Grewathang st and line extended to Dochula at 02:33hrs.
4	09.07.2022	12:23hrs	09.07.2022	12:20hrs	0	20.240	66kV LSA - Dochula feeder			NA			66kV LSA - Dochula feeder tripped at 12:23hrs informed to BPSO and line charged at 12:20hrs from Grewathang st and line extended to Dochula at 12:30hrs.
5	20.07.2022	00:42hrs	20.07.2022	00:51hrs	0	14.850	66kV LSA - Dochula feeder			Dist Trip B & Dist Trip-C, Zone 3 opnd			Supply was resumed from Grewathang st at 00:47hrs. 66kV LSA - Dochula feeder tripped at 00:42hrs informed to BPSO and line extended at 00:51hrs.
6	20.07.2022	12:43hrs	20.07.2022	12:51hrs	0	14.850	66kV LSA - Dochula feeder			Dist Trip B & Dist Trip-C, Zone 3 opnd			Supply was resumed from Grewathang st at 00:47hrs. 66kV LSA - Dochula feeder tripped at 00:42hrs informed to BPSO and line extended at 00:51hrs.
7	21.07.2022	17:18hrs	21.07.2022	17:20hrs	0	17.200	66kV LSA - Dochula feeder			Dist Trip B & Dist Trip-C, Zone 3 opnd			66kV LSA - Dochula feeder tripped at 17:18hrs informed to BPSO and supply was extended from Grewathang at 17:17hrs and line extended at 17:20hrs towards Dochula.



Transmission System Performance Report

Third Quarterly Report-2022

(F) 66/33/11kV Jemina Substation												
66 kV side Tripping												
1	01.07.2022	18:39	01.07.2022	18:45	0	-3.870	66 kV Changchaba	Black out	Earth fault	Non directional E.F operated	Line Segment	Transient
2	01.07.2022	18:39	01.07.2022	19:26	0	1.950	66 kV Chando	Black out	Earth fault	Non directional E.F operated	Line Segment	Transient
(G) 66/33/11kV Dechencholing substation												
1	01.07.2022	18:29hrs	01.07.2022	18:37hrs	0	-21.48	66KV IC	All whole is	Supply failed from source			
2	20.07.2022	00:42hrs	20.07.2022	00:48hrs	0	-21.29	65KV IC	All whole is	Supply failed from source			
(H) 66/11kV Ita Substation												
1	01.07.22	18:38	01.07.22	18:48	0	-1.88	AE	unknown	O/C	jangbasa	Tripped from Pangbasa end	
2	14.07.22	0:44	14.07.22	0:39	0	-0.68	AE	unknown	O/C	jangbasa	Tripped from Pangbasa end	
3	14.07.22	1:27	14.07.22	4:21	0	-0.56	AE	unknown	O/C	jangbasa	Tripped from Pangbasa end	
4	15.07.22	1:27	15.07.22	3:18	0	0.67	AE	unknown	O/C	jangbasa	Tripped from Pangbasa end	
5	18.07.22	1:11	18.07.22	4:52	0	-0.51	AE	unknown	O/C	jangbasa	Tripped from Pangbasa end	
(I) 220kV Substation Sentsikha												
1	01.07.22	18:21hrs	01.07.22	18:26hrs			600kV 20MVA-1 transformer	Sentsikha Substation	REF Trip	REF Trip	Transient fault	Transient
2	01.07.22	18:21hrs	01.07.22	18:27hrs		21.81	66kV Sentsikha - Dechencholing Line	Dechencholing and Damg Substation	Distance protection Opd, Zone 1, Trip B	Distance protection Opd, Zone 1, Trip B	Transient fault	Transient
3	07.07.22	06:13hrs	07.07.22	06:21hrs		49.05	66kV Sentsikha - Dechula Line	Dechula vs	Directional earth fault protection operated	O/C EF Opd, D002 trip	Transient fault	
4	07.07.22	06:13hrs	07.07.22	06:21hrs		49.05	66kV Sentsikha - Dechencholing Line	Dechencholing and Damg Substation	Broken Conductors	Distance protection Opd, BRC Trip	Transient fault	
5	08.07.22	09:08hrs	08.07.22	09:25hrs		45.90	66kV Sentsikha - Dechula Line	Dechula vs	Y & Bph OC Trip	Backup OC EF relay opd, Y&Bph D-7 Trip	Transient fault	
6	08.07.22	09:21hrs	08.07.22	09:26hrs		41.18	66kV Sentsikha - Dechula Line	Dechula vs	Y & Bph OC Trip	Backup OC EF relay opd, Y&Bph D-7 Trip	Transient fault	
7	08.07.22	11:20hrs	08.07.22	12:25hrs		45.81	66kV Sentsikha - Dechula Line	Dechula vs	Y & Bph OC Trip	Backup OC EF relay opd, Y&Bph D-7 Trip	Transient fault	
8	20.07.22	06:46hrs	20.07.22	06:58hrs			66kV Sentsikha - Dechula Line	Dechula vs	Y & Bph OC Trip	Backup OC EF relay opd, Y&Bph D-7 Trip, fault Current I=27.9A, I _B =1.14kA, I _C =1.14kA, I ₀ =17.4k	Transient fault	
9	20.07.22	06:46hrs	20.07.22	06:51hrs			66kV Sentsikha - Dechencholing Line	Dechencholing and Damg Substation	Broken Conductors	Tripped on Broken Conductors, Fault Current I=11.3A, I _B =0.93A, I _C =0.84A		
10	20.07.22	09:53hrs	20.07.22	09:58hrs			66kV Sentsikha - Dechula Line	Dechula vs	Y & Bph OC Trip	Backup OC EF relay opd, Y&Bph D-7 Trip, fault Current I=5.03A, I _B =1.14kA, I _C =1.14kA, I ₀ =0.26	Transient fault	
11	21.07.22	17:16hrs	21.07.22	17:31hrs			66kV Sentsikha - Dechula Line	Dechula vs	Y & Bph OC Trip	Backup OC EF relay opd, Y&Bph D-7 Trip, fault Current I=11.7A, I _B =1.10kA, I _C =1.08kA, I ₀ =0.56	Transient fault	
(J) 66/33/11kV Pangbasa substation												
1	01.07.2022	18:38hrs	01.07.2022	18:43hrs	0		Has Line	Has	Shortcircuit	Tripped on E.F & O/C	Pan-Has	Transient
2	14.07.2022	00:44hrs	14.07.2022	1:00hrs	0	0.7	Has Line	Has	Tripping	De O/C	Pan-Has	Transient
3	14.07.2022	3:50hrs	14.07.2022	4:10hrs	0	0.7	Has Line	Has	Tripping	De O/C	Pan-Has	Transient
4	14.07.2022	4:10hrs	14.07.2022	4:22hrs	0		Has Line	Has	Tripping	De O/C	Pan-Has	Transient
5	15.07.2022	1:50hrs	15.07.2022	2:10hrs	0		Has Line	Has	Tripping	De O/C	Pan-Has	Transient
6	15.07.2022	2:10hrs	15.07.2022	2:17hrs	0		Has Line	Has	Tripping	De O/C	Pan-Has	Transient
7	15.07.2022	2:10hrs	15.07.2022	2:30hrs	0		Has Line	Has	Tripping	De O/C	Pan-Has	Transient
8	15.07.2022	2:30hrs	15.07.2022	2:48hrs	0		Has Line	Has	Tripping	De O/C	Pan-Has	Transient
9	15.07.2022	2:50hrs	15.07.2022	3:03hrs	0		Has Line	Has	Tripping	De O/C	Pan-Has	Transient
10	18.07.2022	3:50hrs	18.07.2022	4:07hrs	0		Has Line	Has	Tripping	De O/C	Pan-Has	Transient
(K) 66/33kV Damg Substation												
1	01.07.2022	18:21 hrs	01.07.2022	18:31 hrs	0	-4	66 kV Incoming Line	Whole Substation	Trip	NA		Transmission Line tripped from Sentsikha Substation (3 Phase Tripped)
2	07.07.2022	06:15 hrs	07.07.2022	06:21 hrs	0	-4.13	66 kV Incoming Line	Whole Substation	Trip	NA		Transmission Line tripped from Sentsikha Substation
3	08.07.2022	11:13 hrs	08.07.2022	11:14 hrs	0	-4.02	66 kV Incoming Line	Whole Substation	Trip	NA		Transmission Line tripped from Dechencholing Substation due to installation of meter
4	20.07.2022	00:44 hrs	20.07.2022	00:48 hrs	0	-4.04	66 kV Incoming Line	Whole Substation	Trip	NA		Transmission Line tripped from Sentsikha Substation
(L) 66/11kV Dechula Substation												
1	07.07.22	6:15	07.07.22	6:21		-11.83	66kV Sentsikha	Sentsikha - Dechula	Transit fault	under voltage and 88 relay	Sentsikha	Temporary
2	07.07.22	6:15	07.07.22	6:21		-10.29	66kV Lobeysa	Lobeysa - Dechula	Transit fault	under voltage and 88 relay	Lobeysa	Temporary
3	08.07.22	18:48	08.07.22	18:57		-11.14	66kV Sentsikha	Sentsikha - Dechula	Transit fault	under voltage and 88 relay	Sentsikha	Temporary
4	08.07.22	19:48	08.07.22	20:00		-29.57	66kV Lobeysa	Lobeysa - Dechula	Transit fault	under voltage and 88 relay	Lobeysa	Temporary
5	08.07.22	2:20	08.07.22	2:25		-11.92	66kV Sentsikha	Sentsikha - Dechula	Transit fault	under voltage and 88 relay	Sentsikha	Temporary
6	08.07.22	2:20	08.07.22	2:47		-30.34	66kV Lobeysa	Lobeysa - Dechula	Transit fault	under voltage and 88 relay	Lobeysa	Temporary
7	08.07.22	12:23	08.07.22	12:23		-11.88	66kV Sentsikha	Sentsikha - Dechula	Transit fault	under voltage and 88 relay	Sentsikha	Temporary
8	08.07.22	12:23	08.07.22	12:25		-30.17	66kV Lobeysa	Lobeysa - Dechula	Transit fault	under voltage and 88 relay	Lobeysa	Temporary
9	20.07.22	6:43	20.07.22	6:52		-29.87	66kV Sentsikha	Sentsikha - Dechula	Transit fault	under voltage and 88 relay	Sentsikha	Temporary
10	20.07.22	6:43	20.07.22	6:55		-11.42	66kV Sentsikha	Sentsikha - Dechula	Transit fault	under voltage and 88 relay	Sentsikha	Temporary
11	20.07.22	19:23	20.07.22	20:08		-29.90	66kV Lobeysa	Lobeysa - Dechula	Transit fault	under voltage and 88 relay	Lobeysa	Temporary
12	20.07.22	19:23	20.07.22	19:29		-11.67	66kV Sentsikha	Sentsikha - Dechula	Transit fault	under voltage and 88 relay	Sentsikha	Temporary
13	21.07.22	17:16	21.07.22	17:22		-30.28	66kV Lobeysa	Lobeysa - Dechula	Transit fault	under voltage and 88 relay	Lobeysa	Temporary
14	21.07.22	17:16	21.07.22	17:32		-11.84	66kV Sentsikha	Sentsikha - Dechula	Transit fault	under voltage and 88 relay	Sentsikha	Temporary



Transmission System Performance Report

Third Quarterly Report-2022

August 2021

Sl No.	Date of Tripping	Time of outages	Date of Normalization	Time of fault was cleared	Duration of Outages (Hrs)	MW before outage (MW)	Feeder Name	Name of the Substation/Lines affected by the fault	Reasons of fault	Relay operations	Exact location of fault [Line segment/ Substation]	Type of outages	Remarks
66kV & Above													
1A) 400/220/66/11 kV Malhase Substation													
1	01.08.2022	19:07	01.08.2022	21:05	1	179	200MVA ICT	Malhase Se	FWD OPTD	FWD Y-Phase, 06 OPTD			IL1=276.34kA, IL2=239.44kA, IL3=251.3
2	08.08.2022	7:23	08.08.2022	7:29	0	25	66kV Pasakha I	Malhase Se	O/C on B phase	06 OPTD, General trip IEF 50N trip	line		IL1=1825.53A<12.31, I2=219.37A<130.54, I3=585.41A<151.18, IL4=1176.84A<184.80
3	08.08.2022	7:23	08.08.2022	7:30	0	26	66kV Pasakha II	Malhase Se	O/C on Y-phase	06 OPTD, General trip IEF 50N trip	line		IL1=204<132.91, I2=743.12A<55.73, I3=270.35A<106.15
4	08.08.2022	7:33	08.08.2022	7:30	0	5.6	66kV Pasakha IV	Malhase Se	O/C on B-phase	06 OPTD, General trip IEF 50N trip	line		IL1=2315.03A<50.57, I2=292.37A<98.58, IL3=180.51A<38.88
5	18.08.2022	14:57	18.08.2022	15:17	0	22	50/63 MVA Transformer III	Malhase Se		06 OPTD, LBB-Trip, general Trip			IL1=110.88A<114.2, IL2=75.28A<174.65, IL3=313.80A<52.28
6	18.08.2022	14:57	18.08.2022	1:13	10	23	50/63 MVA Transformer III	Malhase Se		DLTC BUCH Trip, DIFF Trip, 06 OPTD			IL1=148.56A<119.84, IL2=104.47A<146.39, IL3=129.88<120.21
7	18.08.2022	14:57	28.08.2022	16:59	194	54.2	220kV Malhase-Birpara fdr	Malhase S&S Birpara SS		Zone 1 Trip, AR OPTD	1.573KM		IL1=7.662kA, I2=7.919kA, I3=571.2A
8	18.08.2022	14:57	26.08.2022	17:12	194	70	220kV Malhase-Singhiguan fdr	Malhase S&S Birpara SS		Dis Pickup 13 DN, Limp L3-EF	70m		IL1=206kA, IL2=0.01kA, IL3=7.76kA
9	18.08.2022	14:57	18.08.2022	15:17	0	22	66kV LV 606	Malhase Se		51N START	0/3		I=171.28A<97A, Y=182A<130, B=310A<119, N=408.93A<127.89
10	19.08.2022	6:35	19.08.2022	6:59	0	64	200MVA ICT	Malhase Se	Temporary fault	06 OPTD	0/3		IL1=331A, IL2=304A, IL3=095A
11	19.08.2022	6:35	19.08.2022	7:51	1	11	220kV Malhase-Santse fdr	Malhase Se-Santse	Temporary fault	07 OPTD	line		IL1=58.77kA<68.27, IL2=36.41A<254.4, IL3=58.17A<187.2, IL4=58.53A<167.3
12	19.08.2022	6:25	19.08.2022	10:26	3	-79	220kV Malhase-Chokha fdr	Malhase Se-Chokha/S	Start R-phase	07 OPTD	line		IL1=384.2A<249.9, IL2=223.4A<57.86<57.86, IL3=568A<38.75, IL4=305.3A<330.3
13	19.08.2022	6:35	19.08.2022	7:59	1	44	50/63 MVA Transformer I	Malhase Se		06 OPTD, DSP OPTD	0/3		IL1=31A<249.9, IL2=26A<91.83, IL3=31A<140.11, IL4=88A<173.34
14	19.08.2022	6:35	19.08.2022	7:33	0	42	66kV Pasakha feeder I	Malhase Se	O/C, E/F	IOC 50 Trip, IEF 50N Trip, General Trip, 06 OPTD	line		IL1=54.74A<48.83, IL2=316.74A<120.62, IL3=885.39A<74.71, ILN=3137.37A<166.02
15	19.08.2022	6:35	19.08.2022	6:43	0			Malhase Se	O/C, E/F	IEF 50N trip, 06 optd, general trip, IEF 50 trip			IL1=6420.49A<54.29, IL2=629.18A<128.62, IL3=6485.32A<109.52, ILN=7519.76A<113.68
16	20.08.2022	1:45	20.08.2022	3:03	1	18.4	220kV Malhase-Santse fdr	Malhase Se-Santse	E/F	M1 Trip, R phase Trip, Zone 1 Trip, R/L Trip	30.3 KM		IL1=184.6A, IL2=338.3A, IL3=162.3A, IN=3286A
17	21.08.2022	3:32	21.08.2022	5:42	0	17	220kV Malhase-Santse fdr	Malhase Se-Santse	O/C on B phase and Y-phase	M1 Trip, Zone 1 Trip			IL1=6803A, IL2=6477A, IL3=131.4A, IN=5197A
18	21.08.2022	3:32	21.08.2022	5:40	0	66	200MVA ICT	Malhase Se	Temporary fault	07 OPTD			IL1=199.5A<30.96, IL2=185.6A<44.24, IL3=158.1A<155.3
19	21.08.2022	11:09				41	50/63 MVA Transformer I	Malhase Se	LBB & FWD operated did not charged, lapsed under shutdown	LBB Trip, 06POTD	0/3		IL1=389.54A<2.17, IL2=380.11A<34.48, IL3=314.28A<110.06
20	21.08.2022	11:09	21.08.2022	14:17	3		66kV Bus Coupler	Malhase Se	O/C on R, Y & B Phase	51 Trip, 06OPTD	0/3		IL1=1762.53A, IL2=1745.75A<119.75, IL3=1772.81<120.53, IL4=1753A<90.38
21	21.08.2022	11:09	21.08.2022	14:19	3	50	66kV pasakha IV	Malhase Se	O/C	51 Trip, 06OPTD	line		IL1=786.4A, IL2=789.53A<120.42, IL3=790.83A<120.11
22	21.08.2022	12:09	21.08.2022	14:18	2	44	66kV pasakha II	Malhase Se	O/C	51 Trip, 06OPTD	line		IL1=23A<80, IL2=977.20A<75.72, IL3=602.78A<102.18
23	21.08.2022	18:10	21.08.2022	18:16	0	24	200MVA ICT	Malhase Se	Temporary fault	06 OPTD			IL1=073A<192.4, IL2=247A<72.17, IL3=157A<134.3
24	21.08.2022	11:29	21.08.2022	15:21	3	-12.65	66kV malhase-Phuntching fdr	Malhase Se-Phuntching fdr	O/C	O/C Trip 1-LE/11	line		IA=530.4A, IB=585A, IC=503.3A, IN=4467A
25	21.08.2022	18:10	21.08.2022	18:12	0	-31	220kV Malhase-Chokha fdr	Malhase Se-Chokha/S	Temporary fault	06 optd	line		IL1=80.05A<145.1, IL2=65.98A<21.86, IL3=67.44A<276.3, IL4=5887A<70.5
26	21.08.2022	18:10	21.08.2022	18:30	0	15	66kV Pasakha IV	Malhase Se	O/C	IEF 50N<06 optd, General trip, 06 trip	line		IL1=2345.05A<12.88deg, IL2=372.65A<73.8deg, IL3=235.31A<1.47deg
27	21.08.2022	18:10	21.08.2022	18:19	0	22	50/63 MVA Transformer III	Malhase Se	Temporary fault	BB optd, Differential optd.	0/3		IL1=38A<11.32deg, IL2=218.14A<1.28deg, IL3=203.78A<118.97deg
28	21.08.2022	18:10	21.08.2022	18:33	0	13	220kV Malhase-Santse fdr	Malhase Se-Santse	Temporary fault	B/B Trip	line		IL1=52.76A<71.85deg, IL2=22.99A<262.8deg, IL3=44.18A<139.2deg, IL4=51.58A<114.8deg
29	22.08.2022	14:52	23.08.2022	14:25	0	31	50/63 MVA Transformer III	Malhase Se	Temporary fault	BB optd, Differential optd.	0/3		IL1=183.86A<6.41deg, IL2=72.46A<20.01deg, IL3=102.86A<81.95deg, IL4=281.29A<28.10deg
30	22.08.2022	14:32	23.08.2022	14:47	0	3	220kV Malhase-Santse fdr	Malhase Se-Santse	O/C on y phase and with E/F	Main Protection trip-O/C relay trip-Loop L3-N	line		IL1=92.18A<350.7deg, IL2=3733A<168.8deg, IL3=33.1A<14.3deg, IL4=3633A<143.5deg
31	23.08.2022	14:48	23.08.2022	16:18	1	3	220kV Malhase-Santse fdr	Malhase Se-Santse	O/C on Y & B phase and with E/F	General trip-Main 1 trip	line		IL1=56.29A<223.0deg, IL2=4350A<171.9deg, IL3=6075A<34.8deg, IL4=3153A<102.6deg
32	26.08.2022	18:55	26.08.2022	18:47	0	33	50/63 MVA Transformer III	Malhase Se	Temporary fault	06OPTD, 027 Trip, Diff Trip	0/3		IL1=40.83A<39.53 deg, IL2=364.11A<52.67 deg, IL3=279.86A<170.42 deg, IL4=308.45A<80.03 deg
33	26.08.2022	18:30	27.08.2022	14:47	30	26.08	220kV Malhase-Birpara fdr	Malhase S&S Birpara SS	Birpara line LA got punctured.	Phase ABC, Distance zone 1 tripped, AR Lockout, Fault location=508.3m.	line		IA= 772.5A, IB= 639.5A, IC= 744.1kA
34					0								
35					0								
0B) 220/66/11 kV Singhiguan Substation													
1	17.07.22	3:32	17.07.22	3:45	0	0.897	220kV Single-Santse Feeder	Singhiguan ss					couldnt download fault due to Digi software communication problem.
2	18.07.22	12:00	18.07.22	13:58	1	0.02	11kV Feeder 1	Singhiguan ss					IL1= 9.05kA, IL2= 7.87kA, IL3= 1.74kA
3	18.07.22	17:50	18.07.22	20:35	2	3226	11kV Feeder 2	Singhiguan ss					IL1= 0.03kA, IL2= 7.95kA, IL3= 0.05kA
4	18.07.22	10:40	18.07.22	10:42	0	0.13	11kV Feeder 1	Singhiguan ss		Transit Fault			IL1= 0.1kA, IL2= 0.01kA, IL3= 0.19kA
5	23.07.22	16:59	23.07.22	17:31	0	0.132	11kV Feeder 1	Singhiguan ss					IL1= 1.08kA, IL2= 0.01kA, IL3= 1.16kA
6	24.07.22	9:09	24.07.22	9:10	0	0.857	11kV Feeder 1	Singhiguan ss	a/c & E/F, IEF Trip, General trip				IL1=2.79kA, IL2= 6.01kA, IL3= 6.01kA
7	26.07.22	20:58	26.07.22	21:15	0	0.955	11kV Feeder 2	Singhiguan ss		Tripped on O/C T&E Phase			IL1= 9.07kA, IL2= 8.54kA, IL3= 3.13kA
8	28.07.22	25:39	28.07.22	23:44	0	8	66kV B/Concast feeder	Singhiguan ss					IL1=11.28kA, IL2= 58.93kA, IL3= 95.53kA



Transmission System Performance Report

Third Quarterly Report-2022

06/33/11 kV Phuentsholing Substation												
1	13.08.2022	18:36	13.08.2022	18:40	0	-4.77	66kV Chukha-Pling feeder	Black out at Pling ss			Tripped at chukha end	At 18:36hrs 66kV Chukha-Pling feeder got tripped from chukha end and 66kV Pling Gontu feeder got tripped at our end causing black out at Pling. At 18:40hrs normalised the 66kV Chukha-Pling from Chukha end and at 18:45hrs normalised 66kV Pling-Gontu feeder after getting clearance from BPSO.
2	13.08.2022	18:56	13.08.2022	18:43	0	-1.04	66kV Pling Gontu fdr	Black out at Pling ss	Overcurrent	Re-995.7A, R-1.038kA, J-51.71A, VAB-4.560kV, VBC-34.00kV, VCA-57.51kV, IHM-11.72A, DND-12.38A	Tripped at our end	
3	14.08.2022		14.08.2022	14:24			66kV Pling Malhase fdr	66kV Pling Malhase fdr				At 14:24hrs charged 66kV Pling Malhase feeder which was under idle charge condition with closing code 111 from BPSO. At 18:59hrs opened CB of above fdr with opening code 0943 from BPSO and said feeder kept under idle charged condition.
4	14.08.2022	14:30	14.08.2022	18:56	4	-1.57	66kV Pling Gontu fdr	66kV Pling Gontu fdr	Shutdown	Nil	Line	At 14:30hrs 66kV Pling Gontu feeder taken shut down by TMD/Pling against work permit no 004 with opening code 0941 from BPSO for RoW clearing between location PPW 2 to PPW 3. At 18:56hrs normalised with closing code 114 from BPSO.
5	18.08.2022	15:25	18.08.2022	15:32	0	-2.97	66kV Chukha-Pling feeder	Black out at Pling ss	Tripped at their end	Nil	Tripped at their end	Tripped at Chukha end.
6	18.08.2022	15:25	18.08.2022	15:45	0	-3.15	66kV Pling Gontu fdr	Black out at Pling ss	Earth fault	Re-995.7A, R-1.038kA, J-51.71A, VAB-4.560kV, VBC-34.00kV, VCA-57.51kV, IHM-11.72A, DND-12.38A	System	Tripped at our end. At 15:45hrs test charged after getting clearance from BPSO and stood normal.
7	18.08.2022		18.08.2022	15:28			66kV Pling Malhase fdr	66kV Pling Malhase fdr				At 15:28hrs charged 66kV Pling Malhase feeder which was under idle charge condition with closing code 134 from BPSO, since 66kV Chukha-Pling supply fail from Chukha end and 66kV Pling Gontu tripped at our end. At 15:57hrs opened CB of above fdr with opening code 0943 from BPSO and said feeder kept under idle charged condition.
8	19.08.2022		19.08.2022	8:34			66kV Pling Malhase fdr	66kV Pling Malhase fdr				At 08:34hrs as per instruction from BPSO charged 66kV Pling Malhase feeder which was under idle charge condition with closing code 134 from BPSO due to voltage fluctuation. On dated 21.08.2022 at 11:39hrs opened CB of 66kV Pling Malhase feeder with opening code 0943 from BPSO and feeder kept under idle charged condition.
9	21.08.2022	11:09	21.08.2022	11:29	0	-8.87	66kV Chukha-Pling feeder	66kV Chukha-Pling feeder		DFTN OPTD, 106406		Test charged as per instruction from BPSO with charging code 156 but didn't withstand. Informed to BPSO. At 11:39hrs test charged with same charging code as per instruction from BPSO and stood normal.
10	21.08.2022	11:09	21.08.2022	11:16	0	-8.97	66kV Pling Gontu fdr	66kV Pling Gontu fdr		operated only 106 & 108		At 11:16hrs test charged as per instruction from BPSO with charging code 157 and stood normal.
11	21.08.2022		21.08.2022	15:24			66kV Pling Malhase fdr	66kV Pling Malhase fdr				At 15:24hrs as per instruction from BPSO charged 66kV Pling Malhase feeder which was under idle charge condition with closing code 140 from BPSO. At 17:13hrs opened CB of 66kV Pling Malhase feeder with opening code 0943 as per instruction from BPSO and feeder was put back to idle charged condition.
12	25.08.2022		25.08.2022	16:05			66kV Pling Malhase fdr	66kV Pling Malhase fdr				At 16:05hrs as per instruction from BPSO charged 66kV Pling Malhase feeder which was under idle charge condition with closing code 140 from BPSO. At 16:11hrs opened CB of 66kV Pling Malhase feeder with opening code 09604 as per instruction from BPSO and feeder was put back to idle charged condition. The operation was carried out to build up the voltage.
13	26.08.2022		26.08.2022	8:51			66kV Pling Malhase fdr	66kV Pling Malhase fdr				At 08:51 66 kV Pling Malhase feeder charged from our end with charging code 106 from BPSO due to high rise in winding temperature of 50/63MVA transformer II & III at Malhase end. At 17:31hrs opened CB of 66kV Pling Malhase feeder with opening code 0956 from BPSO and said feeder was put back to idle charged condition.
06/33/11 kV Gedu Substation												
1	13.08.2022	18:55	13.08.2022	18:40	0	1.3	66kV Gedu Chukha Feeder.	Black out	Tripped from Chukha end.		Line segment	66kV supply returned from Chukha end.
2	18.08.2022	15:26	18.08.2022	15:32	0	1.53	66kV Gedu Chukha Feeder.	Black out	Tripped from Chukha end.		Line segment	66kV supply returned from Chukha end.
06/33/11 kV Gontu Substation												
1	13.08.2022	18:39	13.08.2022	18:44	0	-9.279	66kV Dhamdum feeder	Whole Gontu	Grid failed	Nil	Chukha	tripped from Dhamdum end
2	13.08.2022	18:55	13.08.2022	18:43	0	0.96	66kV Gontu Phuentsholing	Whole Gontu	Grid failed	Nil	Chukha	Tripped from pling end
3	18.08.2022	15:25	18.08.2022	15:57	0	-7.784	66kV Dhamdum Line	Gontu	Tripped	General tripped.	Gontu III	Tripped
4	18.08.2022	14:56	18.08.2022	18:02	3	-3.16	Siggaygnan	Dhamdum	heavy rain with wind	REL 670 trip	NA	Line tripped due to E/F on ED facility. Zone 1(General trip) 400KV conductor sag and fall on 220KV line. In Fdr: kept under shut down
5	23.08.2022	14:53	23.08.2022	14:47	0	-13.12	220kV Malhase feeder	Dhamdum	heavy rain with wind	REL 670 trip	NA	Feeder tripped due to Zone 1(General trip)/RYB Fault and VT fuse fail but only Breaker trip from Malhase end
6	23.08.2022	14:48	23.08.2022	16:18	1	-17.12	220kV Malhase feeder	Dhamdum	heavy rain with wind	REL 670 trip	NA	Feeder tripped from Malhase end. Relay indicated, Zone 1(General trip)/RYB Fault and VT fuse fail only
7	24.08.2022	15:15	23.08.2022	13:14	22	6.74	50/63MVA Transformer II	Dhamdum	windy	shut down	NA	50/63MVA transformer II taken emergency shut down due to abnormal sound produced from the Circuit breaker R0 against work permit No-1598. BPSO shutdown code no. 0965
8	13.08.2022	18:55	13.08.2022	16:44	0	9.24	Gontu		Transient fault	REC670	NA	Tripped on O/C Fault current value 1) L1 - 2.250A 2) L2 - 2.424A 3) L3 - 2.318A 4) R0 - 0.001A
9	18.08.2022	15:43	18.08.2022	15:53	0	6.2	Gontu		Transient fault	REC670	NA	Tripped on O/C Fault current value(Y & R) 1) L1 - 0.294A 2) L2 -1.090A 3) L3 - 1.965A 4) R0 - 0.001A
10	23.08.2022	14:02	23.08.2022	14:05	0	9.2	66kV Gontu feeder		Transient fault	REL 670 General trip, Zone 2 trip, 3 phase fault.	NA	Fault current value(BF) 1) = Fault mag=162.22A, Fault angle=14.75deg. 2) = Fault mag= 42.19A, Fault angle=145.01deg. 3)=1882.45A, Fault angle= 43.85deg.
11	23.08.2022	14:02	23.08.2022	14:12	0	0	66kV Bus coupler		Transient fault	no relay operation	NA	Trip same time with Gontu feeder.
06/20kV Wana Substation												
1	08-01-22	9:46hrs	08-01-22	10:08hrs		5.830MW	66/33KV EMVA transformer	Fdr I and II	WTI tripped	WTI tripped	EMVA WTI tripped	Tripped
2	08-02-22	7:10hrs	08-02-22	7:50hrs		5.890MW	66/33KV EMVA transformer	Fdr I and II	WTI tripped	WTI tripped	EMVA WTI tripped	Tripped
3	08-02-22	10:40hrs	08-02-22	11:15hrs		5.554MW	66/33KV EMVA transformer	Fdr I and II	WTI tripped	WTI tripped	EMVA WTI tripped	Tripped
4	08-05-22	13:04hrs	08-05-22	13:22hrs		5.304MW	66/33KV EMVA transformer	Fdr I and II	WTI tripped	WTI tripped	EMVA WTI tripped	Tripped
5	08-05-22	19:40hrs	08-05-22	19:52hrs		5.810MW	66/33KV EMVA transformer	Fdr I and II	WTI tripped	WTI tripped	EMVA WTI tripped	Tripped
6	08-05-22	8:19hrs	08-05-22	8:40hrs		5.380MW	66/33KV EMVA transformer	Fdr I and II	WTI tripped	WTI tripped	EMVA WTI tripped	Tripped
7	08-05-22	9:19hrs	08-05-22	10:02hrs		5.280MW	66/33KV EMVA transformer	Fdr I and II	WTI tripped	WTI tripped	EMVA WTI tripped	Tripped
8	08-05-22	10:54hrs	08-05-22	11:22hrs		5.280MW	66/33KV EMVA transformer	Fdr I and II	WTI tripped	WTI tripped	EMVA WTI tripped	Tripped
9	13/8/2022	17:50hrs	13/8/2022	17:56hrs		480MW	66KV SF6 breaker	Fdr I and II	Earth fault on Y phase	Earth fault on Y phase	Fdr II Chupcha	Tripped
10	28/8/2022	8:45hrs	26/8/2022	8:30hrs		150MW	66KV SF6 breaker	Fdr I and II	Earth Fault	EF relay operated	Fdr I Chupcha	Tripped
11	28/8/2022	09:20hrs	28/8/2022	09:30hrs		245MW	66KV SF6 breaker	Fdr I and II	OC and EF on ABC phase	OC and EF on ABC phase	Fdr II Chupcha	Tripped
06/20kV Olakha Substation												
1	03-08-22	2:33	07-08-22	2:42	0	2.86	66/33KV 20MVA Transformer I	All the 33kV was effected as the 20MVA Transformer I & II was tripped	Over current and earth fault	Earth Fault Over Current Operated	Distribution line	Transient fault
2	03-08-22	2:33	03-08-22	2:42	0	2.86	66/33KV 20MVA Transformer II	All the 33kV was effected as the 20MVA Transformer I & II was tripped	Over current and earth fault	Earth Fault Over Current Operated	Distribution line	Transient fault
3	04-08-22	5:04	04-08-22	5:22	0	3.15	66/33KV 20MVA Transformer I	All the 33kV was effected as the 20MVA Transformer I & II was tripped	Over current and earth fault	Earth Fault Over Current Operated	Distribution line	Transient fault
4	04-08-22	5:04	04-08-22	5:29	0	3.13	66/33KV 20MVA Transformer II	All the 33kV was effected as the 20MVA Transformer I & II was tripped	Over current and earth fault	Earth Fault Over Current Operated	Distribution line	Transient fault
06/33/11kV Dochasholing substation												
1	23.08.2022	08:40hrs	23.08.2022	08:56hrs	0	4.215	66kV Dandi line	only Dandi line	Tripped on Distance relay	Dist relay: LA-44 02A, B-1.15KA, & JC 1.515KA, Fault resistance -2.049G	Fault location: 29.21KM Zone-1	Tripped
06/11kV Basa Substation												
1	21.08.2022	15:35	21.08.2022	15:46	0	-0.91	66kV inverter	All	unknown	O/C	Pugheza	The supply was normalised after resetting the relay.
2	26.08.2022	6:08	26.08.2022	6:22	0	-0.81	66kV inverter	All	unknown	O/C & E/F	Pugheza	The supply was normalised after resetting the relay.



Transmission System Performance Report

Third Quarterly Report-2022

(J) 220kV Substation Sentsikka											
Sl. No.	Start Date	End Date	Duration	Time	From	To	Reason	Impact	Remarks	Category	Count
1	01-08-22	16:21hrs	01-08-22	16:21hrs	46.46	60kV Sentsikka-Dochula Line	Dochula s/s	Y & Bph OC Trip	Backup OC/EF relay opd., Y&Bph D-2 Trip IA=240.5A,IB=5.368A, IC=5.807A,ADIN=17.38A	Transient	1
2	04-08-22	07:05hrs	04-08-22	07:10:00hrs	46.46	60kV Sentsikka-Dochula Line	Dochula s/s	Y & Bph OC Trip	Backup OC/EF relay opd., Y&Bph D-2 Trip IA=211.5A,IB=5.190A, IC=5.018A,ADIN=17.88A	Transient	1
3	16-08-22	07:31hrs	16-08-22	07:34hrs	46.46	60kV Sentsikka-Dochula Line	Dochula s/s	Y & Bph OC Trip	Backup OC/EF relay opd., Y&Bph D-2 Trip IA=275A,IA,IB=5.71A, A,IC=5.322A,ADIN=17.89A	Transient	1
4	20-08-22	05:52hrs	21-08-22	05:47hrs	47.21	60kV Sentsikka-Dochula Line	Dochula s/s	Y & Bph OC Trip	Backup OC/EF relay opd., Y&Bph D-2 Trip IA=303.5A,IA,IB=5.58A, A,IC=5.498A,ADIN=17.01A	Transient	1
5	26-08-22	18:58hrs	21-08-22	18:48hrs	45.77	60kV Sentsikka-Dochula Line	Dochula s/s	Y & Bph OC Trip	Backup OC/EF relay opd., Y&Bph D-2 Trip O.C.IA=245.2A,IB=5.398A, IC=5.603A	Transient	1
(K) 66-33kV Changdaphu Substation											
1	26-08-22	18:54hrs	26-08-22	18:57hrs	5.85	66kV Changdaphu-Obakha Line	66kV Changdaphu-Obakha Line		Distance Protection, Zone 2 Yph Trip, R=120.16Z, Y=564.00Z, B=625.66Z	Transient	1
(L) 66-33kV Dzanj Substation											
1	23-08-2022	06:44 hrs	23-08-2022	08:58 hrs	0	66 kV Incoming Line	Whole Substation	Tripping	NA	Transmission Line tripped from Dechencholing Substation	
(M) 66-11kV Dochula Substation											
1	01-08-22	16:21	01-08-22	16:21	-02.86	66kV Sentsikka	Sentsikka - Dochula	Transient fault	Under voltage and Motor	Sentsikka	Transient
2	01-08-22	17:21	01-08-22	18:31	-03.47	66kV Loherya	Loherya - Dochula	Transient fault	Under voltage and Motor	Loherya	Transient
3	04-08-22	7:05	04-08-22	7:11	-31.76	66kV Sentsikka	Sentsikka - Dochula	Transient fault	Under voltage and Motor	Sentsikka	Transient
4	04-08-22	7:07	04-08-22	7:18	-32.24	66kV Loherya	Loherya - Dochula	Transient fault	Under voltage and Motor	Loherya	Transient
5	16-08-22	7:31	16-08-22	7:37	-32.34	66kV Sentsikka	Sentsikka - Dochula	Transient fault	Under voltage and Motor	Sentsikka	Transient
6	16-08-22	7:31	16-08-22	7:37	-32.42	66kV Loherya	Loherya - Dochula	Transient fault	Under voltage and Motor	Loherya	Transient
7	21-08-22	5:52	21-08-22	5:48	-32.89	66kV Sentsikka	Sentsikka - Dochula	Transient fault	Under voltage and Motor	Sentsikka	Transient
8	21-08-22	5:52	21-08-22	5:57	-32.29	66kV Loherya	Loherya - Dochula	Transient fault	Under voltage and Motor	Loherya	Transient
9	26-08-22	18:54	26-08-22	18:48	-23.64	66kV Sentsikka	Sentsikka - Dochula	Transient fault	Under voltage and Motor	Sentsikka	Transient
10	26-08-22	18:54	26-08-22	18:47	-27.88	66kV Loherya	Loherya - Dochula	Transient fault	Under voltage and Motor	Loherya	Transient



Transmission System Performance Report

Third Quarterly Report-2022

September 2021

Sl No.	Date of Tripping	Time of outages	Date of Normalization	Time of fault was cleared	Duration of Outages (Hrs)	MW before outage (MW)	Feeder Name	Name of the Substation/Lines affected by the fault	Reasons of fault	Relay operations	Exact location of fault [Line segment/ Substation]	Type of outages	Remarks
66kV & Above													
(A) 400/220/66/11 kV Malhae Substation													
1	06-09-2022	0:08	06-09-2022	0:12	0	22	50 MVA transformer III	Malhae Substation	Tripping	86 optd, DIFF Harm Blk			IL1= 85.32<167.70deg, IL2= 152.23A<64.93deg,IL3= 317.11A<61.26deg,IL4= 178.63<41.14deg, Transformer charged with charging code 252/BPS0
2	06-09-2022	0:08	06-09-2022	0:22	0	134	220kV Chukha feeder III	Malhae Substation	Tripping	86 optd, DIFF Harm Blk, MCOM Relay, START BN, Tripped Phase, ABC Start Element Distance, Distance trip Zone AR lockout shot system frequency 49.93, fault duration:53.41ms, Relay time :01.70ms.	11.42 km		IA= 408.8A, IB=5.40kA,IC=267.1A, Charged with Code 251/BPS0
3	07-09-2022	15:51	07-09-2022	15:59	0	-	66kV Bus Coupler	Malhae Substation	Tripping	86 optd JEF, 50N Trip,IOC, 50 TRIP,GENERAL TRIP			IL1=11.2920A<59.91deg,IL2=125.07A<61.57deg,IL3=1323557A<62.06deg, IL4= 9495.09A<20.76deg
4	07-09-2022	15:51	07-09-2022	15:59	0	17	66kV Pasakha fdr no I	Malhae Substation	Tripping	86 optd JEF, 50N Trip,IOC, 50 TRIP,GENERAL TRIP			IL1=1101.00A<107.54deg,IL2=85.25A<61.36deg, IL3=1079.85A<93.43deg, IL4= 371.73A<13.46deg
5	15-09-2022	22:41	15-09-2022	22:46	0	10	220kV Malhae-Samtse	Malhae Substation	Tripping	M1 trip,Zone 1 trip	18.3km		IL1=24.28A<232.2, IL2=56.69A<238.3, IL3=2080A<39.58, IL4=2134A<38.78
6	15-09-2022	22:58	15-09-2022	22:44	0	-	220kV bus coupler	Malhae Substation	Tripping	86 OPTD,			
7	15-09-2022	22:41	15-09-2022	22:48	0	34	50 MVA transformer III	Malhae Substation	Tripping	OLTC trip,DIFF Retrain,DIFF Trip,DIFF WARM,DIFF WARM Trip			IL1=91.86A<27.36deg,IL2=151.47A<120.59deg,IL3=65.52A<126.91deg,IL4=227.62<98.85
8	16-09-2022	23:28	16-09-2022	23:47	0	119	220kV Chukha feeder III	Malhae Substation	Tripping	86 optd, Zone 1 Tripped			IA =461.3A,IB =419.9A,IC=2.710A
9	16-09-2022	23:28	16-09-2022	23:49	0	27	50 MVA transformer III	Malhae Substation	Tripping	DIFF, TRIP, 27 TRIP,86 Optd			IL1 =91.99 A< 43.17 DEG,IL2 =151.66 A< 112.19 DEG,IL3=63.07A< 119.95DEG,IL4=56.36<94.36DEG
10	16-09-2022	10:28	16-09-2022	10:31	0	88	50 MVA transformer III	Malhae Substation	Tripping	EXT TRIP, 86 OPTD,			IL1 = 106.82 A, IL2= 423.8 A, IL3= 284.97A,IL4= 217.19A
11	16-09-2022	19:34	16-09-2022	19:50	0	10.4	220kV Malhae-Samtse	Malhae Substation	Tripping	I/O Trip			IL1=1031A<278.41deg,IL2=100.8A<102.32deg,IL3=2961A<31.20deg,IL4=1908A<337.9
12	16-09-2022	19:34	16-09-2022	19:39	0	28	50 MVA transformer III	Malhae Substation	Tripping	EXT TRIP, 86 OPTD,			IL1=13.15A<47.12deg,IL2=111.5A<132.39deg,IL3=67.55A<144.37
13	16-09-2022	22:28	16-09-2022	22:31	0	28	50 MVA transformer III	Malhae Substation	Tripping	EXT TRIP, 86 OPTD, OLTC, 86 OPTD,			IL1 = 106.82 A, IL2= 423.8 A, IL3= 284.97A,IL4= 217.19A
14	20-09-2022	8:31	20-09-2022	8:34	0	0	220 kV Bus coupler	Malhae Substation	Tripping	86 optd,			No data displayed
15	22-09-2022	3:55	22-09-2022	3:00	0	115	220kV Chukha feeder III	Malhae Substation	Tripping	I/C,Zone 1 trip, ILY, B phase Trip, fault location =8.159Km.	fault location =8.159Km,Ed=80.00ms		IL1=10.94A,IL2=7.15K,IL3=0.471KA
16	22-09-2022	3:55	22-09-2022	3:01	0	28	50 MVA transformer III	Malhae Substation	Tripping	DIFF trip, 86 optd			IL1=151.35A<19.74deg,IL2=96.02A<34.56deg,IL3=78.86A<41.48deg,IL4=222.34A<29.22
17	22-09-2022	3:55	22-09-2022	3:00	0	-	220kV bus coupler	Malhae Substation	Tripping	CBFF			IA=11.6A,IB=684A, IC=3810A,IE=5393A,F IDMT IB=3393A.
18	22-09-2022	3:04	22-09-2022	3:06	0	-	220kV bus coupler	Malhae Substation	Tripping	CBFF			
19	22-09-2022	3:04	22-09-2022	3:08	0	28	50 MVA transformer III	Malhae Substation	Tripping	DIFF, TRIP,86 Optd,			IL1=484.52A<95.10deg,IL2=176.25A<30.73deg,IL3=142.81A<154.32deg,IL4=210.83A<86.84deg
20	22-09-2022	3:04	22-09-2022	4:04	1	111	220kV Chukha feeder III	Malhae Substation	Tripping	Zone 1 trip,86 optd	Zone 1 trip, fault location =11.92Km.		IA=1056A,IB=7023A,IC=5.829A
21	22-09-2022	4:04	22-09-2022	4:12	0	115	220kV Malhae-Samtse	Malhae Substation	Tripping	N1-trip,zone1 trip,	Fault loop=L1-L2,distance =0.2KM		M1=trip,zone1 trip,Fault loop=L1-L2, distance =0.2KM,IL1=4972A<284.6deg,IL2=6654A<164.7deg,IL3=4980A<38.75deg,IL4=794.7A<165.7deg
22	22-09-2022	4:04	22-09-2022	4:11	0	66	400/220kV, 200MVA ICT	Malhae Substation	Tripping	Busbar trip			IL1=177.4A<40.00deg,IL2=181.48<164.8deg,IL3=139.1A<66.65deg
23	23-09-2022	1:57	23-09-2022	2:07	0	19	66kV Pasakha fdr no II	Malhae Substation	Tripping	67 Trip, 86 OPTD, General Trip, 67N Trip			IL1=0.63A<15.85deg, IL2=166.41A<14.28deg,IL3= 165.86A<162.83deg, IL4=15.2A<15.65deg
24	23-09-2022	1:57	23-09-2022	2:06	0	19	66kV Pasakha fdr no IV	Malhae Substation	Tripping	67N Trip, General Trip			IL1= 318.61A<96.07deg,IL2= 668.2A<124.6deg, IL3=2509.85A<81.22deg, IL4=519.61A<96.07deg
25	23-09-2022	1:57	23-09-2022	2:05	0	-	66kV Bus Coupler	Malhae Substation	Tripping	General Trip, 67 Trip, 67, 67, 67, 67			IL1=919.04A<80.79deg, IL3=487.09A<125.7deg, IL3=4758.81A<66.85deg,IL4=5940.01A<72.8deg
26	23-09-2022	17:27	23-09-2022	17:35	0	73	400/220kV, 200MVA ICT	Malhae Substation	Tripping				
27	23-09-2022	17:27	23-09-2022	17:37	0	-	220 kV Bus coupler	Malhae Substation	Tripping				
28	23-09-2022	17:27	23-09-2022	17:45	0	27	50 MVA transformer II	Malhae Substation	Tripping				IL1=71.85A<2.71deg,IL2=714.69A<124.06deg,IL3=704.74A<97deg
29	23-09-2022	17:27	24-09-2022	17:46	24	19	66kV Pasakha fdr no II	Malhae Substation	Tripping				"IL1=0.29A<1.11deg,IL2=886.11 A/<38.29deg,IL3=838.52 A/<62.82deg Test charge done at 18:25hrs, date 23/09/2022 but could not hold and kept on open condition. Taken shutdown for OPG wire resting by TMD/pling (work permit number 288) on 24/09/2022 at 8:45 hours and Test charged at 24/09/2022 @ 15:39 but could not hold. Test charge done @ 14:45 hold in this charge with no load given"
30	23-09-2022	17:27	24-09-2022	17:46	24	20	66kV Pasakha fdr no IV	Malhae Substation	Tripping				"IL1=814.97A<149.38deg,IL2=573.27A /<158.57deg, IL3=2202.2A/<67.25deg Test charge done at 18:25hrs @ 23/09/2022 but could not hold and kept on open condition. Taken shutdown for OPG wire resting by TMD/pling (work permit number 288) on 24/09/2022 at 8:45 hour and test charged at 24/09/2022 @ 13:40 but could not hold - Test charged hold @ 14:45 on 24/09/2022 in this charge condition"
31	23-09-2022	17:27	24-09-2022	17:46	24	19	66kV Pasakha fdr no I	Malhae Substation	hand tripped				"Handtripped during charging of 220/66kV 50 MVA Transformer 2, test charged at 20:45 on 23/09/2022 but could not hold in ring system with 66kV bhutan Concast.Taken shutdown for OPG wire resting by TMD/pling (work permit number 288) on 24/09/2022 at 8:45 hour and test charged & hold at 24/09/2022 13:59 dated 24/09/2022 but hand tripped at 14:00 hrs dated 24/09/2022 due to mixing Y phase current and is currently being attended by TMD pling (Work Permit Number 290 issued by TMD pling) at 15:35 hrs. and at 17:30 hrs. Work permit no 290 was returned by TMD PLING and all 66kV out going feeder Charged at 17:45 hrs."
32	23-09-2022	17:27	24-09-2022	18:23	24	7.2	66kV Phusholing fdr	Malhae Substation	Tripping	N1 trip,86optd			IL1=1.233A<197.5k,IL3=1.223A<2.03k, kept in open condition.
33	23-09-2022	20:48	23-09-2022	20:53	0	-	220 kV Bus coupler	Malhae Substation	Tripping	86 optd,	line		No data displayed
34	23-09-2022	20:48	23-09-2022	20:55	0	56	400/220kV, 200MVA ICT	Malhae Substation	Tripping	86 optd,	line		IL1=6058A<35.35DEG,IL2=0.160A<28.57DEG,IL3=0.005A<173.4DEG, tripped due to test charge of 66kV feeder Tripped while doing test charge on 66kV Pasakha I and 66kV bhutan Concast fdr.
35	23-09-2022	20:48	23-09-2022	20:58	0	0.42	50 MVA transformer II	Malhae Substation	Tripping	86 optd,	line		IA=0.06A, IB=0.03A, IC=0.02A, no load 66kV feeders not Tripped while doing test charge on 66kV Pasakha I and 66kV bhutan Concast fdr.]
36	23-09-2022	21:42	23-09-2022	22:38	0	88	220kV Bhepa feeder	Malhae Substation	Tripping	I/C on R&B phase,general trip,zone 1 trip.	fault location: Distance=55.84KM.		IA=2.157A, IB=170.6A, IC=2.650A
38	28-09-2022	18:48	28-09-2022	18:44	0	108	220kV Chukha feeder III	Malhae Se	Tripping		line		General Trip, Zone 1 Trip, Fault loop=L3-N, Dist= 4.00 Km, Trip value IL1=578.8A/200.1deg, IL2=122.9A/73.22deg, IL3=5504A/44.84deg, IL4=5284A/47.38deg
39	28-09-2022	18:48	28-09-2022	18:45	0	25	50MVA Transformer III	Malhae Se	Tripping				027 TRIP, DIFF TRIP, Tripped value IL1=76.52A/<61.44deg, IL2=139.94A/<118.24deg,IL3=86.52A/<123.68deg, IL4=271.19A/<107.0deg
40	30-09-2022	12:32	30-09-2022	12:39	0	117.44	220kV Malhae-Chukha	Malhae Se	Tripping				tripped (BE protection)
41	30-09-2022	12:32	30-09-2022	12:37	0	70	400/220kV, 200MVA ICT	Malhae Se	Tripping				tripped (BH protection)
42	30-09-2022	12:32	30-09-2022	12:41	0	14.54	220kV Malhae-Samtse	Malhae Se	Tripping				tripped (BH protection)
43	30-09-2022	12:32	30-09-2022	12:36	0	30.08	220kV Malhae-Bhepa	Malhae Se	Tripping				tripped (BH protection)
44	30-09-2022	12:32	30-09-2022	12:38	0	220 kV Bus coupler	Malhae Se	Tripping					tripped (BH protection)
45	30-09-2022	12:32	30-09-2022	12:37	0	36	400/220kV, 200MVA ICT	Malhae Se	Tripping				tripped (BH protection)
46	30-09-2022	12:32	30-09-2022	12:37	0	220 kV Bus coupler	Malhae Se	Tripping					tripped (BH protection)
47	30-09-2022	13:05	30-09-2022	13:18	0	75.84	220kV Malhae-Chukha	Malhae Se	Tripping				IB trip,IL1=91.72A<104deg,IL2=113A<79.05deg,IL3=101.32A,IL4=6.067A<152.4deg
48	30-09-2022	13:05	30-09-2022	13:22	0	9.9	220kV Malhae-Samtse	Malhae Se	Tripping				IB trip,IL1=27.72A<28A,IL2=28.2A<28.6deg,IL3=28.8A<34.3deg,IL4=82A<1.2deg



Transmission System Performance Report

Third Quarterly Report-2022

02209/11 kV Singhiyam Substation												
#	Date	Time	Duration	Severity	Count	Equipment	Location	Event	Directional Time O/C Trip	Line	Remarks	
**	07.09.2022	15:51	7:9.22	15:54	0	32	66kV Bhutan Concept fdr.	Singhiyam Sa	O/C	Directional Time O/C Trip, I-E > DIRECTIONAL TRIP, GENERAL TRIP, 06 OPTD.	line	IL1=1.14kA, IL2=0.36kA, IL3=0.34kA
**	07.09.2022	15:51	7:9.22	15:54	0	-	66kV Bus 1	Singhiyam Sa	-	Bus open, IEP trip	-	-
**	16.9.22	19:34	16.9.22	20:58	1	7	220kV Singhiyam- Samsa	Singhiyam Sa	tripped	zone 3 trip fault loop L3-N 144km	line	IL1=41.31A, IL2=194.2, IL3=45.02A, I4=248.1, IL5=1358A, I6=85, IL7=1204A, I8=84
**	16.9.22	22:20	16.9.22	22:36	0	0.1	220kV Singhiyam- Samsa	Singhiyam Sa	tripped	General Trip, Zone 1 Trip, F/L-11-N, Distance=230km	line	IL1=2891A, I2=381.6deg, I3=86.15A, I4=96.50deg, I5=88.01A, I6=11.7deg, I7=2714A, I8=8deg
**	17.9.22	22:16	17.9.22	22:17	0	0.067	11kV Feeder no 1	Singhiyam Sa	O/C	General trip, Time O/C trip, IEP trip	line	IL1=1.38kA, IL2=1.43kA, IL3=1.39kA
**	18.9.22	16:40	18.9.22	16:48	0	0.06	11kV Feeder no 1	Singhiyam Sa	O/C	General trip, O/C trip, IEP trip	line	IL1=1.05kA, IL2=0.01kA, IL3=0.01kA
**	19.9.22	21:01	19.9.22	21:10	13	0.261	11kV Feeder III	Singhiyam Sa	O/C	Regulate over current trip	line	Fault Current IL1=0.02kA, IL2=0.02kA, IL3=0.29kA
**	20.9.22	14:53	20.9.22	17:29	2	1.25	11kV Feeder III	Singhiyam Sa	O/C	Regulate over current trip	line	IL1=0.03kA, IL2=0.02kA, IL3=0.39kA
**	21.9.22	2:04	21.9.22	11:52	9	0.458	11kV Feeder III	Singhiyam Sa	O/C	General trip, O/C trip, IEP trip	line	IL1=0.01kA, IL2=0.01kA, IL3=0.39kA
**	21.9.22	11:45	21.9.22	16:31	#N/A	0.50	11kV Feeder III	Singhiyam Sa	O/C	General trip, O/C trip, IEP trip	line	IL1=0.06kA, IL2=0.07kA, IL3=0.44kA
**	22.9.22	0:56	22.9.22	13:46	12	0.643	11kV Feeder III	Singhiyam Sa	O/C	General trip, O/C trip, IEP trip	line	IL1=0.05kA, IL2=0.05kA, IL3=0.43kA
**	22.9.22	4:04	22.9.22	4:32	0	2.09	220kV Singhiyam- Samsa	Singhiyam Sa	tripped	-	line	IL1=525.1A, I2=159.3deg, I3=2342A, I4=277.5deg, I5=230B, I6=46.32deg, I7=1475A, I8=541.7deg
**	23.9.22	3:07	23.9.22	3:06	0	27.5	66kV Bhutan Concept fdr.	Singhiyam Sa	tripped	directional time O/C trip, I-E > Directional trip, I-E > Directional Trip General trip	line	IL1=0.46kA, IL2=1.11kA, IL3=5.62kA
**	23.9.22	17:27	24.9.22	15:47	20	28	66kV Bhutan Concept fdr.	Singhiyam Sa	tripped	Diff time O/C trip, I-E > diff trip, I-E > diff trip	line	IL1=4.35kA, I2=0.08kA, I3=6.36kA test charge at 20:49 hrs but could not hold and kept on open condition.
**	25.9.22	10:03	25.9.22	10:21	0	0.779	11kV Feeder II	Singhiyam Sa	O/C	General trip, Time O/C trip, IEP > trip	line	IL1=0.05kA, IL2=0.04kA, IL3=1.34kA
02209/11 kV Phuntsholing Substation												
1	07.09.2022	18:23	07.09.2022	18:28	0	-3.43	66kV Chukha-Ping feeder	Black out at Ping sa		Tripped at chukha end		At 18:26hrs 66kV Chukha-Ping feeder got tripped from chukha end and 66kV Ping Gantu feeder got tripped at Gantu end (a 66kV Dhamdhun-Gantu feeder got tripped at Gantu end) causing black out at Ping. At 18:29hrs normalised the 66kV Chukha-Ping from Chukha end and at 18:32hrs normalised 66kV Dhamdhun-Gantu feeder from Gantu feeder.
2	07.09.2022	18:23	07.09.2022	18:32	0	-2.07	66kV Ping-Gantu fdr	Black out at Ping sa		66kV Dhamdhun-Gantu fdr tripped from Dhamdhun Sa		
3	11.09.2022	20:35	11.09.2022	20:43	0	-3.09	66kV Chukha-Ping feeder	Black out at Ping sa		Tripped at chukha end		At 20:35hrs 66kV Chukha-Ping feeder got tripped from chukha end and 66kV Ping Gantu feeder got tripped at Gantu end (a 66kV Dhamdhun-Gantu feeder got tripped at Gantu end) causing black out at Ping. At 20:43hrs normalised the 66kV Chukha-Ping from Chukha end and at 20:42hrs normalised 66kV Dhamdhun-Gantu feeder from Gantu feeder.
4	11.09.2022	20:35	11.09.2022	20:42	0	-3.05	66kV Ping-Gantu fdr	Black out at Ping sa		66kV Dhamdhun-Gantu fdr tripped from Dhamdhun Sa		
5			11.09.2022	20:38	20	Idle charge	66kV Ping-Malbasse fdr	66kV Ping-Malbasse fdr				At 20:38hrs charged 66kV Ping-Malbasse feeder which was under idle charge condition with closing code 271 from BPSO. At 20:43hrs opened CB of above fdr with opening code 1815 from BPSO and said feeder kept under idle charged condition after normalising 66kV Chukha and Gantu feeder.
**	15.09.2022	22:15	15.09.2022	22:22	0	-3.67	66kV Chukha-Ping feeder	66kV Chukha-Ping feeder	Tripped at both end	DSTN OPTD, 186A05	Tripped at both end	Tripped on fault
**	15.09.2022	22:38	15.09.2022	23:07	0	-4.58	66kV Ping-Gantu fdr	Black out at Ping sa	Tripped at both end	DSTN OPTD, 186A06	Tripped at both end	Tripped on fault
**	15.09.2022	22:38	15.09.2022	22:46	0	-3.67	66kV Chukha-Ping feeder	Black out at Ping sa	Tripped at chukha end		Tripped at chukha end	At 22:38hrs 66kV Chukha-Ping feeder got tripped from chukha end and 66kV Ping-Gantu feeder got tripped at Gantu end causing black out at Ping. At 22:46hrs normalised 66kV Chukha-Ping fdr from Chukha end with charging code 290.
**	16.09.2022	19:33	16.09.2022	19:41	0	-1.89	66kV Chukha-Ping feeder	66kV Chukha-Ping feeder	Tripped at chukha end		Tripped at chukha end	At 19:33hrs 66kV Chukha-Ping feeder got tripped from chukha end causing black out at Ping. At 19:41hrs normalised 66kV Chukha-Ping fdr from Chukha end.
**	16.09.2022	19:33	16.09.2022	20:02	0	-4.70	66kV Ping-Gantu fdr	66kV Ping-Gantu fdr	Tripped at their end	66kV Dhamdhun-Gantu fdr tripped from Dhamdhun Sa		At 19:33hrs 66kV Ping-Gantu feeder got tripped at Gantu end (a 66kV Dhamdhun-Gantu fdr tripped at Dhamdhun end) causing black out at Ping. At 20:02hrs normalised 66kV Ping-Gantu fdr from Dhamdhun end.
**	16.09.2022	23:20	17.09.2022	0:50	1	-4.06	66kV Chukha-Ping feeder	66kV Chukha-Ping feeder	Tripped at chukha end		Tripped at chukha end	At 23:20hrs 66kV Chukha-Ping fdr tripped from chukha end (Ping black out) and as per instruction from BPSO opened CB for said fdr at 23:50hrs at our end. At 00:50hrs charged from our end as per instruction from BPSO with charging code 296 and stood normal.
**	16.09.2022	23:20	17.09.2022	11:04	10	-0.15	66kV Ping-Gantu fdr	66kV Ping-Gantu fdr	Tripped at their end	66kV Dhamdhun-Gantu fdr tripped from Dhamdhun Sa		At 23:20hrs 66kV Ping-Gantu feeder got tripped at Gantu end (a 66kV Dhamdhun-Gantu fdr tripped at Dhamdhun end) causing black out at Ping. At 23:57hrs test charged from Gantu end but got tripped at our end operating distance relay. As per instruction from BPSO test charged from our end but again got tripped activating same relay. On dated 17.09.2022 at 11:04hrs as per instruction from BPSO against closing code 300 66kV Ping-Gantu fdr charged and stood normal.
**			16.09.2022	23:53		Idle charge	66kV Ping-Malbasse fdr	66kV Ping-Malbasse fdr				At 23:53hrs as per instruction from BPSO charged 66kV Ping-Malbasse feeder which was under idle charged condition, since 66kV Chukha-Ping fdr and 66kV Ping-Gantu fdr couldn't stand while test charging. On dated 17.09.2022 at 11:04hrs opened CB of 66kV Ping-Malbasse feeder with opening code 1019 as per instruction from BPSO and feeder was put back to idle charged condition.
**	20.09.2022	8:31	20.09.2022	8:37	0	-3.02	66kV Chukha-Ping feeder	66kV Chukha-Ping feeder	Tripped at chukha end		Tripped at chukha end	At 08:31hrs 66kV Chukha-Ping fdr tripped from chukha end (Ping black out) and at 08:37hrs normalised the supply from Chukha end with charging code 316.
**	20.09.2022	8:31	20.09.2022	8:41	0	-2.11	66kV Ping-Gantu fdr	66kV Ping-Gantu fdr	Tripped at our end	DSTN OPTD, 186A06	Tripped at our end	At 08:31hrs 66kV Ping-Gantu feeder got tripped at our end causing black out at Ping. At 08:41hrs as per instruction from BPSO charged Ping-Gantu fdr against closing code 318.
**	22.09.2022	5:49	22.09.2022	8:35	0	-4.86	66kV Chukha-Ping feeder	66kV Chukha-Ping feeder	Tripped at our end	DSTN OPTD, 186A06	Tripped at our end	Tripped on fault
**	22.09.2022	8:53	22.09.2022	9:53	0	-4.86	66kV Chukha-Ping feeder	66kV Chukha-Ping feeder	Tripped at both end	DSTN OPTD, 186A06	Tripped at both end	Tripped on fault
**			22.09.2022	4:55		Idle charge	66kV Ping-Malbasse fdr	66kV Ping-Malbasse fdr				At 04:55hrs as per instruction from BPSO charged 66kV Ping-Malbasse feeder which was under idle charged condition.
**	20.09.2022	12:31	20.09.2022	12:34	0	-2.23	66kV Ping-Gantu fdr	66kV Ping-Gantu fdr	Tripped at our end	DSTN OPTD, 186A06	Tripped at our end	The cause of tripping was due to transient fault. (Ping black out)
**	23.09.2022	1:57	23.09.2022	2:07	0	-3.01	66kV Ping-Gantu fdr	66kV Ping-Gantu fdr	Tripped at our end	DSTN OPTD, 186A06	Tripped at our end	The cause of tripping was due to transient fault. (Ping black out)
**	23.09.2022	1:57	23.09.2022	2:10	0	-7.43	66kV Chukha-Ping feeder	66kV Chukha-Ping feeder	Tripped at chukha end		Tripped at chukha end	The cause of tripping was due to transient fault. (Ping black out)
**	23.09.2022	1:57	23.09.2022	2:04	0	6.12	66kV Ping-Malbasse fdr	66kV Ping-Malbasse fdr	Tripped at Malbasse end		Tripped at Malbasse end	The cause of tripping was due to transient fault. (Ping black out)
**	23.09.2022	17:27	23.09.2022	17:35	0	-7.26	66kV Chukha-Ping feeder	66kV Chukha-Ping feeder	Tripped at chukha end		Tripped at chukha end	The cause of tripping was due to transient fault. (Ping black out)
**	23.09.2022	17:27	23.09.2022		0	7.20	66kV Ping-Malbasse fdr	66kV Ping-Malbasse fdr	Tripped at Malbasse end		Tripped at Malbasse end	The cause of tripping was due to transient fault. (Ping black out). As per instruction of BPSO 66kV Ping-Malbasse feeder kept open at our end with opening code 033.
**	23.09.2022	17:27	23.09.2022	17:43	0	-3.94	66kV Ping-Gantu fdr	66kV Ping-Gantu fdr	Tripped at our end	DSTN OPTD, 186A06	Tripped at our end	The cause of tripping was due to transient fault. (Ping black out). At 17:37hrs test charged as per instruction from BPSO but couldn't withstand. At 17:43hrs again test charged as per instruction from BPSO and stood normal.
**	27.09.2022	7:42	27.09.2022	7:50	0	-3.00	66kV Chukha-Ping feeder	66kV Chukha-Ping feeder	Tripped at both end		Tripped at both end	The cause of tripping was due to transient fault.
**	28.09.2022	18:42	28.09.2022	18:52	0	-2.53	66kV Chukha-Ping feeder	66kV Chukha-Ping feeder	Tripped at both end	Tripping relay 186A 06	Tripped at both end	The cause of tripping was due to transient fault. Test charged after getting clearance from BPSO with charging code 1442.
**	28.09.2022	19:12	28.09.2022	22:46	3	-0.84	66kV Chukha-Ping feeder	66kV Chukha-Ping feeder	Tripped at both end	Tripping relay 186A 06	Tripped at both end	As per instruction from BPSO CB kept open for 66kV Ping at our end.
**			28.09.2022	19:16		Idle charge	66kV Ping-Malbasse fdr	66kV Ping-Malbasse fdr				At 19:16hrs charged 66kV Ping-Malbasse with charging code 1444 since CB kept open for 66kV Ping-chukha feeder at our end as per instruction from BPSO. At 22:30hrs CB opened for said feeder with opening code 040 from BPSO and feeder kept under idle charged.
**			29.09.2022	10:23		Idle charge	66kV Ping-Malbasse fdr	66kV Ping-Malbasse fdr				At 10:23hrs charged 66kV Ping-Malbasse with charging code 1452 as per instruction from BPSO. At 22:30hrs CB opened for said feeder with opening code 040 from BPSO and feeder kept under idle charged.
**	29.09.2022	13:30	29.09.2022	13:37	0	-6.27	66kV Ping-Gantu fdr	66kV Ping-Gantu fdr	Tripped at both end	186A06	Tripped at both end	The cause of tripping was due to transient fault.
**	30.09.2022	12:52	30.09.2022	13:30	0	-9.19	66kV Chukha-Ping feeder	66kV Chukha-Ping feeder	Tripped at our end	DSTN OPTD, 186A06	Tripped at our end	Tripped on fault
**	30.09.2022	13:05	30.09.2022	13:18	0	-2.26	66kV Chukha-Ping feeder	66kV Chukha-Ping feeder	Tripped at our end	DSTN OPTD, 186A06	Tripped at our end	Tripped on fault
**			30.09.2022	13:19		-5.07	66kV Ping-Malbasse fdr	66kV Ping-Malbasse fdr				At 13:19hrs CB opened for 66kV Ping-Malbasse feeder with opening code 064 from BPSO and feeder kept under idle charged.



Transmission System Performance Report

Third Quarterly Report-2022

Transmission System Performance Report - Third Quarterly Report-2022													
(D) 66/33/11 kV Gedu Substation													
1	15.09.2022	22:15	15.09.2022	22:22	0	1.06	66KV Chukha-P/line	Balckout	Bad weather condition	Line segment	66KV supply charged from Chukha end.		
2	15.09.2022	22:39	15.09.2022	22:46	0	1.06	66KV Chukha-P/line	Balckout	Bad weather condition	Line segment	66KV supply charged from Chukha end.		
3	16.09.2022	19:34	16.09.2022	19:42	0	2.71	66KV Chukha-P/line	Balckout	Bad weather condition	Line segment	66KV supply charged from Chukha end.		
4	16.09.2022	23:29	16.09.2022	23:47	0	1.43	66KV Chukha-P/line	Balckout	Bad weather condition	Line segment	66KV supply charged from Chukha end.		
5	22.09.2022	1:49	22.09.2022	3:15	0	1.1	66KV Chukha-P/line	Balckout	Bad weather condition	Line segment	66KV supply charged from Chukha end.		
6	22.09.2022	8:53	22.09.2022	9:13	1	1.1	66KV Chukha-P/line	Balckout	Bad weather condition	Line segment	66KV supply charged from Chukha end.		
7	23.09.2022	1:08	23.09.2022	2:05	0	1.36	66KV Chukha-P/line	Balckout	Bad weather condition	Line segment	66KV supply charged from Chukha end.		
8	28.09.2022	7:43	28.09.2022	7:47	0	2.03	66KV Chukha-P/line	Balckout	Bad weather condition	Line segment	66KV supply charged from Chukha end.		
9	28.09.2022	18:42	28.09.2022	18:52	0	1.07	66KV Chukha-P/line	Balckout	Bad weather condition	Line segment	66KV supply charged from Chukha end.		
10	28.09.2022	19:11	28.09.2022	19:24	0	1.09	66KV Chukha-P/line	Balckout	Bad weather condition	Line segment	66KV supply charged from Chukha end.		
(E) 66/33/11 kV Guntia Substation													
1	07.09.2022	17:21	07.09.2022	17:28	0	2.23	66KV Phuentsholing feeder	Guntia substation	Tripped from Chukha	Line segment	grid fail	Tripped from chukha end and supply resumed at 17:28hrs	
2	07.09.2022	17:25	07.09.2022	17:32	0	-6.956	66KV Dhamdhum feeder	Guntia substation	B-phase & Y-Phase fault	Line segment	Transient fault	Charged as per the instruction from BPSO and charge withdrawn	
3	11.09.2022	20:35	11.09.2022	20:39	0	3.51	66KV Phuentsholing feeder	Guntia substation	Grid failed	Line segment	grid fail	Grid failed and supply resumed at 20:39hrs	
4	11.09.2022	20:35	11.09.2022	20:42	0	-9.924	66KV Dhamdhum feeder	Guntia substation	Three Phase fault	Line segment	Transient fault	Charged the line as per the instruction received from BPSO and charge withdrawn	
5	15.09.2022	22:39	15.09.2022	23:08	0	1.54	66KV Phuentsholing feeder	Nil	Over current	51 Cc and 51 Bc	Guntia substation	Transient fault	Charged the line as per the instruction received from BPSO and charge withdrawn charging code 290
6	15.09.2022	22:41	15.09.2022	23:48	0	-6.54	66KV Dhamdhum feeder	Guntia substation	Grid failed	Nil	Malhaase substation	grid fail	Grid failed and supply resumed at 22:48hrs
7	16.09.2022	23:28	16.09.2022	23:37	0	-0.22	66KV Phuentsholing feeder	Nil	Over current	51 Cc and 51 Bc	Line segment	Transient fault	Test charged the line as per the instruction of BPSO and kept breaker open at pling end at charged on 17.09.2022 at 11:04 hrs from pling end
8	16.09.2022				0								
9	20.09.2022	8:31	20.09.2022	8:41	0	2.11	66KV Phuentsholing feeder	Guntia substation	Grid failed	Nil	Line segment	Transient fault	Tripped from source
10	20.09.2022	8:31	20.09.2022	8:41	0	-6.725	66KV Dhamdhum feeder	Guntia substation	Grid failed	Nil	Line segment	Transient fault	Tripped from source
11	22.09.2022	4:05	22.09.2022	4:15	0	-7.44	66KV Dhamdhum feeder	Guntia substation	Grid failed	Nil	Malhaase substation	Transient fault	Tripped from Malhaase end and supply resumed at 04:15hrs
12	22.09.2022	15:30	22.09.2022	15:33	0	2.48	66KV Phuentsholing feeder	Guntia substation	Grid failed	Nil	Line segment	Transient fault	Tripped from pling end and supply resumed at 15:33hrs
13	22.09.2022	13:30	22.09.2022	13:38	0	-11.096	66KV Dhamdhum feeder	Guntia substation	Y phase fault	Distance relay operated, General trip, Zone 4 trip, Y phase fault.	Line segment	Transient fault	Charged the line as per the instruction of BPSO and charge withdrawn.
14	23.09.2022	3:27	23.09.2022	9:05	5	0.01	66/11KV SMVA Transformer	Nil	Over current	IDMTL 50B & 50B	Line segment	Feeder fault	Tripped along with 33KV Guntia feeder and charged the transformer after keeping 33KV feeder in trip position.
15	23.09.2022	17:27	23.09.2022	17:42	0	-10.977	66KV Dhamdhum feeder	Guntia substation	Grid failed	Nil	Line segment	Grid Failed	Grid failed from Malhaase substation.
16	23.09.2022	17:43	23.09.2022	17:45	0	4.98	66 KV Phuentsholing feeder	Guntia substation	Hand tripped as per BPSO	Nil	Guntia substation	Hand tripped	Breaker opened as per BPSO instruction, as P/Line 33 could not charge line.
17	23.09.2022	20:35	23.09.2022	20:45	0	3.25	66 KV Phuentsholing feeder	Guntia substation	Grid failed	Grid failed	Line segment	Grid Failed	Grid failed from Malhaase substation.
18	23.09.2022	20:35	23.09.2022	20:45	0	-8.049	66KV Dhamdhum feeder	Guntia substation	Grid failed	Grid failed	Line segment	Grid Failed	Grid failed from Malhaase substation.
19	26.09.2022	10:04	26.09.2022	11:20	1	1.55	66KV Phuentsholing feeder	Nil	Shutdown as per BPSO	Nil	Pling end	Shutdown	Availed shutdown for arresting sparking from Y phase CT terminal pad at Phuentsholing T/S Against opening code No 044 and shutdown withdrawn at 11:20 after charging code No 1423 given from BPSO
20	30.09.2022	12:52	30.09.2022	12:58	0	-16.056	66KV Dhamdhum feeder	Guntia substation	Grid failed	Nil	Malhaase substation	Transient fault	Tripped from Malhaase end and supply resumed at 12:58hrs
21	30.09.2022	13:05	30.09.2022	13:17	0	-10.354	66KV Dhamdhum feeder	Guntia substation	Grid failed	Nil	Malhaase substation	Transient fault	Tripped from Malhaase end and supply resumed at 13:17hrs
(F) 220/66/33 kV Dhamdhum Substation													
1	15.09.2022	22:41	15.09.2022	22:46	0	-8.0	Malhaase	Santse					Grid supply fail
2	16.09.2022	19:29	16.09.2022	19:50	0	-16.28	220KV Malhaase fir.	Santse	Lightning/thunder and heavy rainfall	REL 678	Dhamdhum Substation		General trip, Zone 1, V phase fault supply failed from Malhaase end.
3	16.09.2022	19:29	16.09.2022	20:03	0	-3.09	220KV Singye fir.	Santse	Lightning/thunder and heavy rainfall	REL 678	Dhamdhum Substation		General trip, Zone 1 trip, R phase fault, supply failed from Malhaase end.
4	16.09.2022	22:31	16.09.2022	22:35	0	-0.07	Singyequm	Santse	Lightning/thunder and heavy rainfall	REL 678	Dhamdhum Substation		General trip, Zone 1, Over current on BP
5	23.09.2022	17:25	23.09.2022	17:42	0	-11.23	malhaase	Santse			Dhamdhum Substation		line tripped from malhaase end. No equipment was operated from dhamdhum s/s.
6	23.09.2022	20:34	23.09.2022	20:44	0	-8.02	220KV Malhaase fir.	Santse	Cloudy		Dhamdhum Substation		line tripped from malhaase end. No equipment was operated from dhamdhum s/s.
7	23.09.2022	21:34	23.09.2022	21:44	0	-4.04	220KV Singye fir.	Santse	Cloudy		Dhamdhum Substation		line tripped from malhaase end. No equipment was operated from dhamdhum s/s.
8	30.09.2022	12:51	30.09.2022	12:57	0	-14.49	220KV malhaase feeder	Santse	sunny		Dhamdhum Substation		line tripped from malhaase end. No equipment was operated from dhamdhum s/s.
9	30.09.2022	13:05	30.09.2022	13:17	0	-10.06	220KV malhaase feeder	Santse	sunny		Dhamdhum Substation		line tripped from Malhaase end. No equipment was operated from dhamdhum s/s.
Sl. No.	Date of Tripping	Time of outages	Date of Normalisation	Time of fault was cleared	Duration of Outages (Hrs)	MW before outages (MW)	Feeder Name	Name of the Substation/Lines affected by the fault	Reason of fault	Relay operation as	Exact location of fault [Line segment / Substation]	Type of outages	Remarks
(A) 66KV Chukha switching station													
1	16.09.2022	22:38hrs	16.09.2022	22:47hrs	0.09	7.85MW	66KV Chukha Feeder	Para, Parghasa, Jemsa	Grid Fail	no operation at Chukha	General trip	Grid fail	Grid fail
2	22.09.2022	02:48hrs	22.09.2022	02:55hrs	0.07	7.85MW							
3	22.09.2022	03:55hrs	22.09.2022	04:07hrs	0.12	5.23MW							
4	24.09.2022	08:15hrs	24.09.2022	11:05hrs	2.9	4.40MW	66KV Para Feeder	Fed from Parghasa Substation	Failure	CB open Line 2 & Bus isolator open, E-switch closed.	For 220KV L.L.O rrroring	Failure	Failure by TPO Chukha as per the station approval no 226
5	24.09.2022	18:23hrs	24.09.2022	18:37hrs	0.14	10.815MW		Parghasa substation	Transient fault	CB open 1Ph	Change	Tripped	Tripped due to over
6	24.09.2022	19:49hrs	24.09.2022	19:57hrs	0.08	10.815MW							
7	28.09.2022	07:23hrs	29.09.2022	17:48hrs	10.25	8.75MW	66KV Parghasa Feeder	Fed from Para Substation	Failure	CB open Line 2 & Bus isolator open, E-switch closed.	For 220KV L.L.O rrroring	Failure	Failure by TPO Chukha as per the station approval no 226
(B) 66/33kV Waza Substation													
1	16/9/2022	23:28hrs	16/9/2022	23:47hrs	0.19	320MW	66KV IC	F & I and II	66KV IC failed from chukha end	66KV IC failed from chukha end	66KV IC failed from chukha end	Tripped	
2	22/9/2022	2:40hrs	22/9/2022	2:55hrs	0.15	250MW	66KV IC	F & I and II	66KV IC failed from chukha end	66KV IC failed from chukha end	66KV IC failed from chukha end	Tripped	
3	22/9/2022	1:55hrs	22/9/2022	4:53hrs	2.98	250MW	66KV IC	F & I and II	66KV IC failed from chukha end	66KV IC failed from chukha end	66KV IC failed from chukha end	Tripped	
4	26/9/2022	15:03hrs	28/9/2022	15:10hrs	0.07	1.57	66KV SF 8 Breaker	F & I and II	Over current on ABC phase	Over current relay operated	F & I Chajcha Shemaga ngika	Tripped	Line tripped due to free fall on 33KV circuit breaker at waza while TMD Tamabik is charging 66KV 300W



Transmission System Performance Report

Third Quarterly Report-2022

IC 66.25kV Olakha Substation											
Sr	Date	Time	Start Date	End Date	Duration	Remarks	Substation	Reason	Category	Remarks	
1	16-09-22	23:28	16-09-22	23:47	0	-7.92	66kV Olakha-Sensokha	All 66kV Olakha-Sensokha and 66kV Olakha-Changdaphu was effected	Grid fail	Under Voltage operated Transmission line Grid fail	Grid fail from Chokha and Branch Charged from Chokha and Branch and stand normal
2	16-09-22	23:28	16-09-22	23:47	0	2.41	66kV Olakha-Changdaphu	All 66kV Olakha-Sensokha and 66kV Olakha-Changdaphu was effected	Grid fail	Under Voltage operated Transmission line Grid fail	Grid fail from Chokha and Branch Charged from Chokha and Branch and stand normal at Olakha and
3	21-09-22	6:29	21-09-22	6:57	0	4.29	66kV Olakha-Changdaphu	All 66kV Olakha-Sensokha and 66kV Olakha-Changdaphu was effected	Fault	NA Transmission line Transmission fault	The supply was supplied from Changdaphu and there was no other operation and only under voltage indication was operated at Olakha Substation
4	22-09-22	2:28	22-09-22	2:56	0	-1.1	66kV Olakha-Sensokha	All 66kV Olakha-Sensokha and 66kV Olakha-Changdaphu was effected	Grid fail	Under Voltage operated Transmission line Grid fail	Grid fail from Chokha and Branch Charged from Chokha and Branch and stand normal
5	22-09-22	3:55	22-09-22	4:13	0	-4.34	66kV Olakha-Sensokha	All 66kV Olakha-Sensokha and 66kV Olakha-Changdaphu was effected	Grid fail	Under Voltage operated Transmission line Grid fail	Grid fail from Chokha and Branch Charged from Chokha and Branch and stand normal
6	22-09-22	4:27	22-09-22	4:51	0	-4.34	66kV Olakha-Sensokha	All 66kV Olakha-Sensokha and 66kV Olakha-Changdaphu was effected	Grid fail	Under Voltage operated Transmission line Grid fail	Grid fail from Chokha and Branch Charged from Chokha and Branch and stand normal
7	22-09-22	2:29	22-09-22	2:56	0	2.41	66kV Olakha-Changdaphu	All 66kV Olakha-Sensokha and 66kV Olakha-Changdaphu was effected	Grid fail	Under Voltage operated Transmission line Grid fail	Grid fail from Chokha and Branch Charged from Chokha and Branch and stand normal
8	22-09-22	3:57	22-09-22	4:13	0	2.55	66kV Olakha-Changdaphu	All 66kV Olakha-Sensokha and 66kV Olakha-Changdaphu was effected	Grid fail	Under Voltage operated Transmission line Grid fail	Grid fail from Chokha and Branch Charged from Chokha and Branch and stand normal
9	22-09-22	4:27	22-09-22	4:51	0	3.09	66kV Olakha-Changdaphu	All 66kV Olakha-Sensokha and 66kV Olakha-Changdaphu was effected	Grid fail	Under Voltage operated Transmission line Grid fail	Grid fail from Chokha and Branch Charged from Chokha and Branch and stand normal
10	23-09-22	3:40	23-09-22	3:51	0	2.02	66kV Olakha-Changdaphu	Only 66kV Olakha-Changdaphu was effected	Fault	Under Voltage operated Transmission line Transmission fault	No relay was operated at Olakha Substation and charged from Changdaphu and stand normal
11	23-09-22	4:56	23-09-22	5:02	0	5.67	66kV Olakha-Changdaphu	Only 66kV Olakha-Changdaphu was effected	Fault	Under Voltage operated Transmission line Transmission fault	No relay was operated at Olakha Substation and charged from Changdaphu and stand normal



(F) 66/33/11kV Jamina Substation												
Sr	Date	Time	Start	End	Duration	Remarks	Equipment	Impact	Supply	Source	Generator	Notes
1	16.09.2022	23:28	16.09.2022	23:47	0	2.76 & 1.06 (book import), Chaugadaha & Chanda respectively	66kV Line Chaugadaha & Chanda	Black out	Supply failed from source, no operation at the Substation end	N/A	Generator source	Supply failed from generation source & no operation at the Substation end
2	22.09.2022	2:50	22.09.2022	2:57	0	1.29 & 1.06, Chaugadaha & Chanda respectively	66kV Line Chaugadaha & Chanda	Black out	Supply failed from source, no operation at the Substation end	N/A	Generator source	Supply failed from generation source & no operation at the Substation end
3	22.09.2022	3:56	22.09.2022	4:54	0	1.20	66kV Line Chanda	Black out	Grid fail also tripped the breaker at the Substation end	SOTF	Grid fail	Supply failed from generation & also tripped the breaker at the Substation end
4	22.09.2022	3:56	22.09.2022	6:30	2	-1.08	66kV Line Chaugadaha	Black out till 04:54 hrs	Grid fail also tripped the breaker at the Substation end	SOTF	Grid fail	Supply failed from generation & also tripped the breaker at the Substation end. As per the recovery action of BPSO, the line charged only at 06:30 hrs.
(G) 66/33/11kV Dochancholing substation												
1	16.09.2022	23:46hrs	16.09.2022	23:46hrs	0	-21.36	66kV Sontakha Incomer	Whole system blackout	Supply failed from source.			
2	22.09.2022	02:49hrs	22.09.2022	02:54hrs	0	-20.80	66kV Sontakha Incomer	Whole system blackout	Supply failed from source.			
3	22.09.2022	03:55hrs	22.09.2022	04:18hrs	0	-21.61	66kV Sontakha Incomer	Whole system blackout	Supply failed from source.			
4	22.09.2022	04:25hrs	22.09.2022	04:52hrs	0	-21.61	66kV Sontakha Incomer	Whole system blackout	Supply failed from source.			
(H) 66/11kV Raa Substation												
1	16.09.2022	23:28	16.09.2022	23:47	0	-0.97	66kV incomer	All	grid fail	O/C	Chanda power house	Supply tripped from the source
2	18.09.2022	11:42	18.09.2022	11:56	0	-1.63	66kV incomer	All	grid fail	O/C & EF	Chanda power house	Supply tripped from the source
3	22.09.2022	2:49	22.09.2022	2:57	0	-0.88	66kV incomer	All	grid fail	O/C & EF	Chanda power house	Supply tripped from the source
4	22.09.2022	3:55	22.09.2022	4:42	0	-0.66	66kV incomer	All	grid fail	O/C & EF	Chanda power house	Supply tripped from the source
5	24.09.2022	10:10	24.09.2022	10:24	0	-1.64	66kV incomer	All	grid fail	O/C & EF	Chanda power house	Supply tripped from the source
6	24.09.2022	14:22	24.09.2022	14:46	0	-2.14	66kV incomer	All	grid fail	O/C	Chanda power house	Supply tripped from the source
7	28.09.2022	7:52	28.09.2022	11:26	33	-2.23	66kV incomer	All	220 L.L.O crossing for Janjer substation	N/A	Chanda overloading station	Supply tripped by TUP Chanda, Triped for 220V L.L.O crossing for Janjer substation with the opening code No 754 by BPSO. The same was normalised after getting the clear information with a clearing code No 14514hs.





3) 220kV Substation Samskha												
No.	Date	Time	Date	Time	Location	Equipment	Event	Duration	Impact	Category	Remarks	Remarks
1	15.09.2022	18:10hrs	15.09.2022	18:20hrs	60kV Samskha-Dochula	Dochula v/s	Y & Bph OC Trip	Backup OC/EF v/s opsl, Y&Bph I> Trip IA=263.2AJ II=5.799 KA,IC=5.605EA DN=17.26A	Transient			
2	16.09.2022	24:20hrs	16.09.2022	24:47hrs	220kV Samskha-Chukha	Samskha v/s	Out Fault	Chukha Back-out E-PH-A 280.6A Y-PHA 70.35A B-PH-670.7A	Transient			
3	21.09.2022	06:20hrs	21.09.2022	06:40hrs	60kV Samskha-Dochula	Dochula v/s	Y & Bph OC Trip	Backup OC/EF v/s opsl, Y&Bph I> Trip IA=263.2AJ II=5.799 KA,IC=5.605EA DN=17.26A	Transient			
4	22.09.2022	02:40hrs	22.09.2022	02:50hrs	220kV Samskha-Bumthang	Samskha v/s	Out Fault	Man-2 Opst, EYBph sp	Transient			
5	22.09.2022	02:40hrs	22.09.2022	03:00hrs	60kV Samskha-Dochula	Dochula v/s	Y & Bph OC Trip	Backup OC/EF v/s opsl, Y&Bph I> Trip IA=263.2AJ II=5.799 KA,IC=5.605EA DN=17.26A	Transient			
6	22.09.2022	03:55hrs	22.09.2022	04:10hrs	220kV Samskha-Chukha	Samskha v/s	Out Fault	Man-2, F TB report	Transient			
7	23.09.2022	03:40hrs	23.09.2022	03:52hrs	60kV Samskha-Dochula	Dochula v/s	Y & Bph OC Trip	Backup OC/EF v/s opsl, Y&Bph I> Trip IA=174.1A II=5.748EA IC=5.623EA DN=17.05A	Transient			
8	23.09.2022	04:50hrs	23.09.2022	05:00hrs	60kV Samskha-Dochula	Dochula v/s	Y & Bph OC Trip	Backup OC/EF v/s opsl, Y&Bph I> Trip IA=172.1A II=5.212EA IC=5.026EA DN=17.01A	Transient			
9	23.09.2022	21:42hrs	23.09.2022	22:00hrs	220kV Samskha-Bumthang	Samskha v/s	Man-2 protection Opst, EYBph sp		Transient			
10	23.09.2022	21:42hrs	23.09.2022	22:00hrs	60kV Samskha-Dochula	Dochula v/s	Y & Bph OC Trip	Backup OC/EF v/s opsl, Y&Bph I> Trip I	Transient			
11	24.09.2022	02:47hrs	24.09.2022	02:50hrs	60kV Samskha-Dochula	Dochula v/s	Y & Bph OC Trip	Backup OC/EF v/s opsl, Y&Bph I> Trip I	Transient			
12	27.09.2022	10:04hrs	27.09.2022	11:10hrs	60kV Samskha-Dochula	Dochula v/s	Y & Bph OC Trip	Backup OC/EF v/s opsl, Y&Bph I> Trip I	Transient			
13	28.09.2022	18:17hrs	28.09.2022	18:40hrs	60kV Samskha-Dochula	Dochula v/s	Y & Bph OC Trip	Backup OC/EF v/s opsl, Y&Bph I> Trip I	Transient			



Transmission System Performance Report

Third Quarterly Report-2022

(K) 66/33kV Changdaphu Substation													
Sr	Date	Start Time	End Date	End Time	Duration	Severity	Equipment	Location	Reason	Impact	Resolution	Remarks	Category
1	15.09.2022	18:18hrs	15.09.2022	18:32hrs			66kV Changdaphu-Obakha Line	66kV Changdaphu-Obakha Line	Distance Protection, Zone 2 RVDph Trip				Transient
2	16.09.2022	23:28hrs	16.09.2022	00:18hrs			66kV Changdaphu-Obakha Line	66kV Changdaphu-Obakha Line	Distance Protection, Zone 2 RVDph Trip				Transient
3	21.09.2022	06:29hrs	21.09.2022	06:51hrs			66kV Changdaphu-Obakha Line	66kV Changdaphu-Obakha Line	Distance Protection, Zone 2 RVDph Trip				Transient
4	22.09.2022	03:59hrs	22.09.2022	04:23hrs			66kV Changdaphu-Obakha Line	66kV Changdaphu-Obakha Line	Distance Protection, Zone 2 RVDph Trip				Transient
5	23.09.2022	03:48hrs	23.09.2022	03:51hrs			66kV Changdaphu-Obakha Line	66kV Changdaphu-Obakha Line	Distance Protection, Zone 2 RVDph Trip				Transient
6	23.09.2022	04:56hrs	23.09.2022	05:02hrs			66kV Changdaphu-Obakha Line	66kV Changdaphu-Obakha Line	Distance Protection, Zone 2 RVDph Trip				Transient
7	23.09.2022	21:42hrs	23.09.2022	22:09hrs			66kV Changdaphu-Obakha Line	66kV Changdaphu-Obakha Line	Distance Protection, Zone 2 RVDph Trip				Transient
8	24.09.2022	02:47hrs	24.09.2022	02:59hrs			66kV Changdaphu-Obakha Line	66kV Changdaphu-Obakha Line	Distance Protection, Zone 2 RVDph Trip				Transient
9	28.09.2022	18:37hrs	28.09.2022	18:48hrs			66kV Changdaphu-Obakha Line	66kV Changdaphu-Obakha Line	Distance Protection, Zone 2 RVDph Trip				Transient
(L) 66/33kV Dangi Substation													
1	16.09.2022	2328 hrs	16.09.2022	2348 hrs	0	-3.91	66 kV De-energizing Dangi Line	Whole Substation		Tripping	NA	NA	Tripped from Dangi Substation
2	19.09.2022	1008 hrs	19.09.2022	1513 hrs	5	0.01	Power Transformer I	NA		Shutdown	NA	NA	Aval shutdown by Check Bucher for annual maintenance of Transformer
3	21.09.2022	0945 hrs	21.09.2022	1035 hrs	8	3.84	Power Transformer II	NA		Shutdown	NA	NA	Aval shutdown by Check Bucher for annual maintenance of Transformer
4	22.09.2022	0249 hrs	22.09.2022	0254 hrs	0	-4.13	66 kV De-energizing Dangi Line	Whole Substation		Tripping	NA	NA	Went on Grid Failure
5	22.09.2022	0356 hrs	22.09.2022	0418 hrs	0	-4.32	66 kV De-energizing Dangi Line	Whole Substation		Tripping	NA	NA	Went on Grid Failure
6	22.09.2022	0836 hrs	22.09.2022	1159 hrs	2	2.19	Power Transformer I	NA		Shutdown	NA	NA	Aval shutdown by Check Bucher for annual maintenance of Transformer i.e. testing of transformer
7	22.09.2022	1214 hrs	22.09.2022	1720 hrs	5	2.02	Power Transformer II	NA		Shutdown	NA	NA	Aval shutdown by Check Bucher for annual maintenance of Transformer i.e. testing of transformer



(M) 66/11kV Dochula Substation												
1	02-09-22	11:35	02-09-22	12:46	1	-12.31	Dochula		Shut down taken by GE with work permit no.2321 to replace the electronic energy meter. Operating mode no.1005 issued by BPSO. Fender charged at 12:46hrs with closing code no.236 given by	Temporary		
2	02-09-22	12:50	02-09-22	13:40		-18.54	Dochula		Shut down taken by GE with work permit no.2322 to replace the electronic energy meter. Operating mode no.1006 issued by BPSO. Fender charged at 13:40hrs with closing code no.237 given by	Temporary		
3	15-09-22	18:10	15-09-22	18:20		-12.25	66kV Sentsikha	Sentsikha - Dochula	Front end Under voltage and 56 relay	Sentsikha	Temporary	DRI
4	15-09-22	18:19	15-09-22	18:27		-10.75	66kV Lobeysa	Lobeysa - Dochula	Front end Under voltage and 56 relay	Lobeysa	Temporary	DRI
5	16-09-22	23:28	17-09-22	0:12		-31.82	66kV Sentsikha	Sentsikha - Dochula	Front end Under voltage and 56 relay	Shut down	Temporary	DRI
6	16-09-22	23:28	17-09-22	0:12		-30.28	66kV Lobeysa	Lobeysa - Dochula	Front end Under voltage and 56 relay	Shut down	Temporary	DRI
7	21-09-22	6:29	21-09-22	6:46		-31.39	66kV Sentsikha	Sentsikha - Dochula	Front end Under voltage and 56 relay	Sentsikha	Temporary	DRI
8	21-09-22	6:29	21-09-22	6:44		-30.34	66kV Lobeysa	Lobeysa - Dochula	Front end Under voltage and 56 relay	Lobeysa	Temporary	DRI
9	22-09-22	2:09	22-09-22	2:10		-31.19	66kV Sentsikha	Sentsikha - Dochula	Grid Fed from Chakha Under voltage and 56 relay	Shut down	Temporary	DRI
10	22-09-22	2:09	22-09-22	2:09		-29.64	66kV Lobeysa	Lobeysa - Dochula	Grid Fed from Chakha Under voltage and 56 relay	Shut down	Temporary	DRI
11	22-09-22	3:56	22-09-22	5:50	1	-29.02	66kV Sentsikha	Sentsikha - Dochula	Grid Fed from Chakha Under voltage and 56 relay	Shut down	Temporary	DRI
12	22-09-22	3:56	22-09-22	6:23		-28.32	66kV Lobeysa	Lobeysa - Dochula	Grid Fed from Chakha Under voltage and 56 relay	Shut down	Temporary	DRI
13	22-09-22	4:29	22-09-22	4:57		-2.17	66kV Lobeysa	Lobeysa - Dochula	Lobeysa Substation is hand tripped. Dochula Fender due to overloading at Basochu. Under voltage and 56 relay	Shut down	Temporary	DRI
14	23-09-22	3:48	23-09-22	3:57		-30.09	66kV Lobeysa	Lobeysa - Dochula	Front end Under voltage and 56 relay	Lobeysa	Temporary	DRI
15	23-09-22	3:48	23-09-22	3:54		-31.25	66kV Sentsikha	Sentsikha - Dochula	Front end Under voltage and 56 relay	Lobeysa	Temporary	DRI
16	23-09-22	4:56	23-09-22	5:05		-19.05	66kV Lobeysa	Lobeysa - Dochula	Front end Under voltage and 56 relay	Lobeysa	Temporary	DRI
17	23-09-22	4:56	23-09-22	5:05		-21.11	66kV Sentsikha	Sentsikha - Dochula	Front end Under voltage and 56 relay	Lobeysa	Temporary	DRI
18	23-09-22	21:07	23-09-22	22:04		-26.2	66kV Lobeysa	Lobeysa - Dochula	Front end Under voltage and 56 relay	Sentsikha	Temporary	DRI
19	23-09-22	21:03	23-09-22	22:04		-28.25	66kV Sentsikha	Sentsikha - Dochula	Front end Under voltage and 56 relay	Sentsikha	Temporary	DRI
20	24-09-22	2:47	23-09-22	2:55		-26.31	66kV Lobeysa	Lobeysa - Dochula	Front end Under voltage and 56 relay	Sentsikha	Temporary	DRI
21	24-09-22	2:47	23-09-22	2:55		-28.68	66kV Sentsikha	Sentsikha - Dochula	Front end Under voltage and 56 relay	Sentsikha	Temporary	DRI
22	25-09-22	18:36	25-09-22	18:49		-26.78	66kV Lobeysa	Lobeysa - Dochula	Front end Under voltage and 56 relay	Sentsikha	Temporary	DRI
23	25-09-22	18:36	23-09-22	18:48		-30.29	66kV Sentsikha	Sentsikha - Dochula	Front end Under voltage and 56 relay	Sentsikha	Temporary	DRI