



ལྷན་ཁྲིམས་དང་འཕེལ་རྒྱུ་ལྷན་ཁྲིམས་ རྒྱལ་ཁབ་རྒྱུ་ལུགས་ཁྲིམས་།  
Ministry of Energy and Natural Resources  
Royal Government of Bhutan  
Bhutan Power System Operator  
Thimphu: Bhutan



THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 28-Dec-2025(+ve:import, +ve:export)							
Report Details	Date	Time	National Coincidental Peak Load (MW)		Date	Time	Load
	December 27, 2025	9:00 AM			08-Nov-25	19:03:00	1,477.00
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks	
1	6 x 170MW THP	Unit-I	186.26	400kV THP - Siliguri Line - I	277.94	Unit-IV,V,VI under Shutdown (Annual Maintenance). 400kV THP_SIL Line-IV on Standby. 400kV THP-Malbase Line under shutdown.	
		Unit-II	186.73	400kV THP - Siliguri Line - II	277.72		
		Unit-III	182.11	400kV THP - Siliguri Line - IV	0.00		
		Unit-IV	0.00	400kV THP - Malbase Line - III	0.00		
		Unit-V	0.00	400kV Malbase - Siliguri Line	-280.64		
		Unit-VI	0.00	-	-		
		<b>Total</b>	<b>555.10</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>-0.10%</b>		
2	4 x 180MW MHP	Unit-I	0.00	400kV MHP - Jigmeling Line - I	98.55	Unit-IV on Standby. Unit-I under Shutdown (AMP). 400kV MHP-JIG Line - II and IV kept on Standby as other two lines can cater the load.	
		Unit-II	146.13	400kV MHP - Jigmeling Line - II	0.00		
		Unit-III	155.48	400kV MHP - Jigmeling Line - III	99.12		
		Unit-IV	0.00	400kV MHP - Jigmeling Line - IV	0.00		
		-	-	220kV Jigmeling - BitDeer Line - I	197.69		
		-	-	220kV Jigmeling - BitDeer Line - II	195.25		
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	433.82		
		-	-	400kV Jigmeling - Alipurduar Line - I	-11.64		
		-	-	400kV Jigmeling - Alipurduar Line - II	-12.36		
		-	-	80MVA, 220/132kV ICT - I (HV)	-20.21		
		-	-	80MVA, 220/132kV ICT - II (HV)	-19.88		
		-	-	132kV MHP - Yurno Line - II	67.35		
		-	-	132kV MHP - Tintibi Line	63.19		
		-	-	132kV Gelephu - Salakati Line	-40.68		
<b>Total</b>	<b>301.61</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.39%</b>				
3	6 x 170MW PHP-II	Unit-I	0.00	400kV PHP II - Jigmeling - I	107.64	Unit-I, Unit-II & Unit-III under Shutdown (Annual Maintenance). Unit-V on Standby.	
		Unit-II	0.00	400kV PHP II - Jigmeling - II	106.91		
		Unit-III	0.00	400kV PHP II - Alipurduar - I	43.41		
		Unit-IV	149.52	400kV PHP II - Alipurduar - II	43.71		
		Unit-V	0.00	-	-		
		Unit-VI	150.33	-	-		
		<b>Total</b>	<b>299.85</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>-0.61%</b>		
4	4 x 84MW CHP	Unit-I	0.00	220kV CHP - Birpara Line - I	-75.61	Unit-I under Shutdown (Upgradation works on common Emergency Cooling Water pipelines). Unit-II under Shutdown(Annual Maintenance).	
		Unit-II	0.00	220kV CHP - Birpara Line - II	-75.15		
		Unit-III	84.25	220kV CHP - Gedu	34.46		
		Unit-IV	85.31	220kV CHP - Jamjee - I	94.61		
		-	-	220kV CHP - Jamjee - II	92.93		
		-	-	220kV CHP - Jamjee - III	90.48		
		-	-	220kV Malbase - Birpara Line	-107.60		
		-	-	66kV CHP - Gedu Line	7.21		
<b>Total</b>	<b>169.56</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.37%</b>				
5	2 x 12MW BHP (U/S)	Unit-I	4.00	220kV BHP - Semtokha Line	50.04	BHP L/S Unit-II on Standby.	
		Unit-II	4.26	66kV BHP - Lobeysa Line	17.97		
		<b>Total</b>	<b>8.26</b>	220kV BHP - Tsirang Line	-43.40		
6	2 x 20MW BHP (L/S)	Unit-I	16.41	5MVA, 66/11kV TFR	0.30		
		Unit-II	0.00	30MVA ICT, 220/66kV (HV)	10.15		
		<b>Total</b>	<b>16.41</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>-0.97%</b>		
7	2 x 63MW DHP	Unit-I	0.00	220kV DHP - Tsirang Line	0.00	Total Plant Shutdown from 10:27 hrs (09.10.2025) due to Seepage in HRC .	
		Unit-II	0.00	220kV DHP - Dagapela Line	0.00		
		-	-	220kV BitDeer - Dagapela Line	21.63		
		-	-	5MVA, 220/33kV TFR	0.27		
<b>Total</b>	<b>0.00</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.00%</b>				
8	4 x 15MW KHP	Unit-I	11.66	132kV KHP - Nangkor Line	8.53	Unit-IV on Standby. Unit-III under Shutdown.	
		Unit-II	11.66	132kV KHP - Kilikhar Line	14.18		
		Unit-III	0.00	5MVA, 132/11kV TFR	0.39		
		Unit-IV	0.00	132kV Motanga - Rangia Line	-17.65		
		<b>Total</b>	<b>23.32</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.94%</b>		
9	2 x 59MW NHP	Unit-I	0.00	132kV NHP-MHP-I	0.00	Unit-I under Shutdown (Annual Maintenance) 132kV NHP-MHP line I under ideal charge at NHP end.	
		Unit-II	27.79	132kV NHP-MHP-II	27.78		
		<b>Total</b>	<b>27.79</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.04%</b>		
10	2 x 9MW SHP	Unit-I	0.00	66kV SHP-Damdhum (Samtse)	0.00	Unit-I on Standby Interim measure: Evacuation is through 33kV System.	
		Unit-II	6.10	-	-		
		<b>Total</b>	<b>6.10</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>100.00%</b>		
11	17.38 MWp Sephu (Solar)	Inverter-1	1.40	33kV SSP-Wangdue	6.28	All Inverters and Feeders in Service.	
		Inverter-2	2.49	33kV SSP-Trongsa	0.00		
		Inverter-3	2.39	-	-		
		Inverter-4	0.00	-	-		
		Inverter-5	0.00	-	-		
		<b>Total</b>	<b>6.28</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.00%</b>		


Note: Generation-Load Summary (MW) for 27-Dec-25 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	1,414.28	1,392.83	21.45

Note: Generation-Load Summary (MW) for 27-Dec-24 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	1,002.23	965.17	37.06

09:00 hrs Statistical Comparison (MW) for this and last year




THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 28-Dec-2025(-ve:import, +ve:export)							
Report	Date	Time	National Coincidental Peak Load (MW)		Date	Time	Load
Details	December 27, 2025	18:00:00			08-Nov-25	19:03:00	1,477.00
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks	
1	6 x 170MW THP	Unit-I	183.50	400kV THP - Siliguri Line - I	275.15	Unit- IV,V,VI under Shutdown (Annual Maintenance). 400kV THP, SIL Line -IV on Standby. 400kV THP-Malbase Line under Shutdown.	
		Unit-II	183.74	400kV THP - Siliguri Line - II	275.19		
		Unit-III	186.77	400kV THP - Siliguri Line - IV	0.00		
		Unit-IV	0.00	400kV THP - Malbase Line - III	0.00		
		Unit-V	0.00	400kV Malbase - Siliguri Line	-284.36		
		Unit-VI	0.00	-	-		
		<b>Total</b>	<b>554.01</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.66%</b>		
2	4 x 180MW MHP	Unit-I	0.00	400kV MHP - Jigmeling Line - I	119.50	Unit-I under Shutdown (Annual Maintenance). Unit-IV on Standby. 400kV MHP-JIG Line - II and IV kept on Standby as other two Lines can cater the load.	
		Unit-II	175.43	400kV MHP - Jigmeling Line - II	0.00		
		Unit-III	175.93	400kV MHP - Jigmeling Line - III	120.67		
		Unit-IV	0.00	400kV MHP - Jigmeling Line - IV	0.00		
		-	-	220kV Jigmeling - BitDeer Line - I	199.82		
		-	-	220kV Jigmeling - BitDeer Line - II	202.34		
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	439.64		
		-	-	400kV Jigmeling - Alipurduar Line - I	5.10		
		-	-	400kV Jigmeling - Alipurduar Line - II	4.25		
		-	-	80MVA, 220/132kV ICT - I (HV)	-19.95		
		-	-	80MVA, 220/132kV ICT - II (HV)	-19.69		
		-	-	132kV MHP - Yurmo Line - II	70.38		
		-	-	132kV MHP - Tintibi Line	66.99		
		-	-	132kV Gelephu - Salakati Line	-46.66		
		<b>Total</b>	<b>351.36</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.44%</b>		
3	6 x 170MW PHP-II	Unit-I	0.00	400kV PHP II - Jigmeling -I	109.46	Unit-I & II under Shutdown (Annual Maintenance). Unit III under shutdown for runner inspection. Unit-V on Standby.	
		Unit-II	0.00	400kV PHP II - Jigmeling -II	109.18		
		Unit-III	0.00	400kV PHP II - Alipurduar -I	67.50		
		Unit-IV	180.00	400kV PHP II - Alipurduar -II	67.67		
		Unit-V	0.00	-	-		
		Unit-VI	179.80	-	-		
		<b>Total</b>	<b>359.80</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>1.66%</b>		
4	4 x 84MW CHP	Unit-I	90.08	220kV CHP - Birpara Line - I	-77.24	Unit- III on standby. Unit-II under Shutdown(Annual Maintenance).	
		Unit-II	0.00	220kV CHP - Birpara Line - II	-76.69		
		Unit-III	0.00	220kV CHP - Gedu	36.40		
		Unit-IV	89.78	220kV CHP - Jamjee - I	97.87		
		-	-	220kV CHP - Jamjee - II	96.66		
		-	-	220kV CHP - Jamjee - III	93.62		
		-	-	220kV Malbase - Birpara Line	-110.24		
-	-	66kV CHP - Gedu Line	8.04				
<b>Total</b>	<b>179.86</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.67%</b>				
5	2 x 12MW BHP (U/S)	Unit-I	0.00	220kV BHP - Sertokha Line	68.40	L/S Unit-II & U/S unit-I on Standby.	
		Unit-II	8.20	66kV BHP - Lobessa Line	23.83		
		<b>Total</b>	<b>8.20</b>	220kV BHP - Tsirang Line	-67.84		
6	2 x 20MW BHP (L/S)	Unit-I	16.50	5MVA, 66/11kV TFR	0.62		
		Unit-II	0.00	30MVA ICT, 220/66kV (HV)	16.31		
		<b>Total</b>	<b>16.50</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>-1.26%</b>		
7	2 x 63MW DHP	Unit-I	0.00	220kV DHP - Tsirang Line	0.00	Total Plant Shutdown from 10:27 hrs (09.10.2025) due to Seepage in HRC .	
		Unit-II	0.00	220kV DHP - Dagapela Line	0.00		
		-	-	220kV BitDeer - Dagapela Line	22.64		
		-	-	5MVA, 220/33kV TFR	0.27		
<b>Total</b>	<b>0.00</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.00%</b>				
8	4 x 15MW KHP	Unit-I	11.16	132kV KHP - Nangkor Line	6.72	Unit-IV on Standby. Unit-III under Shutdown(AMP).	
		Unit-II	11.20	132kV KHP - Kilikhar Line	14.98		
		Unit-III	0.00	5MVA, 132/11kV TFR	0.46		
		Unit-IV	0.00	132kV Motanga - Rangia Line	-17.02		
		<b>Total</b>	<b>22.36</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.89%</b>		
9	2 x 59MW NHP	Unit-I	0.00	132kV NHP-MHP-I	0.00	Unit-I under Shutdown. 132kV NHP-MHP line I under ideal charge at NHP end.	
		Unit-II	28.03	132kV NHP-MHP-II	27.74		
		<b>Total</b>	<b>28.03</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>1.03%</b>		
10	2 x 9MW SHP	Unit-I	6.08	66kV SHP-Damdhum (Samtse)	0.00	Unit-II under shutdown. Interim measure: Evacuation is through 33kV System.	
		Unit-II	0.00	-	-		
		<b>Total</b>	<b>6.08</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>100.00%</b>		

Note: Generation-Load Summary (MW) for 27-Dec-2025 at 18:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	1,526.20	1,443.55	82.65

19:00 hrs Statistical Comparison (MW) for this and last year



Note: Generation-Load Summary (MW) for 27-Dec-2024, at 18:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	1,038.13	1,008.25	29.88

Note: Daily Energy (MUs) and Power(MW) Statistics for 27-Dec-2025

Sl. No.	Total Energy Generation	Daily Energy Met	Net Energy Import (IEX and Solar)	Net Energy Export	Peak Cross-border (MW)
1	20.10	32.75	12.67	0.00	-943.08

- The Instantaneous load balance does not tend towards zero. This could be due to the following reasons:
  - Not all the meters are digital and nor are all the meter at all locations can be read at same time (say 9:00hrs) due to many meter to be read manually. ii) The clocks of all the locations are not synchronized.
- This report, compiled using the SCADA data, is prepared to give an overall idea of the generation & load flow for the system at a particular instant. This report also gives energy and import/export figures.
- When SCADA data are unavailable for certain stations due to technical issues, required data are collected from the site.