



འབྲུག་རྒྱལ་ཁབ་ལོ་ནུབ་ལྷན་ཁག་གི་རྒྱུ་རྩུ་གཞི་སྒྲིག་ཁང་།
Ministry of Energy and Natural Resources
Royal Government of Bhutan
Bhutan Power System Operator
Thimphu: Bhutan



THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 04-Jan-2026(+ve:import, -ve:export)							
Report Details	Date	Time	National Coincidental Peak Load (MW)		Date	Time	Load
	January 3, 2026	9:00 AM			08-Nov-25	19:03:00	1,477.00
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks	
1	6 x 170MW THP	Unit-I	174.30	400kV THP - Siliguri Line - I	82.19	Unit- IV,V,VI under Shutdown (Annual Maintenance). 400kV THP_SIL Line -IV under Shutdown.	
		Unit- II	170.70	400kV THP - Siliguri Line - II	80.92		
		Unit- III	169.34	400kV THP - Siliguri Line- IV	0.00		
		Unit- IV	0.00	400kV THP - Malbase Line - III	346.98		
		Unit- V	0.00	400kV Malbase - Siliguri Line	19.63		
		Unit- VI	0.00	-	-		
		Total	514.34	Auxiliary Consumption & Transformation Losses at Generator end	0.83%		
2	4 x 180MW MHP	Unit-I	0.00	400kV MHP - Jigmeling Line - I	94.78	Unit-IV on Standby. Unit-I under Shutdown (AMP). 400kV MHP-JIG Line - II and IV kept on Standby as other two lines can cater the load.	
		Unit-II	131.21	400kV MHP - Jigmeling Line - II	0.00		
		Unit-III	150.96	400kV MHP - Jigmeling Line - III	95.43		
		Unit-IV	0.00	400kV MHP - Jigmeling Line - IV	0.00		
		-	-	220kV Jigmeling - BitDeer Line - I	199.94		
		-	-	220kV Jigmeling - BitDeer Line - II	198.14		
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	425.82		
		-	-	400kV Jigmeling - Alipurduar Line - I	-24.00		
		-	-	400kV Jigmeling - Alipurduar Line - II	-25.46		
		-	-	80MVA, 220/132kV ICT - I (HV)	-14.74		
		-	-	80MVA, 220/132kV ICT - II (HV)	-14.53		
		-	-	132kV MHP - Yurmo Line - II	62.23		
		-	-	132kV MHP - Tintibi Line	55.35		
		-	-	132kV Gelephu - Salakati Line	-44.64		
		Total	282.17	Auxiliary Consumption & Transformation Losses at Generator end	0.81%		
3	6 x 170MW PHP-II	Unit-I	0.00	400kV PHP II - Jigmeling -I	189.97	Unit-I & II under Shutdown (Annual Maintenance). Unit III under Shutdown for runner inspection. Unit-V on Standby. 400kV PHP II-Jigmeling-II on Standby. 400kV PHP_II-Alipurduar-I on Standby.	
		Unit- II	0.00	400kV PHP II - Jigmeling -II	0.00		
		Unit- III	0.00	400kV PHP II - Alipurduar -I	0.00		
		Unit- IV	131.10	400kV PHP II - Alipurduar -II	72.16		
		Unit- V	0.00	-	-		
		Unit- VI	130.70	-	-		
		Total	261.80	Auxiliary Consumption & Transformation Losses at Generator end	-0.13%		
4	4 x 84MW CHP	Unit-I	84.17	220kV CHP - Birpara Line - I	-51.62	Unit-III under Shutdown (Upgradation works on common Emergency Cooling Water pipelines). Unit-II under Shutdown(Annual Maintenance).	
		Unit- II	0.00	220kV CHP - Birpara Line - II	-51.17		
		Unit- III	0.00	220kV CHP - Gedu	-38.72		
		Unit- IV	80.23	220kV CHP - Jamjee - I	102.07		
		-	-	220kV CHP - Jamjee - II	101.20		
		-	-	220kV CHP - Jamjee - III	98.30		
		-	-	220kV Malbase - Birpara Line	-39.04		
		-	-	66kV CHP - Gedu Line	4.96		
		Total	164.40	Auxiliary Consumption & Transformation Losses at Generator end	-0.38%		
5	2 x 12MW BHP (U/S)	Unit-I	0.00	220kV BHP - Semtokha Line	26.89	L/S Unit-II under Shutdown. U/S Unit-I on Standby.	
		Unit- II	7.50	66kV BHP - Lobeysa Line	16.91		
		Total	7.50	220kV BHP - Tsirang Line	-21.00		
6	2 x 20MW BHP (L/S)	Unit-I	15.50	5MVA, 66/11kV TFR	0.39		
		Unit- II	0.00	30MVA ICT, 220/66kV (HV)	9.79		
		Total	15.50	Auxiliary Consumption & Transformation Losses at Generator end	-0.83%		
7	2 x 63MW DHP	Unit-I	0.00	220kV DHP - Tsirang Line	0.00	Total Plant Shutdown from 10:27 hrs (09.10.2025) due to Seepage in HRC .	
		Unit-II	0.00	220kV DHP - Dagapela Line	0.00		
		-	-	220kV BitDeer - Dagapela Line	56.58		
		-	-	5MVA, 220/33kV TFR	0.27		
		Total	0.00	Auxiliary Consumption & Transformation Losses at Generator end	0.00%		
8	4 x 15MW KHP	Unit-I	0.00	132kV KHP - Nangkhor Line	10.45	Unit-I on Standby. Unit-III under Shutdown(Annual Maintenance).	
		Unit-II	12.20	132kV KHP - Kilikhar Line	13.45		
		Unit- III	0.00	5MVA, 132/11kV TFR	0.50		
		Unit- IV	12.21	132kV Motanga - Rangja Line	-2.65		
		Total	24.41	Auxiliary Consumption & Transformation Losses at Generator end	0.04%		
9	2 x 59MW NHP	Unit-I	0.00	132kV NHP-MHP-I	0.00	Unit-I under Shutdown (Annual Maintenance) 132kV NHP-MHP line I under ideal charge at NHP end.	
		Unit- II	28.00	132kV NHP-MHP-II	27.90		
		Total	28.00	Auxiliary Consumption & Transformation Losses at Generator end	0.36%		
10	2 x 9MW SHP	Unit-I	5.62	66kV SHP-Damdhum (Samtse)	0.00	Unit-II on Standby. Interim measure: Evacuation is through 33kV System.	
		Unit- II	0.00	-	-		
		Total	5.62	Auxiliary Consumption & Transformation Losses at Generator end	100.00%		
11	17.38 MWp Sephu (Solar)	Inverter-1	1.53	33kV SSP-Wangdue	6.85	All Inverters and Feeders in Service.	
		Inverter-2	2.72	33kV SSP-Trongsa	6.27		
		Inverter-3	2.60	-	-		
		Inverter-4	3.46	-	-		
		Inverter-5	2.81	-	-		
		Total	13.12	Auxiliary Consumption & Transformation Losses at Generator end	0.00%		


Note: Generation-Load Summary (MW) for 03-Jan-26 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	1,316.86	1,300.54	16.32


Note: Generation-Load Summary (MW) for 03-Jan-25 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	960.96	925.04	35.92

09:00 hrs Statistical Comparison
(MW) for this and last year



THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 04-Jan-2026(-ve:import, +ve:export)							
Report Details	Date	Time	National Coincidental Peak Load (MW)		Date	Time	Load
	January 3, 2026	18:00:00			08-Nov-25	19:03:00	1,477.00
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks	
1	6 x 170MW THP	Unit- I	180.36	400kV THP - Siliguri Line - I	95.72	Unit- IV,V,VI under Shutdown (Annual Maintenance). 400kV THP_SIL Line IV & 400kV MAL-SIL under Shutdown till 07th Jan.	
		Unit- II	180.72	400kV THP - Siliguri Line - II	94.17		
		Unit- III	183.79	400kV THP - Siliguri Line - IV	0.00		
		Unit- IV	0.00	400kV THP - Malbase Line - III	350.71		
		Unit- V	0.00	400kV Malbase - Siliguri Line	0.00		
		Unit- VI	0.00	-	-		
		Total	544.87	Auxiliary Consumption & Transformation Losses at Generator end	0.78%		
2	4 x 180MW MHP	Unit-I	0.00	400kV MHP - Jigmeling Line - I	102.49	Unit-I under Shutdown (Annual Maintenance). Unit-IV on Standby. 400kV MHP-JIG Line - II and IV kept on Standby as other two Lines can cater the load.	
		Unit-II	159.89	400kV MHP - Jigmeling Line - II	0.00		
		Unit-III	150.58	400kV MHP - Jigmeling Line - III	103.15		
		Unit-IV	0.00	400kV MHP - Jigmeling Line - IV	0.00		
		-	-	220kV Jigmeling - BitDeer Line - I	199.39		
		-	-	220kV Jigmeling - BitDeer Line - II	209.09		
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	439.64		
		-	-	400kV Jigmeling - Alipurduar Line - I	-16.73		
		-	-	400kV Jigmeling - Alipurduar Line - II	-17.46		
		-	-	80MVA, 220/132kV ICT - I (HV)	-14.95		
		-	-	80MVA, 220/132kV ICT - II (HV)	-14.73		
		-	-	132kV MHP - Yurmo Line - II	69.51		
		-	-	132kV MHP - Tintibi Line	60.72		
		-	-	132kV Gelephu - Salakati Line	-54.57		
		Total	310.47	Auxiliary Consumption & Transformation Losses at Generator end	0.76%		
3	6 x 170MW PHP-II	Unit- I	0.00	400kV PHP II - Jigmeling -I	210.45	Unit-I & II under Shutdown (Annual Maintenance). Unit III under Shutdown for runner inspection. Unit-V on Standby. 400kV PHP_II-Jigmeling-II on Standby. 400kV PHP_II-Alipurduar-I on Standby.	
		Unit- II	0.00	400kV PHP II - Jigmeling -II	0.00		
		Unit- III	0.00	400kV PHP II - Alipurduar -I	0.00		
		Unit- IV	144.67	400kV PHP II - Alipurduar -II	87.28		
		Unit- V	0.00	-	-		
		Unit- VI	155.00	-	-		
		Total	299.67	Auxiliary Consumption & Transformation Losses at Generator end	0.65%		
4	4 x 84MW CHP	Unit- I	75.46	220kV CHP - Birpara Line - I	-60.22	Unit-III under Shutdown (Upgradation works on common Emergency Cooling Water pipelines). Unit-II under Shutdown(Annual Maintenance).	
		Unit- II	0.00	220kV CHP - Birpara Line - II	-59.78		
		Unit- III	0.00	220kV CHP - Gedu	-49.02		
		Unit- IV	74.43	220kV CHP - Jamjee - I	105.86		
		-	-	220kV CHP - Jamjee - II	104.45		
		-	-	220kV CHP - Jamjee - III	101.55		
		-	-	220kV Malbase - Birpara Line	-46.08		
		-	-	66kV CHP - Gedu Line	5.80		
		Total	149.89	Auxiliary Consumption & Transformation Losses at Generator end	0.83%		
5	2 x 12MW BHP (U/S)	Unit- I	0.00	220kV BHP - Semothka Line	47.00	L/S Unit-II under Shutdown. U/S unit-I on Standby.	
		Unit- II	7.60	66kV BHP - Lobeysa Line	23.71		
		Total	7.60	220kV BHP - Tsiwang Line	-48.74		
6	2 x 20MW BHP (L/S)	Unit- I	15.00	5MVA, 66/11kV TFR	0.60		
		Unit- II	0.00	30MVA ICT, 220/66kV (HV)	16.20		
		Total	15.00	Auxiliary Consumption & Transformation Losses at Generator end	0.13%		
7	2 x 63MW DHP	Unit-I	0.00	220kV DHP - Tsiwang Line	0.00	Total Plant Shutdown from 10:27 hrs (09.10.2025) due to Seepage in HRC .	
		Unit-II	0.00	220kV DHP - Dagapela Line	0.00		
		-	-	220kV BitDeer - Dagapela Line	57.91		
		-	-	5MVA, 220/33kV TFR	0.20		
		Total	0.00	Auxiliary Consumption & Transformation Losses at Generator end	0.00%		
8	4 x 15MW KHP	Unit-I	0.00	132kV KHP - Nangkhor Line	0.64	Unit-I and II on Standby. Unit-III under Shutdown(AMP).	
		Unit-II	0.00	132kV KHP - Kilikhar Line	14.14		
		Unit- III	0.00	5MVA, 132/11kV TFR	0.54		
		Unit- IV	15.38	132kV Motanga - Rangia Line	-18.73		
		Total	15.38	Auxiliary Consumption & Transformation Losses at Generator end	0.39%		
9	2 x 59MW NHP	Unit-I	0.00	132kV NHP-MHP-I	0.00	Unit-I under Shutdown. 132kV NHP-MHP line I under ideal charge at NHP end.	
		Unit-II	28.01	132kV NHP-MHP-II	27.77		
		Total	28.01	Auxiliary Consumption & Transformation Losses at Generator end	0.86%		
10	2 x 9MW SHP	Unit- I	5.57	66kV SHP-Damdhum (Samtse)	0.00	Unit-II on Standby. Interim measure: Evacuation is through 33kV System.	
		Unit- II	0.00	-	-		
		Total	5.57	Auxiliary Consumption & Transformation Losses at Generator end	100.00%		
Note: Generation-Load Summary (MW) for 03-Jan-2026 at 18:00 hrs							
Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)		Total Export(+ve)/ Import(-ve)	19:00 hrs Statistical Comparison (MW) for this and last year	
1	Both Eastern & Western (Whole Bhutan)	1,376.46	1,372.86		3.60	Tt. Exp./Imp.	36.03 3.60
Note: Generation-Load Summary (MW) for 03-Jan-2025, at 18:00 hrs							
Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)		Total Export(+ve)/ Import(-ve)	Tt.Load	
1	Both Eastern & Western (Whole Bhutan)	1,007.17	971.14		36.03	971.14 1,007.17	
Note: Daily Energy (MUs) and Power(MW) Statistics for 03-Jan-2026							
Sl. No.	Total Energy Generation	Daily Energy Met	Net Energy Import (IEX and Solar)	Net Energy Export	Peak Cross-border (MW)	Tt. Gen.	
1	18.87	30.88	12.01	0.00	-913.61	1,007.17 1,007.17	
■ Y-2024 ■ Y-2025							



1. The Instantaneous load balance does not tend towards zero. This could be due to the following reasons:
 i) Not all the meters are digital and nor are all the meter at all locations can be read at same time (say 9:00hrs) due to many meter to be read manually. ii) The clocks of all the locations are not synchronized.
 2. This report, compiled using the SCADA data, is prepared to give an overall idea of the generation & load flow for the system at a particular instant. This report also gives energy and import/export figures.
 3. When SCADA data are unavailable for certain stations due to technical issues, required data are collected from the site.