



འབྲུག་རྒྱལ་ཁབ་ལོ་ནུ་རྒྱུ་ལྟུང་ལྟུང་གི་ རྒྱལ་ཁབ་རྒྱུ་ལྟུང་ལྟུང་།
Ministry of Energy and Natural Resources
Royal Government of Bhutan
Bhutan Power System Operator
Thimphu: Bhutan



THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 12-Jan-2026(+ve:import, +ve:export)									
Report Details		Date	Time	National Coincidental Peak Load (MW)		Date	Time	Load	
		January 11, 2026	9:00 AM			08-Nov-25	19:03:00	1,477.00	
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements		Load (MW)		Remarks	
1	6 x 170MW THP	Unit-I	139.15	400kV THP - Siliguri Line - I		53.48		Unit-IV,V & VI under Shutdown (Annual Maintenance). 400kV THP_SIL Line IV under Shutdown as the 400kV THP_NIP line was declared faulty after being unable to charge following the completion of LIFO work.	
		Unit-II	139.50	400kV THP - Siliguri Line - II		52.65			
		Unit-III	146.50	400kV THP - Siliguri Line - IV		0.00			
		Unit-IV	0.00	400kV THP - Malbase Line - III		319.36			
		Unit-V	0.00	400kV Malbase - Siliguri Line		-7.00			
		Unit-VI	0.00						
		Total	425.15	Auxiliary Consumption & Transformation Losses at Generator end		-0.08%			
2	4 x 180MW MHP	Unit-I	0.00	400kV MHP - Jigmeling Line - I		104.49		Unit-I under Shutdown (Annual Maintenance). Unit-IV on Standby. 400kV MHP-JIG Line - II & IV on Standby as other two lines can cater the load.	
		Unit-II	150.79	400kV MHP - Jigmeling Line - II		0.00			
		Unit-III	150.44	400kV MHP - Jigmeling Line - III		105.17			
		Unit-IV	0.00	400kV MHP - Jigmeling Line - IV		0.00			
		-	-	220kV Jigmeling - BitDeer Line - I		191.66			
		-	-	220kV Jigmeling - BitDeer Line - II		200.01			
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)		432.36			
		-	-	400kV Jigmeling - Alipurduar Line - I		2.18			
		-	-	400kV Jigmeling - Alipurduar Line - II		1.45			
		-	-	80MVA, 220/132kV ICT - I (HV)		-20.38			
		-	-	80MVA, 220/132kV ICT - II (HV)		-20.11			
		-	-	132kV MHP - Yurmo Line - II		56.21			
		-	-	132kV MHP - Tintibi Line		58.70			
		-	-	132kV Gelephu - Salakati Line		-35.28			
		Total	301.23	Auxiliary Consumption & Transformation Losses at Generator end		0.49%			
3	6 x 170MW PHP-II	Unit-I	0.00	400kV PHP II - Jigmeling -I		231.09		Unit-I & II under Shutdown (Annual Maintenance). Unit-III under Shutdown for runner inspection. Unit-V on Standby. 400kV PHP II-Jigmeling-II on Standby. 400kV PHP_II-Alipurduar-I on Standby.	
		Unit-II	0.00	400kV PHP II - Jigmeling -II		0.00			
		Unit-III	0.00	400kV PHP II - Alipurduar -I		0.00			
		Unit-IV	175.20	400kV PHP II - Alipurduar -II		120.08			
		Unit-V	0.00						
		Unit-VI	174.70						
		Total	349.90	Auxiliary Consumption & Transformation Losses at Generator end		-0.36%			
4	4 x 84MW CHP	Unit-I	0.00	220kV CHP - Birpara Line - I		-55.40		Unit-I & II under Shutdown (Annual Maintenance).	
		Unit-II	0.00	220kV CHP - Birpara Line - II		-55.00			
		Unit-III	69.76	220kV CHP - Gedu		-39.42			
		Unit-IV	70.69	220kV CHP - Jamjee - I		96.49			
		-	-	220kV CHP - Jamjee - II		95.50			
		-	-	220kV CHP - Jamjee - III		92.21			
		-	-	220kV Malbase - Birpara Line		-46.00			
		-	-	66kV CHP - Gedu Line		5.65			
		Total	140.45	Auxiliary Consumption & Transformation Losses at Generator end		0.30%			
5	2 x 12MW BHP (U/S)	Unit-I	0.00	220kV BHP - Semtokha Line		40.01		L/S Unit-II under Shutdown. U/S Unit-I on Standby.	
		Unit-II	7.20	66kV BHP - Lobeysa Line		15.05			
		Total	7.20	220kV BHP - Tsirang Line		-34.06			
6	2 x 20MW BHP (L/S)	Unit-I	14.40	5MVA, 66/11kV TFR		0.54			
		Unit-II	0.00	30MVA ICT, 220/66kV (HV)		9.02			
		Total	14.40	Auxiliary Consumption & Transformation Losses at Generator end		0.28%			
7	2 x 63MW DHP	Unit-I	0.00	220kV DHP - Tsirang Line		0.00		Total Plant Shutdown from 10:27 hrs (09.10.2025) due to Seepage in HRC .	
		Unit-II	0.00	220kV DHP - Dagapela Line		0.00			
		-	-	220kV BitDeer - Dagapela Line		57.40			
		-	-	5MVA, 220/33kV TFR		0.20			
		Total	0.00	Auxiliary Consumption & Transformation Losses at Generator end		0.00%			
8	4 x 15MW KHP	Unit-I	11.13	132kV KHP - Nangkor Line		8.67		Unit-II on Standby. Unit-III under Shutdown (Annual Maintenance).	
		Unit-II	0.00	132kV KHP - Kilikhar Line		13.06			
		Unit-III	0.00	5MVA, 132/11kV TFR		0.40			
		Unit-IV	11.17	132kV Motanga - Rangia Line		-9.93			
		Total	22.30	Auxiliary Consumption & Transformation Losses at Generator end		0.78%			
9	2 x 59MW NHP	Unit-I	0.00	132kV NHP-MHP-I		0.00		Unit-I under Shutdown (Annual Maintenance). 132kV NHP-MHP line I under ideal charge. at NHP end.	
		Unit-II	25.01	132kV NHP-MHP-II		24.82			
		Total	25.01	Auxiliary Consumption & Transformation Losses at Generator end		0.76%			
10	2 x 9MW SHP	Unit-I	5.18	66kV SHP-Damdhum (Samtse)		0.00		Unit-II on Standby. Interim measure: Evacuation is through 33kV System.	
		Unit-II	0.00						
		Total	5.18	Auxiliary Consumption & Transformation Losses at Generator end		100.00%			
11	17.38 MWp Sephu (Solar)	Inverter-1	1.44	33kV SSP-Wangdue		6.18		All Inverters and Feeders in Service.	
		Inverter-2	2.44	33kV SSP-Trongsa		5.92			
		Inverter-3	2.31						
		Inverter-4	3.25						
		Inverter-5	2.67						
		Total	12.11	Auxiliary Consumption & Transformation Losses at Generator end		0.08%			
Note: Generation-Load Summary (MW) for 11-Jan-26 at 09:00 hrs									
Sl. No.	Region	Total Generation		Total Domestic Load (Total Generation - Total Export)		Total Export(+ve)/Import(-ve)		09:00 hrs Statistical Comparison (MW) for this and last year	
1	Both Eastern & Western (Whole Bhutan)	1,302.93		1,281.70		21.23		Tt. Exp./Imp. 44.14 21.23	
Note: Generation-Load Summary (MW) for 11-Jan-25 at 09:00 hrs									
Sl. No.	Region	Total Generation		Total Domestic Load (Total Generation - Total Export)		Total Export(+ve)/Import(-ve)		09:00 hrs Statistical Comparison (MW) for this and last year	
1	Both Eastern & Western (Whole Bhutan)	865.64		821.50		44.14		Tt. Load 821.50 821.70 Tt. Gen. 865.64 830.93 ■ Y-2024 ■ Y-2025	

THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 12-Jan-2026(-ve:import, +ve:export)							
Report Details	Date	Time	National Coincidental Peak Load (MW)		Date	Time	Load
	January 11, 2026	18:00:00			08-Nov-25	19:03:00	1,477.00
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks	
1	6 x 170MW THP	Unit- I	180.40	400kV THP - Siliguri Line - I	87.59	Unit- IV, V & VI under Shutdown (Annual Maintenance). 400kV THP_SIL Line IV under Shutdown as the 400kV THP_NIP line was declared faulty after being unable to charge following the completion of LILO work.	
		Unit- II	180.64	400kV THP - Siliguri Line - II	86.74		
		Unit- III	180.00	400kV THP - Siliguri Line - IV	0.00		
		Unit- IV	0.00	400kV THP - Malbase Line - III	365.93		
		Unit- V	0.00	400kV Malbase - Siliguri Line	24.00		
		Unit- VI	0.00	-	-		
		Total	541.04	Auxiliary Consumption & Transformation Losses at Generator end	0.14%		
2	4 x 180MW MHP	Unit-I	0.00	400kV MHP - Jigmeling Line - I	92.48	Unit-I under Shutdown (Annual Maintenance). Unit-IV on Standby. 400kV MHP - Jigmeling line II & IV on Standby as other two Lines can cater the load.	
		Unit-II	150.12	400kV MHP - Jigmeling Line - II	0.00		
		Unit-III	150.41	400kV MHP - Jigmeling Line - III	92.50		
		Unit-IV	0.00	400kV MHP - Jigmeling Line - IV	0.00		
		-	-	220kV Jigmeling - BitDeer Line - I	195.00		
		-	-	220kV Jigmeling - BitDeer Line - II	203.00		
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	449.82		
		-	-	400kV Jigmeling - Alipurduar Line - I	-26.18		
		-	-	400kV Jigmeling - Alipurduar Line - II	-26.18		
		-	-	80MVA, 220/132kV ICT - I (HV)	-24.06		
		-	-	80MVA, 220/132kV ICT - II (HV)	-23.79		
		-	-	132kV MHP - Yurmo Line - II	69.90		
		-	-	132kV MHP - Tintibi Line	70.16		
		-	-	132kV Gelephu - Salakati Line	-36.76		
		Total	300.53	Auxiliary Consumption & Transformation Losses at Generator end	0.00%		
3	6 x 170MW PHP-II	Unit- I	0.00	400kV PHP II - Jigmeling -I	208.00	Unit-I & II under Shutdown (Annual Maintenance). Unit III under Shutdown for runner inspection. Unit-V on Standby. 400kV PHP_II-Jigmeling-II on Standby. 400kV PHP_II-Alipurduar-I on Standby.	
		Unit- II	0.00	400kV PHP II - Jigmeling -II	0.00		
		Unit- III	0.00	400kV PHP II - Alipurduar -I	0.00		
		Unit- IV	150.00	400kV PHP II - Alipurduar -II	92.80		
		Unit- V	0.00	-	-		
		Unit- VI	151.00	-	-		
		Total	301.00	Auxiliary Consumption & Transformation Losses at Generator end	0.07%		
4	4 x 84MW CHP	Unit- I	0.00	220kV CHP - Birpara Line - I	-60.79	Unit-I & II under Shutdown (Annual Maintenance).	
		Unit- II	0.00	220kV CHP - Birpara Line - II	-60.50		
		Unit- III	64.67	220kV CHP - Gedu	-64.18		
		Unit- IV	65.61	220kV CHP - Jamjee - I	104.26		
		-	-	220kV CHP - Jamjee - II	103.52		
		-	-	220kV CHP - Jamjee - III	102.77		
		-	-	220kV Malbase - Birpara Line	-33.92		
		-	-	66kV CHP - Gedu Line	4.57		
		Total	130.28	Auxiliary Consumption & Transformation Losses at Generator end	0.48%		
5	2 x 12MW BHP (U/S)	Unit- I	0.00	220kV BHP - Semtokha Line	52.10	L/S Unit-II under Shutdown. U/S unit-I on Standby.	
		Unit- II	7.10	66kV BHP - Lobeysa Line	22.03		
		Total	7.10	220kV BHP - Tsirang Line	-53.35		
6	2 x 20MW BHP (L/S)	Unit- I	14.40	5MVA, 66/11kV TFR	0.67		
		Unit- II	0.00	30MVA ICT, 220/66kV (HV)	15.62		
		Total	14.40	Auxiliary Consumption & Transformation Losses at Generator end	0.23%		
7	2 x 63MW DHP	Unit-I	0.00	220kV DHP - Tsirang Line	0.00	Total Plant Shutdown from 10:27 hrs (09.10.2025) due to Seepage in HRC .	
		Unit-II	0.00	220kV DHP - Dagapela Line	0.00		
		-	-	220kV BitDeer - Dagapela Line	58.53		
		-	-	5MVA, 220/33kV TFR	0.20		
		Total	0.00	Auxiliary Consumption & Transformation Losses at Generator end	0.00%		
8	4 x 15MW KHP	Unit- I	0.00	132kV KHP - Nangkhori Line	7.75	Unit-I on Standby. Unit-III under Shutdown(AMP).	
		Unit-II	12.73	132kV KHP - Kilikhar Line	17.14		
		Unit- III	0.00	5MVA, 132/11kV TFR	0.44		
		Unit- IV	12.78	132kV Motanga - Rangia Line	-7.53		
		Total	25.51	Auxiliary Consumption & Transformation Losses at Generator end	0.71%		
9	2 x 59MW NHP	Unit-I	0.00	132kV NHP-MHP-I	0.00	Unit-I under Shutdown. 132kV NHP-MHP line I under ideal charge at NHP end.	
		Unit-II	25.03	132kV NHP-MHP-II	24.83		
		Total	25.03	Auxiliary Consumption & Transformation Losses at Generator end	0.00%		
10	2 x 9MW SHP	Unit- I	5.18	66kV SHP-Damdhum (Samtse)	0.00	Unit-II on Standby. Interim measure: Evacuation is through 33kV System.	
		Unit- II	0.00	-	-		
		Total	5.18	Auxiliary Consumption & Transformation Losses at Generator end	100.00%		
Note: Generation-Load Summary (MW) for 11-Jan-2026 at 18:00 hrs							
Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)		Total Export(+ve)/ Import(-ve)	19:00 hrs Statistical Comparison (MW) for this and last year	
1	Both Eastern & Western (Whole Bhutan)	1,350.07	1,310.80		39.27		
Note: Generation-Load Summary (MW) for 11-Jan-2025, at 18:00 hrs							
Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)		Total Export(+ve)/ Import(-ve)	19:00 hrs Statistical Comparison (MW) for this and last year	
1	Both Eastern & Western (Whole Bhutan)	923.83	889.09		34.74		
Note: Daily Energy (MUs) and Power(MW) Statistics for 11-Jan-2026							
Sl. No.	Total Energy Generation	Daily Energy Met	Net Energy Import (IEX and Solar)	Net Energy Export	Peak Cross-border (MW)	Tt. Exp./Imp. 34.74 39.27 Tt.Load 889.09 310.80 Tt. Gen. 923.83 1350.07 Y-2024 Y-2025	
1	17.16	30.41	13.25	0.00	-945.50		

- The Instantaneous load balance does not tend towards zero. This could be due to the following reasons:
 - Not all the meters are digital and nor are all the meter at all locations can be read at same time (say 9:00hrs) due to many meter to be read manually.
 - The clocks of all the locations are not synchronized.
- This report, compiled using the SCADA data, is prepared to give an overall idea of the generation & load flow for the system at a particular instant. This report also gives energy and import/export figures.
- When SCADA data are unavailable for certain stations due to technical issues, required data are collected from the site.