



ལྷན་ཁག་དང་འཛམ་གླིང་ཚོད་ལྷན་གྱི་ཉེན་མཚན། དཔལ་དཀྱིལ་ལྷན་གྲུབ་ཚན་གྱི་ལྷན་ཁག་།
 Ministry of Energy and Natural Resources
 Royal Government of Bhutan
 Office of the Bhutan Power System Operator
 Thimphu: Bhutan



THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 19-Sep-2024(-ve:import, +ve:export)

Report Details	Date	Time	National Coincidental Peak Load (MW)	Date	Time	Load
	18-Sep-24	09:00 hrs		30-Dec-23	18:00 hrs	955.51

Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks
1	6 x 170MW THP	Unit- I	184.91	400kV THP - Siliguri Line - I	236.04	
		Unit- II	185.23	400kV THP - Siliguri Line - II	236.04	
		Unit- III	185.30	400kV THP - Siliguri Line - IV	222.15	
		Unit- IV	184.19	400kV THP - Malbase Line - III	418.75	
		Unit- V	185.61	400kV Malbase - Siliguri Line	181.54	
		Unit- VI	185.73	-	-	
		Total	1,110.97	Auxiliary Consumption & Transformation Losses at Generator end	-0.18%	
2	4 x 180MW MHP	Unit-I	195.12	400kV MHP - Jigmeling Line - I	264.49	400kV MHP-JLG Line II on Standby. 132kV MHP_Yurmoo Line-I not in Service. 400kV JLG_ALI Interim Line I on Standby.
		Unit-II	189.93	400kV MHP - Jigmeling Line - II	0.00	
		Unit-III	193.24	400kV MHP - Jigmeling Line - III	274.00	
		Unit-IV	170.63	400kV MHP - Jigmeling Line - IV	273.41	
		-	-	132kV MHP - Yurmo Line - I	0.00	
		-	-	132kV MHP - Yurmo Line - II	60.98	
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	115.50	
		-	-	400kV Jigmeling - Puna - Alipurduar Line - I	0.00	
		-	-	400kV Jigmeling - Puna - Alipurduar Line - II	171.64	
		-	-	400kV Jigmeling - Alipurduar Line - I	258.18	
		-	-	400kV Jigmeling - Alipurduar Line - II	257.46	
		-	-	80MVA, 220/132kV ICT - I (HV)	36.12	
		-	-	80MVA, 220/132kV ICT - II (HV)	35.84	
		-	-	220kV Tsirang - Jigmeling Line	9.86	
		-	-	132kV Gelephu - Salakati Line	31.62	
Total	748.92	Auxiliary Consumption & Transformation Losses at Generator end	0.41%			
3	4 x 84MW CHP	Unit- I	91.85	220kV CHP - Birpara Line - I	37.08	
		Unit- II	91.19	220kV CHP - Birpara Line - II	36.78	
		Unit- III	91.00	220kV CHP - Gedu	62.39	
		Unit- IV	91.44	220kV CHP - Jamjee (old) - I	74.15	
		-	-	220kV CHP - Jamjee - II (new)	74.87	
		-	-	220kV CHP - Jamjee - III (new)	72.26	
		-	-	220kV Malbase - Birpara Line	35.21	
		-	-	66kV CHP - Gedu Line	8.63	
Total	365.48	Auxiliary Consumption & Transformation Losses at Generator end	-0.39%			
4	2 x 12MW BHP (U/S)	Unit- I	9.01	220kV BHP - Semtokha Line	87.18	
		Unit- II	9.79	66kV BHP - Lobeyasa Line	24.84	
Total	18.80	220kV BHP - Tsirang Line	-64.38			
5	2 x 20MW BHP (L/S)	Unit- I	15.00	5MVA, 66/11kV TFR	0.47	
		Unit- II	14.45	30MVA ICT, 220/66kV (HV)	7.14	
Total	29.45	Auxiliary Consumption & Transformation Losses at Generator end	0.29%			
6	2 x 63MW DHP	Unit-I	38.35	220kV DHP - Tsirang Line	76.88	220kV DHP_Dagapela Line on Standby.
		Unit-II	39.02	220kV DHP - Dagapela Line	0.00	
		-	-	220kV Jigmeling - Dagapela Line	53.10	
		-	-	5MVA, 220/33kV TFR	0.30	
Total	77.37	Auxiliary Consumption & Transformation Losses at Generator end	0.25%			
7	4 x 15MW KHP	Unit- I	16.53	132kV KHP - Nangkor Line	42.32	
		Unit-II	16.51	132kV KHP - Kilikhar Line	22.97	
		Unit- III	16.62	5MVA, 132/11kV TFR	0.30	
		Unit- IV	16.46	132kV Motanga - Rangia Line	61.26	
Total	66.12	Auxiliary Consumption & Transformation Losses at Generator end	0.80%			
8	2 x 59MW NHP	Unit-I	63.91	132kV NHP-MHP-I	63.51	
		Unit-II	64.01	132kV NHP-MHP-II	63.54	
Total	127.92	Auxiliary Consumption & Transformation Losses at Generator end	0.68%			

Note: Generation-Load Summary (MW) for 18-Sep-24 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,602.07	607.37	610.47	984.84	-3.10
2	Eastern Grid	942.96	172.66	168.17	780.16	4.49
Total		2,545.03	780.03	778.64	1,765.00	1.39

Note: Generation-Load Summary for 18-Sep-23 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,172.56	558.93	553.56	602.90	5.37
2	Eastern Grid	591.74	188.69	186.19	413.78	2.50
Total		1,764.30	747.62	739.75	1,016.68	7.87

THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 19-Sep-2024(-ve:import, +ve:export)							
Report Details	Date	Time	National Coincidental Peak Load (MW)		Date	Time	Load
	18-Sep-2024	19:00 hrs			30-Dec-2023	18:00 hrs	955.51
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks	
1	6 x 170MW THP	Unit-I	185.32	400kV THP - Siliguri Line - I	227.21		
		Unit-II	184.70	400kV THP - Siliguri Line - II	225.97		
		Unit-III	185.86	400kV THP - Siliguri Line - IV	217.66		
		Unit-IV	185.71	400kV THP - Malbase Line - III	443.80		
		Unit-V	185.25	400kV Malbase - Siliguri Line	165.09		
		Unit-VI	185.11	-	-		
		Total	1,111.95	Auxiliary Consumption & Transformation Losses at Generator end	-0.24%		
2	4 x 180MW MHP	Unit-I	197.05	400kV MHP - Jigmeling Line - I	274.51	400kV MHP-JLG Line II on Standby. 132kV MHP_Yurmo Line- I not in Service. 400kV JLG_ALI Interim Line I on Standby.	
		Unit-II	197.83	400kV MHP - Jigmeling Line - II	0.00		
		Unit-III	190.92	400kV MHP - Jigmeling Line - III	284.16		
		Unit-IV	195.40	400kV MHP - Jigmeling Line - IV	283.73		
		-	-	132kV MHP - Yurmo Line - I	0.00		
		-	-	132kV MHP - Yurmo Line - II	63.71		
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	150.55		
		-	-	400kV Jigmeling - Puna - Alipurduar Line - I	0.00		
		-	-	400kV Jigmeling - Puna - Alipurduar Line - II	171.41		
		-	-	400kV Jigmeling - Alipurduar Line - I	256.46		
		-	-	400kV Jigmeling - Alipurduar Line - II	255.13		
		-	-	80MVA, 220/132kV ICT - I (HV)	48.49		
		-	-	80MVA, 220/132kV ICT - II (HV)	48.10		
		-	-	220kV Tsirang - Jigmeling Line	-0.22		
		-	-	132kV Gelephu - Salakati Line	40.18		
Total	781.20	Auxiliary Consumption & Transformation Losses at Generator end	0.27%				
3	4 x 84MW CHP	Unit-I	91.85	220kV CHP - Birpara Line - I	40.29		
		Unit-II	91.19	220kV CHP - Birpara Line - II	39.75		
		Unit-III	91.00	220kV CHP - Gedu	48.69		
		Unit-IV	91.44	220kV CHP - Jamjee (old) - I	76.07		
		-	-	220kV CHP - Jamjee - II (new)	76.70		
		-	-	220kV CHP - Jamjee - III (new)	74.19		
		-	-	220kV Malbase - Birpara Line	50.96		
		-	-	66kV CHP - Gedu Line	9.41		
		-	-	3x3MVA, 66/11kV TFR	1.02		
		Total	365.48	Auxiliary Consumption & Transformation Losses at Generator end	-0.18%		
4	2 x 12MW BHP (U/S)	Unit-I	9.40	220kV BHP - Sento Kha Line	93.07		
		Unit-II	9.00	66kV BHP - Lobeyasa Line	27.27		
		Total	18.40	220kV BHP - Tsirang Line	-69.90		
5	2 x 20MW BHP (L/S)	Unit-I	16.74	5MVA, 66/11kV TFR	0.69		
		Unit-II	16.15	30MVA ICT, 220/66kV (HV)	10.36		
		Total	32.89	Auxiliary Consumption & Transformation Losses at Generator end	0.31%		
6	2 x 63MW DHP	Unit-I	37.35	220kV DHP - Tsirang Line	73.86	220kV DHP_Dagapela Line on Standby.	
		Unit-II	36.99	220kV DHP - Dagapela Line	0.00		
		-	-	220kV Jigmeling - Dagapela Line	53.73		
		-	-	5MVA, 220/33kV TFR			
Total	74.34	Auxiliary Consumption & Transformation Losses at Generator end	0.65%				
7	4 x 15MW KHP	Unit-I	16.61	132kV KHP - Nangkor Line	38.68		
		Unit-II	16.50	132kV KHP - Kilikhar Line	26.17		
		Unit-III	16.46	5MVA, 132/11kV TFR	0.41		
		Unit-IV	16.71	132kV Motanga - Rangia Line	69.02		
		Total	66.28	Auxiliary Consumption & Transformation Losses at Generator end	1.54%		
8	2 x 59MW NHP	Unit-I	63.94	132kV NHP-MHP-I	63.49		
		Unit-II	63.91	132kV NHP-MHP-II	63.52		
		Total	127.85	Auxiliary Consumption & Transformation Losses at Generator end	0.66%		

Note: Generation-Load Summary (MW) for 18-Sep-2024 at 19:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,603.06	636.35	639.04	966.93	-2.69
2	Eastern Grid	975.33	182.91	178.95	792.20	3.96
	Total	2,578.39	819.26	817.99	1,759.13	1.27

Note: Generation-Load Summary (MW) for 18-Sep-2023, at 19:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,076.33	642.58	635.92	454.83	6.66
2	Eastern Grid	548.09	204.05	200.98	322.96	3.07
	Total	1,624.42	846.63	836.90	777.79	9.73

Note: Daily Energy (MUs) and Power(MW) Statistics for 18-Sep-2024

Sl. No.	Net Energy Export (Bilateral)	Net Energy Import (Bilateral)	Daily Energy Met	Total Energy Generation	Peak Cross-border (MW)	Imp./Exp. through Exchange (MUs)
1	39.27	0.00	18.30	59.29	1,829.81	1.67

- The Instantaneous load balance, calculated as (Total generation - (Total export-Import) - Total domestic load), do not tend towards zero. This could be due to the following reasons:
 - Not all the meters are digital and nor are all the meter at all locations can be read at same time (say 9:00hrs) due to many meter to be read manually. ii) The clocks of all the locations are not synchronized.
- This report, compiled using the SCADA data, is prepared to give an overall idea of the generation & load flow for the system at a particular instant. This report also gives energy and import/export figures.
- When SCADA data are unavailable for certain stations due to technical issues, required data are collected from the site.