

Bhutan Power Corporation Limited

Bhutan Power System Operator

Thimphu: Bhutan



Transmission System Performance Report

First Quarterly Report – January to March, 2022



Table of Contents

- 1. INTRODUCTION 2**
- 2. NATIONAL PEAK DEMAND 2**
- 2.1. POWER (MW) CONSUMED BY COUNTRY 2
- 3. ENERGY AVAILABILITY AND REQUIREMENT FOR THE COUNTRY 3**
- 3.1. ENERGY (MU) CONSUMED BY COUNTRY 3
- 4. PERFORMANCE OF GENERATING PLANTS 4**
- 4.1. POWER AND ENERGY GENERATION 4
- 4.2. PLANT CAPACITY FACTOR 5
- 5. EXPORT AND IMPORT OF ELECTRICITY 5**
- 6. FREQUENCY PROFILE 6**
- 6.1. FREQUENCY FOR THE MONTH OF JANUARY, 2020 6
- 6.2. FREQUENCY FOR THE MONTH OF FEBRUARY, 2020 7
- 6.3. FREQUENCY FOR THE MONTH OF MARCH, 2020 8
- 6.4. FREQUENCY SUMMARY FOR THE MONTH OF JANUARY TO MARCH, 2020 9
- 7. VOLTAGE PROFILE OF SELECTED SUBSTATION 9**
- 7.1. VOLTAGE PROFILE FOR THE JANUARY, 202010
- 7.2. VOLTAGE PROFILE FOR MONTH OF FEBRUARY, 202011
- 7.3. VOLTAGE PROFILE FOR THE MONTH OF MARCH, 202013
- 7.4. VOLTAGE SUMMARY FOR THE MONTH OF JANUARY TO MARCH, 202014
- 8. MAJOR OUTAGES OF FEEDERS AND EQUIPMENT 15**
- 8.1. MAJOR OUTAGES IN EASTERN GRID15
- 8.2. MAJOR OUTAGES IN WESTERN GRID15
- 9. ANNEXURES 15**



1. Introduction

The electricity transmission network in Bhutan is solely owned by Bhutan Power Corporation limited (BPC) and electricity generation is solely owned by Druk Green Power Corporation Limited (DGPC). Bhutan Power System Operator (BPSO) under BPC is responsible for safe, secure and efficient operation of Bhutan transmission network and generation.

This quarterly report is prepared in compliance to the Grid Code Regulation (GCR) 2008, clause 6.14.1, “System Operator has to submit a quarterly report covering the performance of the Transmission System to all Licensees, Authority and Ministry”. This transmission performance report contains summary of growth of peak demand, performance of generating stations (power and energy generation), energy availability and requirement for the country, export and import of electricity to/ from India, frequency profile of selected substation and voltage profile of few important substations.

All the index and other calculations in this report have been executed based on the data received from substations and generating plants.


2. National Peak Demand

The national peak demand till now is recorded at **435.35MW** which was occurred on December 26, 2021 at 18:00 hours. This is calculated by summation of Feeder Loading at Plants minus Export.

Table 2.1. The National Peak Demand since 2007

Year	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021
Peak Load (MW)	157.36	187.05	237.17	256.95	276.24	282.44	313.94	333.41	336.52	335.87	362.09	399.35	387.66	374.53	435.35
% Growth over previous Year	-	18.87	26.79	8.34	7.51	2.24	11.15	6.20	0.93	-0.19	7.81	10.29	-2.93	-3.39	16.24

Graph 2.1. The growth in National Peak Demand since 2007



2.1. Power (MW) consumed by country

Following methods are used to calculate peak demand for the Eastern Grid, Western Grid and National demand.


1. **National Demand** = (Sum of all total generation)-(Sum of all Export of Import)
2. **National Demand** = (Sum of all feeders loading at hydropower station) – (Sum of all Export/Import)
3. **National Demand** = (Sum of all substation loading)

For this report, the National Demand was calculated using method-3.

Table 2.1.2. Domestic demand for Eastern Grid, Western Grid and National using method- 3

Grid	Eastern Grid Load (MW)		Western Grid Load (MW)		National Load (MW)	
	Max	Min	Max	Min	Max	Min
January	16.70	1.29	66.18	1.02	380.90	208.18
February	18.01	0.34	63.97	0.00	399.67	0.85
March	0.00	0.00	63.28	41.53	367.10	151.46

Graph 2.1.2. Domestic demand for Eastern Grid, Western Grid and National using method- 3



The national load pattern for the month of January to March, 2021 calculated using method-3 is attached as **Annexure-II**

3. Energy Availability and Requirement for the country

3.1. Energy (MU) consumed by Country

The total energy consumed within Bhutan is computed from the total energy DGPC had sold to BPC including the royalty energy.

Table 3.1.1. Total Energy (MU) consumed

Month	Total Ex-bus (MU)	Total Export/Import (MU)	Total energy sold to BPC (MU)
January	223.22598590	25.71304504	197.51294086
February	183.71918284	25.61050110	158.10868174
March	410.26617736	156.12332138	254.14285598

Graph 3.1.1. Total Energy (MU) consumed





Table 3.1.2. Energy (MU) consumed

Grid	Eastern Grid Consumption (MU)	Western Grid Consumption (MU)	Total Consumption (MU)
January	42.76	243.19	285.9544153
February	34.91	212.15	247.0559331
March	45.03	220.06	265.0912595

Graph 3.1.2. Energy (MU) consumed



4. Performance of generating plants

4.1. Power and Energy Generation


The maximum total generation for the first quarter of year 2022 was 1,226.77 MW in month of March and minimum generation was 605.29 MW in the February month.

Table: 4.1.1 Summary of maximum and minimum generation by various hydropower plant

Generation By	BHP (MW)		CHP (MW)		THP (MW)		KHP (MW)		DHP (MW)		MHPA (MW)		TOTAL (MW)	
	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min
January	30.04	0.00	256.79	12.13	0.00	0.00	48.24	8.86	32.99	22.47	280.21	12.22	648.27	55.68
February	28.62	0.00	185.33	21.57	0.00	0.00	48.96	10.03	47.50	22.93	294.88	19.30	605.29	73.83
March	48.46	0.00	251.31	28.67	480.00	110.00	65.64	10.06	40.25	22.17	341.11	20.87	1,226.77	191.77

Source: Hydropower Plants (DGPC)

Graph: 4.1.1 Summary of maximum and minimum generation by various hydropower plant



Daily maximum, minimum and average generation by each generating plant for the month of January to March, 2022 is attached as

Annexure-I.



4.2.Plant Capacity Factor

The capacity factor of each generating plant was calculated as below:


$$Capacity\ factor = \frac{Total\ energy\ plant\ has\ produce\ over\ a\ period}{Total\ energy\ plant\ would\ produce\ when\ operated\ at\ full\ capacity}$$

Table 4.2.1: Total generation and capacity factor of various hydropower plants

Month	BHP (MU)	BHP (CF)	CHP (MU)	CHP (CF)	THP (MU)	THP (CF)	KHP (MU)	KHP (CF)	DHP (MU)	DHP (CF)	MHP (MU)	MHP (CF)
January	17.88000	38.80%	83.62000	34.57%	0.000000	0.00%	15.320000	35.46%	19.80	21.83%	86.58	16.70%
February	14.91000	31.31%	67.01000	26.81%	0.000000	0.00%	12.680000	28.41%	17.72	18.90%	71.38	13.33%
March	18.34000	39.80%	102.86000	42.52%	111.12000	15.13%	24.480000	56.67%	19.79	21.81%	133.67	25.79%

Source: TD, BPC

Graph 4.2.1: Capacity factor of various hydropower plants



5. Export and Import of Electricity

Maximum export for the First quarter of year 2022 was 217.46 MW in the month of March to Binaguri substation in India. The minimum export recorded was 0.00 MW to Birpara substation in India during the month of January and February.

Table 5.1. Export of electricity to India

Export To	Binaguri (MW)		Birpara (MW)		Salakoti and Rangia (MW)	
	Max	Min	Max	Min	Max	Min
January	0.00	0.00	0.00	0.00	18.99	0.04
February	0.00	0.00	39.25	0.66	25.11	0.07
March	217.46	0.09	100.60	0.27	51.10	0.05

Graph 5.1. Export of electricity to India





Table 5.2. Import of electricity from India.

Import From	Binaguri (MW)		Birpara (MW)		Salakoti and Rangia (MW)	
	Max	Min	Max	Min	Max	Min
January	120.36	36.73	157.91	1.44	39.23	0.05
February	110.56	4.36	137.92	0.46	38.54	0.29
March	88.36	0.09	135.32	0.05	33.74	0.11

Graph 5.2. Import of electricity to India



6. Frequency profile

The nominal allowed frequency range shall be 50Hz ± 1% in Bhutan. The system is normally managed such that frequency is maintained within operational limit of 49.5 Hz to 50.5 Hz. However, frequency may move outside these limit under faulty condition.

As per the Grid Code 2008, clause 6.4.1 the frequency is classified into three different bands as follows:

- a. Normal state
The transmission System frequency is within the limit of 49.5Hz to 50.5Hz.
- b. Alert state
The Transmission System frequency is beyond the normal operating limit but within 49.0Hz to 50.0Hz.
- c. Emergency state
There is generation deficiency and frequency is below 49.0Hz.

The frequency at 220kV Bus at 220/66/11kV Semtokha substation in the western grid and 132kV Bus at 60MW Kurichhu Hydropower Plant in the eastern grid is considered.

6.1.Frequency for the month of January, 2022

Table 6.1.1. Bus Frequency profile of Semtokha Substation

Sl. No.	Operating State	Frequency
1	Normal State	100.00%
2	Alert State	0.00%
3	Emergency State	0.00%
4	Blackout/Other	0.00%

Graph 6.1.1. Bus Frequency of Semtokha Substation





Table 6.1.2. Bus frequency of Kurichhu Hydro Power Plant

Sl. No.	Operating State	Frequency
1	Normal State	99.87%
2	Alert State	0.13%
3	Emergency State	0.00%
4	Blackout/Other	0.00%

Graph 6.1.2. Bus frequency of Kurichhu Hydro Power Plant



In the month of January, 2022, the Western grid was have managed to operate 100% in operating limit and Eastern grid was maintained at normal operating range of 99.87% and deviated 0.13% to Alert State.

6.2.Frequency for the month of February, 2022

Table 6.2.1. Bus frequency of Semtokha Substation

Sl. No.	Operating State	Frequency
1	Normal State	90.19%
2	Alert State	0.00%
3	Emergency State	0.00%
4	Blackout/Other	9.81%

Graph 6.2.1. Bus frequency of Semtokha Substation





Table 6.2.2. Bus frequency of Kurichhu Hydro Power Plant

Sl. No.	Operating State	Frequency
1	Normal State	89.52%
2	Alert State	0.00%
3	Emergency State	0.54%
4	Blackout/Other	9.95%

Graph 6.2.2. Bus frequency of Kurichhu Hydro Power Plant



In the month of February, 2022, the western grid frequency was maintained at normal operating range of 90.19% and deviated 9.81 to blackout/others. Eastern grid was maintained 89.52% in normal operating range and deviated 0.54% to Emergency state and 9.95% to Blackout/other.

6.3.Frequency for the month of March, 2022

Table 6.3.1. Bus frequency of Semtokha Substation

Sl. No.	Operating State	Frequency
1	Normal State	99.87%
2	Alert State	0.00%
3	Emergency State	0.00%
4	Blackout/Other	0.13%

Graph 6.3.1. Bus frequency of Semtokha Substation





Table 6.3.2. Bus frequency of Kurichhu Hydro Power Plant

Sl. No.	Operating State	Frequency
1	Normal State	100.00%
2	Alert State	0.00%
3	Emergency State	0.00%
4	Blackout/Other	0.00%

Graph 6.3.2. Bus frequency of Kurichhu Hydro Power Plant




6.4. In the month of March, 2022, the western grid frequency was maintained at normal operating range of 99.87% and deviated 0.13% to Blackout/other whereas Eastern grid was maintained at normal operating range of 100%.

6.5. Frequency Summary for the month of January to March, 2022

Table 6.4.1. Frequency summary for the month of January to March, 2022.

Bus Frequency at Semtokha Substation (Hz)		Bus Frequency at Kurichhu Hydropower Plant (Hz)	
Max	Min	Max	Min
50.10	49.70	50.13	49.49
50.00	49.50	53.10	43.20
50.00	49.50	50.18	49.64

Graph 6.4.1. Frequency summary for the month of January to March, 2022



Daily maximum, minimum and average Frequency of Semtokha substation in western grid and Kurichhu Hydro Power Plant in eastern grid for the month of January to March, 2022 is attached as **Annexure-III**

7. Voltage Profile of selected substation

As per the Grid Code 2008, clause 6.4.1 the voltage at all connection point is classified into three different bands as follows:

1. *Normal State*
The voltage at all connection points are within the limits of 0.95 times and 1.05 times of the normal values
2. *Alert State*
The voltage at all connection points are outside the normal limit but within the limits of 0.9 times and 1.1 times of the nominal values.
3. *Emergency State*
Transmission system voltages are outside the limit of 0.9 times and 1.1 times of nominal values.

Due to the location of 400/22/66/11kV Malbase substation in western grid and 132/33/11kV Nangkhor substation in the eastern grid, the voltage profile of these substations are considered.

7.1.Voltage profile for the January, 2022

Table 7.1.1. Voltage Profile for 400/220/66kV Malbase Substation

Sl. No.	Operating State	400kV Bus Voltage	220kV Bus Voltage	66kV Bus Voltage
1	Normal State	58.06%	100.00%	100.00%
2	Alert State	41.13%	0.00%	0.00%
3	Emergency State	0.81%	0.00%	0.00%
4	Blackout/Other	0.00%	0.00%	0.00%

Graph 7.1.1. Voltage Profile for 400/220/66kV Malbase Substation






Table 7.1.2. Voltage Profile of 220/66/11kV Semtokha Substation

Sl. No.	Operating State	220kV Bus Voltage	66kV Bus Voltage
1	Normal State	99.60%	97.85%
2	Alert State	0.40%	2.15%
3	Emergency State	0.00%	0.00%
4	Blackout/Other	0.00%	0.00%

Graph 7.1.2. Voltage Profile of 220/66/11kV Semtokha Substation






Table 7.1.3. Voltage Profile of 132/33/11kV Nangkhor Substation

Sl. No.	Operating State	132kV Bus Voltage
1	Normal State	99.87%
2	Alert State	0.13%
3	Emergency State	0.00%
4	Blackout/Other	0.00%

Graph 7.1.3. Voltage Profile of 132/33/11kV Nangkhor Substation





7.2. Voltage Profile for month of February, 2022

Table 7.2.1. Voltage Profile for 400/220/66kV Malbase Substation

Sl. No.	Operating State	400kV Bus Voltage	220kV Bus Voltage	66kV Bus Voltage
1	Normal State	60.22%	90.32%	90.05%
2	Alert State	29.84%	0.00%	0.00%
3	Emergency State	0.27%	0.00%	0.27%
4	Blackout/Other	9.68%	9.68%	9.68%

Graph 7.2.1. Voltage Profile for 400/220/66kV Malbase Substation






Table 7.2.2. Voltage Profile of 220/66/11kV Semtokha Substation

Sl. No.	Operating State	220kV Bus Voltage	66kV Bus Voltage
1	Normal State	90.05%	99.46%
2	Alert State	0.13%	0.13%
3	Emergency State	0.13%	0.00%
4	Blackout/Other	9.68%	0.40%

Graph 7.2.2. Voltage Profile of 220/66/11kV Semtokha Substation






Table 7.2.3. Voltage Profile of 132/33/11kV Nangkhor Substation

Sl. No.	Operating State	132kV Bus Voltage
1	Normal State	90.19%
2	Alert State	0.13%
3	Emergency State	0.00%
4	Blackout/Other	9.68%

Graph 7.2.3. Voltage Profile of 132/33/11kV Nangkhor Substation



7.3.Voltage Profile for the month of March, 2022

Table 7.3.1. Voltage Profile for 400/220/66kV Malbase Substation

Sl. No.	Operating State	400kV Bus Voltage	220kV Bus Voltage	66kV Bus Voltage
1	Normal State	91.80%	100.00%	99.87%
2	Alert State	8.20%	0.00%	0.13%
3	Emergency State	0.00%	0.00%	0.00%
4	Blackout/Other	0.00%	0.00%	0.00%

Graph 7.3.1. Voltage Profile for 400/220/66kV Malbase Substation




Table 7.3.2. Voltage Profile of 220/66/11kV Semtokha Substation

Sl. No.	Operating State	220kV Bus Voltage	66kV Bus Voltage
1	Normal State	99.87%	99.33%
2	Alert State	0.00%	0.54%
3	Emergency State	0.00%	0.00%
4	Blackout/Other	0.13%	0.13%

Graph 7.3.2. Voltage Profile of 220/66/11kV Semtokha Substation






Table 7.3.3. Voltage Profile of 132/33/11kV Nangkhor Substation

Sl. No.	Operating State	132kV Bus Voltage
1	Normal State	100.00%
2	Alert State	0.00%
3	Emergency State	0.00%
4	Blackout/Other	0.00%

Graph 7.3.3. Voltage Profile of 132/33/11kV Nangkhor Substation




7.4.Voltage Summary for the Month of January to March, 2022

Table 7.4.1. Voltage Summary for the month of January to March, 2022

Substation	Malbase Substation						Nangkhor Substation	
	400kV Bus Voltage (kV)		220kV Bus Voltage (kV)		66kV Bus Voltage (kV)		132kV Bus Voltage (kV)	
Month	Max	Min	Max	Min	Max	Min	Max	Min
January	429.00	236.50	228.00	212.00	68.50	63.00	143.40	129.32
February	565.00	320.50	227.00	214.00	69.00	58.00	138.81	128.60
March	425.00	403.50	225.50	213.50	68.00	60.50	136.94	129.67

Graph 7.4.1. Voltage Summary for the month of January to March, 2022





Daily maximum, minimum and average bus voltage of Malbase substation in western grid and Nangkhor substation in eastern grid for the month of January to March, 2022 is attached as **Annexure-IV**

8. Major Outages of Feeders and Equipment -to be continue

The transmission lines and equipment which were shut down for annual maintenance and hand/force trip are not considered in the report.

8.1.Major Outages in Eastern Grid

It had been observed that there was very few fault tripping during the first quarter of the year. Almost all the tripping occurred are of transient in nature or temporary fault which have been restored within few minutes. During the month of January, The 132/33kV Motanga Substation had a major issue as 132kV, Rangia Feeder tripped for almost 12hrs due Y-phase LA was punctured. During the month of February at 132/33/11 kV Kilikhar Station, 132kV Corlong feeder got tripped which lasted for almost 52hrs, and at Nanglam station, Nanglam-Tingtibi feeder tripped for almost 36hrs on 5th. There was no major issue during the month of March.

The feeders and equipment outages for the Eastern grid is attached as **Annexure-V**.

8.2.Major Outages in Western Grid

During the first quarter of the year, there was some outage occurred in western grid but there was not much major issue.

During the month of January one major outage took place at 220kV Semtokha Station, the outage lasted for about 25 hrs. During the month of February there was a tripping at Damji line at 66kv Decholing Station which lasted for almost 105hrs. Again during the month of March there was the same issue at Damji line at Decholing Station which lasted for almost 104hrs.

The feeders and equipment outages for the Western grid is attached as **Annexure-VI**.

9. Annexuresn (not updated)

Annexure-I

Table: Generation of January, 2022

Jan-22 Date	BHP (MW)			CHP (MW)			THP (MW)			KHP (MW)			DHP (MW)			MHP (MW)		
	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava
1	0.00	0.00	0.00	175.04	76.75	139.07	0.00	No Generati	Error	32.64	10.52	25.08	31.98	30.25	30.91	226.05	25.24	147.71
2	29.24	25.51	26.39	168.92	19.30	121.33	0.00	No Generati	Error	30.78	10.18	23.26	30.98	29.46	30.37	268.39	35.24	139.64
3	26.95	25.49	26.18	184.52	53.05	134.90	0.00	No Generati	Error	45.28	10.09	24.20	31.95	29.25	30.14	244.01	25.30	122.80
4	0.00	25.50	26.07	178.99	24.72	129.55	0.00	No Generati	Error	32.16	10.08	22.54	30.48	28.69	29.52	240.38	40.46	133.03
5	0.00	25.86	26.10	256.79	19.26	120.44	0.00	No Generati	Error	45.27	10.08	22.35	30.46	28.97	29.66	250.34	20.18	117.12
6	0.00	25.54	25.89	184.75	22.82	111.76	0.00	No Generati	Error	44.21	10.06	21.57	29.50	28.98	29.21	260.15	15.23	123.99
7	26.42	25.54	25.89	184.45	37.24	138.90	0.00	No Generati	Error	30.24	10.07	22.30	29.09	28.46	28.83	240.42	13.15	131.00
8	26.12	24.89	25.41	171.06	20.63	124.22	0.00	No Generati	Error	30.24	10.08	24.08	29.00	27.81	28.42	258.55	19.83	129.11
9	25.73	24.54	25.25	182.55	21.27	126.10	0.00	No Generati	Error	30.25	10.17	22.33	29.78	27.46	28.43	240.64	17.31	113.88
10	25.43	24.42	25.00	181.08	37.35	125.20	0.00	No Generati	Error	32.90	10.08	22.24	28.68	26.97	28.05	246.36	15.20	135.62
11	28.23	21.41	24.36	184.00	28.67	118.50	0.00	No Generati	Error	32.16	10.09	23.18	27.99	27.27	27.68	256.08	12.22	121.40
12	30.04	23.89	25.07	184.61	30.19	117.56	0.00	No Generati	Error	32.98	10.10	21.93	30.98	27.23	28.18	255.03	19.18	115.30
13	27.37	24.28	25.85	182.81	25.92	120.57	0.00	No Generati	Error	33.00	10.18	22.90	32.99	27.96	30.08	271.35	20.23	117.18
14	26.88	23.69	24.64	184.18	18.02	113.24	0.00	No Generati	Error	30.33	10.08	22.00	29.47	26.94	27.90	224.29	16.35	115.77
15	25.20	23.45	24.07	184.46	30.68	113.97	0.00	No Generati	Error	32.43	10.07	20.91	27.99	26.46	27.27	254.45	12.37	131.63
16	24.42	22.46	23.54	184.74	19.77	112.46	0.00	No Generati	Error	32.29	10.06	22.16	27.98	25.47	26.44	225.45	16.92	108.77
17	23.93	22.57	23.11	170.90	24.36	103.29	0.00	No Generati	Error	30.40	10.04	18.48	26.93	24.99	26.10	260.31	14.28	114.29
18	25.05	18.89	22.96	183.45	21.11	124.58	0.00	No Generati	Error	48.24	10.08	23.83	26.46	23.98	25.59	234.15	22.87	126.77
19	26.01	19.10	22.85	179.24	15.14	102.94	0.00	No Generati	Error	32.13	10.02	20.10	25.98	24.97	25.26	259.61	15.15	108.90
20	23.66	20.15	22.06	170.01	48.28	104.81	0.00	No Generati	Error	30.29	10.06	18.75	25.47	24.94	25.11	253.94	19.27	105.13
21	28.23	20.28	23.81	183.70	24.53	106.19	0.00	No Generati	Error	45.33	10.09	21.80	26.48	25.07	25.70	240.37	20.16	114.31
22	25.61	20.28	23.16	209.87	23.62	98.40	0.00	No Generati	Error	32.25	8.86	22.39	26.48	24.98	25.76	255.74	13.22	109.98
23	24.63	20.86	23.12	175.71	12.13	105.61	0.00	No Generati	Error	32.22	10.07	19.13	26.96	24.96	25.79	229.30	13.15	100.53
24	23.35	22.27	22.66	200.71	20.50	106.86	0.00	No Generati	Error	32.22	10.12	19.80	26.96	24.46	25.81	249.54	20.50	110.85
25	23.05	22.22	22.49	169.38	20.97	101.25	0.00	No Generati	Error	32.15	10.07	20.75	25.97	24.46	25.23	252.82	20.20	111.78
26	24.10	21.50	22.64	179.99	20.58	102.81	0.00	No Generati	Error	30.16	10.06	19.67	25.74	24.56	24.89	242.68	19.67	96.50
27	23.61	20.98	22.13	219.60	20.47	110.53	0.00	No Generati	Error	30.26	10.07	18.75	26.25	24.18	24.99	241.24	20.57	116.18
28	22.15	5.69	17.36	180.34	19.64	100.60	0.00	No Generati	Error	32.20	10.01	18.67	30.98	22.94	24.88	248.75	19.90	97.78
29	22.28	20.75	21.38	180.34	20.77	101.98	0.00	No Generati	Error	30.30	10.51	20.25	24.45	23.07	23.73	245.43	29.74	111.34
30	22.15	19.22	21.49	180.81	20.43	102.13	0.00	No Generati	Error	30.25	10.06	19.75	24.45	23.07	23.73	280.21	21.47	107.31
31	27.26	14.28	20.88	179.86	32.09	103.17	0.00	No Generati	Error	30.26	10.05	18.66	23.87	22.47	23.40	264.14	25.52	111.88
Max	30.04			256.79			0.00			48.24			32.99			280.21		
Min		0.00			12.13			0.00			8.86			22.47				12.22

Graph: Generation for the month January, 2022




Table: Generation for the month of February, 2022

Jan-22 Date	BHP (MW)			CHP (MW)			THP (MW)			KHP (MW)			DHP (MW)			MHP (MW)			
	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	
1	0.00	0.00	0.00	184.59	25.50	99.16	0.00	No Generati	Error	32.23	10.07	18.82	24.07	23.56	23.75	235.29	20.38	102.79	
2	27.68	14.09	21.79	183.46	27.55	95.01	0.00	No Generati	Error	30.24	10.08	18.46	25.01	22.93	24.08	220.77	19.30	92.77	
3	27.23	19.99	22.21	170.05	27.05	93.26	0.00	No Generati	Error	32.29	10.08	20.21	24.46	23.26	23.77	222.66	20.27	99.96	
4	0.00	19.99	22.21	184.51	24.30	99.87	0.00	No Generati	Error	30.18	10.05	18.91	36.93	23.25	25.42	211.21	19.84	111.16	
5	0.00	7.74	24.67	184.69	30.69	112.84	0.00	No Generati	Error	48.96	10.12	20.80	42.45	32.46	38.17	294.88	21.41	111.27	
6	0.00	18.01	23.50	177.82	23.93	112.69	0.00	No Generati	Error	32.27	10.59	21.56	35.94	27.00	29.89	234.78	20.31	103.79	
7	28.10	14.67	24.08	183.20	23.70	115.20	0.00	No Generati	Error	30.22	10.20	19.84	32.97	27.46	29.70	230.37	20.57	119.35	
8	27.65	22.66	23.66	180.73	46.38	113.07	0.00	No Generati	Error	32.25	10.09	19.56	28.46	25.96	27.17	246.51	25.53	121.37	
9	28.09	19.63	22.68	182.09	41.40	110.05	0.00	No Generati	Error	32.27	10.09	19.81	27.47	25.97	26.81	242.45	20.45	111.73	
10	28.21	13.78	22.95	181.96	29.88	107.49	0.00	No Generati	Error	28.39	10.06	18.00	28.42	25.57	26.77	241.59	21.51	115.40	
11	27.99	20.63	22.68	172.18	40.11	108.70	0.00	No Generati	Error	30.25	10.17	19.39	28.47	26.46	27.39	266.10	20.37	112.94	
12	27.75	12.57	22.84	181.81	32.16	102.08	0.00	No Generati	Error	30.22	10.18	20.05	27.95	25.47	26.84	246.11	20.81	100.48	
13	28.07	11.35	21.41	182.85	21.57	100.87	0.00	No Generati	Error	32.22	10.17	19.06	30.96	25.92	28.36	232.21	20.20	99.05	
14	28.62	17.21	22.65	183.68	31.42	100.42	0.00	No Generati	Error	26.23	10.18	18.53	32.92	26.66	28.94	265.69	21.90	112.90	
15	28.52	4.99	22.11	172.62	28.30	101.13	0.00	No Generati	Error	30.24	10.22	19.33	37.92	25.95	29.36	235.43	19.90	110.60	
16	28.31	20.49	23.57	183.91	28.85	100.69	0.00	No Generati	Error	30.33	10.28	21.15	33.94	25.95	28.96	229.12	20.21	109.18	
17	27.69	12.36	22.09	185.33	25.52	106.76	0.00	No Generati	Error	30.13	10.10	19.78	29.36	26.42	27.47	215.11	20.70	116.22	
18	27.37	12.39	20.76	180.01	29.45	97.59	0.00	No Generati	Error	30.18	10.06	20.35	27.98	23.97	26.64	241.41	25.53	113.74	
19	27.45	12.50	21.35	170.26	30.29	99.77	0.00	No Generati	Error	30.19	10.05	20.04	26.47	24.93	25.99	250.74	20.70	103.94	
20	27.79	16.08	22.06	183.66	29.85	91.78	0.00	No Generati	Error	30.15	10.05	19.31	27.99	25.91	27.11	256.37	22.34	100.42	
21	27.05	16.74	20.73	184.36	30.57	97.79	0.00	No Generati	Error	30.19	10.18	18.84	27.50	23.45	25.76	235.44	20.81	94.29	
22	27.29	14.62	20.84	184.24	29.43	100.01	0.00	No Generati	Error	25.09	10.10	19.39	47.50	23.17	26.32	251.99	20.31	111.22	
23	27.28	10.06	20.21	175.60	36.62	98.46	0.00	No Generati	Error	28.15	10.05	18.53	25.72	23.17	24.30	255.87	20.03	97.56	
24	26.90	12.13	20.12	173.82	37.89	98.46	0.00	No Generati	Error	30.20	10.05	18.88	24.71	23.18	23.92	264.60	20.88	105.34	
25	26.88	12.06	20.21	175.85	29.43	90.32	0.00	No Generati	Error	27.69	10.08	18.52	24.49	23.18	23.90	243.26	19.63	91.97	
26	26.81	15.27	19.99	174.90	32.55	93.62	0.00	No Generati	Error	30.03	10.03	18.45	26.19	23.19	24.87	264.92	20.28	95.52	
27	26.81	20.20	21.03	176.32	29.02	98.83	0.00	No Generati	Error	27.63	10.03	17.71	25.91	23.68	24.69	250.74	20.45	103.62	
28	26.75	11.91	19.56	176.13	28.34	94.51	0.00	No Generati	Error	30.21	10.11	20.57	25.24	23.69	24.64	277.57	20.11	111.06	
29	0.00	No Generati	Error	104.61	104.61	104.61	0.00	No Generati	Error	0.00	No Generati	Error	0.00	No Generati	error	0.00	No Generati	0.00	
30	0.00	No Generati	Error	0.00	No Generati	Error	0.00	No Generati	Error	0.00	No Generati	Error	0.00	No Generati	error	0.00	No Generati	0.00	
31	0.00	No Generati	Error	0.00	No Generati	Error	0.00	No Generati	Error	0.00	No Generati	Error	0.00	No Generati	Error	0.00	No Generati	Error	
Max	28.62			185.33			0.00			48.96			47.50			294.88			
Min		0.00			21.57			0.00			10.03			22.93			19.30		

Source: THP, CHP, BHP, KHP, MHP (DGPC)

Graph: Generation for the month of February, 2022




Table: Generation for the month of March, 2022

Mar-22	BHP (MW)			CHP (MW)			THP (MW)			KHP (MW)			DHP (MW)			MHP (MW)			
Date	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	
1	0.00	0.00	0.00	167.94	29.58	96.44	0.00	No Generati	Error	30.28	10.06	19.12	26.02	23.21	25.33	260.63	20.87	106.76	
2	26.08	17.13	21.39	184.71	30.79	95.34	0.00	No Generati	Error	30.34	10.19	20.60	38.28	24.68	28.77	245.71	20.93	103.68	
3	28.05	12.69	22.69	169.73	30.69	94.54	0.00	No Generati	Error	29.00	10.20	20.46	30.12	26.21	27.86	244.52	20.91	104.63	
4	0.00	12.51	22.49	170.37	30.11	97.37	0.00	No Generati	Error	30.19	10.09	20.12	27.77	25.21	26.58	250.78	21.28	113.06	
5	0.00	12.57	23.50	184.10	28.67	99.00	0.00	No Generati	Error	30.22	10.08	20.96	28.07	25.20	26.66	262.11	22.41	115.21	
6	0.00	12.02	22.28	184.02	30.80	101.52	0.00	No Generati	Error	30.19	10.09	22.06	31.23	26.16	28.11	259.85	26.31	133.83	
7	30.06	12.28	25.68	184.46	31.01	105.69	0.00	No Generati	Error	45.30	10.11	25.36	40.25	26.68	32.97	305.85	31.37	147.44	
8	30.12	15.99	24.90	180.55	29.61	123.38	0.00	No Generati	Error	45.33	10.48	28.78	37.27	25.21	29.52	312.43	22.74	163.65	
9	28.13	20.39	23.86	179.98	29.87	121.05	0.00	No Generati	Error	40.21	10.49	28.78	32.04	25.24	28.74	209.78	52.27	163.49	
10	30.29	20.82	24.18	174.80	45.53	130.44	0.00	No Generati	Error	40.59	20.35	30.09	33.25	25.24	29.25	258.61	69.88	175.01	
11	30.43	22.82	26.20	182.76	45.97	132.83	0.00	No Generati	Error	49.50	20.30	35.70	37.28	26.44	30.72	301.50	123.52	185.17	
12	29.12	20.48	25.43	184.00	35.48	131.71	0.00	No Generati	Error	48.26	20.40	32.99	33.30	26.24	28.85	260.95	65.11	188.43	
13	28.76	13.75	23.67	184.03	35.71	132.96	0.00	No Generati	Error	45.26	20.32	33.83	30.25	25.21	27.62	255.56	130.70	185.48	
14	28.86	7.58	24.29	183.62	46.01	137.49	0.00	No Generati	Error	48.47	20.87	33.73	29.76	25.19	27.32	220.98	135.14	185.08	
15	30.13	12.35	27.04	180.98	78.04	136.25	0.00	No Generati	Error	45.90	30.07	36.94	32.76	25.20	28.57	225.45	115.62	189.57	
16	30.17	22.08	27.08	163.42	119.22	140.41	0.00	No Generati	Error	40.36	30.07	33.34	30.78	25.20	28.05	247.37	124.64	199.79	
17	30.63	8.15	26.26	182.08	131.89	149.30	280.00	110.00	207.69	45.49	20.15	34.23	31.27	25.25	27.93	247.45	126.86	200.14	
18	32.06	8.17	28.09	172.98	140.56	156.61	340.00	260.00	297.08	45.93	20.16	39.21	31.76	25.70	28.16	273.91	160.49	205.60	
19	32.10	8.03	26.87	182.52	150.35	166.19	385.00	310.00	346.25	49.50	30.28	45.08	33.28	25.72	28.05	341.11	161.85	245.24	
20	31.19	9.46	28.80	226.96	134.44	186.89	465.00	310.00	384.17	49.50	35.26	48.79	30.26	25.76	27.75	301.74	185.84	236.93	
21	30.26	23.50	27.48	220.10	155.54	167.29	480.00	295.00	352.29	49.50	30.52	42.07	28.30	25.22	27.02	251.57	174.09	229.83	
22	29.24	23.13	26.48	182.70	154.02	162.97	345.00	285.00	316.46	46.41	31.41	40.08	27.23	24.19	25.56	247.88	170.67	215.25	
23	29.90	17.94	25.95	165.73	146.05	156.36	335.00	290.00	316.04	45.57	30.64	37.73	28.23	23.19	26.19	233.10	175.43	208.31	
24	29.79	9.14	23.90	168.36	130.82	147.98	320.00	255.00	278.54	48.56	30.96	42.17	26.74	22.20	24.94	230.56	160.67	200.27	
25	37.50	13.03	23.49	222.14	139.88	168.60	370.00	280.00	320.21	45.46	30.84	37.38	26.74	23.20	24.77	220.26	155.91	196.19	
26	48.46	17.56	31.28	200.18	143.99	179.90	445.00	305.00	400.00	53.70	30.13	35.46	29.30	24.21	26.89	225.76	154.87	193.27	
27	27.27	16.84	21.15	144.71	129.78	137.58	285.00	255.00	263.96	34.80	20.17	29.14	25.24	22.20	23.59	198.03	135.71	162.30	
28	26.96	16.87	20.32	147.95	118.39	133.87	290.00	240.00	257.71	40.38	30.05	35.10	23.71	22.21	22.88	190.37	143.79	168.82	
29	27.50	12.65	22.01	161.27	126.62	142.66	350.00	230.00	269.58	45.31	30.22	35.76	24.24	22.18	22.86	323.53	135.56	198.80	
30	26.25	21.43	22.28	249.71	133.19	183.27	480.00	250.00	354.17	48.45	30.35	40.29	24.21	22.17	23.09	340.08	140.75	217.74	
31	25.88	17.80	22.66	251.31	147.53	189.35	480.00	290.00	379.38	65.64	40.21	49.66	24.72	22.72	23.59	312.82	200.39	245.12	
Max	48.46			251.31			480.00			65.64			40.25			341.11			
Min		0.00			28.67			110.00			10.06			22.17			20.87		

Source: THP, CHP, BHP, KHP, MHP (DGPC)

Graph: Generation for the month of March, 2022




Table: National demand for January, 2022

Jan-22	Max	Min	Ava
0:00	342.15	231.90	255.09
1:00	259.54	215.69	241.57
2:00	258.89	213.30	239.53
3:00	253.06	209.13	236.63
4:00	251.44	208.18	238.98
5:00	255.79	210.35	240.94
6:00	268.40	225.95	251.43
7:00	297.88	250.97	279.00
8:00	347.14	288.74	311.43
9:00	345.10	298.00	317.20
10:00	339.35	275.45	312.96
11:00	339.75	274.35	309.61
12:00	340.76	266.24	310.93
13:00	338.65	269.29	309.19
14:00	330.98	271.65	304.68
15:00	328.28	271.79	304.31
16:00	321.39	273.93	306.36
17:00	354.37	287.76	321.26
18:00	380.90	305.20	350.09
19:00	380.56	322.55	354.72
20:00	361.84	299.68	341.56
21:00	344.58	292.38	324.11
22:00	323.37	272.73	299.68
23:00	296.90	252.81	272.71
	380.90		
		208.18	

Graph: National Demand for January, 2022

Annexure-II






Table: National Demand for February, 2022

Feb-22	Max	Min	Ava
0:00	358.01	2.75	222.85
1:00	281.76	12.74	233.26
2:00	278.28	0.93	229.02
3:00	273.68	0.86	227.18
4:00	269.94	0.85	224.89
5:00	273.07	0.87	227.71
6:00	277.97	1.01	234.89
7:00	310.75	1.86	258.14
8:00	347.31	2.56	286.37
9:00	353.14	2.64	295.93
10:00	354.77	2.46	292.64
11:00	360.02	2.11	293.16
12:00	366.59	1.97	298.26
13:00	360.86	1.89	295.61
14:00	351.28	1.84	289.21
15:00	352.28	1.72	289.33
16:00	351.56	1.97	287.49
17:00	361.24	2.56	297.61
18:00	385.09	4.10	323.75
19:00	399.67	3.96	335.90
20:00	385.43	3.32	321.85
21:00	363.10	2.56	306.90
22:00	331.82	1.92	282.62
23:00	308.41	1.39	259.62
	399.67		
		0.85	

Graph: National Demand for February, 2022




Table: National Demand for March, 2022

Mar-22	Max	Min	Ava
0:00	332.74	175.63	254.12
1:00	264.52	154.42	249.33
2:00	265.70	158.26	247.05
3:00	263.89	151.46	245.22
4:00	264.63	159.24	245.76
5:00	266.40	161.08	249.11
6:00	278.86	191.91	260.39
7:00	306.65	218.70	285.47
8:00	320.75	234.42	303.43
9:00	327.13	232.31	304.27
10:00	317.15	228.57	295.57
11:00	319.10	230.19	292.96
12:00	325.10	230.01	296.04
13:00	319.13	222.71	285.62
14:00	317.00	200.52	279.22
15:00	313.09	196.27	277.75
16:00	319.93	198.27	281.75
17:00	327.66	209.15	291.36
18:00	353.04	228.79	311.10
19:00	367.10	249.17	334.22
20:00	353.63	240.88	318.11
21:00	343.18	218.48	300.88
22:00	313.50	201.80	281.50
23:00	287.98	186.26	265.42
	367.10		
		151.46	

Graph: National Demand for March, 2022






Table: Daily maximum, minimum and average frequency for the month of January, 2022

Jan-22 Date	Bus Frequency at Semtokha Substation			Bus Frequency at Kurichhu Hydropower Plant		
	Max	Min	Ava	Max	Min	Ava
1	50.00	49.80	49.94	50.11	49.89	50.02
2	50.00	49.80	49.95	50.08	49.92	50.02
3	50.00	49.80	49.94	50.08	49.81	49.99
4	50.00	49.80	49.93	50.10	49.79	50.00
5	50.00	49.70	49.93	50.06	49.84	50.00
6	50.00	49.80	49.95	50.12	49.87	50.02
7	50.00	49.70	49.96	50.11	49.74	50.01
8	50.10	49.80	49.97	50.13	49.94	50.03
9	50.00	49.90	49.97	50.08	49.95	50.02
10	50.10	49.90	49.95	50.10	49.94	50.05
11	50.00	49.90	49.97	50.10	49.94	50.02
12	50.10	49.80	49.98	50.12	49.93	50.02
13	50.00	49.90	49.97	50.09	49.94	50.02
14	50.10	49.80	49.93	50.10	49.87	50.01
15	50.00	49.80	49.93	50.11	49.86	50.02
16	50.00	49.80	49.94	50.07	49.49	49.99
17	50.00	49.90	49.96	50.08	49.95	50.02
18	50.00	49.70	49.93	50.07	49.85	50.01
19	50.00	49.80	49.95	50.09	49.89	50.00
20	50.00	49.90	49.95	50.10	49.93	50.01
21	50.00	49.80	49.95	50.11	49.75	49.99
22	50.00	49.90	49.97	50.08	49.89	50.01
23	50.00	49.90	49.98	50.09	49.97	50.02
24	50.00	49.80	49.97	50.13	49.88	50.03
25	50.00	49.90	49.95	50.10	49.90	50.03
26	50.00	49.80	49.93	50.06	49.87	50.00
27	50.00	49.90	49.95	50.09	49.97	50.03
28	50.00	49.80	49.93	50.08	49.84	50.00
29	50.00	49.80	49.93	50.09	49.82	49.99
30	50.00	49.80	49.96	50.08	49.92	50.03
31	50.00	49.90	49.95	50.07	49.92	50.02
Max	50.10			50.13		
Min		49.70			49.49	

Source: TD (BPC), KHP (DGPC)

Graph: Daily maximum, minimum and average frequency for the month of January, 2022






Table: Daily maximum, minimum and average frequency for the month of February, 2022

Feb-21 Date	Bus Frequency at Semtokha Substation			Bus Frequency at Kurichhu Hydropower Plant		
	Max	Min	Ava	Max	Min	Ava
1	50.00	49.80	49.95	50.08	49.89	50.00
2	50.00	49.50	49.92	50.06	49.87	50.02
3	50.00	49.80	49.96	50.09	49.79	50.01
4	50.00	49.80	49.95	50.11	49.94	50.03
5	50.00	49.90	49.98	50.07	49.94	50.03
6	50.00	49.90	49.97	50.09	49.94	50.02
7	50.00	49.80	49.96	53.10	43.20	49.77
8	50.00	49.70	49.94	50.06	49.78	49.99
9	50.00	49.90	49.98	50.07	49.96	50.03
10	50.00	49.80	49.96	50.09	49.97	50.04
11	50.00	49.70	49.94	50.12	49.95	50.02
12	50.00	49.90	49.95	50.06	49.89	49.99
13	50.00	49.80	49.94	50.06	49.89	50.00
14	50.00	49.90	49.96	50.20	49.82	50.02
15	50.00	49.70	49.93	50.08	49.85	49.99
16	50.00	49.90	49.93	50.09	49.85	49.99
17	50.00	49.80	49.94	50.07	49.86	50.01
18	50.00	49.80	49.97	50.08	49.93	50.01
19	50.00	49.80	49.96	50.08	49.87	50.01
20	50.00	49.90	49.95	50.07	49.91	50.01
21	50.00	49.80	49.95	50.06	45.90	49.81
22	50.00	49.70	49.95	50.09	49.83	50.01
23	50.00	49.90	49.93	50.08	49.94	50.01
24	50.00	49.70	49.91	50.07	49.87	49.98
25	50.00	49.80	49.95	50.10	49.86	50.00
26	50.00	49.80	49.96	50.08	49.91	50.02
27	50.00	49.90	49.97	50.10	49.93	50.03
28	50.00	49.90	49.98	50.08	49.92	50.02
29	0.00	Error	Error	0.00	Error	Error
30	0.00	Error	Error	0.00	Error	Error
31	0.00	Error	Error	0.00	Error	Error
Max	50.00			53.10		
Min		49.50			43.20	

Source: TD (BPC), KHP (DGPC)

Graph: Daily maximum, minimum and average frequency for the month of February, 2022







Table: Daily maximum, minimum and average frequency for the month of March, 2022

Date	Bus Frequency at Semtokha Substation			Bus Frequency at Kurichhu Hydropower Plant		
	Max	Min	Ava	Max	Min	Ava
1	50.00	49.80	49.95	50.09	49.84	50.02
2	50.00	49.80	49.95	50.10	49.88	50.03
3	50.00	49.80	49.95	50.08	49.86	50.01
4	50.00	49.80	49.94	50.18	49.87	50.00
5	50.00	49.90	49.97	50.08	49.96	50.02
6	50.00	49.80	49.95	50.09	49.87	50.02
7	50.00	49.80	49.93	50.06	49.86	50.00
8	50.00	49.90	49.95	50.08	49.91	50.02
9	50.00	49.90	49.95	50.06	49.85	49.99
10	50.00	49.80	49.95	50.07	49.85	50.01
11	50.00	49.80	49.93	50.08	49.81	50.00
12	50.00	49.80	49.93	50.05	49.91	50.00
13	50.00	49.80	49.95	50.08	49.89	50.03
14	50.00	49.80	49.93	50.08	49.80	50.00
15	50.00	49.80	49.93	50.04	49.81	49.95
16	50.00	49.90	49.92	50.06	49.81	49.98
17	50.00	49.70	49.90	50.06	49.79	49.96
18	50.00	49.70	49.95	50.09	49.88	50.01
19	50.00	49.90	49.95	50.13	49.89	50.02
20	50.00	49.80	49.93	50.08	49.89	49.99
21	50.00	49.70	49.91	50.07	49.71	49.96
22	50.00	49.50	49.87	50.04	49.65	49.93
23	50.00	49.60	49.88	50.04	49.67	49.93
24	50.00	49.70	49.90	50.08	49.84	49.95
25	50.00	49.60	49.88	50.03	49.64	49.92
26	50.00	49.70	49.91	50.10	49.78	49.97
27	50.00	49.80	49.95	50.07	49.90	50.03
28	50.00	49.70	49.95	50.09	49.80	50.00
29	50.00	49.80	49.93	50.08	49.88	49.99
30	50.00	49.80	49.93	50.05	49.91	49.99
31	50.00	49.80	49.91	50.06	49.80	49.97
Max	50.00			50.18		
Min		49.50			49.64	

Source: TD (BPC), KHP (DGPC)

Graph: Daily maximum, minimum and average frequency for the month of March, 2022





Annexure-IV

Table: Daily maximum, minimum and average Voltage for the month of January, 2022

Jan-22 Date	Malbase Substation									Nangkhor Substation		
	400kV Bus Voltage (kV)			220kV Bus Voltage (kV)			66kV Bus Voltage (kV)			132kV Bus Voltage (kV)		
	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava
1	424.50	408.00	418.21	223.00	214.50	219.79	67.00	64.00	65.54	136.30	131.70	134.01
2	427.00	405.50	419.21	226.50	214.00	220.83	68.00	64.30	66.40	136.90	131.12	133.73
3	426.50	321.50	410.27	225.00	214.50	219.96	68.00	65.00	66.08	136.50	130.49	133.56
4	426.00	408.00	417.15	224.00	214.50	219.15	67.00	64.00	65.91	135.27	129.40	133.51
5	426.00	407.50	416.50	224.50	214.00	218.96	68.00	64.00	65.75	136.31	129.32	133.51
6	424.50	409.50	418.35	223.00	214.50	219.25	67.00	64.50	65.94	135.30	131.74	133.23
7	424.50	406.50	417.65	224.00	214.00	219.29	67.00	64.00	65.73	136.50	131.32	134.29
8	425.00	407.00	418.94	223.50	214.00	220.04	67.00	65.00	66.02	135.78	130.08	133.34
9	427.00	322.00	415.54	226.50	216.00	221.19	67.18	65.00	66.30	136.30	130.29	133.61
10	429.00	409.50	418.73	228.00	215.00	220.21	68.00	64.20	65.93	136.10	130.08	133.24
11	426.00	236.50	401.83	225.00	214.00	219.63	68.00	65.00	66.10	136.70	130.90	133.63
12	427.50	412.00	421.02	226.00	217.00	222.06	67.00	65.00	66.15	136.50	131.30	133.76
13	428.50	408.50	419.81	225.00	214.50	220.63	68.00	65.00	66.35	135.69	130.20	133.29
14	426.00	407.50	419.13	224.00	215.50	220.65	68.00	65.00	66.38	135.40	130.20	133.24
15	425.00	407.50	418.83	224.00	213.00	219.85	67.00	64.00	66.02	134.86	129.40	133.40
16	427.00	404.50	419.83	224.50	214.00	221.02	68.00	64.00	66.52	136.10	129.87	134.18
17	428.50	407.50	419.23	226.50	215.00	221.13	68.50	65.00	66.45	136.30	130.87	134.08
18	427.00	407.50	418.46	225.00	214.50	220.38	68.00	65.00	66.33	143.40	131.90	134.55
19	424.50	408.50	417.42	225.00	214.50	220.19	68.00	64.40	66.11	135.90	130.70	133.88
20	426.50	408.00	418.77	225.00	215.00	220.46	68.00	65.00	66.28	135.90	129.60	133.61
21	425.00	407.50	418.54	224.00	215.00	220.69	68.00	64.00	66.21	136.31	131.50	134.14
22	427.00	410.50	419.71	225.00	216.00	220.77	67.00	65.00	66.11	136.50	130.91	133.86
23	423.50	409.00	418.73	224.50	216.00	221.44	67.00	65.00	66.48	136.52	130.70	134.42
24	425.50	404.50	417.85	224.50	214.50	220.33	68.00	64.50	65.97	135.42	131.12	134.04
25	425.00	405.50	417.21	224.50	214.50	219.90	67.00	65.00	65.88	135.90	131.74	134.01
26	425.00	407.50	418.60	224.50	216.00	220.77	68.00	65.00	66.33	136.52	131.95	134.51
27	425.00	402.00	416.60	225.00	212.50	220.00	68.00	64.00	66.00	136.52	131.33	134.60
28	424.00	407.00	416.77	223.50	215.00	219.69	68.00	65.00	66.21	136.73	130.08	134.01
29	424.00	404.50	416.79	224.50	213.00	218.46	67.00	64.00	65.29	136.73	130.29	133.93
30	424.50	406.50	419.27	223.50	214.50	220.40	67.00	64.50	66.04	135.60	130.70	133.67
31	427.00	404.50	418.29	224.50	212.00	219.81	67.00	63.00	65.66	136.10	131.12	133.59
Max	429.00			228.00			68.50			143.40		
Min		236.50			212.00			63.00			129.32	
Source: TD, BPC												

Graph: Daily maximum, minimum and average Voltage for the month of January, 2022






Table: Daily maximum, minimum and average Voltage for the month of February, 2022

Feb-22 Date	Malbase Substation									Nangkor Substation		
	400kV Bus Voltage (kV)			220kV Bus Voltage (kV)			66kV Bus Voltage (kV)			132kV Bus Voltage (kV)		
	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava
1	424.50	407.50	416.83	223.50	214.00	219.63	67.00	64.00	65.79	136.31	130.40	133.36
2	425.50	410.00	418.94	224.00	215.00	220.00	68.00	65.00	66.19	136.52	130.91	134.03
3	425.00	409.00	418.23	224.50	215.50	220.56	67.12	65.00	66.30	136.90	132.16	134.59
4	424.00	407.50	418.02	223.50	216.00	220.75	68.00	65.00	66.46	136.10	131.42	133.72
5	428.00	404.00	418.90	226.50	214.50	222.15	69.00	65.00	66.88	137.77	132.16	134.66
6	424.50	407.00	418.58	227.00	216.50	221.71	69.00	65.00	66.79	135.69	131.74	133.61
7	427.00	403.50	417.15	226.00	214.50	220.92	68.00	64.00	66.42	135.86	129.25	132.76
8	424.50	403.50	416.58	225.00	214.00	220.49	68.00	64.00	66.01	135.90	130.20	133.96
9	426.50	405.00	417.35	225.00	214.50	220.19	68.00	64.00	65.92	136.31	130.20	133.68
10	565.00	407.00	424.75	225.00	214.00	221.35	68.00	64.25	66.48	136.94	130.71	133.99
11	424.50	410.50	418.52	224.50	217.00	221.25	68.00	65.00	66.33	135.48	131.74	134.43
12	427.00	412.50	420.19	226.50	214.00	221.77	68.00	65.00	66.55	137.56	133.40	135.41
13	424.50	412.50	418.44	225.00	217.50	221.10	67.00	65.40	66.48	136.73	131.74	134.49
14	425.50	407.00	417.94	225.00	214.00	221.00	68.00	64.50	66.38	136.52	131.95	134.11
15	424.50	410.00	416.44	224.50	216.50	219.54	67.00	64.50	65.66	137.56	131.10	134.78
16	425.00	411.00	417.98	224.50	216.50	220.46	67.00	65.00	66.06	136.94	133.20	134.77
17	426.00	412.00	418.27	225.00	216.00	220.56	68.00	65.00	66.46	136.52	131.12	134.59
18	425.50	320.50	413.46	225.50	217.00	220.35	68.00	65.00	65.98	137.85	131.12	134.29
19	424.00	409.50	417.27	224.50	216.00	220.04	67.00	58.00	65.33	137.50	131.74	134.93
20	422.50	410.50	415.69	223.50	216.00	219.25	67.00	65.00	65.71	136.73	130.91	133.50
21	425.00	409.50	416.33	225.00	216.00	220.00	67.50	65.00	65.76	138.81	131.12	133.67
22	424.50	409.00	416.85	224.50	216.00	220.15	68.00	65.00	66.05	136.94	131.50	134.52
23	422.00	410.00	415.77	224.50	216.50	219.75	68.00	65.00	65.92	137.56	128.60	134.08
24	420.50	412.50	416.63	222.00	217.50	219.63	67.00	65.00	66.00	137.32	131.12	134.22
25	422.50	411.50	417.04	223.50	217.00	219.75	67.00	65.00	66.08	135.60	130.91	133.26
26	425.50	411.50	417.92	225.00	216.00	220.15	67.00	65.00	65.88	135.91	131.12	133.80
27	425.50	410.50	418.77	225.00	216.00	221.00	67.60	65.00	66.09	135.40	132.50	134.21
28	424.50	408.50	416.98	225.00	215.00	220.13	67.80	64.00	66.11	136.31	131.54	134.23
29	0.00	Error	Error	0.00	Error	Error	0.00	Error	Error	0.00	Error	Error
30	0.00	Error	Error	0.00	Error	Error	0.00	Error	Error	0.00	Error	Error
31	0.00	Error	Error	0.00	Error	Error	0.00	Error	Error	0.00	Error	Error
Max	565.00			227.00			69.00			138.81		
Min		320.50			214.00			58.00			128.60	

Source: TD, BPC

Graph: Daily maximum, minimum and average Voltage for the month of February, 2022







Table: Daily maximum, minimum and average Voltage for the month of March, 2022

Mar-22 Date	Malbase Substation									Nangkhor Substation		
	400kV Bus Voltage (kV)			220kV Bus Voltage (kV)			66kV Bus Voltage (kV)			132kV Bus Voltage (kV)		
	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava
1	424.00	411.50	417.17	224.50	218.00	220.42	67.00	65.00	66.20	136.31	131.95	133.99
2	424.50	412.00	417.40	225.00	216.50	220.21	68.00	65.00	66.08	136.94	131.27	134.56
3	424.50	411.50	416.79	223.50	218.00	220.17	67.00	65.00	65.96	136.70	130.20	133.42
4	425.00	409.00	417.08	225.50	215.50	220.40	67.00	65.00	66.00	135.28	131.30	133.90
5	425.00	411.50	416.83	225.00	217.50	220.42	68.00	65.00	66.25	136.10	131.50	133.88
6	421.00	409.50	415.58	223.00	216.00	219.56	67.00	64.00	65.71	136.10	131.12	133.90
7	422.50	409.50	414.56	223.00	215.50	219.35	67.00	65.00	65.70	135.42	131.12	133.51
8	425.00	409.50	416.71	225.50	217.00	220.58	68.00	65.00	66.26	136.10	131.70	133.81
9	422.50	407.50	415.67	223.00	214.00	219.44	67.00	65.00	65.70	135.90	130.70	133.80
10	421.50	411.00	415.33	223.50	217.50	219.71	67.00	63.50	65.75	134.86	132.30	133.34
11	419.50	413.00	417.27	222.50	217.50	220.65	67.00	65.60	66.35	135.90	131.95	133.64
12	421.50	409.00	415.98	223.00	216.00	219.77	67.00	64.00	65.90	135.20	130.70	133.22
13	421.00	407.50	416.19	222.00	214.50	219.52	67.00	64.50	65.83	135.20	131.45	133.45
14	420.00	407.50	415.33	223.00	215.00	219.04	67.50	64.00	65.77	136.10	129.67	133.09
15	419.50	408.50	414.31	222.00	216.00	218.67	66.00	65.00	65.56	134.86	130.91	133.17
16	419.50	408.00	414.25	222.00	213.50	217.94	66.00	64.00	65.20	135.90	131.53	133.53
17	421.50	406.50	412.31	222.00	215.50	218.92	67.00	64.50	65.56	134.86	131.32	133.33
18	413.50	409.00	411.58	222.50	218.00	220.17	66.50	65.00	65.92	136.10	132.89	134.12
19	417.50	405.00	413.06	223.50	214.50	219.69	67.50	64.00	65.97	135.69	132.56	134.06
20	413.00	403.50	409.60	220.50	214.00	217.75	66.25	65.00	65.42	135.48	131.95	133.67
21	412.50	405.50	409.77	220.00	216.00	217.88	66.11	64.00	65.20	135.07	131.53	133.47
22	414.50	406.00	410.81	222.50	215.50	218.38	66.56	65.00	65.47	136.10	130.70	133.44
23	417.00	406.50	410.54	224.00	215.50	218.35	67.00	65.00	65.62	135.07	130.91	133.16
24	414.00	407.50	411.21	222.00	215.50	219.27	67.00	60.50	65.70	136.10	131.32	133.64
25	413.50	407.50	409.96	221.00	216.00	218.10	65.97	64.86	65.20	134.56	131.32	133.44
26	414.00	405.50	411.00	221.00	214.50	218.33	66.00	64.00	65.29	135.69	130.08	133.19
27	414.00	406.50	411.48	221.00	216.00	218.88	67.00	64.00	65.71	134.86	131.74	133.12
28	415.00	409.00	412.25	222.00	214.50	218.54	67.00	65.00	65.55	135.07	131.54	133.63
29	415.50	409.00	412.23	221.50	217.00	219.38	67.00	65.00	66.07	134.68	132.36	133.53
30	415.00	407.00	410.79	222.00	216.50	218.90	67.00	65.00	65.87	134.75	132.36	133.47
31	413.50	406.50	410.81	221.50	217.00	218.92	66.00	65.00	65.51	134.86	131.95	133.58
Max	425.00			225.50			68.00			136.94		
Min		403.50			213.50			60.50			129.67	

Source: TD, BPC

Graph: Daily maximum, minimum and average Voltage for the month of March, 2022





Annexure-V

Eastern Grid Outages for January 2022

MONTHLY OUTAGE REPORT FOR THE MONTH OF JANUARY, 2022 UNDER SMD DEOTHANG, TD, BPC.

Division: SMD-DEOTHANG		Substation: 132/33/11kV Nangkor Substation		Month: Jan-22											
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping		Normalization Time		Duration of Outage		MW before Outage (MW)	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time	(Hrs)	(Min)		Protection Relay Optd	Fault Details (As recorded by relay)			
132kV Feeders															
1	SMVA Transformer-I, 132/22/11kV	132kV	Tripping	1/2/2022	10:47 hrs	1/2/2022	10:43 hrs	0	2	0.68	Non directional IDMT PROTIN Relay operated	O/C relay-50A & tripping relay 86 operated	Tripped on feeder fault	-	Tripped due to fault on 33kV Tsebar feeder
2	SMVA Transformer-II, 132/22/11kV	132kV	Tripping	1/2/2022	10:47 hrs	1/2/2022	10:48 hrs	0	1	0.52	Non directional IDMT PROTIN Relay operated	Non dir/O/C relay-50A & tripping relay 86 operated	Tripped on feeder fault	-	Tripped due to fault on 33kV Tsebar feeder
3	SMVA Transformer-I, 132/22/11kV	132kV	Tripping	1/3/2022	03:12 hrs	1/3/2022	03:13 hrs	0	1	0.42	Non directional IDMT PROTIN Relay operated	O/C relay-50A & tripping relay 86 operated	Tripped due to feeder fault	-	Tripped due to fault on 33kV Tsebar feeder.
4	SMVA Transformer-II, 132/22/11kV	132kV	Tripping	1/3/2022	03:12 hrs	1/3/2022	03:14 hrs	0	2	0.25	Non directional IDMT PROTIN Relay operated	O/C relay-50A & tripping relay 86 operated	Tripped due to feeder fault	-	Tripped due to fault on 33kV Tsebar feeder.
5	Nangkor-Nganglam	132kV	Tripping	1/12/2022	08:14 hrs	1/12/2022	08:29 hrs	0	15	-14.4	MCOMP14DB & P442	Directional -O/C & E/F Relay: Start O CN, tripped O N.O.C start b-1, E/F1 start (N1)=12, trip (N1)=2 VAB=127.8kV, VBC=99.91kV, VCA=94.07kV, VAN=73.38kV, VBN=72.45kV, VCN=38.08kV, VN=0.01A-40.32A, IB=93.69A, IC=953.5A, INDerived=1.016A, IN measured=1.013KA & tripping relay 86 operated at our end. Distance relay: Start O CN, fault duration=203.4ms, relact trip time=0.005, fault location=44.14KM, IA=42.0A, IB=95.19A, IC=945.5A, VAN=73.54kV, VBN=72.87, VCN=38.31kV, fault resistance=5.824Ω, fault zone=Zone 3	Tripped on fault	-	Informed to BPSO, and charged as per their instruction.
6	SMVA Transformer-I, 132/22/11kV	132kV	Tripping	1/17/2022	09:00 hrs	1/17/2022	09:05 hrs	0	5	1.09	Non directional IDMT PROTIN Relay operated	O/C relay-50A & tripping relay 86 operated	Tripped due to feeder fault	-	Tripped due to fault on 33kV Wanrong feeder
7	SMVA Transformer-II, 132/22/11kV	132kV	Tripping	1/17/2022	09:00 hrs	1/17/2022	09:05 hrs	0	5	0.82	Non directional IDMT PROTIN Relay operated	O/C relay-50A & tripping relay 86 operated	Tripped due to feeder fault	-	Tripped due to fault on 33kV Wanrong feeder

Division: SMD-DEOTHANG		Substation: 132/33/11kV Nanglam Substation		Month: Jan-22											
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping		Normalization Time		Duration of Outage		MW before Outage (MW)	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time	(Hrs)	(Min)		Protection Relay Optd	Fault Details (As recorded by relay)			
132kV															
1	Tingthi-Nganglam	132kV	Tripping	12.01.2022	8:10	12.01.2022	8:25	0	15	-28.91	Micom relay P442	IA=122.4A, IB=243.1A, IC=1.232KA, Ph-CN Tripped ABC	Over Current	-	Supply restored after confirmation from BPSO and coordination to Tingthi end
2	3MVA Tr-II	132kV	Tripping	27.01.2022	14:58	27.01.2022	15:03	#REF!	5	0.752	O/C & E/F Microm relay		Due to 33kV Dechenling Feeder	-	Supply restored after isolating the 33kV Dechenling Feeder and withstood.

Division: SMD-DEOTHANG		Substation: 132/33kV Moranga Substation		Month: Jan-22											
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping		Normalization Time		Duration of Outage		MW before Outage (MW)	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time	(Hrs)	(Min)		Protection Relay Optd	Fault Details (As recorded by relay)			
132kV															
1	DML Factory Feeder	132kV	Tripping	1/7/2022	2:24:00 PM	1/7/2022	2:28:00 PM	0	4	0	86A & 86B OPTD			-	Charged the feeder with a charging code 1039 from BPSO
2	Droobang Feeder	132kV	Tripping	1/8/2022	12:05	1/8/2022	12:19	0	14	-24.62	86A & 86B OPTD			-	Charged the feeder with a charging code 1046 from BPSO
3	Rangia Feeder	132kV	Tripping	1/8/2022	12:05	1/9/2022	0:51	12	46	4.42			Y-Phase LA was punctured at Rangia end.	-	Charged the feeder with a charging code 1048 from BPSO(Bhutan), 817 from NLDG(India) and 4588 from ERLDC(India).
4	DML Factory Feeder	132kV	Tripping	1/15/2022	12:43:00 PM	15/1/2022	12:45:00 PM	0	2	0	86A & 86B OPTD			-	Charged the feeder with a charging code 1095 from BPSO

Division: SMD-DEOTHANG		Substation: 132/33kV Phuntshoang Substation		Month: Jan-22											
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping		Normalization Time		Duration of Outage		MW before Outage (MW)	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time	(Hrs)	(Min)		Protection Relay Optd	Fault Details (As recorded by relay)			
132/33kV Transformer-II (10MVA)															
1	132/33kV Transformer-II (10MVA)	132kV	Transient Fault	1/13/2022	16:03	1/13/2022	16:07		4	0.49	86A and 86B	(DPHLPDOCI) Trip value: L1: 3.6A, L2: 159.6 A, L3: 156.15 A, L4: 0.00 A.	er current and Earth fa	Unknown	Charged
132/33kV Transformer-I (10MVA)															
2	132/33kV Transformer-I (10MVA)	132kV	Transient Fault	1/26/2022	11:14	1/26/2022	11:17		3	0.23	86A and 86B	(DPHLPDOCI) Trip value: L1: 3.1A, L2: 323.4A, L3: 318.3 A, L4: 0.00 A.	er current and Earth fa	Unknown	Charged
132/33kV Transformer-II (10MVA)															
3	132/33kV Transformer-II (10MVA)	132kV	Trip On Fault	1/28/2022	8:30	1/28/2022	8:32		2	0.92	86A and 86B	(DPHLPDOCI) Trip value: L1: 68.1 A, L2: 2A, L3: 71.25A, L4: 0.00 A.	er current and Earth fa	Unknown	Charged

1. 400/220/132/33kV Jigmeling Substation															
Sl. No.	Date of Tripping	Time of Outages/ Time of Tripping	Date of Normalization	Time of Fault was Cleared	Duration of Outages (Hrs)	MW before Outage (MW)	Name of feeder	Name of the Substation/lines Affected by the Fault	Reasons of Fault	Relay Operations	Fault Location(KM)	Type of outages	Remarks		
1) 66kV Above															
1	26.01.2022	18:39 hrs	26.01.2022	18:47 hrs	0	36.52	132kV Tingthi	Tingthi	Main 1; Relay General Trip, B phase trip. Line loop B-G	SIPROTEC 7SA52	Distance: 42.8 km	Transient			
2. 220/66/33kV Dhajay Substation															
1) 66kV and above															
1	12.01.2022	05:38:20hrs	12.01.2022	05:51:32hrs		-16.96	Jigmeling feet Dhajay St o/c		Main-1=IA=1.76kA, IB=1.59kA, IC=1.57kA. main-2, Ia=0157.01A, II Tripped				feeder restored after a		

February 2022

MONTHLY OUTAGE REPORT FOR THE MONTH OF FEBRUARY, 2022 UNDER SMD DEOTHANG, TD, BPC.

Division: SMD-DEOTHANG		Substation: 132/33/11kV Karichu Substation		Month: Feb-22											
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping		Normalization Time		Duration of Outage		MW before Outage (MW)	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time	(Hrs)	(Min)		Protection Relay Optd	Fault Details (As recorded by relay)			
132kV Feeders															
1	132kV/Commer	132kV	Tripped	2/5/2022	12:43hrs	2/5/2022	12:50hrs	0	7	3.420	Nil	Nil	Tripped	-	Tripped from Karichu end
2	132kV Corlang	132kV	Tripped	2/5/2022	14:13hrs	2/7/2022	19:10 hrs	52	57	10.368	Distance protection relay	Start Phase: CN, Trip Phase: ABC, Distance: 4.342KM towards Corlang SS, IA=3.228A, IB=0.00A, IC=363.2A, Zone 1.	Tripped	-	Tripped due to heavy snowfall (conductor snapped at Korla Location KK 28 Y phase & K3 Y B phase)
3	132kV Corlang	132kV	Tripped	2/8/2022	14:29hrs	2/8/2022	18:12hrs	3	43	8.923	NA	Nil	Shutdown	Maintenance of CVT	Shutdown Taken by Corlang Incharge to Maintenance work for CVT
132kV															
1	SMVA Transformer - I	132kV	Tripped	09.02.2022	10:59	09.02.2022	11:08	0	9	1.992	NA	NA	Due to out going feeder(UDZORONG)	NA	Both SMVA transformer got tripped as line fault with Udorong feeder.
	SMVA Transformer - II	132kV	Tripped	09.02.2022	10:59	09.02.2022	11:08	0	9	1.932	NA	NA	Due to out going feeder(UDZORONG)	NA	Both SMVA transformer got tripped as line fault with Udorong feeder.
2	132kV Corlang	132kV	Tripped	21.02.2022	2:20	21.02.2022	2:44	0	24	-4.248	NA	NA	Grid fail from Karichu	NA	Grid fail from Karichu
	SMVA Transformer - I	132kV	Tripped	22.02.2022	7:45	22.02.2022	9:08	1	23	2.271	NA	NA	Due to out going feeder(UDZORONG)	NA	SMVA transformer I got tripped as line fault with Udorong feeder. Tripping coil burned and replaced



Transmission System Performance Report

First Quarterly Report-2022

Division: SMD-DEOTHANG		Substation: 132/33/11kV Nangkor Substation		Month: Feb-22												
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping		Normalization Time		Duration of Outage (Hrs)	Duration of Outage (Min)	MW before Outage (MW)	Protection Relay Optd	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time					Fault Details (As recorded by relay)				
132kV Feeders																
1	Nangkor-Deothang Line	132kV	Tripping	21/2/2022	15:26 hrs	21/2/2022	15:37 hrs	0	10	16.7	MICOMPI4DB & Distance relay	Directional -OC & EF Relay: Start 0 BN, tripped 0 N.O.C start I-1, E/F start IN1-12, trip IN1-2 VAB=82.38kV, VBC=82.52kV, VCA=126.14kV, VAN=68.89kV, VBN=19.78kV, VCN=73.9 kV, VN=0.01A-49.35A, IB=1.067KA, IC=96.93A, IN Derived=11.01KA, IN measured=1.01KA & tripping relay 86 operated at our end. Distance relay: Start 0 BN, fault duration=209.8ms, relay trip time=0.000, fault location=36.69KM, IA=50.40A, IB=1.070KA, IC=1.007A, VAN=66.55kV, VBN=33.88kV, VCN=66.29kV, fault resistance=1.011Ω, fault zone=Zone 3.		Tripped on feeder fault	-	Informed to BPSO, and charged the feeder as per their instruction.
2	SMVA Transformer-I, 132/22/11kV	132kV	Tripping	2/4/2022	19:06 hrs	2/4/2022	19:11 hrs	0	5	1.3	Non directional IDMT PROTIN Relay operated	O/C relay-50A & tripping relay 86 operated		Tripped on feeder fault	-	Tripped due to fault on 33kV Wamrong feeder
3	SMVA Transformer-I, 132/22/11kV	132kV	Tripping	2/5/2022	07:32 hrs	2/5/2022	07:36 hrs	0	4	0.78	Non directional IDMT PROTIN Relay operated	Non dir O/C relay-50A & tripping relay 86 operated		Tripped on feeder fault	-	Tripped due to fault on 33kV Wamrong feeder
4	SMVA Transformer-II, 132/22/11kV	132kV	Tripping	2/5/2022	07:32 hrs	2/5/2022	07:35 hrs	0	3	0.55	Non directional IDMT PROTIN Relay operated	O/C relay-50A & tripping relay 86 operated		Tripped due to feeder fault	-	Tripped due to fault on 33kV Wamrong feeder.
5	SMVA Transformer-I, 132/22/11kV	132kV	Tripping	2/5/2022	08:53 hrs	2/5/2022	08:56 hrs	0	3	0.47	Non directional IDMT PROTIN Relay operated	O/C relay-50A & tripping relay 86 operated		Tripped due to feeder fault	-	Tripped while test charging Wamrong feeder
6	SMVA Transformer-II, 132/22/11kV	132kV	Tripping	2/5/2022	08:53 hrs	2/5/2022	08:55 hrs	0	2	0.58	Non directional IDMT PROTIN Relay operated	O/C relay-50A & tripping relay 86 operated		Tripped due to feeder fault	-	Tripped while test charging Wamrong feeder
7	SMVA Transformer-I, 132/22/11kV	132kV	Tripping	2/5/2022	10:21 hrs	2/5/2022	10:23 hrs	0	2	0.99	Non directional IDMT PROTIN Relay operated	O/C relay-50A & tripping relay 86 operated		Tripped due to feeder fault	-	Tripped while due to fault on Teobar feeder
8	SMVA Transformer-II, 132/22/11kV	132kV	Tripping	2/5/2022	10:21 hrs	2/5/2022	10:22 hrs	0	1	1.25	Non directional IDMT PROTIN Relay operated	O/C relay-50A & tripping relay 86 operated		Tripped due to feeder fault	-	Tripped while due to fault on Teobar feeder
9	SMVA Transformer-II, 132/22/11kV	132kV	Tripping	2/5/2022	15:32 hrs	2/5/2022	15:35 hrs	0	3	1.09	Non directional IDMT PROTIN Relay operated	O/C relay-50A & tripping relay 86 operated		Tripped due to feeder fault	-	Tripped while test charging Wamrong feeder
10	Nangkor-Nanglam	132kV	Tripping	2/6/2022	06:46 hrs	2/6/2022	06:53 hrs	0	7	-12.45	MICOMPI4DB	Directional -OC & EF Relay: Tripped 0 N: Start 0 AN.O.C start I-1, E/F start IN1-12, trip IN1-2 VAB=104.5kV, VBC=133.48kV, VCA=107.18kV, VAN=47.16kV, VBN=75.89kV, VCN=74.7 kV, VN=0.01A-400.3A, IB=89.91KA, IC=37.20A, IN Derived=565.0A, IN measured=565.1A & tripping relay 86 operated at our end.		Tripped on feeder fault	-	Informed to BPSO, and charged as per their instruction.
11	SMVA Transformer-II, 132/22/11kV	132kV	Tripping	2/6/2022	16:05 hrs	2/6/2022	16:07 hrs	0	2	0.86	Non directional IDMT PROTIN Relay operated	O/C relay-50A & tripping relay 86 operated		Tripped due to feeder fault	-	Tripped while test charging Wamrong feeder
12	SMVA Transformer-II, 132/22/11kV	132kV	Tripping	2/20/2022	17:37 hrs	2/20/2022	17:55 hrs	0	8	1.49	Non directional IDMT PROTIN Relay operated	O/C relay-50A & tripping relay 86 operated		Tripped due to feeder fault	-	Tripped due to fault on 33kV Wamrong, Yurung & Nanang feeders
14	Main Grid/Rangja Grid	132kV	Tripping	2/21/2022	02:22 hrs	2/21/2022	02:45 hrs	0	23	7.1	-	-		-	-	Supply failed from Rangja Substation
15	Nangkor-Nanglam Line	132kV	Tripping	2/25/2022	16:17 hrs	2/25/2022	16:30 hrs	0	13	-7.22	MICOMPI4DB & Distance Relay	Directional -OC & EF Relay: Tripped 0 N: Start 0 BCN.O.C start I-1, E/F start IN1-12, trip IN1-2 VAB=108.8kV, VBC=69.78kV, VCA=105.8kV, VAN=74.6kV, VBN=43.78kV, VCN=44.14 kV, VN=0.01A-29.96A, IB=85.2A, IC=828.2A, IN Derived=92.4A, IN measured=92.1A & tripping relay 86 operated at our end. Distance relay Indication: Start 0 BC, TOC start, Tripped Elerts-No, Fault alarm No, fault duration=136.9ms, relay trip time=0.00, IA=31.25A, IB=860.2A, IC=851.7A, VAN=74.62kV, VBN=43.88kV, VCN=44.07kV, fault zone=none.		Tripped on feeder fault	-	Informed to BPSO, and charged the feeder as per their instruction.

Division: SMD-DEOTHANG		Substation: 132/33/11kV Nanglam Substation		Month: Feb-22												
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping		Normalization Time		Duration of Outage (Hrs)	Duration of Outage (Min)	MW before Outage (MW)	Protection Relay Optd	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time					Fault Details (As recorded by relay)				
132kV																
2	Nanglam-Tingbi	132kV	Tripping	05.02.2022	15:13	05.02.2022	15:49	0	36	-24.46	Micom relay P442	IA= 15.77A IB= 1.314KA IC= 1.328A Tripped on Zone 1 Fault Location 28.20km		Over Current	-	Supply normalised with vide Closing code# 1221 issued by Madam Tshering Choden, BPSO
3	Nanglam-Tingbi	132kV	Tripping	06.02.2022	06:49	07.02.2022	19:09	36	20	-18.74	Micom relay P442	IA= 743.7A IB= 90.39A IC= 136.1A IN= 833.4ATripped on Zone 3 Fault Location 297.19km		Earth Fault/Conductor Snapped	-	Feeder Test charged at 07:00hrs from our end as per BPSO instruction with vide closing code# 1227 issued by Madam Karma Yangdon, BPSO but Tingbi end observed one phase is missing at their end (R-PH) and around we received a call saying that conductor is Snapped at Pathang site and immediately the CB was hand tripped from our end and informed to BPSO. The supply was normalised after completing the restringing of Conductor with vide closing code# 1238 issued by Madam Choden
5	SMVA Transformer	132kV	Tripping	20.02.2022	19:32	20.02.2022	19:39	6	6	1.427	-	Tripped due to 33kV Pathang feeder fault		Earth Fault	-	-
6	Nangkor-Nanglam	132kV	Grid Fail	21.02.2022	02:22	21.02.2022	02:45	0	23	-	NA	NA		Grid Fail	-	Grid fail from Nangkor end since the station is feeds from single source as Nanglam-Tingbi feeder is under shutdown

Division: SMD-DEOTHANG		Substation: 132/33kV Mtshang Substation		Month: Feb-22												
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping		Normalization Time		Duration of Outage (Hrs)	Duration of Outage (Min)	MW before Outage (MW)	Protection Relay Optd	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time					Fault Details (As recorded by relay)				
1	Deothang Feeder	132kV	Tripping	2/2/2022	5:29:00 PM	2/2/2022	15:39:00 PM	0	10	-15.47	OC on B-phase, EF, 86 A & B operated	-		transient fault	-	-
2	Rangja Feeder	132kV	Tripping	2/2/2022	5:29:00 PM	2/2/2022	15:59:00 PM	0	30	-12.09	OC/EF and 86A/B operated	-		transient fault	-	Charged the feeder with a charging code 1089 from BPSO(Bhutan), NLDC(India) 52 and NERLDC(India) 28
3	DML Factory Feeder	132kV	Tripping	2/2/2022	5:29:00 PM	2/2/2022	19:50:00 PM	4	21	0	86A & 86B OPTD	-		transient fault	-	Charged from BPSO instruction verbally.
4	DML Factory Feeder	132kV	Tripping	2/3/2022	11:22:00 PM	2/3/2022	21:27:00 PM	0	5	0	OC/EF	-		transient fault	-	Charged from BPSO instruction verbally.
5	15 MVA, TR-I(HV)	132/33kV	Tripping	2/5/2022	8:02:00AM	2/5/2022	8:17:00AM	0	15	0	90/51 OC SEP	-		transient fault	-	-
6	15 MVA, TR-I(LV)	132/33kV	Tripping	2/5/2022	8:02:00AM	2/5/2022	8:18:00AM	0	16	0	86A & 86B OPTD	-		transient fault	-	-
7	33kV Azisa feeder	33kV	Tripping	2/5/2022	8:22:00AM	2/5/2022	7:41:00AM	1	19	0	-	-		transient fault	-	-
8	15 MVA, TR-I(HV)	132/33kV	Tripping	2/5/2022	8:26:00AM	2/5/2022	8:34:00AM	0	8	0	-	-		transient fault	-	-
9	15 MVA, TR-I(LV)	132/33kV	Tripping	2/5/2022	8:26:00AM	2/5/2022	8:36:00AM	0	10	0	86A & 86B OPTD	-		transient fault	-	-
10	33kV Azisa feeder	33kV	Tripping	2/5/2022	8:26:00AM	2/5/2022	9:56:00AM	1	30	0	-	-		transient fault	-	-
11	33kV Azisa feeder	33kV	Tripping	2/5/2022	8:58:00AM	2/5/2022	10:28:00AM	0	20	0	-	-		transient fault	-	-
12	15 MVA, TR-I(HV)	132/33kV	Tripping	2/5/2022	08:58:00AM	2/5/2022	10:38:00AM	0	10	0	-	-		transient fault	-	-
13	15 MVA, TR-I(LV)	132/33kV	Tripping	2/5/2022	08:58:00AM	2/5/2022	10:40:00AM	0	12	0	-	-		transient fault	-	-
14	33kV Azisa feeder	33kV	Tripping	2/5/2022	08:58:00AM	2/5/2022	11:05:00AM	0	37	0	-	-		transient fault	-	-
15	DML Factory Feeder	132kV	Tripping	2/6/2022	23:39	6/2/2022	20:02	8	23	0	86A & 86B OPTD	-		transient fault	-	Charged the feeder with a charging code 1228 from BPSO. Feeder kept shutdown as per BPSO instruction
16	Rangja Feeder	132kV	Tripping	2/21/2022	14:22	6/2/2022	14:44	0	22	-17.12	86A & 86B OPTD	OC & EF		transient fault	-	Charged the feeder with a charging code 1231(BPSO), 2154(NLDC), 1447(NERLDC). Feeder kept shutdown.
17	15 MVA, TR-I(LV)	132/33kV	Tripping	2/21/2022	14:22	6/2/2022	14:48	0	26	0.03	-	OC & EF		transient fault	-	-
18	Rangja Feeder	132kV	Tripping	2/25/2022	19:01	2/25/2022	19:23	0	22	-0.27	86A & 86B OPTD	OC & EF		transient fault	-	Charged the feeder with a charging code 1258(BPSO), 2644(NLDC), 1780(NERLDC).

Division: SMD-DEOTHANG		Substation: 132/33kV Corhang Substation		Month: Feb-22												
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping		Normalization Time		Duration of Outage (Hrs)	Duration of Outage (Min)	MW before Outage (MW)	Protection Relay Optd	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time					Fault Details (As recorded by relay)				
7	132 kV Khikhar-Corhang Feeder	132 kV	Trip on fault	05.02.2022	12:29 hrs	05.02.2022	12:58 hrs	0	29	-11.530	Distance Relay (P442)	Distance Relay (P442) operated on Zone 1 trip. Recorded fault values: Started phase-BC, Tripped phase-ACB, fault duration=49.97 ms, relay trip time=79.79ms, fault location=33.35 km, IA=39.096A, IB=497.4A, IC=556.3A, VAN=75.12 kV, VBN=39.16kV, VCN=37.25 kV		transient fault	-	Informed to BPSO, and charged as per their instruction.
8	132 kV Khikhar-Corhang Feeder	133 kV	Trip on fault	05.02.2023	14:11 hrs	07.02.2022	19:07 hrs	28	56	-9.930	Distance Relay (P442) and Backup Relay (P14D)	Distance Relay (P442) operated on Zone 1 trip. Recorded fault values: Started phase-BN, Tripped phase-B, fault duration=49.97 ms, relay trip time=79.95ms, fault location=28.89 km, IA=25.46A, IB=606.6A, IC=43.16A, VAN=74.44 kV, VBN=14.65kV, VCN=77.39 kV. Backup Relay (P14D): Started phase-BN, OC started I-1, E/F start IN1-1 IA=25.01A, IB=595.5 A, IC=44.80 A, VAB=84.71kV, VBC=82.07 kV, VCA=133.0 kV, IN=881.1 A, VAN=74.22kV, VBN=14.53 kV, VCN=77.18 kV, VN=58.54 kV.		transient fault	-	Conductor snapped in between location KK-28 & KK-29 and in between Location no. KK-30 & KK-31

Division: SMD-DEOTHANG		Substation: 132/33kV Phumthong Substation		Month: Feb-22												
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping		Normalization Time		Duration of Outage (Hrs)	Duration of Outage (Min)	MW before Outage (MW)	Protection Relay Optd	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Remarks
				Date	Time	Date	Time					Fault Details (As recorded by relay)				
5	132/33kV Transformer-I (10MVA)	132kV	Transient fault	2/5/2022	1:56	2/5/2022	2:00	0	4	0.14	86A and 86B	(DPHLPDOCI) Trip value: L1: 6A, L2: 65.55A, L3: 65.4 A, L4: 0.00 A.		Over current and Earth fault	Unknown	Charged
10	132/33kV Transformer-II (10MVA)	132kV	Transient fault	2/5/2022	19:27	2/5/2022	19:40	0	13	0.63	86A and 86B	(DPHLPDOCI) Trip value: L1: 331.8A, L2: 340.5A, L3: 672.6A, L4: 0.00 A.		Over current	Unknown	Charged

1. 400/220/132/33kV Jigmeling Substation																
Sl. No.	Date of Tripping	Time of Outages/ Time of Tripping	Date of Normalization	Time of Fault was Cleared	Duration of Outages (Hrs)	MW before Outage (MW)	Name of the Substation/Lines Affected by the Fault	Reasons of Fault	Relay Operations	Fault Location(KM)	Type of outages	Remarks				
ii) 66kV & Above																
1	08.02.2022	14:35 hrs	08.02.2022	15:37 hrs	1	-26.09	400kV Alipurduar line 1	Alipurduar r SS	DTT	7SA52 & 7SA611						
2	08.02.2022	16:59 hrs				-25.6	400kV Alipurduar line 1	Alipurduar r SS	DTT	7SA52 & 7SA612						
3	16.02.2022	20:31 hrs	16.02.2022	21:08 hrs	0	73.45	400kV Alipurduar line 2	Alipurduar r SS	DTT	7SA52 & 7SA613						
4	17.06.2022	13:00 hrs				59.47	400kV Alipurduar line 2	Alipurduar r SS	DTT trip on L123	7SA52 & 7SA614						
NO TRIPPING																
4. 132/33kV Tintibi Substation																
ii) 66kV & Above																
1	2/5/2022	15:18	2/5/2022	15:52	0	24.77	132kV Tingtibi-Nanglam fdr Line	132kV Tingtibi-manglam	Temporary fault	Distance protection relay:Start phase:BCN,Trip Phase:ABC,Zone-1,Fault Location:31.62Km.	31.62KM	Temporary				
2	2/6/2022	6:49	2/7/2022	19:08	0	19.08	132kV Tingtibi-Nanglam fdr Line	132kV Tingtibi-manglam	Conductor snped at TN-63&64	Distance protection relay:Start phase:AN,Trip Phase:ABC,Zone-1,Fault Location:11.45Km.	11.45	Line fault				



Transmission System Performance Report

First Quarterly Report-2022

For March 2022

MONTHLY OUTAGE REPORT FOR THE MONTH OF MARCH 2022 UNDER SMD DEOTHANG, TD, BPC.

SMD DEOTHANG 132/33/11kV Kalkhor Substation Mar-22																
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shutdown/Tripping)	Shutdown/Tripping Time		Normalization Time		Duration of Outage		MW before Outage (MW)	Protection Relay Ojtd	Tripping Details Fault Details (As recorded by relay)	Type/Cause of Fault	Reason for Shutdown	Weather Condition during the Outage	Remarks
				Date	Time	Date	Time	(Hrs)	(Min)							
132kV Feeders																
1	Corbung	132	Tripped	3/24/2022	14:50 hrs	3/24/2022	14:58 hrs	8	12.456	86	Relay Trip 80.27ms Fault duration 55.19ms IA 25.89A IB 14.00AC 28.16A VAN 75.42kV VBN 78.41kV VCN 78.47kV Fault record Broken conductor	Transit Fault	NA	Clear	Tripped on OC and E/F (Transit Fault)	
<div style="text-align: center;"> SMD DEOTHANG 132/33/11kV Nangkor Substation Mar-22 </div>																
1	SMVA Transformer-I 132/22/11kV	132kV	Tripping	3/14/2022	07:25 hrs	3/14/2022	07:30 hrs	0	5	0.61	Non directional IDMT PROTIN Relay operated	Tripped on feeder fault	-	Clear	Tripped due to fault on 33kV Warrong feeder	
2	SMVA Transformer-II 132/22/11kV	132kV	Tripping	3/14/2022	07:25 hrs	3/14/2022	07:27 hrs	0	2	0.43	Non directional IDMT PROTIN Relay operated	Tripped on feeder fault	-	Heavy Rainfall	Tripped due to fault on 33kV Warrong feeder.	
3	Nangkor-Deothang	132kV	Tripping	3/24/2022	12:40 hrs	3/24/2022	12:48 hrs	0	8	21.7	MCOMP14DB Directional -OC & E/F Relay: Tripped 0 N: Start 0 CNOC start 1-1, E/F1 start IN1-12, trip IN1-2, VAB=132.2kV, VBC=128.3kV, VCA=109.4kV, VAN=74.48kV, VBN=76.28kV, VCN=63.96kV, IA=123.0A, IB=121.4A, IC=538.8A, ID=derived=44.5A, IN measured=44.5A & tripping relay 86 operated at our end.	Tripped on fault	-	Cloudy & Windy	Informed to BPSO, Through & charged the feeder as per their instruction.	
<div style="text-align: center;"> SMD DEOTHANG 132/33/11kV Deothang Substation Mar-22 </div>																
1	Deothang-Nangkor line	132kV	Tripped	24/03/2022	12:40	24/03/2022	12:48	0	8	-32.868	OC and E/F at Nangkor end	Grid fail	NA	Windy	At our end the breaker condition was in normal.	
2	Deothang-Montanga line	132kV	Tripped	24/03/2022	12:40	24/03/2022	12:45	0	6	30.88	OC at Montanga end	Grid fail	NA	Windy	At our end the breaker condition was in normal.	
<div style="text-align: center;"> SMD DEOTHANG 132/33/11kV Nanglam Substation Mar-22 </div>																
1	Nanglam-Tingthi	132kV	Tripping	14/03/2022	5:04	14/03/2022	12:38	7	34	-10.82	Mcom relay P442	Over Current: Dis-Instants: Punctured at Tingthi Substation	Sunny	Supply restored after coordination to Tingthi end as per closing code 1307 issued by Madam Karun Choudh, BPSO.		
2	Nanglam-Montanga	132kV	Tripping	28/03/2022	15:49	-	-	-	-	-	-	Over current and earth fault relay operated	Clear	Line Test charging as per the BPSO Closing code# 1362 issued by Madam Karun Datta.		
<div style="text-align: center;"> SMD DEOTHANG 132/33kV Montanga Substation Mar-22 </div>																
1	Deothang Feeder	132kV	Tripping	3/24/2022	12:40	3/24/2022	12:45	0	5	-11.89	OC, 86 A & B operated.	transient fault	-	Sunny	the feeder was charged after obtaining the verbal instruction from BPSO.	
2	Rangja Feeder	132kV	Tripping	3/24/2022	13:09:00 pm	3/24/2022	14:11:00 pm	1	2	2.45	OC, 86 A & B operated.	transient fault	-	Normal	Charged the feeder with a charging code 1346 from BPSO(Bhatnagar, NLDC(India) 1788 and NERL (CC)India) 3588	
3	15 MVA, TR-I(HV)	132/33kV	Tripping	3/25/2022	17:08:00 PM	3/25/2022	17:10:00 PM	0	2	0.19	86A & 86B OPTD	OC, 86 A & B operated, REF protection trip, 50S1 tripped REF 615 protection trip	transient fault	-	Normal	Charged from BPSO instruction verbally.
4	15 MVA, TR-II(HV)	132/33kV	Tripping	3/26/2022	0:29	3/26/2022	0:31	0	2	0.09	OC, 86A & 86B OPTD	over current and earth fault relay operated	transient fault	-	Rainy	Charged from BPSO instruction verbally.
5	15 MVA, TR-III(HV)	132/33kV	Tripping	3/30/2022	9:35:00AM	3/30/2022	9:41:00AM	0	6	0.21	86A & 86B OPTD	OC & E/F	transient fault	-	Rainy	Transformer charged after verbal clearance from BPSO.
<div style="text-align: center;"> SMD DEOTHANG 132/33kV Corbung Substation Mar-22 </div>																
5	132 LV, 10 MVA Transformer-I	132/33 kV	Tripping	07/03/2022	22:07 hrs	07/03/2022	22:19 hrs	0	12	0.980	Differential Relay (P643) and 86 A & 86B	Started Phase BC, Tripped phase BC, Diff protection Start, Diff protection bias trip, Restricted EF start REF-LV, Restricted EF Trip REF-LV, Fault type Internal, System frequency 50.08, Fault duration 75.00ms, CB operated Time 65.00 ms, Relay Trip time 5.00 ms, IA-1 magnitude 5.219A, IB-1 magnitude 230.6 A, IC-1 magnitude 226.9 A, IA-2 magnitude 0.00 A, IB-2 magnitude 0.00 A, IC-2 magnitude 0.00 A, IA-3 magnitude 20.75 A, IB-3 magnitude 15.29 A, IC-3 magnitude 7.642 A, IA-HV magnitude 5.219 A, IB-HV magnitude 230.6 A, IC-HV magnitude 226.9 A, IA-LV magnitude 20.75 A, IB-LV magnitude 15.29 A, IC-LV magnitude 7.642 A, ID-HV magnitude 133.2 A, ID-LV magnitude 5.785 A, IN-HV measured mag 1.618 A, IN-LV measured mag 236.0 A, VAN magnitude 0.00 V, VBN 0.00 V, VCN 0.00V, V magnitude 130.3kV, V1 magnitude 0.00V, V2 magnitude 0.00 V, VN derived mag 0.00 V, VAB magnitude 0.00 V, VBC magnitude 0.00 V, VCA magnitude 0.00 V, IA diff 0.005PU, IB diff 5.246 PU, IC diff 5.265 PU, IA bias 0.116 PU, IB bias 2.668 PU, IC bias 2.632 PU, REF LV REF DIF 166.3 A.	Transient fault	Clear	Test Charge was done stand	
<div style="text-align: center;"> SMD DEOTHANG 132/33kV Phantothang Substation Mar-22 </div>																
1	132/33kV Transformer-II (10MVA)	132kV	Transient fault	3/1/2022	7:59	3/1/2022	8:01	2	0.97	86A and 86B	(DPHLPDOCI) Trip value; LI: 4.05A, L2: 148.2A, L3: 144.15A, La0.00 A.	Over current and Earth fault	Unknown	Sunny	Charged	
6	132/33kV Transformer-II (10MVA)	132kV	Transient fault	3/1/2022	8:42	3/1/2022	8:44	2	0.71	86A and 86B	(DPHLPDOCI) Trip value; LI: 232.2A, L2: 112.65A, L3: 119.55A, La0.00 A.	Over current	Unknown	Sunny	Charged	
9	132/33kV Transformer-I (10MVA)	132kV	Transient fault	3/13/2022	5:50	3/13/2022	5:55	5	0.17	86A and 86B	(DPHLPDOCI) Trip value; LI: 158.1A, L2: 2A, L3: 159.3A, La0.00 A.	Over current and Earth fault	Unknown	clear	Charged	
24	132/33kV Transformer-II (10MVA)	132kV	Transient fault	3/24/2022	19:47	3/24/2022	19:50	3	1.20	86A and 86B	(DPHLPDOCI) Trip value; LI: 171.15A, L2: 179.7A, L3: 351A, La0.00A.	Over current	Unknown	clear	Charged	
27	132/33kV Transformer-II (10MVA)	132kV	Transient fault	3/24/2022	19:57	3/24/2022	20:00	3	1.2	86A and 86B	(DPHLPDOCI) Trip value; LI: 165.9A, L2: 173.7A, L3: 339.75A, La0.00A.	Over current	Unknown	clear	Charged	
34	132/33kV Transformer-I (10MVA)	132kV	Transient fault	3/25/2022	14:57	3/25/2022	14:59	2	0.26	86A and 86B	(DPHLPDOCI) Trip value; LI: 59.4A, L2: 135.15A, L3: 104.1A, La0.00 A.	Over current and Earth fault	Unknown	Rainy	Charged	
37	132/33kV Transformer-I (10MVA)	132kV	Transient fault	3/25/2022	15:29	3/25/2022	15:32	3	0.22	86A and 86B	(DPHLPDOCI) Trip value; LI: 128.85A, L2: 127.65A, L3: 135A, La0.00 A.	Over current and Earth fault	Unknown	Rainy	Charged	
40	132/33kV Transformer-II (10MVA)	132kV	Transient fault	3/25/2022	16:35	3/25/2022	16:39	4	0.26	86A and 86B	(DPHLPDOCI) Trip value; LI: 171.15A, L2: 179.7A, L3: 351A, La0.00A.	Over current	Unknown	Rainy	Charged	
43	132/33kV Transformer-II (10MVA)	132kV	Transient fault	3/25/2022	19:27	3/25/2022	19:30	3	0.69	86A and 86B	(DPHLPDOCI) Trip value; LI: 168.75A, L2: 175.35A, L3: 344.4A, La0.00A.	Over current	Unknown	Rainy	Charged	
46	132/33kV Transformer-II (10MVA)	132kV	Transient fault	3/26/2022	7:39	3/26/2022	7:42	3	0.57	86A and 86B	(DPHLPDOCI) Trip value; LI: 168.75A, L2: 175.35A, L3: 344.4A, La0.00A.	Earth Fault	Unknown	Sunny	Charged	

1. 400/220/132/33kV Jigmeling Substation

Sl. No.	Date of Tripping	Time of Outages/ Time of Tripping	Date of Normalization	Time of Fault was Cleared	Duration of Outages (Hrs)	MW before Outage (MW)	Name of feeder	Name of the Substation/lines Affected by the Fault	Reasons of Fault	Relay Operations	Fault Location(KM)	Type of outages	Remarks
66kV Above													
1	08.02.2022	14:35 hrs	08.02.2022	15:37 hrs	1	-26.09	400kV Alipurdhar line 1	Alipurdhar	DTT	7SA52 & 7SA611			
2	08.02.2022	16:59 hrs				-25.6	400kV Alipurdhar line 1	Alipurdhar	DTT	7SA52 & 7SA612			
3	16.02.2022	20:31 hrs	16.02.2022	21:08 hrs	0	73.45	400kV Alipurdhar line 2	Alipurdhar	DTT	7SA52 & 7SA613			
4	17.06.2022	13:00 hrs				59.47	400kV Alipurdhar line 2	Alipurdhar	DTT trip on L123	7SA52 & 7SA614			

4. 132/33kV Tintibi Substation

66kV & Above													
Sl. No.	Date of Tripping	Time of Outages/ Time of Tripping	Date of Normalization	Time of Fault was Cleared	Duration of Outages (Hrs)	MW before Outage (MW)	Name of feeder	Name of the Substation/lines Affected by the Fault	Reasons of Fault	Relay Operations	Fault Location(KM)	Type of outages	Remarks
1	2/5/2022	15:18	2/5/2022	15:52	0	24.77	132kV Tingtibi-Nanglam fdr Line	132kV Tingtibi-Nanglam fdr Line	Temporary fault	Distance protection relay: Start phase: BC, Trip Phase: ABC, Zone-1, Fault Location: 31.62Km	31.62KM	Temporary	
2	2/6/2022	6:49	2/7/2022	19:08	0	19.08	132kV Tingtibi-Nanglam fdr Line	132kV Tingtibi-Nanglam fdr Line	Conductor snapped at TN-63A64	Distance protection relay: Start phase: AN, Trip Phase: ABC, Zone-1, Fault Location: 11.45Km	11.45	Line fault	



Transmission System Performance Report

First Quarterly Report-2022

Annexure-VI

Western grid Outages for January 2022

Sl No.	Date of Tripping	Time of outages	Date of Normalization	Time of fault was cleared	Duration of Outages (Hrs)	MW before outage (MW)	Feeder Name	Name of the Substation/lines affected by the fault	Reasons of fault	Relay operations	Exact location of fault [Line segment/ Substation]	Type of outages	Remarks
(B) 66/33/11 kV Phuntsholing Substation													
1	06.01.2022	9:24	06.01.2022	11:16	1	0.66	5MVA TRF 66/11kV	5MVATRF 66/11kV	BUCH Trip	OLTC BUCH Trip, Tripping relay 86	Substation	Tripped on Fault	At 09:19hrs 5MVA transformer (66/11kV) got tripped on OLTC BUCH. Couldn't reset the relay and informed to Rinchen Zangmo, Sr.Engineer regarding above fault. Issued shutdown with work permit no.339 for carrying out physical inspection. Released gas and cleaned contact parts. At 11:16hrs normalised the transformer.
(D) 66/33/11kV Lobysa Substation													
66kV LSA - Basochu feeder													
1	28.01.2022	12:32hrs	28.01.2022	12:49hrs	0	-21.580	66kV LSA - Basochu feeder			86 relay operated			66kV LSA - Basochu feeder got tripped at 12:32hrs and charged the line as per BPSO at 12:49hrs and breaker towards hand tripped as per BPSO at 12:48hrs.
2	28.01.2022	13:03hrs	28.01.2022	13:11hrs	0	-6.840	66kV LSA - Basochu feeder			NA			66kV LSA - Basochu feeder got tripped at 13:03hrs without any relay & breaker operation at our end and supply resumed at 13:11hrs from Basochu and supply extended to Daochula at 13:14hrs as per BPSO.
66kV LSA - Dochula feeder													
1	28.01.2022	12:48hrs	28.01.2022	13:14hrs	0	15.190	66kV LSA - Dochula feeder			NA			66kV LSA - Dochula feeder hand tripped as per BPSO at 12:48hrs and charged the feeder at 13:14hrs.
(G) 66/33/11kV Dechencholing substation													
1	26.01.2022	14:40hrs	26.01.2022	14:44hrs	0	-33.98	66kV Semtokha IC	whole s/s fdr.	Supply failed from source.				
2	28.01.2022	12:36hrs	28.01.2022	12:50hrs	0	-33.54		whole s/s fdr.	Supply failed from source.				
3	29.01.2022	07:58hrs	29.01.2022	08:16hrs	0	3.642	66kV Damji line	Damji line	Transcend fault	86A, 86B, Dist prn, 3phase, Zone-I & Soft/Tor trip.	Distance not shown	tripped	
(H) 66/11kV Haa Substation													
1	27.01.2022	9:20hrs					66/11kV 5MVA transformer - II	66/11kV 5MVA transformer - II	Oil leakage from the 11kV terminal box of Y phase.	Bhuloz relay	Haa ss		Bhuloz relay was operated due to low oil level in the conservator tank of 66/11kV 5MVA transformer - ii and also oil leakage from the terminal box of LV line of transformer. The same was informed to maintenance head SMD, Semtokha for necessary action. Due to lockdown the work couldn't be proceeded further, till then the supply was fed from 5MVA transformer - I. Source fail from Chukha power house, normalised the supply from the source.
(I) 220kV Substation Semtokha													
1	28.01.2022	12:34hrs	28.01.2022	12:49hrs		-63.150	220kV Sem-CHP	Semtokha Substation	CB tripped at CHP end while doing test charge				Transient
2	28.01.2022	12:32hrs	28.01.2022	14:16hrs	25	-63.58	220kV Sem-BHP	220kV SEM-BHP Line	Fault Loop= L1-N	Main-1&2 Trip, fault loop- L1-N (Ia=2.39KA, Ib=222.5A, Ic=130.1A)	Distance=5.2KM		Permanent
3	25.01.2022	12:08hrs	25.01.2022	12:12hrs		34.69	66kV Sem-Dling Line	66kV Sem-Dling Line	Broken Conductor	Distance Prn. Optd. BRC Tr			Transient
4	26.01.2022	14:39hrs	26.01.2022	14:44hrs		34.69	66kV Sem-Dling Line	66kV Sem-Dling Line	Broken Conductor	Distance Prn. Optd. BRC Tr			Transient
(K) 66/33kV Changidaphu Substation													
1	28.01.2022	12:34hrs	28.01.2022	13:03hrs		-3.95	66kV Changidaphu - Olakhaline	66kV Changidaphu - Olakhaline	Grid failed	Dist. Prm. Optd. Zone-1, Rph trip			Transient
(L) 66/33kV Damji Substation													
1	25.01.2022	12:07 hrs	25.01.2022	12:13 hrs	0	-3.24	66 kV Incoming Line	Whole Substation	Trip	NA			Line trip from Semtokha Substation
2	26.01.2022	14:40 hrs	26.01.2022	14:45 hrs	0	-1.19	66 kV Incoming Line	Whole Substation	Trip	NA			Line trip from Semtokha Substation
3	29.01.2022	07:53 hrs	29.01.2022	08:19 hrs	0	-3.01	66 kV Incoming Line	Whole Substation	Trip	NA			Line trip from Dechencholing Substation
(M) 66/11kV Dochula Substation													
1	28/1/2022	12.36	28/1/2022	12.53	0		86 relay	Source Fail from Chukha & Basochu	Line fault between semtokha to Rurichu	Temporary fault			While charging the Rurichu line from semtokha Chukha got tripped due to the line fault in between Semtokha to Rurichu.
2	28/1/2022	12.36	28/1/2022	12.58	0		86 relay	Source Fail from Chukha & Basochu	Line fault between semtokha to Rurichu	Temporary fault			

February 2022

Sl No.	Date of Tripping	Time of outages	Date of Normalization	Time of fault was cleared	Duration of Outages (Hrs)	MW before outage (MW)	Feeder Name	Name of the Substation/lines affected by the fault	Reasons of fault	Relay operations	Exact location of fault [Line segment/ Substation]	Type of outages	Remarks
(A) 400/220/66/11 kV Malbase Substation													
66kV & Above													
1	01.02.2022	16:59	01.02.2022	17:05	0	48	220kV Chukha Feeder	Malbase Substation	overcurrent on R phase.	Distance Zone 1, AR operated.	9.4929 km	Overcurrent Outage	IL1=5.566kA, IL2=311A, IL3=386.9A
2	01.02.2022	16:59	01.02.2022	17:12	0	22	50MVA Transformer III	Malbase Substation		Differential Start, OLTC Buchholz Trip, Differential Trip.	-	-	IL1=89.97A<126.94 deg, IL2=79.88A<178.9 deg, IL3=130.9A<129.26 deg.
3	10.02.2022	15:37	10.02.2022	15:55	0	27	66kV Pasakha Feeder I	Industrial Site		IEF-SON_Trip,86 Operated,General Trip.	-	-	IL1=228.08A<57.66 deg, IL2=209.67A<147.73deg, IL3=148.03A< -67.51deg.
4	10.02.2022	15:37	10.02.2022	15:55	0	29	66kV Pasakha Feeder IV	Industrial Site		IEF-SON_Trip,86 Operated,General Trip.	-	-	IL1=609.62A<80.46 deg, IL2=552.45A<115.14deg, IL3=1719.66A<69.45deg.
5	10.02.2022	15:37	10.02.2022	15:55	0	27	66kV Pasakha Feeder II	Industrial Site		IEF-SON_Trip,86 Operated,General Trip.	-	-	IL1=0.34A<139.27 deg, IL2=702.13A<133.46deg, IL3=2369.77<-79.96deg.
6	10.02.2022	15:37	10.02.2022	15:55	0	-	66kV Bus Coupler	Malbase Substation		IEF-SON_Trip,86 Operated,General Trip.	-	-	IL1=552.12A<116.54 deg, IL2=29.01A<116.26deg, IL3=332.77<84.69deg, Neutral current=1054.78<109.17deg.
7	20.02.2022	23:12	20.02.2022	23:24	0	28	220 kV Chukha feeder	Malbase Substation		AR Lockout Shot, Zone 1 Trip.	9.281 km	-	R phase=5.023kA, Y phase=5.039kA, Y phase=4.917kA.
(B) 220/66/11 kV Singhigaon Substation													
1	10.02.2022	15:38	10.02.2022	15:48	0	10	66kV Bhutan Concast Feeder	Singhigaon Substation	Overcurrent on B phase	O/C Trip, DIR Time-trip, IE>>DIR trip, I>> DIR Trip.	Druk wang Factory	Overcurrent Outage	IL1=0.35kA, IL2=0.38kA, IL3=5.12kA
(B) 66/33/11 kV Phuntsholing Substation													
1	01.02.2022	16:58	01.02.2022	17:11	0	3.47	66kV Chukha feeder	66kV Chukha feeder	Overcurrent	Ia=373.7A, Ib=1.041kA, Ic=982.1A, VAB=11.04kV, VBC=13.85kV, VCA=10.39kV, Im=409.3A, Ind=409.6A, VAN=5.177kV, VBN=7.872kV, VCN=7.222kV, 86 & 186	Substation	Tripped on fault	66kV Chukha-Pling feeder got tripped at both end (i.e Pling & Chukha end). At 17:11hrs normalised the feeder after getting clearance from BPSO.
2	02.02.2022	8:04	02.02.2022	8:32	0	0.09	66kV Chukha feeder	66kV Chukha feeder	Overcurrent	Ia=37.19A, Ib=775.5A, Ic=756.6A, VAB=58.57kV, VBC=21.83kV, VCA=55.87kV, Im=6.114A, Ind=6.078A, VAN=38.46kV, VBN=25.01kV, VCN=17.64kV, 86 & 186	Substation	Tripped on fault	66kV Chukha-Pling feeder got tripped at both end (i.e Pling & Chukha end). At 08:22hrs test charge the feeder after getting clearance from BPSO with charging code 1093 but got tripped on distance relay. Informed to BPSO and at 08:32hrs normalised the feeder after opening 66kV Pling- Gedu section line isolator at Gedu end.
3	05.02.2022	5:26	05.02.2022	5:32	0	-3.63	66kV Chukha feeder	66kV Chukha feeder	Overcurrent	Ia=35.18A, Ib=976.9A, Ic=995.1A, VAB=60.83kV, VBC=13.79kV, VCA=58.43kV, Im=10.96A, Ind=10.85A, VAN=39.56kV, VBN=24.30kV, VCN=18.88kV, 86 & 186	Substation	Tripped on fault	66kV Chukha-Pling feeder got tripped at both end (i.e Pling & Chukha end). At 05:26hrs normalised the feeder after getting clearance from BPSO.
4	20.02.2022	23:13	20.02.2022	23:25	0	-2.30	66kV Chukha feeder	66kV Chukha feeder	Distance relay	General Trip, 186 & 86	Substation	Tripped on fault	66kV Chukha-Pling feeder got tripped at both end (i.e Pling & Chukha end, weather condition at Chukha heavy lighting and rain). At 23:25hrs normalised the feeder after getting clearance from BPSO.
5	21.02.2022	1:54	21.02.2022	2:22	0	-2.00	66kV Chukha feeder	66kV Chukha feeder	Distance relay	General Trip, 186 & 86	Substation	Tripped on fault	66kV Chukha-Pling feeder got tripped at both end (i.e Pling & Chukha end, weather condition at Chukha heavy lighting and rain). At 02:10hrs test charged with charging code 1230 from BPSO but got tripped on same fault. At 02:22hrs as per instruction from BPSO normalised the feeder after opening line isolator of 66kV Chukha-Gedu section from Gedu end.
6	21.02.2022	15:28	21.02.2022	15:40	0	-4.98	66kV Pling-Gomtu feeder	66kV Pling-Gomtu feeder			Dhamdhum substaion		At 15:29hrs 66kV Gomtu-Pling feeder got tripped from Gomtu end (i.e from Dhamdhum substation) and causing black out at Phuntsholing. At 15:36hrs normalised 66kV Pling-Malbase feeder with closing code 1235 from BPSO. Weather condition was raining with lightning.
7	21.02.2022	15:36					66kV Pling-Malbase feeder						At 15:29hrs 66kV Gomtu-Pling feeder got tripped from Gomtu end (i.e from Dhamdhum substation) and causing black out at Phuntsholing. At 15:36hrs normalised 66kV Pling-Malbase feeder with closing code 1235 from BPSO. Weather condition was raining with lightning.
8	25.02.2022	16:17	25.02.2022	16:33	0	-5.85	66kV Chukha-Pling feeder	66kV Chukha feeder	Distance relay	General Trip, 186 & 86	Substation	Tripped on fault	66kV Chukha-Pling feeder got tripped at both end (i.e Pling & Chukha end and 66kV Gomtu feeder from end causing black out at Phuntsholing. At 16:20hrs charged 66kV Malbase feeder with closing code 1255 from BPSO. At 16:33hrs normalised 66kV Chukha-Pling feeder after getting clearance from BPSO. At 16:40hrs normalised 66kV Gomtu feeder with closing code 1256 from BPSO.
9	25.02.2022	16:17	25.02.2022	16:40	0	-2.75	66kV Pling-Gomtu feeder	66kV Pling-Gomtu feeder	Distance relay	General Trip, time=41sec, fault imp= 6.68, fault angle=131deg, fault I= 4.09A, fault location= 45.7 and 186 & 86	Substation	Tripped on fault	
10			25.02.2022	16:20	16	idle	66kV Pling-Malbase feeder						Both 66kV feeder got tripped causing black out at Phuntsholing. At 16:20hrs charged 66kV Pling-Malbase feeder with closing code 1256 from BPSO.



Transmission System Performance Report

First Quarterly Report-2022

(D) 66/33/11 kV Gedu Substation													
1	01.02.2022	16:58	01.02.2022	17:12	0	2.78	66kV Incomer	Gedu Substation	Bad weather condition		Line segment	Tripped on both the 66kV Chukha and Phuntsholing end. Charged from Chukha end.	
2	02.02.2022	8:04	02.02.2022	8:42	0	2.8	66kV Incomer	Gedu Substation	Bad weather condition		Line segment	Tripped on both the 66kV Chukha and Phuntsholing end. Charged from Phuntsholing end.	
3	05.02.2022	5:25	05.02.2022	5:32	0	1	66kV Incomer	Gedu Substation	Bad weather condition		Line segment	Tripped on both the 66kV Chukha and Phuntsholing end. Charged from Chukha end.	
4	20.02.2022	23:10	20.02.2022	23:25	0	1.58	66kV Incomer	Gedu Substation	Bad weather condition		Line segment	Tripped on both the 66kV Chukha and Phuntsholing end. Charged from Chukha end.	
5	21.02.2022	1:56	21.02.2022	2:21	0	0.93	66kV Incomer	Gedu Substation	Bad weather condition		Line segment	Tripped on both the 66kV Chukha and Phuntsholing end. Charged from Phuntsholing end.	
6	21.02.2022	15:20	21.02.2022	15:35	0	2.33	66kV Incomer	Gedu Substation	Bad weather condition		Line segment	Tripped on both the 66kV Chukha and Phuntsholing end. Charged from Phuntsholing end.	
7	25.02.2022	16:16	25.02.2022	16:34	0	2.9	66kV Incomer	Gedu Substation	Bad weather condition		Line segment	Tripped on both the 66kV Chukha and Phuntsholing end. Charged from Chukha end.	
(E) 66/33/11 kV Gomtu Substation													
1	08.02.2022	18:57	09.02.2022	20:39	1	2.673	66/11kV 10MVA Transformer	Nil	Sparking occurred on LV terminal	Nil	Gomtu Substation	Shutdown	Taken shutdown for new replacement of LV cable termination by maintenance team.
2	09.02.2022	08:11	09.02.2022	08:19	0	4.15	66/11kV 5MVA Transformer.	Gomtu Substation	Over load	86 & 30AB Aux Operated	Gomtu Substation		Due to over loading of Transformer got tripped.
3	21.02.2022	15:27	21.02.2022	15:40	0	-8.42	66kV Damdum feeder	Gomtu Substation	Nil	Nil	Dhamdhum substation	Transient fault	66kV supply tripped from Damdum Substation, supply fed from P/ling at 15:40 hrs. 66kV Damdum resumed at 17:01 hrs.
(F) 220/66/33 kV Dhamdum Substation													
1	21.02.2022	15:27	21.02.2022	16:00	0	5.35	50/63MVA TRF.1 (203)	Dhamdum	Transient Fault	RET670	N/A	N/A	Fault Mag.:128.11KV and Fault angle :-7.55Deg.
2	21.02.2022	15:27	21.02.2022	15:59	0	5.32	50/63 MVA TRF 2 (205)	Dhamdum	Transient Fault	RET670	N/A	N/A	Fault Mag.:128.11KV and Fault angle :-7.55Deg.
3	21.02.2022	15:27	21.02.2022	17:01	1	8.1	66kV Gomtu fdr.	Gomtu	Transient Fault	REL670:General trip,Zone 1 trip R phase and 86 relay trip.	N/A	-	Fault value:R phase fault mag.:3408.74Amp and fault angle :-74.35 deg.

SL No.	Date of Tripping	Time of outages	Date of Normalization	Time of fault was cleared	Duration of Outages (Hrs)	MW before outage (MW)	Feeder Name	Name of the Substation/lines affected by the fault	Reasons of fault	Relay operations	Exact location of fault [Line segment/ Substation]	Type of outages	Remarks
(A) 66kV Chumdu switching station													
1	04.02.2022	22:27hrs	05.02.2022	14:35hrs	16hrs	2.92MW	66kV Pangbasa feeder	Pangbasa substation		G/rip, Y&B ph. CB open.			
2		00:13hrs		00:28hrs		6.22MW							
3		01:14hrs		01:21hrs		(-)3.99MW							
4		02:12hrs		02:22hrs		0.25MW							
5		06:26hrs		14:22hrs	7hrs	1.26MW			due to heavy snow fall	G/rip, Y&B ph. CB open.	66kV transmission line	Trip	
6	05.02.2022	00:25hrs	05.02.2022	00:56hrs		3.02MW	66kV Paro feeder	Paro substation		G/rip, Y&B ph. CB open.			
7		01:09hrs		14:30hrs	13hrs	4.03MW							
8		24:56hrs		01:02hrs		(-)7.95MW							
9		02:05hrs		04:10hrs	2hrs	(-)0.15MW	66kV Chukha feeder	Paro, Pangbasa, Jemina		G/rip, Y&B ph. CB open. Dist prtn optd.			
10		07:34hrs	06.02.2022	15:11hrs	41hrs	(-)1.2MW		Fed from 66kV Jemina feeder					
11	08.02.2022	11:06hrs	08.02.2022	12:43hrs	1hr	0.3MW	66kV Chukha Feeder	Fed from 66kV Jemina feeder	For jumpering out at Wisa T-Off	CB open, Line& Bus isolator open, E/swich closed			
12	09.02.2022	16:43hrs	09.02.2022	17:39hrs		0.45MW			For jumpering out at Wisa T-Off				
13		02:05hrs		02:11hrs		3.88MW							
14	14.02.2022	06:50hrs	14.02.2022	06:55hrs		2.58MW	66kV Paro feeder	Paro substation	Transient fault	CB open, OC			
15		07:05hrs		07:21hrs		7.64MW					Chumdo end	trip	
16		20:22hrs	20.02.2022	20:28hrs		(-)15.75MW	66kV Chukha feeder	Fed from 66kV Jemina feeder	Trip	CB open,Dist prtn optd, 3ph trip			
17	20.02.2022	21:00hrs	21.02.2022	12:26hrs	15hrs		66kV Pangbasa feeder	Pangbasa substation	Trip	G/rip, Dist prtn optd, 3ph	Chumdo end	Trip	
18	21.02.2022	21:31hrs	20.02.2022	21:41hrs		3.45MW	66kV Pangbasa feeder	Pangbasa substation	Trip	G/rip, Dist prtn optd, 3ph	Chumdo end	Trip	
19	21.02.2022	08:46hrs	21.02.2022	09:39hrs		(-)14.67MW	66kV Jemina feeder	Paro,Pangbasa Watsa	Trip	No operation at chumdo end.	Changidaphu end	trip	
(B) 66/33kV Watsa Substation													
1	5/2/2022	00:56hrs	5/2/2022	01:02hrs		.450MW	66KV IC	Fdr. I and II		Dist. Realay 21.8km, Gen. zone 1 at chukha end	66KV IC	Tripped	
2	5/2/2022	1:33hrs	5/2/2022	1:35hrs		.450MW	66KV IC	Fdr. I and II		Dist. Realay 21.8km, Gen. zone 1 at chukha end	66KV IC	Tripped	
3	5/2/2022	1:51hrs	5/2/2022	1:56hrs		.450MW	66KV IC	Fdr. I and II		Dist. Realay 21.8km, Gen. zone 1 at chukha end	66KV IC	Tripped	
4	5/2/2022	2:05hrs	5/2/2022	3:02hrs		.450MW	66KV IC	Fdr. I and II		Dist. Realay 21.8km, Gen. zone 1 at chukha end	66KV IC	Tripped	
5	5/2/2022	3:02hrs	5/2/2022	5:10hrs	2hrs	.450MW	66KV IC	Fdr. I and II		Dist. Realay 21.8km, Gen. zone 1 at chukha end	66KV IC	Tripped	
6	5/2/2022	7:34hrs	6/2/2022	15:11hrs	19hrs	.450MW	66KV IC	Fdr. I and II		Dist. Realay 21.8km, Gen. zone 1 at chukha end	66KV IC	Tripped	66KV back feeded from chumdo end after opening jumper towards chukha by TMD olakha
9	16/2/2022	20:50hrs	16/2/2022	20:56hrs		.660MW	66KV SF6 breaker	Fdr. I and II	OC, OCH, EF and EFH	OC, OCH, EF and EFH on B phase	Fdr. I Wanakha	Tripped	Test charge but line couldn't hold and breaker charged after opening Wanakha isolator
10	20/2/2022	20:20hrs	20/2/2022	20:28hrs		.190MW	66KV IC	Fdr. I and II		Dist. Realay 14.9km, zone 1 at chukha end	66KV IC	Tripped	
11	20/2/2022	21:00hrs	21/2/2022	12:26hrs	15hrs	.190MW	66KV IC	Fdr. I and II	Conductor got twisted at chapcha near greff canteen	Dist. Realay 14.9km, zone 1 at chukha end	66KV IC	Tripped	Conductor got twisted with each other at chapcha near greff. Line charged after clearing fault by TMD Tsimalakha
(C) 66/33kV Olakha Substation													
1	2/5/2022	1:15	2/5/2022	1:19		2.92	66kV Olakha - Changidaphu line	Olakha Substation	Dist.Protn.Relay-21 Optd.	DISTANCE PROTIN RELAY-21 Optd.Indication 1.2.4.12 & 13. 1.General trip. 2.Distance Optd. 4. Zone 2 Optd. 12.LBB Optd.13.U/V Optd. & Trip relay-86 & distance of fault at 18.8 km (Zone 2)	Fault on 66kV Olakha - Changidaphu line	Transient Fault	Reset all the operated relay & indication Charged the 66kV line as per BPSO instruction given and hold normal.
2	2/5/2022	2:28	2/5/2022	2:38		0.83	66kV Olakha - Changidaphu line	Olakha Substation	Dist.Protn.Relay-21 Optd.	DISTANCE PROTIN RELAY-21 Optd.Indication 1.2.3.12 & 13. 1.General trip. 2.Distance Optd. 3. Zone 1 Optd. 12.LBB Optd.13.U/V Optd. & Trip relay-86 & distance of fault at 3.7 km (Zone 1)	Fault on 66kV Olakha - Changidaphu line	Transient Fault	Reset all the operated relay & indication & consult with BPSO and charged the line & hold normal.
3	2/5/2022	3:09	2/5/2022	3:15		1.3	66kV Olakha - Changidaphu line	Olakha Substation	Dist.Protn.Relay-21 Optd.	DISTANCE PROTIN RELAY-21 Optd.Indication 1.2.3.12 & 13. 1.General trip. 2.Distance Optd. 3. Zone 1 Optd. 12.LBB Optd.13.U/V Optd. & Trip relay-86 & distance of fault at 1.6 km (Zone 1)	Fault on 66kV Olakha - Changidaphu line	Transient Fault	Reset all the operated relay & indication & consult with BPSO and charged the line & hold normal.
4	2/5/2022	3:27	2/5/2022	3:32		1.3	66kV Olakha - Changidaphu line	Olakha Substation	Dist.Protn.Relay-21 Optd.	DISTANCE PROTIN RELAY-21 Optd.Indication 1.2.3.12 & 13. 1.General trip. 2.Distance Optd. 3. Zone 1 Optd. 12.LBB Optd.13.U/V Optd. & Trip relay-86 & distance of fault at 1.8 km (Zone 1)	Fault on 66kV Olakha - Changidaphu line	Transient Fault	Reset all the operated relay & indication & consult with BPSO and charged the line & hold normal.
5	2/5/2022	4:08	2/5/2022	4:14		1.51	66kV Olakha - Changidaphu line	Olakha Substation	Dist.Protn.Relay-21 Optd.	DISTANCE PROTIN RELAY-21 Optd.Indication 1.2.3.12 & 13. 1.General trip. 2.Distance Optd. 3. Zone 1 Optd. 12.LBB Optd.13.U/V Optd. & Trip relay-86 & distance of fault at 2.2 km (Zone 1)	Fault on 66kV Olakha - Changidaphu line	Transient Fault	Reset all the operated relay & indication & consult with BPSO and charged the line & hold normal.
6	2/5/2022	5:53	2/5/2022	7:52	1	0.7	66kV Olakha - Changidaphu line	Olakha Substation	Dist.Protn.Relay-21 Optd.	DISTANCE PROTIN RELAY-21 Optd.Indication 1.2.3.12 & 13. 1.General trip. 2.Distance Optd. 3. Zone 1 Optd. 12.LBB Optd.13.U/V Optd. & Trip relay-86 & distance of fault at 2.7 km (Zone 1)	Fault on 66kV Olakha - Changidaphu line	Transient Fault	As per the BPSO instruction given 66kVOlakha - Changidaphu breaker kept open due to continous tripping. Again as per BPSO instruction 66kV Olakha - Changidaphu breaker closed at 07:52 Hrs & hold normal.



Transmission System Performance Report

First Quarterly Report-2022

7	2/5/2022	8:50	2/5/2022	10:53	2	0.0	66kV Olakha - Changidaphu line	Olakha Substation	Dist.Protn.Relay-21 Optd.	DISTANCE PROT N RELAY-21 Optd.Indication 1,2,3,12 & 13. 1.General trip. 2.Distance Optd. 3. Zone 1 Optd. 12.LBB Optd.13.U/V Optd. & Trip relay-86 & distance of fault at 1.4 km (Zone 1)	Fault on 66kV Olakha - Changidaphu line		As per the BPSO instruction given 66kV Olakha - Changidaphu breaker closed at 8:56 hrs but it couldn't stand as Distance relays shows is 5.2 km on zone 1. Thereby 66kV breaker of Changidaphu was kept open as per BPSO instruction. After information 66kV Olakha - Changidaphu breaker closed /charged at 10:53 Hrs as per BPSO instruction and hold normal	
9	2/5/2022	14:45	2/5/2022	14:50		0.0	66kV Olakha - Changidaphu line	Olakha Substation	Earth Fault and Over Current Operated	DISTANCE PROT N RELAY-21 Optd.Indication 1, 12 & 13. General Trip 12.LBB operated 13.U/V Optd. & Trip relay-86)	Line Segments	Due to Continuous snow Fall	Reset all the operated relay & indication and after consult with BPSO and charged the line & hold normal.	
10	2/5/2022	15:16	2/5/2022	15:18		4.1	66kV Olakha - Changidaphu line	Olakha Substation	Earth Fault and Over Current Operated	DISTANCE PROT N RELAY-21 Optd.Indication 1, 12 & 13. General Trip 12.LBB operated 13.U/V Optd. & Trip relay-86)	Line Segments	Due to Continuous Show Fall	Reset all the operated relay & indication and after consult with BPSO and charged the line & hold normal.	
11	2/5/2022	12:26	2/5/2022	12:29		13.8	20MVA Transformer - I	All the 33kV Outgoing feeders was effected	Directional Over Current and Earth fault along with 86 relay operated	Directional Over Current and Earth fault along with 86 relay operated. Indication. 1&5. 1. General Tripped 5. Over current and Earth fault operated	Line Segments	Temporary fault due to heavy snowfall	Reset the relays and test Charged the Transformer and hold normal	
12	2/5/2022	12:26	2/5/2022	12:29		13.7	20MVA Transformer - II	All the 33kV Outgoing feeders was effected	Directional Over Current and Earth fault along with 86relay operated	Directional Over Current and Earth fault along with 86relay operated. Indication. 1&5. 1. General Tripped 5. Over current and Earth fault operated	Line Segments	Temporary fault due to heavy snowfall	Reset the relays and test Charged the Transformer and hold normal	
13	2/5/2022	13:08	2/5/2022	13:09		14.7	20MVA Transformer - I	The 33kV outgoing was not effected as the feeders was fed from 20MVA Transformer II	Directional Over Current and Earth fault along with 86 relay operated	Directional Over Current and Earth fault along with 86 relay operated. Indication. 1&5. 1. General Tripped 5. Over current and Earth fault operated	Line Segments	Temporary fault due to heavy snowfall	Reset the relays and test Charged the Transformer and hold normal	
14	2/5/2022	14:45	2/5/2022	14:50		15.9	20MVA Transformer - I	The 33kV outgoing was not effected as the feeders was fed from 20MVA Transformer II	Due to Tripping of 66kV Changedaphu feeders, 20MVA Transformer I was tripped	Only Relay 86 was operated	Line Segments	Temporary fault due to heavy snowfall	Reset the relays and test Charged the Transformer and hold normal	
15	2/5/2022	14:45	2/5/2022	14:50			66kV Bus Coupler	The 33kV outgoing was not effected as the feeders was fed from 20MVA Transformer II	Over Current and Earth fault along with 86 relay operated	Over current and Earth fault relay 50/51. Indication 1,2 3. 1.General trip. 2.Over current operated . 3. Earth Fault Operated along with Trip relay-86	Line Segments	Temporary fault due to heavy snowfall	Reset the relays and test Charged the 66kV Bus and hold normal	
16	2/5/2022	15:16	2/5/2022	15:18		8.5	20MVA Transformer - I	The 33kV outgoing was not effected as the feeders was fed from 20MVA Transformer II	Due to Tripping of 66kV Changedaphu feeders, 20MVA Transformer I was tripped	Only Relay 86 was operated	Line Segments	Temporary fault due to heavy snowfall	Reset the relays and test Charged the Transformer and hold normal	
17	2/5/2022	15:16	2/5/2022	15:18			66kV Bus Coupler	The 33kV outgoing was not effected as the feeders was fed from 20MVA Transformer II	Over Current and Earth fault along with 86 relay operated	Over current and Earth fault relay 50/51. Indication 1,2 3. 1.General trip. 2.Over current operated . 3. Earth Fault Operated along with Trip relay-86	Line Segments	Temporary fault due to heavy snowfall	Reset the relays and test Charged the 66kV Bus and hold normal	
18	2/21/2022	8:48	2/21/2022	8:52		19.91	66kV Olakha - Changidaphu line	Olakha Substation	Dist.Protn.Relay-21 Optd.	DISTANCE PROT N RELAY-21 Optd.Indication 1,2,3,12 & 13. 1.General trip. 2.Distance Optd. 3. Zone 1 Optd. 12.LBB Optd.13.U/V Optd. & along with Trip relay-86 & distance of fault at 11.5 km (Zone 1)	Line Segments	Transient Fault	Reset all the operated relay & indication and after consult with BPSO and charged the line & hold normal.	
(D) 66/33/11kV Lobeysa Substation														
66kV LSA - Basochu feeder														
1	05.02.2022	11:12hrs	05.02.2022	11:20hrs	0	-4.180	66kV LSA - Basochu feeder	66/33/11kV Lobeysa substation				NA	66kV LSA - Basochu feeder tripped at 11:12hrs and charged the line as per BPSO at 11:20hrs from Gewathang substation.	
66kV LSA - Dochula feeder														
1	05.02.2022	01:43hrs	05.02.2022	01:49hrs	0	12.020	66kV LSA - Dochula feeder	NA				Dist & 86 relay operated	66kV LSA - Dochula feeder tripped at 01:43hrs and informed to BPSO and charged at 01:49hrs as per BPSO.	
2	05.02.2022	02:13hrs	05.02.2022	02:29hrs	0	2.430	66kV LSA - Dochula feeder	NA				Dist & 86 relay operated	66kV LSA - Dochula feeder tripped at 02:13hrs and informed to BPSO and charged at 02:29hrs as per BPSO with charging code 1212 .	
3	05.02.2022	09:13hrs	05.02.2022	09:31hrs	0		66kV LSA - Dochula feeder	NA				Dist & 86 relay operated	66kV LSA - Dochula feeder tripped at 09:13hrs and informed to BPSO and charged at 09:31hrs as per BPSO .	
4	05.02.2022	09:39hrs	05.02.2022	10:04hrs	0		66kV LSA - Dochula feeder	NA				Dist & 86 relay operated	66kV LSA - Dochula feeder tripped at 09:39hrs and informed to BPSO and charged at 09:31hrs as per BPSO .	
5	05.02.2022	10:58hrs	05.02.2022	23:26hrs	12	5.000	66kV LSA - Dochula feeder	NA				Dist & 86 relay operated	66kV LSA - Dochula feeder tripped at 10:58hrs and informed to BPSO and charged at 23:26hrs as per BPSO with the closing code 1225 .	
6	15.02.2022	15:58hrs	15.02.2022	16:11hrs	0	-8.010	66kV LSA - Dochula feeder	66/33/11kV Lobeysa substation				NA	66kV LSA - Dochula feeder tripped at 15:58hrs and informed to BPSO and charged at 16:11hrs,at that time supply was feeded from Dochula to Gewathang end since their was line problem between Gewathang to Basochu(One phase conductor snapped)	
7	15.02.2022	18:28hrs	16.02.2022	17:57hrs	23	-7.990	66kV LSA - Dochula feeder	66/33/11kV Lobeysa substation				Dist & 86 relay operated	66kV LSA - Dochula feeder tripped at 18:28hrs and informed to BPSO kept the feeder trip and the supply was resumed from Basochu at 19:03hrs and Dochula supply synorized at 17:57hrs on 16.02.2022 after rejumping at tower No.31 with the closing code 1821.	
(E) 66/33/11 kV Paro Substation														
1	05.02.2022	00:25hrs	05.02.2022	00:56hrs			66kV Haa line							
2	05.02.2022	01:09hrs	05.02.2022	01:30hrs	13		66kV Haa line							
2	05.02.2022	24:56hrs	01.02hrs	02:05hrs	2	5	66kV chumdo line	Paro ss	Due to heavy snow fall	No relay operation			Long	
3	14.02.2022	02:05hrs	02:11hrs	06:50hrs	5	16	66kV chumdo line	Paro ss	Tripped from changedaphu	No relay operation			transient	
4	21.02.2022	08:46hrs	21.02.2022	09:39hrs			66kV chumdo line	Paro ss	Tripped from changedaphu	No relay operation			transient	
(F) 66/33/11kV Jemina Substation														
1	05.02.2022	0:07	05.02.2022	14:14	21	4.62	Both 66kV feeder chumdo and changedaphu	Blackout	O/C	186 & 86	line segment		Upon test charging at 14:14 Hrs, line stood normal.(66kV olakha vie changedaphu fdr. Jumping out at IT park area.)	
2	21.02.2022	8:48	21.02.2022	9:39	0		66kV Changedaphu feeder	66kV Changedaphu feeder		No relay operation at jemina end.	line segment		66kV supply fail from changedaphu end and resumed at 09:39hrs.	
(G) 66/33/11kV Dechencholing substation														
1	01.02.2022	16:58hrs	01.02.2022	17:05hrs	0	-37.17	66kV Sesmtokha IC	whole s/s fdr.		Supply failed from source. According the Semsokha operator line tripped due to under voltage.				
2	05.02.2022	00:00hrs	05.02.2022	00:05hrs	0	0.747	66KV Danji Fdr.	Danji line	Tripped on dist relay optd.	Dist relay, 86A, 86B Zone-1	not known	Tripped	Test charged the fdr after getting closing code; 1205 from BPSO fdr stand normal.	
3	05.02.2022	01:35hrs	09.02.2022	10:46hrs	105hrs	0	66KV Danji Fdr.	Danji line	Tripped on dist relay & O/C relay	Dist relay, 86A, 86B Zone-1, 4.661KM; IA 5.530A; IB 1.819A; IC 1.820A			It is confirmed that line has fault and issued the work permit to Olakha TMD for line patrolling, later they have found that two conductor was snapped and they re-stringing the conductor and brought back line to normal on dt 09.02.2022 at 10:46hrs.	
4	05.02.2022	09:13hrs	05.02.2022	09:20hrs	0	-4.528	66KV Sesmtokha IC	whole s/s fdr.		Supply failed from Source.				
5	05.02.2022	09:39hrs	05.02.2022	09:43hrs	0	-4.528	66KV Sesmtokha IC	whole s/s fdr.		Supply failed from Source.				
6	05.02.2022	10:58hrs	05.02.2022	11:04hrs	0	-5.439	66KV Sesmtokha IC	whole s/s fdr.		Supply failed from Source.				
7	15.02.2022	13:58hrs	15.02.2022	16:07	0	-37.38	66KV Sesmtokha IC	whole s/s fdr.	Tripped on 86 relay optd	86 relay optd.	Tripped	Test charged the fdr as per the instruction BPSO officials since there will be back out.	
(H) 66/11kV Haa Substation														
1	04.02.2022	20:19	04.02.2022	20:27	0	-2.81	66kV Incomer	All the feeders	unknown	O/C	Pangbesa		Supply failed from Pangbesa substation on operating over current. The same was normalised from their end.	
2	04.02.2022	20:54	04.02.2022	21:04	0	-2.81	66kV Incomer	All the feeders	unknown	O/C on three phases	Chumdo		Supply failed from Pangbesa substation on operating over current. The same was normalised from their end.	
3	04.02.2022	22:00	05.02.2022	15:19	18hrs	-2.81	66kV Incomer	All the feeders	conductor twisted	O/C on three phases	Chapcha		Supply failed from Chumdo substation on operating over current. The same was normalised from their end.	
4	20.02.2022	21:31	20.02.2022	21:41	0	-2.7	66kV Incomer	All the feeders	unknown	O/C on three phases	Chumdo end		Supply failed from Chumdo substation on operating over current on all the phases. The same was normalised from their end.	
5	21.02.2022	8:48	21.02.2022	10:00	0	-2.5	66kV Incomer	All the feeders	unknown	O/C on three phases	Chumdo end		Supply failed from Chumdo substation on operating over current on all the phases. The same was normalised from their end.	



Transmission System Performance Report

First Quarterly Report-2022

(I) 220kV Substation Sertokha												
66kV and above Tripping												
1	06.02.2022	10:13hrs	06.02.2022	10:25hrs		-59.020	220kV Sem-BHP	Sertokha Substation	Phase to Phase Fault	Main-1 Zone 1 Trip, fault loop- L2-L2	Distance= 11.3KM	Transient
2	05.02.2022	01:43hrs	05.02.2022	01:46hrs		43.09	66kV Sem-Dochula Line	Dochula Substation	Fault Loop= L1-N	Dir. EF Fault, fault loop- L1-N R,Y,Bph Trip	Distance=0.5KM	Transient
3	05.02.2022	02:12hrs	05.02.2022	02:16hrs		1.55	66kV Sem-Dochula Line	Dochula Substation	Fault Loop= L1-L	Dist. Prot. Optd, fault loop- L1-L2	Distance=0.5KM	Transient
4	05.02.2022	09:13hrs	05.02.2022	09:20hrs		51.46	66kV Sem-Dochula Line	Dochula Substation	Fault Loop= L1-L	Dist. Prot. Optd, I-2 Trip, Y&Bph Trip, Fault loop-L1-L2	Distance=0.00KM	Transient
5	05.02.2022	09:39hrs	05.02.2022	09:46hrs		5.45	66kV Sem-Dochula Line	Dochula Substation	Fault Loop= L1-L	Dist. Prot. Optd, I-2 Trip, Y&Bph Trip, Fault loop-L1-L2	Distance=0.00KM	Transient
6	05.02.2022	10:38hrs	05.02.2022	10:40hrs		0.42	66kV Sem-Dochula Line	Dochula Substation	Fault Loop= L1-L	Dist. Prot. Optd, I-2 Trip, Y&Bph Trip, Fault loop-L1-L2	Distance=0.00KM	Transient
7	05.02.2022	10:58hrs	05.02.2022	11:32hrs		0.42	66kV Sem-Dochula Line	Dochula Substation	Fault Loop= L1-L	Dist. Prot. Optd, I-2 Trip, Y&Bph Trip, Fault loop-L1-L2	Distance=0.00KM	Transient
8	05.02.2022	11:45hrs	05.02.2022	22:44hrs	11	0.42	66kV Sem-Dochula Line	Dochula Substation	Fault Loop= L1-L	Dist. Prot. Optd, I-2 Trip, Y&Bph Trip, Fault loop-L1-L2	Distance=0.00KM	Transient
9	15.02.2022	15:57hrs	15.02.2022	16:11hrs		64.62	66kV Sem-Dochula Line	Dochula Substation	Fault Loop= L1-L	Dist. Prot. Optd, fault loop- L1-L2, (Ia= 536.5A, Ib=525.8A, Ic=538.0A)	Distance=0.00KM	Transient
10	15.02.2022	18:27hrs	15.02.2022	18:39hrs			66kV Sem-Dochula Line	Dochula Substation	Fault Loop= L1-L	Dist. Prot. Optd, fault loop- L1-L2	Distance=12.00KM	Transient
11	15.02.2022	18:46hrs	15.02.2022	18:59hrs			66kV Sem-Dochula Line	Dochula Substation	Fault Loop= L2-N	Dist. Prot. Optd, Yph Trip, fault loop- L2-N	Distance=8.7KM	Transient
12	05.02.2022	02:29hrs	05.02.2022	02:33hrs		9.32	66kV Sem-Olakra Line	Olakra Substation	Overcurrent Trip	Back Up Relay Optd, I-> Trip, Y&Bph Trip		Transient
13	05.02.2022	03:10hrs	05.02.2022	03:14hrs		8	66kV Sem-Olakra Line	Olakra Substation	Overcurrent Trip	Back Up Relay Optd, I-> Trip, Y&Bph Trip		Transient
14	05.02.2022	3:28hrs	05.02.2022	03:31hrs		8	66kV Sem-Olakra Line	Olakra Substation	Overcurrent Trip	Back Up Relay Optd, I-> Trip, Y&Bph Trip		Transient
15	05.02.2022	04:09hrs	05.02.2022	04:13hrs		6.11	66kV Sem-Olakra Line	Olakra Substation	Overcurrent Trip	Back Up Relay Optd, I-> Trip, Y&Bph Trip		Transient
16	05.02.2022	05:54hrs	05.02.2022	05:56hrs		7.72	66kV Sem-Olakra Line	Olakra Substation	Overcurrent Trip	Back Up Relay Optd, I-> Trip, Y&Bph Trip		Transient
17	05.02.2022	08:52hrs	05.02.2022	08:55hrs		15.17	66kV Sem-Olakra Line	Olakra Substation	Overcurrent Trip	Back Up Relay Optd, I-> Trip, Y&Bph Trip		Transient
18	01.02.2022	16:59hrs	01.02.2022	17:06hrs		19.05	66kV Sem-Dechencholing Line	Dechencholing Substation	Under Voltage	Dist. Prot Optd, Rph Under Voltage Trip		Transient
19	05.02.2022	01:43hrs	05.02.2022	01:45hrs			66kV Sem-Dechencholing Line	Dechencholing Substation	Overcurrent Trip	Dist. Prot Optd, Over current Trip		Transient
20	05.02.2022	02:12hrs	05.02.2022	02:14hrs		4.78	66kV Sem-Dechencholing Line	Dechencholing Substation	Overcurrent Trip	Dist. Prot Optd, Over current Trip		Transient
21	05.02.2022	09:39hrs	05.02.2022	09:43hrs		4.78	66kV Sem-Dechencholing Line	Dechencholing Substation	Under Voltage	Dist. Prot Optd, Under Voltage Trip		Transient
22	05.02.2022	10:38hrs	05.02.2022	10:39hrs		5.21	66kV Sem-Dechencholing Line	Dechencholing Substation	Under Voltage	Dist. Prot Optd, Under Voltage Trip		Transient
23	05.02.2022	10:58hrs	05.02.2022	10:04hrs		5.51	66kV Sem-Dechencholing Line	Dechencholing Substation	Under Voltage	Dist. Prot Optd, Under Voltage Trip		Transient
24	05.02.2022	11:45hrs	05.02.2022	11:48hrs		5.51	66kV Sem-Dechencholing Line	Dechencholing Substation	Under Voltage	Dist. Prot Optd, Under Voltage Trip		Transient
25	05.02.2022	18:41hrs	05.02.2022	18:49hrs		5.51	66kV Sem-Dechencholing Line	Dechencholing Substation	Under Voltage	Dist. Prot Optd, Under Voltage Trip		Transient
26	05.02.2022	15:58hrs	05.02.2022	16:06hrs		33.3	66kV Sem-Dechencholing Line	Dechencholing Substation	Broken Conductor	Dist. Prot Optd, Broken conductor Trip		Transient
66kV and above Shutdown												
16.02.2022	14:40hrs	16.02.2022	17:53hrs	3.00	50.520		Dochula Substation	Shutdown availed by Mr. Chundu Gyeltsen, TMD Olakra for re-conducting				Transient
/33/11kV Pangbesa substation												
04.02.2022	20:15hrs	04.02.2022	20:29hrs	0	2.25		Haa line out	Haa substation	Due to heavy snow fall	Distance		transient
04.02.2022	20:55hrs	04.02.2022	21:06hrs	0	2.18		Haa line out	Haa substation	Due to heavy snow fall	Distance		transient
04.02.2022	22:27hrs	05.02.2022	14:35hrs	16			66kV chumdo line	Pangbasa /Haa substation	Due to heavy snow fall	No relay operation		Long
05.02.2022	22:27hrs	05.02.2022	14:35hrs	16			66kV chumdo line	Pangbasa /Haa substation	Due to heavy snow fall	No relay operation		Long
05.02.2022	24:56hrs	05.02.2022	01:02hrs	0			66kV chumdo line	Pangbasa /Haa substation	Due to heavy snow fall	No relay operation		Long
05.02.2022	02:05hrs	05.02.2022	04:10hrs	0			66kV chumdo line	Pangbasa /Haa substation	Due to heavy snow fall	No relay operation		Long
20.02.2022	21:31hrs	20.02.2022	21:41hrs				66kV chumdo line	Pangbasa /Haa substation	Tripped from chumdo			transient
21.02.2022	21:31hrs	20.02.2022	21:41hrs				66kV chumdo line	Pangbasa /Haa substation	Tripped from chumdo			transient
(K) 66/33kV Changidaphu Substation												
05.02.2022	04:11hrs	05.02.2022	06:01hrs	1			66kV Changidaphu - Jemina Line	Changidaphu, Jemina, Chumdu, Paro and Haa Substation	Grid failed	CB hand tripped from Jemina end as per BPSO advice		Transient
21.02.2022	08:49hrs	21.02.2022	09:38hrs		19.31		66kV Changidaphu - Jemina Line	Changidaphu	Grid failed	Dist. Ptn trip, Zone 1 Y&Bph trip.		Transient
05.02.2022	06:00hrs	05.02.2022	08:19hrs	2			66kV Changidaphu - Olakra Line	Olakra, Changidaphu, Jemina, Chumdu, Paro and Haa Substation	Over Current	Dist. Ptn trip, Zone 1 RY&Bph trip, Over Current trip		Transient
(L) 66/33kV Damji Substation												
01.02.2022	1658 hrs	01.02.2022	1707 hrs	0	-4.45		66 kV Incoming Line	Whole Substation	Trip	NA		Line trip from Sertokha Substation due to under voltage
05.02.2022	0001 hrs	11.02.2022	1115 hrs	6 days & 11 hrs	-2.72		66 kV Incoming Line	Whole Substation	Trip	NA		66 kV Line Fault between Dling & Damji Substation, kept feeder open
15.02.2022	1559 hrs	15.02.2022	1607 hrs	0	-3.67		66 kV Incoming Line	Whole Substation	Trip	NA		Line trip from Sertokha Substation
(M) 66/11kV Dochula Substation												
16/2/2022	14:40	16/2/2022	18:07		3	50.07MW		Shut down taken to connect jumpering at Dochula Tower location SW31 with opening code 0365 and closing code 1281				
								Tower location SW31	Connection of jumper			



Transmission System Performance Report

First Quarterly Report-2022

For March 2022

Sl No.	Date of Tripping	Time of outages	Date of Normalization	Time of fault was cleared	Duration of Outages (Hrs)	MW before outage (MW)	Feeder Name	Name of the Substation/lines affected by the fault	Reasons of fault	Relay operations	Exact location of fault [Line segment/ Substation]	Type of outages	Remarks
(A) 400/220/66/11 kV Malbase Substation													
66kV & Above													
1	13.03.2022	23:08	14.03.2022	13:05	13		66kV Pasakha feeder IV	Malbase s/s	Overcurrent & Earthfault	51N-start,I0C-50-start,86 optd,general trip,IEF 50N trip.			R phase=1916.55A<-166.86 deg, Y phase=101.55A<-4.6deg, B phase=67.821A<-61.93deg, N=1916.55<-166.86deg.
2	13.03.2022	23:08	13.03.2022	23:23	0		66kV Pasakha feeder I	Malbase s/s	Overcurrent & Earthfault	51N-start,I0C-50-start,86 optd,general trip.			R phase=2553.36A<-162.73 deg, Y phase=54.6A<-154.5deg, B phase=61.34A<-179.5deg, N=2666.11A<-17.02deg.
3	13.03.2022	23:08	13.03.2022	23:23	0		66kV Pasakha feeder II	Malbase s/s	Overcurrent & Earthfault	51N-start,I0C-50-start,86 optd,general trip.			R phase=2306.81A<-170.6deg, Y phase=591.24A<-93.34deg, B phase=546.46A<-47.67deg, N=2386.81A<-170.6deg.
4	13.03.2022	23:08	13.03.2022	23:23	0		66kV Bus coupler	Malbase s/s	Overcurrent & Earthfault	50N trip			R phase=554.4A<-19.92deg, Y phase=110.64A<-16.44deg, B phase=110.65A<-32.1deg, N=777.63A<-21.78deg.
(B) 220/66/11 kV Singhgoan Substation													
1	13.03.2022	23:08	14.03.2022	13:04	13	-2	66kV Bhutan Concast Feeder	Singhgoan substation	overcurrent	IE>> DIR trip, I>> DIR trip, Directional time o/c trip.			IL1=50.16kA, IL2=0.4kA, IL3=0.3kA.
(D) 66/33/11 kV Gedu Substation													
1	01.02.2022	16:58	01.02.2022	17:12	0	2.78	66kV Incomer	Gedu Substation	Bad weather condition		Line segment		Tripped on both the 66kV Chukha and Phuntsholing end. Charged from Chukha end.
2	02.02.2022	8:04	02.02.2022	8:42	0	2.8	66kV Incomer	Gedu Substation	Bad weather condition		Line segment		Tripped on both the 66kV Chukha and Phuntsholing end. Charged from Phuntsholing end.
3	05.02.2022	5:25	05.02.2022	5:32	0	1	66kV Incomer	Gedu Substation	Bad weather condition		Line segment		Tripped on both the 66kV Chukha and Phuntsholing end. Charged from Chukha end.
4	20.02.2022	23:10	20.02.2022	23:25	0	1.58	66kV Incomer	Gedu Substation	Bad weather condition		Line segment		Tripped on both the 66kV Chukha and Phuntsholing end. Charged from Chukha end.
5	21.02.2022	1:56	21.02.2022	2:21	0	0.93	66kV Incomer	Gedu Substation	Bad weather condition		Line segment		Tripped on both the 66kV Chukha and Phuntsholing end. Charged from Phuntsholing end.
6	21.02.2022	15:20	21.02.2022	15:35	0	2.33	66kV Incomer	Gedu Substation	Bad weather condition		Line segment		Tripped on both the 66kV Chukha and Phuntsholing end. Charged from Phuntsholing end.
7	25.02.2022	16:16	25.02.2022	16:34	0	2.9	66kV Incomer	Gedu Substation	Bad weather condition		Line segment		Tripped on both the 66kV Chukha and Phuntsholing end. Charged from Chukha end.
(F) 220/66/33 kV Dhamdum Substation													
1	21.02.2022	15:27	21.02.2022	16:00	0	5.35	50/63MVA TRF.1 (203)	Dhamdum	Transient Fault	RET670	N/A	N/A	Fault Mag.:128.11KV and Fault angle :-7.55Deg.
2	21.02.2022	15:27	21.02.2022	15:59	0	5.32	50/63 MVA TRF 2 (205)	Dhamdum	Transient Fault	RET670	N/A	N/A	Fault Mag.:128.11KV and Fault angle :-7.55Deg.
3	21.02.2022	15:27	21.02.2022	17:01	1	8.1	66kV Gomtu fdr.	Gomtu	Transient Fault	REL670:General trip,Zone 1 trip R phase and 86 relay trip.	N/A	-	Fault value:R phase fault mag.:3408.74Amp and fault angle :-74.35 deg.

Tripping Report for the month of MARCH 2022

Sl No.	Date of Tripping	Time of outages	Date of Normalization	Time of fault was cleared	Duration of Outages (Hrs)	MW before outage (MW)	Feeder Name	Name of the Substation/lines affected by the fault	Reasons of fault	Relay operations	Exact location of fault [Line segment/ Substation]	Type of outages	Remarks
(A) 66kV Chumdu switching station													
1	07.03.2022	12:44hrs	07.03.2022	13:05hrs		1.38MW	66kV Jemina feeder	Fed from 66kV Chukha	Trip	O/c, 3ph, CB open	Chumdo	Trip	
(B) 66/33kV Watsa Substation													
1	15/3/2022	14:33hrs	15/3/2022	14:36hrs		.260MW	66kV SF6 breaker	Fdr. I and II	OC,OCH, EF and EFH on ABC phase	OC,OCH, EF and EFH on ABC phase	66kV SF6 breaker	Tripped	LT line cutoff and touches HT line at lonji chapcha as per ESD Chapcha
(D) 66/33/11kV Lobeysa Substation													
66kV LSA - Basochu feeder													
1	07.03.2022	12:53hrs	07.03.2022	13:04hrs	0	-18.990	66kV LSA - Basochu feeder	66/33/11kV Lobeysa substation		NA			66kV LSA - Basochu feeder tripped at 12:53hrs and charged the line as per BPSO at 13:04hrs.(Grid fail)
66kV LSA - Dochula feeder													
1	07.03.2022	12:53hrs	07.03.2022	13:04hrs	0	14.000	66kV LSA - Dochula feeder	66/33/11kV Lobeysa substation		NA			66kV LSA -Dochula feeder tripped at 12:53hrs and charged the line as per BPSO at 13:04hrs.(Grid fail)
(G) 66/33/11kV Dechencholing substation													
1	07.03.2022	12:52hrs	07.03.2022	13:03hrs	0	-30.71	66kV Sesmokra IC	whole s/s fdr.	Supply failed from source.				
2	20.03.2022	14:56hrs	20.03.2022	15:05hrs	0	-28.28	66kV Sesmokra IC	whole s/s fdr.	Supply failed from source.				
3	20.03.2022	14:28hrs	24.03.2022	22:09hrs	104hrs	3.942	66kV Damji Fdr.	Tripped at Semtokha IC	While test charging fdr was not hold; then Olakha TMD team had started doing line patrolling about three days; however TMD didn't find the fault; later fault was at Substation side; then				
4	23.03.2022	22:43hrs	23.03.2022	22:50hrs	0	-19.48	66kV Sesmokra IC	whole s/s fdr.	Supply failed from source.				
5	25.03.2022	20:25hrs	28.03.2022	16:51hrs	66hrs	3.957	66kV Damji Fdr.	Damji line	Tripped on over current & Earthfault relay optd.	O/C & E/F relay, 86A, 86B	Damji S/S	Tripped	Operator observed heavy spark in Y phase Cable joint at Damji end it took few days to repair the cable and charging the fdr.
66KV side Shut down													
1	09.03.2022	11:05hrs	09.03.2022	13:07hrs	2hrs	4.081	66kV Damji Fdr.	Damji line	Shut down taken by Lobeysa TMD team to cleared the ROW of Damji line toward Gasa site.				
(H) 66/11kV Haa Substation													
1	19.03.2022	12:35	19.03.2	12:44	0	-2.01	All the feeders	unknown	O/C	Chumdo	Supply failed from Chomdo substation on operating over current. The same was normalised from their end.	Supply failed from Pangbesa substation on operating over current. The same was normalised from their end.	
(I) 220kV Substation Semtokha													
1	20.03.2022	14:26hrs	20.03.2022	14:30hrs		29.020	66kV Sem-Dechencholing Line	Dechencholing Substation	Earth Fault	Dist. Trip, In>> trip		Transient	
2	20.03.2022	14:33hrs	20.03.2022	14:40hrs		29.020	66kV Sem-Dechencholing Line	Dechencholing Substation	Earth Fault	Dist. Trip, In>> trip		Transient	
3	20.03.2022	14:58hrs	20.03.2022	15:04hrs		14.330	66kV Sem-Dechencholing Line	Dechencholing Substation	Earth Fault	Dist. Trip, In>> trip		Transient	
4	23.03.2022	22:46hrs	23.02.2022	22:50hrs		19.580	66kV Sem-Dechencholing Line	Dechencholing Substation	Earth Fault	Dist. Trip, In>> trip		Transient	
J)66/33/11kV Pangbesa substation													
1	19.03.2022	12:30hrs	19.03.2022	12:35hrs	0	1.45	Haa line out	Haa substation	O/C	Distance		transient	Sunny weather
(L) 66/33kV Damji Substation													
1	07.03.2022	12:55 hrs	07.03.2022	13:06 hrs	0	-3.94	66 kV Incoming Line	Whole Substation	Trip	NA			Line tripped from Semtokha Substation
2	09.03.2022	11:00	09.03.2022	13:09 hrs	2	-3.97	66 kV Incoming Line	Whole Substation	Shutdown	NA			Shutdown avail by Mr. Karma Wangda, TLSMD, Lobesa for RoW clearing
3	20.03.2022	14:25 hrs	24.03.2022	22:09 hrs	127	-3.9	66 kV Incoming Line	Whole Substation	Trip	NA			66 kV Line Fault due to cable termination kit failure at Gantry of Damji Substation. Used Incomer II cable
4	25.03.2022	20:25 hrs	28.03.2022	16:53 hrs	92	-3.9	66 kV Incoming Line	Whole Substation	Trip	NA			66 kV Line Fault due to cable termination kit failure at Incomer II of Gantry at Damji Substation. Restore incomer I cable. Closed CB of 66 kV line at 1824 hrs

