

Bhutan Power Corporation Limited

Bhutan Power System Operator

Thimphu: Bhutan



Transmission System Performance Report

Third Quarterly Report – April to June, 2021



Table of Contents

1. INTRODUCTION 2

2. NATIONAL PEAK DEMAND 2

2.1. POWER (MW) CONSUMED BY COUNTRY 2

3. ENERGY AVAILABILITY AND REQUIREMENT FOR THE COUNTRY 3

3.1. ENERGY (MU) CONSUMED BY COUNTRY 3

4. PERFORMANCE OF GENERATING PLANTS 4

4.1. POWER AND ENERGY GENERATION 4

4.2. PLANT CAPACITY FACTOR 5

5. EXPORT AND IMPORT OF ELECTRICITY 5

6. FREQUENCY PROFILE 6

6.1. FREQUENCY FOR THE MONTH OF APRIL, 2020 6

6.2. FREQUENCY FOR THE MONTH OF MAY, 2020 7

6.3. FREQUENCY FOR THE MONTH OF JUNE, 2020 8

6.4. FREQUENCY SUMMARY FOR THE MONTH OF APRIL TO JUNE, 2020 8

7. VOLTAGE PROFILE OF SELECTED SUBSTATION 9

7.1. VOLTAGE PROFILE FOR THE APRIL, 2020 9

7.2. VOLTAGE PROFILE FOR MONTH OF MAY, 202010

7.3. VOLTAGE PROFILE FOR THE MONTH OF JUNE, 202012

7.4. VOLTAGE SUMMARY FOR THE MONTH OF APRIL TO JUNE, 202013

8. MAJOR OUTAGES OF FEEDERS AND EQUIPMENT 13

8.1. MAJOR OUTAGES IN EASTERN GRID13

8.2. MAJOR OUTAGES IN WESTERN GRID13

9. ANNEXURES 14

1. Introduction

The electricity transmission network in Bhutan is solely owned by Bhutan Power Corporation limited (BPC) and electricity generation is solely owned by Druk Green Power Corporation Limited (DGPC). Bhutan Power System Operator (BPSO) under BPC is responsible for safe, secure and efficient operation of Bhutan transmission network and generation.

This quarterly report is prepared in compliance to the Grid Code Regulation (GCR) 2008, clause 6.14.1, “System Operator has to submit a quarterly report covering the performance of the Transmission System to all Licensees, Authority and Ministry”. This transmission performance report contains summary of growth of peak demand, performance of generating stations (power and energy generation), energy availability and requirement for the country, export and import of electricity to/ from India, frequency profile of selected substation and voltage profile of few important substations.

All the index and other calculations in this report have been executed based on the data received from substations and generating plants.


2. National Peak Demand

The national peak demand till now is recorded at **399.35MW** which was occurred on December 27, 2018 at 18:18 hours. This is calculated by summation of Feeder Loading at Plants minus Export.

Table 2.1. The National Peak Demand since 2007

Year	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
Peak Load (MW)	157.36	187.05	237.17	256.95	276.24	282.44	313.94	333.41	336.52	335.87	362.09	399.35	387.66	374.53
% Growth over previous Year	-	18.87	26.79	8.34	7.51	2.24	11.15	6.20	0.93	-0.19	7.81	10.29	-2.93	-3.39

Graph 2.1. The growth in National Peak Demand since 2007



2.1. Power (MW) consumed by country

Following methods are used to calculate peak demand for the Eastern Grid, Western Grid and National demand.

1. **National Demand** = (Sum of all total generation)-(Sum of all Export of Import)
2. **National Demand** = (Sum of all feeders loading at hydropower station) – (Sum of all Export/Import)
3. **National Demand** = (Sum of all substation loading)


For this report, the National Demand was calculated using method-3.



Table 2.1.2. Domestic demand for Eastern Grid, Western Grid and National using method- 3

Grid	Eastern Grid Load (MW)		Western Grid Load (MW)		National Load (MW)	
	Max	Min	Max	Min	Max	Min
April	2.38	0.52	251.62	142.39	320.31	185.68
May	1.83	0.36	235.12	120.64	304.53	170.15
June	2.06	0.01	328.00	119.17	362.79	132.89

Graph 2.1.2. Domestic demand for Eastern Grid, Western Grid and National using method- 3



The national load pattern for the month of April to June, 2021 calculated using method-3 is attached as **Annexure-II**

3. Energy Availability and Requirement for the country

3.1. Energy (MU) consumed by Country

The total energy consumed within Bhutan is computed from the total energy DGPC had sold to BPC including the royalty energy.

Table 3.1.1. Total Energy (MU) consumed

Month	Total Ex-bus (MU)	Total Export/Import (MU)	Total energy sold to BPC (MU)
April	345.38710969	152.66528988	192.72182069
May	789.01377024	605.78081100	183.23295924
June	1394.53432065	1188.06521019	206.46911045

Graph 3.1.1. Total Energy (MU) consumed





Table 3.1.2. Energy (MU) consumed

Grid	Eastern Grid Consumption	Western Grid Consumption	Total Consumption
Month	(MU)	(MU)	(MU)
April	37.372647000	149.899396	187.2720434
May	32.909221500	141.615677	174.524899
June	35.29364700	156.504260	191.7979066

Graph 3.1.2. Energy (MU) consumed



4. Performance of generating plants

4.1. Power and Energy Generation


The maximum total generation for the second quarter of year 2021 was 2452.34 MW in month of May and minimum generation was 1222.88 MW in the April month.

Table: 4.1.1 Summary of maximum and minimum generation by various hydropower plant

Generation By	BHP (MW)		CHP (MW)		THP (MW)		KHP (MW)		DHP (MW)		MHPA (MW)		TOTAL (MW)	
	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min
April	21.83	4.41	182.08	49.24	263.81	27.60	60.33	10.08	25.02	11.06	357.70	19.70	910.77	122.10
May	65.84	4.12	278.79	124.81	1,122.00	270.00	66.18	31.58	126.92	17.16	792.05	180.03	2,451.78	627.70
June	65.79	0.00	369.79	217.70	1,122.00	430.00	66.00	12.67	127.47	0	594.06	190.64	2,345.11	851.01

Source: Hydropower Plants (DGPC)

Graph: 4.1.1 Summary of maximum and minimum generation by various hydropower plant



Daily maximum, minimum and average generation by each generating plant for the month of April to June, 2021 is attached as **Annexure-I**.

4.2.Plant Capacity Factor

The capacity factor of each generating plant was calculated as below:


$$Capacity\ factor = \frac{Total\ energy\ plant\ has\ produce\ over\ a\ period}{Total\ energy\ plant\ would\ produce\ when\ operated\ at\ full\ capacity}$$

Table 4.2.1: Total generation and capacity factor of various hydropower plants

Month	BHP (MU)	BHP (CF)	CHP (MU)	CHP (CF)	THP (MU)	THP (CF)	KHP (MU)	KHP (CF)	DHP (MU)	DHP (CF)	MHP (MU)	MHP (CF)
April	9.82938	21.33%	64.49959	26.66%	131.146909	17.86%	19.374278	44.85%	10.61	11.70%	109.92	21.20%
May	17.52197	36.80%	143.26610	57.31%	313.24436	41.28%	39.439818	88.35%	20.47452	21.84%	255.067	47.62%
June	9.82938	21.33%	64.49959	26.66%	626.88145	85.36%	19.374278	44.85%	10.61	11.70%	109.92	21.20%

Source: TD, BPC

Graph 4.2.1: Capacity factor of various hydropower plants



5. Export and Import of Electricity

Maximum export for the second quarter of year 2021 was 1,041.00 MW in the month of May to Binaguri substation in India. The minimum export recorded was 0.16 MW to Salakoti and Rangia substation in India during the month of April.

Table 5.1. Export of electricity to India

Export To	Binaguri (MW)		Birpara (MW)		Salakoti and Rangia (MW)	
	Max	Min	Max	Min	Max	Min
April	194.00	11.00	67.40	0.30	33.61	0.16
May	1,041.00	211.00	228.47	2.10	106.55	0.59
June	238.00	1.00	319.50	11.00	165.23	16.94

Graph 5.1. Export of electricity to India




Table 5.2. Import of electricity from India.

Import From	Binaguri (MW)		Birpara (MW)		Salakoti and Rangia (MW)	
	Max	Min	Max	Min	Max	Min
April	0.00	0.00	65.02	0.03	45.50	0.03
May	0.00	0.00	25.30	1.20	29.03	0.17
June	297.00	1.00	0.00	0.00	18.03	18.03

6. Frequency profile

The nominal allowed frequency range shall be 50Hz \pm 1% in Bhutan. The system is normally managed such that frequency is maintained within operational limit of 49.5 Hz to 50.5 Hz. However, frequency may move outside these limit under faulty condition.

As per the Grid Code 2008, clause 6.4.1 the frequency is classified into three different bands as follows:

- Normal state
The transmission System frequency is within the limit of 49.5Hz to 50.5Hz.
- Alert state
The Transmission System frequency is beyond the normal operating limit but within 49.0Hz to 50.0Hz.
- Emergency state
There is generation deficiency and frequency is below 49.0Hz.

The frequency at 220kV Bus at 220/66/11kV Semtokha substation in the western grid and 132kV Bus at 60MW Kurichhu Hydropower Plant in the eastern grid is considered.

6.1.Frequency for the month of April, 2021

Table 6.1.1. Bus Frequency profile of Semtokha Substation

Sl. No.	Operating State	Frequency
1	Normal State	100.00%
2	Alert State	0.00%
3	Emergency State	0.00%
4	Blackout/Other	0.00%

Graph 6.1.1. Bus Frequency of Semtokha Substation





Table 6.1.2. Bus frequency of Kurichhu Hydro Power Plant

Sl. No.	Operating State	Frequency
1	Normal State	96.51%
2	Alert State	0.00%
3	Emergency State	0.13%
4	Blackout/Other	3.36%

Graph 6.1.2. Bus frequency of Kurichhu Hydro Power Plant



In the month of April, 2021, the Western grid has maintained the frequency within the normal operating limit of 100% and Eastern grid have managed to operate the frequency within normal operating limit of 96.51% where 0.13% was deviated to Emergency state and 3.36 % was deviated to blackout and other.

6.2.Frequency for the month of May, 2021

Table 6.2.1. Bus frequency of Semtokha Substation

Sl. No.	Operating State	Frequency
1	Normal State	100.00%
2	Alert State	0.00%
3	Emergency State	0.00%
4	Blackout/Other	0.00%

Graph 6.2.1. Bus frequency of Semtokha Substation





Table 6.2.2. Bus frequency of Kurichhu Hydro Power Plant

Sl. No.	Operating State	Frequency
1	Normal State	99.73%
2	Alert State	0.27%
3	Emergency State	0.00%
4	Blackout/Other	0.00%

Graph 6.2.2. Bus frequency of Kurichhu Hydro Power Plant



In the month of May, 2021, the western grid frequency was maintained at normal operating range of 100% whereas Eastern grid was maintained 99.73% in normal operating range and deviated 0.27% to alert state.

6.3.Frequency for the month of June, 2020

Table 6.3.1. Bus frequency of Semtokha Substation

Sl. No.	Operating State	Frequency
1	Normal State	100.00%
2	Alert State	0.00%
3	Emergency State	0.00%
4	Blackout/Other	0.00%

Graph 6.3.1. Bus frequency of Semtokha Substation





Table 6.3.2. Bus frequency of Kurichhu Hydro Power Plant

Sl. No.	Operating State	132kV Bus Voltage
1	Normal State	96.77%
2	Alert State	0.00%
3	Emergency State	0.00%
4	Blackout/Other	3.23%

Graph 6.3.2. Bus frequency of Kurichhu Hydro Power Plant




In the month of June, 2021, western grid frequency had maintained at 100 % within the normal operating range and deviated other to blackout/other state. The eastern also maintain almost same as western with 96.77 % within normal operating lime and deviated 3.23 % to blackout/other state.

6.4.Frequency Summary for the month of April to June, 2020

Table 6.4.1. Frequency summary for the month of April to June, 2021.

Substation/Plant	Bus Frequency at Semtokha Substation (Hz)		Bus Frequency at Kurichhu Hydropower Plant (Hz)	
	Max	Min	Max	Min
April	50.10	49.80	50.14	0.06
May	50.10	49.80	50.50	49.40
June	50.10	49.80	50.50	0.00

Graph 6.4.1. Frequency summary for the month of April to June, 2021



Daily maximum, minimum and average Frequency of Malbase substation in western grid and Kurichhu Hydro Power Plant in eastern grid for the month of April to June, 2021 is attached as **Annexure-III**

7. Voltage Profile of selected substation

As per the Grid Code 2008, clause 6.4.1 the voltage at all connection point is classified into three different bands as follows:

1. *Normal State*
The voltage at all connection points are within the limits of 0.95 times and 1.05 times of the normal values
2. *Alert State*
The voltage at all connection points are outside the normal limit but within the limits of 0.9 times and 1.1 times of the nominal values.
3. *Emergency State*
Transmission system voltages are outside the limit of 0.9 times and 1.1 times of nominal values.


Due to the location of 400/22/66/11kV Malbase substation in western grid and 132/33/11kV Nangkhor substation in the eastern grid, the voltage profile of these substations are considered.

7.1.Voltage profile for the April, 2021

Table 7.1.1. Voltage Profile for 400/220/66kV Malbase Substation

Sl. No.	Operating State	400kV Bus Voltage	220kV Bus Voltage	66kV Bus Voltage
1	Normal State	98.39%	100.00%	100.00%
2	Alert State	1.61%	0.00%	0.00%
3	Emergency State	0.00%	0.00%	0.00%
4	Blackout/Other	0.00%	0.00%	0.00%

Graph 7.1.1. Voltage Profile for 400/220/66kV Malbase Substation






Table 7.1.2. Voltage Profile of 220/66/11kV Semtokha Substation

Sl. No.	Operating State	220kV Bus Voltage	66kV Bus Voltage
1	Normal State	96.64%	96.64%
2	Alert State	0.00%	0.00%
3	Emergency State	0.13%	0.13%
4	Blackout/Other	3.23%	3.23%

Graph 7.1.2. Voltage Profile of 220/66/11kV Semtokha Substation





Table 7.1.3. Voltage Profile of 132/33/11kV Nangkor Substation

Sl. No.	Operating State	132kV Bus Voltage
1	Normal State	96.51%
2	Alert State	0.00%
3	Emergency State	0.00%
4	Blackout/Other	3.49%

Graph 7.1.3. Voltage Profile of 132/33/11kV Nangkor Substation



7.2. Voltage Profile for month of May, 2021

Table 7.2.1. Voltage Profile for 400/220/66kV Malbase Substation

Sl. No.	Operating State	400kV Bus Voltage	220kV Bus Voltage	66kV Bus Voltage
1	Normal State	99.46%	100.00%	100.00%
2	Alert State	0.54%	0.00%	0.00%
3	Emergency State	0.00%	0.00%	0.00%
4	Blackout/Other	0.00%	0.00%	0.00%

Graph 7.2.1. Voltage Profile for 400/220/66kV Malbase Substation




Table 7.2.2. Voltage Profile of 220/66/11kV Semtokha Substation

Sl. No.	Operating State	220kV Bus Voltage	66kV Bus Voltage
1	Normal State	99.33%	99.33%
2	Alert State	0.13%	0.00%
3	Emergency State	0.27%	0.40%
4	Blackout/Other	0.27%	0.27%

Graph 7.2.2. Voltage Profile of 220/66/11kV Semtokha Substation





Table 7.2.3. Voltage Profile of 132/33/11kV Nangkor Substation

Sl. No.	Operating State	132kV Bus Voltage
1	Normal State	99.73%
2	Alert State	0.13%
3	Emergency State	0.00%
4	Blackout/Other	0.13%

Graph 7.2.3. Voltage Profile of 132/33/11kV Nangkor Substation



7.3.Voltage Profile for the month of June, 2021

Table 7.3.1. Voltage Profile for 400/220/66kV Malbase Substation

Sl. No.	Operating State	400kV Bus Voltage	220kV Bus Voltage	66kV Bus Voltage
1	Normal State	96.77%	96.51%	96.77%
2	Alert State	0.00%	0.27%	0.00%
3	Emergency State	0.00%	0.00%	0.00%
4	Blackout/Other	3.23%	3.23%	3.23%

Graph 7.3.1. Voltage Profile for 400/220/66kV Malbase Substation




Table 7.3.2. Voltage Profile of 220/66/11kV Semtokha Substation

Sl. No.	Operating State	220kV Bus Voltage	66kV Bus Voltage
1	Normal State	96.51%	96.64%
2	Alert State	0.00%	0.00%
3	Emergency State	0.27%	0.00%
4	Blackout/Other	3.23%	3.36%

Graph 7.3.2. Voltage Profile of 220/66/11kV Semtokha Substation





Table 7.3.3. Voltage Profile of 132/33/11kV Nangkhor Substation

Sl. No.	Operating State	132kV Bus Voltage
1	Normal State	96.77%
2	Alert State	0.00%
3	Emergency State	0.00%
4	Blackout/Other	3.23%

Graph 7.3.3. Voltage Profile of 132/33/11kV Nangkhor Substation




7.4.Voltage Summary for the Month of April to June, 2021

Table 7.4.1. Voltage Summary for the month of April to June, 2021

Substation	Malbase Substation						Nangkor Substation	
	400kV Bus Voltage (kV)		220kV Bus Voltage (kV)		66kV Bus Voltage (kV)		132kV Bus Voltage (kV)	
Month	Max	Min	Max	Min	Max	Min	Max	Min
April	423.00	401.50	227.50	212.50	68.00	64.00	137.77	128.21
May	421.50	400.00	229.00	211.00	69.00	63.00	139.43	129.66
June	420.00	395.97	249.00	211.58	66.00	62.96	137.90	128.61

Graph 7.4.1. Voltage Summary for the month of April to June, 2021



Daily maximum, minimum and average bus voltage of Malbase substation in western grid and Nangkor substation in eastern grid for the month of April to June, 2021 is attached as **Annexure-IV**

8. Major Outages of Feeders and Equipment

The transmission lines and equipment which were shut down for annual maintenance and hand/force trip are not considered in the report.

8.1.Major Outages in Eastern Grid

It had been observed that there was multiple tripping occurred during the second quarter of the year compare to the previous quarter. Generally, all the tripping occurred are of transient in nature or temporary fault which have been restored within few minutes. The 132kV Kanglung-Phuntshothang feeder tripped and the duration of outage was 28hrs due to Tripped on AN, Zone-1, Fault Current: IA -624A, IB -39A, IC -53A, Fault Location: 29.59km, OC/EF IA-607A, IB-42A, IC-52A.

The feeders and equipment outages for the Eastern grid is attached as **Annexure-V**.

8.2.Major Outages in Western Grid

It had been observed that there was multiple tripping occurred during the second quarter of the year, the 66kV Malbase- Phuntsholing feeder was under idle charge condition since 66kV chukha-Phuntsholing got tripped at both end for 13hrs. Again 66kV Malbase-Phuntsholing feeder was under idle charge since 66kB Pling-Gomtu feeder got tripped at both end for 14 hrs. 66/33kV Damji Station - 66kv incoming line was tripped at 10:48 hrs and line at Damji Substation had been back feed from Punakha at 14:07 hrs. 66kv line charged at 15:40 hrs as per the closing code 1961 from BPSO.



The detail tripping report of any element is compiled and circulated to relevant stakeholder every month.

The feeders and equipment outages for the Western grid is attached as **Annexure-VI**.

9. Annexures

Annexure-I

Table: Generation of April, 2021

Apr-21 Date	BHP (MW)			CHP (MW)			THP (MW)			KHP (MW)			DHP (MW)			MHP (MW)			
	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	
1	21.20	14.51	17.76	135.49	82.57	99.62	157.68	27.61	90.14	39.34	20.13	27.45	18.98	16.17	17.69	200.09	109.78	137.89	
2	18.61	14.83	16.15	117.37	88.47	102.27	167.62	27.61	52.64	45.35	24.08	31.64	19.70	17.16	18.21	193.41	109.46	141.64	
3	15.06	13.45	14.32	110.03	71.60	84.04	87.67	27.60	37.64	22.29	20.18	21.80	16.85	15.65	16.15	115.23	110.11	114.22	
4	13.99	12.92	13.62	97.23	69.18	77.67	187.64	87.61	104.31	24.27	20.13	22.37	16.37	15.00	15.46	149.79	105.00	117.05	
5	14.10	12.06	13.27	100.12	70.13	76.56	207.66	87.60	123.21	24.29	20.13	21.34	15.36	14.65	15.15	114.94	104.96	110.13	
6	14.13	13.32	13.65	98.93	69.75	75.55	147.68	87.61	124.29	32.20	16.48	24.95	15.09	14.65	14.89	159.70	115.05	132.88	
7	15.51	13.11	13.80	160.99	69.56	96.96	147.67	113.82	127.83	32.20	20.16	26.16	15.16	14.15	14.69	154.81	124.63	135.70	
8	14.14	13.39	13.79	168.71	78.30	123.70	73.86	60.00	70.94	24.19	20.16	20.46	15.47	14.18	15.03	127.11	110.07	114.14	
9	17.73	12.90	14.48	75.91	49.24	71.22	160.00	60.00	80.83	26.24	20.11	22.63	16.47	14.17	15.43	129.92	109.96	124.31	
10	16.36	13.31	14.53	75.43	70.38	71.43	160.00	160.00	160.00	32.27	20.19	26.95	15.47	14.67	15.10	189.60	44.00	163.39	
11	15.63	11.50	13.95	106.02	70.86	86.88	130.00	130.00	130.00	32.24	10.08	27.55	17.18	14.65	15.28	184.97	139.91	159.23	
12	14.24	13.14	13.63	94.81	82.52	85.01	150.00	130.00	134.17	29.04	24.19	27.30	15.16	14.64	14.88	149.93	127.60	143.69	
13	13.76	12.49	13.31	91.33	80.35	82.56	150.00	130.00	133.33	32.25	25.17	28.25	14.67	14.15	14.37	149.93	124.80	141.67	
14	14.57	12.59	13.21	81.61	76.13	77.08	130.00	130.00	130.00	60.33	24.14	27.40	14.64	14.08	14.36	149.79	126.64	137.71	
15	13.86	12.47	13.32	88.23	73.27	78.74	130.00	80.00	127.92	30.31	20.19	24.16	15.01	14.03	14.60	179.69	129.84	151.50	
16	13.55	12.90	13.17	87.12	80.10	83.54	133.81	60.00	80.82	32.41	20.15	26.45	15.04	11.06	14.10	159.84	129.90	144.64	
17	13.75	12.56	13.05	88.80	74.78	84.03	163.84	73.80	122.15	30.21	22.20	24.27	15.26	13.94	14.75	154.71	99.16	131.38	
18	14.05	12.90	13.29	87.50	76.26	79.80	163.84	133.80	146.73	32.82	24.13	27.81	14.96	14.23	14.50	259.81	124.73	163.70	
19	14.48	12.66	13.42	107.40	84.03	96.26	243.83	153.80	177.56	39.40	30.13	34.66	15.70	14.44	15.09	260.17	174.50	198.58	
20	14.64	12.70	13.88	136.85	90.42	112.56	243.86	183.81	213.40	43.21	22.18	26.99	14.76	14.26	14.63	180.26	144.34	155.52	
21	14.02	13.04	13.44	182.08	91.02	115.75	253.82	153.80	177.14	32.51	22.15	25.98	15.17	14.38	14.55	166.32	19.70	129.22	
22	21.83	13.21	15.04	114.10	75.01	87.88	173.84	173.80	173.81	45.32	20.23	24.44	20.00	13.94	15.45	179.73	129.94	151.36	
23	17.60	13.10	14.66	137.15	89.39	117.86	173.84	153.79	162.98	32.04	23.02	25.68	19.98	14.21	16.48	179.78	100.23	146.72	
24	14.76	12.64	13.51	134.22	80.70	103.65	153.83	153.79	153.81	32.67	24.18	27.64	14.96	14.23	14.48	190.12	138.02	161.41	
25	13.71	12.11	13.14	115.10	89.70	95.99	153.84	153.80	153.82	32.57	24.21	27.85	14.58	13.96	14.24	185.47	140.15	162.29	
26	13.47	4.41	12.55	121.54	93.82	104.51	153.84	153.78	153.81	48.40	28.23	35.00	14.23	13.73	13.98	357.70	170.37	216.61	
27	16.81	11.63	12.90	122.75	90.15	108.90	263.81	133.80	172.98	42.36	28.24	32.30	13.96	13.17	13.62	259.83	166.83	194.33	
28	16.04	12.29	13.00	128.09	100.53	106.30	253.83	133.82	205.90	43.89	28.97	35.63	25.02	13.40	15.63	264.99	184.66	223.57	
29	15.70	12.47	13.50	116.73	95.71	106.13	263.81	103.80	208.39	32.22	26.00	28.88	19.97	14.32	16.54	210.05	154.89	179.65	
30	13.65	12.51	12.88	109.18	91.79	104.19	263.81	163.80	192.56	45.18	28.26	34.66	15.37	11.97	14.10	215.18	170.09	180.88	
31	0.00	No Generation	Error	0.00	No Generation	Error	0.00	No Generation	Error	0.00	No Generation	Error	0.00	No Generation	Error	0.00	No Generation	Error	
Max	21.83			182.08			263.81			60.33			25.02			357.70			
Min		4.41			49.24			27.60			10.08			11.06			19.70		

Source: THP, CHP, BHP, KHP, MHP (DGPC)

Graph: Generation for the month April, 2021






Table: Generation for the month of May, 2021

Date	BHP (MW)			CHP (MW)			THP (MW)			KHP (MW)			DHP (MW)			MHP (MW)			
	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	
1	13.63	11.84	12.95	193.34	154.39	173.51	380.00	300.00	330.83	66.00	31.58	47.17	32.00	24.00	28.13	274.73	199.46	231.19	
2	13.37	12.04	12.57	268.33	179.63	203.79	450.00	370.00	400.42	66.00	33.00	60.15	32.00	23.00	24.92	299.17	210.04	246.80	
3	24.32	4.12	14.97	226.21	194.66	204.79	450.00	380.00	416.25	66.00	42.11	52.98	50.33	28.26	38.59	349.59	180.36	258.95	
4	27.94	16.84	22.06	256.38	196.32	217.44	550.00	380.00	451.25	66.11	48.33	59.30	37.29	26.19	29.65	478.66	196.12	296.18	
5	33.62	9.99	19.26	275.01	203.38	233.15	560.00	350.00	470.00	66.18	52.88	65.10	36.17	27.19	30.91	553.28	231.68	393.96	
6	57.07	22.40	30.36	234.88	188.85	212.49	470.00	350.00	421.67	66.00	62.51	65.59	33.21	25.21	29.57	518.90	260.00	348.74	
7	39.24	18.72	25.38	188.84	136.85	178.09	390.00	350.00	360.83	66.00	48.32	61.26	48.41	20.20	25.72	334.07	239.87	269.65	
8	19.46	16.30	17.77	189.88	175.72	181.45	350.00	350.00	350.00	66.00	49.87	62.11	48.19	23.18	33.44	460.86	279.87	349.05	
9	33.23	15.85	18.12	176.79	124.81	152.46	350.00	280.00	307.50	54.06	35.08	44.15	25.22	21.15	22.96	274.99	210.45	238.38	
10	34.20	18.72	22.00	172.63	145.01	156.72	350.00	300.00	306.25	48.49	37.14	43.12	21.19	18.19	20.09	269.74	215.16	245.15	
11	65.22	28.53	43.23	159.31	147.70	156.71	350.00	300.00	307.08	49.32	36.07	43.74	25.00	17.70	19.11	319.61	209.64	247.45	
12	65.22	28.53	43.23	161.88	147.73	152.70	310.00	300.00	305.00	45.00	36.30	39.56	18.18	17.16	17.94	210.46	194.31	201.39	
13	64.79	26.59	40.26	160.09	141.61	147.68	320.00	270.00	292.08	49.50	32.03	42.80	18.70	17.16	17.90	254.73	194.71	231.09	
14	26.42	19.17	22.11	202.15	146.35	152.39	380.00	300.00	303.33	48.48	32.01	41.74	18.21	17.60	17.79	365.07	204.89	225.25	
15	19.56	14.68	18.19	224.26	149.78	177.13	450.00	300.00	354.58	58.35	35.98	48.21	20.19	17.66	18.43	494.70	249.49	341.97	
16	20.26	14.23	16.55	237.95	177.83	216.16	560.00	360.00	472.92	66.00	45.30	63.83	28.18	18.68	23.39	618.84	360.07	451.57	
17	16.40	15.16	16.08	257.40	213.47	228.35	500.00	420.00	467.08	66.00	49.50	63.87	26.17	20.15	23.78	612.36	180.03	358.90	
18	18.05	13.88	15.39	275.10	211.81	237.40	530.00	420.00	469.58	66.00	66.00	66.00	26.18	22.14	24.63	590.14	334.75	422.49	
19	16.51	14.57	15.14	258.66	188.03	231.26	530.00	420.00	467.50	66.00	66.00	66.00	22.17	18.17	20.33	650.69	260.79	435.21	
20	15.67	13.52	14.78	251.97	193.68	211.70	520.00	370.00	435.42	66.00	65.24	65.94	25.19	19.13	21.37	624.31	209.56	431.61	
21	14.86	13.74	14.40	278.72	275.24	276.64	1,122.00	420.00	1,005.88	66.00	49.50	64.37	126.92	29.17	103.28	792.05	719.25	755.73	
22	18.28	13.25	14.15	278.79	274.18	276.99	1,122.00	1,122.00	1,122.00	65.51	48.15	62.21	126.76	117.62	125.94	765.31	720.10	731.62	
23	13.92	13.04	13.46	277.75	275.58	276.73	1,122.00	1,122.00	1,122.00	66.00	65.02	65.68	126.79	63.32	118.19	772.16	763.51	766.62	
24	14.34	12.61	13.37	277.29	275.39	276.47	1,122.00	1,122.00	1,122.00	66.00	49.50	65.31	126.81	65.41	86.79	771.93	660.15	730.90	
25	17.42	13.13	14.60	277.80	275.12	276.66	1,122.00	1,122.00	1,122.00	66.00	66.00	66.00	82.43	55.39	63.09	790.33	613.57	687.62	
26	64.74	7.89	29.69	277.90	274.36	276.71	1,122.00	884.00	1,065.42	66.00	66.00	66.00	87.47	54.16	61.89	756.33	500.56	620.35	
27	65.81	55.56	64.57	277.95	275.40	276.29	935.00	681.00	893.17	66.00	64.84	65.66	84.42	34.22	58.52	774.96	599.51	707.59	
28	65.84	41.09	58.87	277.75	276.00	276.77	831.00	590.00	740.83	66.00	65.62	65.85	90.49	27.21	44.48	629.32	300.08	496.43	
29	42.22	27.27	33.71	278.09	274.44	275.98	700.00	610.00	667.50	66.00	65.03	65.77	56.24	38.23	43.75	540.07	319.99	409.12	
30	30.98	23.29	26.48	276.65	275.26	276.13	710.00	570.00	657.50	66.00	66.00	66.00	50.28	30.22	43.21	510.32	419.89	445.76	
31	38.81	22.53	26.56	277.36	275.18	276.51	690.00	540.00	577.08	66.00	66.00	66.00	55.29	38.42	43.01	549.07	376.39	427.95	
Max	65.84			278.79			1,122.00			66.18			126.92			792.05			
Min		4.12			124.81			270.00			31.58			17.16			180.03		

Source: THP, CHP, BHP, KHP, MHP (DGPC)

Graph: Generation for the month of May, 2021






Table: Generation for the month of June, 2021

Date	BHP (MW)			CHP (MW)			THP (MW)			KHP (MW)			DHP (MW)			MHP (MW)			
	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	
1	31.66	23.42	26.60	333.19	287.76	306.33	607.00	527.00	578.92	66.00	33.00	61.93	45.96	30.01	36.68	539.27	430.00	490.82	
2	49.21	28.11	34.92	327.41	256.45	301.24	660.00	580.00	634.17	66.00	66.00	66.00	69.65	30.99	39.27	518.87	415.04	465.01	
3	29.79	21.34	25.18	278.57	244.73	266.68	540.00	510.00	524.17	66.00	66.00	66.00	31.32	26.24	28.44	493.86	384.74	435.24	
4	24.00	20.47	21.75	256.18	217.70	242.14	510.00	440.00	448.75	66.00	66.00	66.00	52.08	24.02	26.63	454.12	259.28	391.88	
5	20.57	13.14	19.46	288.87	221.04	233.83	480.00	430.00	460.00	66.00	66.00	66.00	24.20	22.49	24.17	569.67	349.23	423.58	
6	26.92	19.58	21.76	292.02	220.15	251.01	680.00	430.00	558.33	66.00	66.00	66.00	34.03	23.50	26.82	508.87	424.45	466.99	
7	54.25	24.14	44.41	367.80	226.95	320.75	998.00	460.00	770.67	66.00	66.00	66.00	81.20	32.99	58.07	592.98	290.35	511.21	
8	59.50	37.07	45.78	368.45	279.47	336.83	920.00	560.00	789.17	66.00	47.80	63.93	70.56	43.20	58.73	594.06	585.27	592.38	
9	52.52	36.09	42.10	292.86	264.77	278.06	680.00	530.00	572.92	66.00	33.00	62.59	64.32	41.19	49.68	593.58	589.21	592.21	
10	34.27	23.70	29.22	331.67	264.41	300.74	750.00	510.00	626.67	66.00	66.00	66.00	52.23	33.96	41.67	593.48	387.84	551.42	
11	30.87	23.49	24.86	330.64	264.98	296.32	680.00	540.00	607.08	66.00	66.00	66.00	33.98	29.96	31.63	593.07	485.21	558.04	
12	64.50	0.00	43.36	369.45	319.47	361.51	1,122.00	650.00	948.25	66.00	65.60	65.93	126.66	30.97	97.23	592.78	494.60	581.63	
13	65.79	24.41	63.34	369.35	367.30	368.26	1,122.00	1,122.00	1,122.00	65.91	65.25	65.52	126.95	120.38	126.23	592.70	591.45	591.99	
14	65.42	44.54	52.17	369.15	367.33	368.22	1,122.00	1,122.00	1,122.00	66.00	33.00	62.24	126.90	74.38	95.34	592.93	493.00	588.05	
15	61.96	18.03	46.23	369.79	367.39	368.60	1,122.00	935.00	1,114.21	66.00	16.50	63.94	126.44	0.00	84.57	593.65	190.64	486.36	
16	50.53	13.84	40.04	369.11	367.33	368.37	1,122.00	1,122.00	1,122.00	66.00	66.00	66.00	107.37	72.31	88.60	593.12	592.06	592.66	
17	43.28	22.68	34.90	369.53	367.96	368.82	1,122.00	1,122.00	1,122.00	66.00	66.00	66.00	126.85	55.31	80.70	593.23	591.94	592.50	
18	52.40	37.72	42.35	368.99	366.69	368.31	1,122.00	935.00	1,114.21	66.00	66.00	66.00	126.92	106.55	122.15	593.39	590.89	592.20	
19	51.62	40.77	46.39	369.63	367.72	368.61	1,122.00	935.00	1,114.21	66.00	66.00	66.00	127.47	116.82	126.42	593.07	491.97	588.00	
20	64.59	42.08	48.30	369.43	366.41	368.34	1,122.00	1,122.00	1,122.00	66.00	66.00	66.00	126.85	126.56	126.75	592.62	588.80	591.33	
21	65.13	38.81	45.82	369.33	276.79	358.68	1,122.00	935.00	1,083.04	66.00	65.87	65.99	126.87	100.20	112.02	593.27	591.39	592.21	
22	65.34	34.45	41.93	369.53	367.70	368.53	1,122.00	935.00	1,083.04	66.00	66.00	66.00	113.40	80.31	90.72	592.64	591.43	592.13	
23	63.21	37.46	47.36	369.45	367.48	368.26	1,122.00	935.00	1,106.42	66.00	65.09	65.52	123.54	79.42	96.03	592.58	591.26	592.04	
24	39.67	31.89	35.95	369.37	275.65	354.68	1,122.00	935.00	1,090.83	65.76	65.04	65.44	84.42	68.34	74.24	592.92	590.67	592.15	
25	48.32	27.10	35.36	369.43	367.27	368.37	1,122.00	801.00	908.21	64.00	16.50	46.01	79.32	64.32	70.06	592.84	394.12	542.90	
26	65.20	44.90	58.61	369.32	367.00	368.35	1,048.00	827.00	872.29	66.00	33.00	53.63	126.88	65.34	84.53	593.59	591.57	592.70	
27	65.43	47.11	56.36	369.18	367.08	368.36	917.00	770.00	856.67	66.00	66.00	66.00	111.60	66.32	82.16	593.11	526.90	583.10	
28	52.14	42.46	46.92	369.32	367.66	368.61	820.00	650.00	756.25	66.00	66.00	66.00	103.46	70.28	80.45	592.14	510.13	549.59	
29	65.56	39.65	46.45	369.69	276.07	338.20	960.00	690.00	759.58	66.00	66.00	66.00	75.38	62.26	68.22	592.94	590.19	591.93	
30	65.59	53.47	62.22	369.25	366.57	368.20	1,122.00	935.00	1,061.75	66.00	12.67	61.03	126.97	74.39	110.19	593.21	591.91	592.58	
31	0.00	No Generation	Error	0.00	No Generation	Error	0.00	No Generation	Error	0.00	No Generation	Error	0.00	No Generation	Error	0.00	No Generation	Error	
Max	65.79			369.79			1,122.00			66.00			127.47			594.06			
Min		0.00			217.70			430.00			12.67			0.00			190.64		

Graph: Generation for the month of June, 2021






Table: National demand for April, 2021

Graph: National Demand for April, 2021

Annexure-II

Apr-21	Max	Min	Ava
0:00	244.56	200.36	225.03
1:00	245.27	196.25	221.65
2:00	241.57	185.68	218.98
3:00	238.33	194.56	217.98
4:00	254.40	195.17	220.45
5:00	263.49	197.89	225.31
6:00	283.86	227.86	251.92
7:00	308.58	236.26	269.86
8:00	295.95	231.98	267.21
9:00	296.84	226.16	263.71
10:00	300.19	224.60	261.44
11:00	299.64	236.17	261.39
12:00	290.36	233.63	261.84
13:00	285.25	229.98	256.72
14:00	287.01	213.22	253.02
15:00	289.06	217.57	252.84
16:00	304.01	228.09	255.05
17:00	295.05	232.37	259.26
18:00	299.46	234.91	263.69
19:00	320.31	262.66	286.86
20:00	318.79	262.26	285.15
21:00	305.67	245.45	271.68
22:00	274.36	222.28	250.97
23:00	257.00	207.86	233.59
	320.31		
		185.68	




Table: National Demand for May, 2021

Graph: National Demand for May, 2021

May-21	Max	Min	Ava
0:00	239.61	174.34	206.66
1:00	230.54	170.15	202.69
2:00	230.27	171.64	201.65
3:00	225.42	173.59	201.95
4:00	228.82	174.41	201.86
5:00	234.16	179.37	209.04
6:00	281.02	205.46	235.65
7:00	292.56	222.53	249.18
8:00	283.22	223.35	249.54
9:00	277.23	219.50	243.40
10:00	283.83	202.34	240.61
11:00	289.51	202.39	241.51
12:00	291.49	203.30	241.63
13:00	273.31	203.34	234.91
14:00	275.15	189.27	231.38
15:00	272.56	197.97	232.92
16:00	278.51	196.94	233.71
17:00	284.31	207.65	240.05
18:00	282.50	223.27	242.44
19:00	304.53	235.31	263.02
20:00	299.86	231.09	264.67
21:00	282.40	220.81	247.96
22:00	263.42	202.11	228.76
23:00	242.33	180.80	212.78
	304.53		
		170.15	







Table: National Demand for June, 2021

Graph: National Demand for June, 2021

Jun-21	Max	Min	Ava
0:00	217.47	143.18	183.75
1:00	216.41	141.12	181.62
2:00	211.32	148.15	184.58
3:00	215.87	132.89	184.54
4:00	211.97	142.98	185.96
5:00	222.26	163.93	197.00
6:00	251.77	189.11	222.79
7:00	260.53	198.88	232.24
8:00	262.51	189.12	228.03
9:00	272.18	190.10	227.53
10:00	277.87	175.56	225.52
11:00	276.22	177.45	224.86
12:00	271.78	168.87	225.57
13:00	264.49	178.88	219.46
14:00	260.47	158.16	216.47
15:00	267.26	159.67	217.45
16:00	261.87	152.10	215.80
17:00	260.01	160.58	216.05
18:00	253.50	173.04	218.05
19:00	270.84	202.86	233.08
20:00	313.66	195.59	241.89
21:00	281.86	180.33	221.05
22:00	362.79	168.62	205.84
23:00	217.04	149.33	189.69
	362.79		
		132.89	



Annexure-III

Table: Daily maximum, minimum and average frequency for the month of April, 2021

Apr-21 Date	Bus Frequency at Semtokha Substation			Bus Frequency at Kurichhu Hydropower Plant		
	Max	Min	Ava	Max	Min	Ava
1	50.10	49.90	49.98	50.12	49.73	49.96
2	50.00	49.90	49.98	50.07	49.86	49.98
3	50.00	49.80	49.96	50.09	49.80	49.96
4	50.00	49.80	49.95	50.07	0.06	47.92
5	50.00	49.80	49.97	50.10	49.78	49.95
6	50.00	49.80	49.97	50.12	49.78	50.00
7	50.00	49.90	49.97	50.09	49.81	49.97
8	50.00	49.80	49.95	50.05	49.83	49.99
9	50.00	49.80	49.95	50.10	49.82	50.01
10	50.10	49.80	49.97	50.09	49.86	50.00
11	50.10	49.90	49.98	50.10	49.91	50.01
12	50.00	49.80	49.97	50.12	49.87	49.99
13	50.00	49.90	49.95	50.06	49.92	50.00
14	50.00	49.90	49.96	50.10	49.85	50.00
15	50.10	49.90	49.96	50.08	49.79	49.99
16	50.00	49.90	49.97	50.14	49.82	49.99
17	50.00	49.90	49.98	50.05	49.81	49.97
18	50.00	49.90	49.96	50.08	49.84	49.99
19	50.00	49.90	49.96	50.07	49.76	50.00
20	50.00	49.80	49.95	50.09	49.85	50.00
21	50.10	49.90	49.98	50.09	49.78	49.99
22	50.00	49.80	49.95	50.10	49.83	50.00
23	50.00	49.80	49.95	50.09	49.89	50.01
24	50.00	49.90	49.96	50.12	49.78	50.00
25	50.00	49.80	49.95	50.12	49.86	50.00
26	50.00	49.90	49.96	50.11	49.80	50.00
27	50.10	49.90	49.98	50.12	49.90	50.02
28	50.10	49.80	49.98	50.08	49.91	50.00
29	50.00	49.80	49.97	50.11	49.90	50.01
30	50.00	49.80	49.95	50.07	49.86	50.00
31	0.00	0.00	0.00	0.00	0.00	0.00
Max	50.10			50.14		
Min		0.00			0.00	

Source: TD (BPC), KHP (DGPC)

Graph: Daily maximum, minimum and average frequency for the month of April, 2021




Table: Daily maximum, minimum and average frequency for the month of May, 2021

May-21 Date	Bus Frequency at Semtokha Substation			Bus Frequency at Kurichhu Hydropower Plant		
	Max	Min	Ava	Max	Min	Ava
1	50.10	49.90	49.98	50.15	49.92	50.03
2	50.00	49.90	49.98	50.08	49.90	50.02
3	50.00	49.80	49.96	50.07	49.70	50.01
4	50.00	49.80	49.95	50.09	49.93	50.01
5	50.00	49.80	49.97	50.15	49.92	50.01
6	50.00	49.80	49.97	50.15	49.92	50.03
7	50.00	49.90	49.97	50.07	49.90	50.01
8	50.00	49.80	49.95	50.07	49.81	50.00
9	50.00	49.80	49.95	50.09	49.88	50.00
10	50.10	49.80	49.97	50.14	49.86	50.03
11	50.10	49.90	49.98	50.11	49.90	50.02
12	50.00	49.80	49.97	50.12	49.86	50.01
13	50.00	49.90	49.95	50.10	49.50	49.99
14	50.00	49.90	49.96	50.07	49.48	49.98
15	50.10	49.90	49.96	50.09	49.83	50.01
16	50.00	49.90	49.97	50.08	49.94	50.02
17	50.00	49.90	49.98	50.09	49.94	50.01
18	50.00	49.90	49.96	50.50	49.93	50.04
19	50.00	49.90	49.96	50.13	49.87	50.02
20	50.00	49.80	49.95	50.08	49.40	49.99
21	50.10	49.90	49.98	50.15	49.93	50.04
22	50.00	49.80	49.95	50.09	49.88	50.00
23	50.00	49.80	49.95	50.06	49.79	49.98
24	50.00	49.90	49.96	50.08	49.94	50.01
25	50.00	49.80	49.95	50.09	49.90	50.01
26	50.00	49.90	49.96	50.15	49.90	50.02
27	50.10	49.90	49.98	50.20	49.95	50.04
28	50.10	49.80	49.98	50.15	49.65	50.02
29	50.00	49.80	49.97	50.15	49.91	50.03
30	50.00	49.80	49.95	50.09	49.83	49.99
31	50.10	49.90	49.97	50.16	49.91	50.02
Max	50.10			50.50		
Min		49.80			49.40	

Source: TD (BPC), KHP (DGPC)

Graph: Daily maximum, minimum and average frequency for the month of May, 2021





Table: Daily maximum, minimum and average frequency for the month of June, 2021

Date	Bus Frequency at Semtokha Substation			Bus Frequency at Kurichhu Hydropower Plant		
	Max	Min	Ava	Max	Min	Ava
1	50.10	49.90	49.98	50.11	49.83	50.01
2	50.00	49.90	49.98	50.07	49.89	50.00
3	50.00	49.80	49.96	50.08	49.81	49.97
4	50.00	49.80	49.95	50.11	49.90	50.00
5	50.00	49.80	49.97	50.10	49.78	50.01
6	50.00	49.80	49.97	50.05	49.88	50.01
7	50.00	49.90	49.97	50.08	49.85	50.00
8	50.00	49.80	49.95	50.50	49.85	50.03
9	50.00	49.80	49.95	50.12	49.92	50.01
10	50.10	49.80	49.97	50.10	49.92	50.02
11	50.10	49.90	49.98	50.08	49.94	50.03
12	50.00	49.80	49.97	50.16	49.94	50.02
13	50.00	49.90	49.95	50.10	49.83	50.00
14	50.00	49.90	49.96	50.12	49.88	49.99
15	50.10	49.90	49.96	50.08	49.92	50.02
16	50.00	49.90	49.97	50.09	49.92	50.01
17	50.00	49.90	49.98	50.12	49.90	50.00
18	50.00	49.90	49.96	50.07	49.91	50.00
19	50.00	49.90	49.96	50.16	49.94	50.02
20	50.00	49.80	49.95	50.06	49.98	50.03
21	50.10	49.90	49.98	50.06	49.70	49.94
22	50.00	49.80	49.95	50.08	49.77	49.94
23	50.00	49.80	49.95	50.07	49.87	50.00
24	50.00	49.90	49.96	50.17	49.75	50.02
25	50.00	49.80	49.95	50.13	49.96	50.03
26	50.00	49.90	49.96	50.07	49.85	50.01
27	50.10	49.90	49.98	50.04	49.84	49.98
28	50.10	49.80	49.98	50.07	49.74	49.98
29	50.00	49.80	49.97	50.10	49.93	50.00
30	50.00	49.80	49.95	50.16	49.90	50.04
31	50.10	49.90	49.97	0.00	Error	Error
Max	50.10			50.50		
Min		49.80			49.70	

Source: TD (BPC), KHP (DGPC)

Graph: Daily maximum, minimum and average frequency for the month of June 2021



Annexure-IV

Table: Daily maximum, minimum and average Voltage for the month of April, 2021

Apr-21 Date	Malbase Substation									Nangkor Substation		
	400kV Bus Voltage (kV)			220kV Bus Voltage (kV)			66kV Bus Voltage (kV)			132kV Bus Voltage (kV)		
	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava
1	416.50	409.00	413.17	225.50	219.50	222.52	67.00	64.00	65.63	135.48	129.66	133.09
2	415.50	407.50	412.25	225.50	218.00	222.44	67.00	64.00	65.54	135.60	128.83	132.04
3	415.00	407.50	411.79	225.50	219.50	222.29	66.00	64.00	65.33	135.20	129.70	132.79
4	415.00	406.00	410.90	226.00	216.50	221.54	66.00	64.00	65.08	135.90	132.20	133.78
5	415.00	408.00	411.50	225.00	220.00	222.13	66.00	64.00	65.00	135.40	131.50	133.40
6	416.50	406.50	412.10	226.00	219.50	222.17	66.00	64.00	65.21	135.07	131.10	132.97
7	417.50	408.00	413.08	226.00	219.00	222.79	66.00	64.00	65.58	136.20	129.40	133.06
8	417.50	407.50	412.54	226.00	219.50	222.21	67.00	65.00	65.79	136.73	128.21	133.28
9	415.50	406.00	411.58	224.00	219.00	221.96	67.00	64.00	65.71	135.60	131.12	133.59
10	417.00	408.50	411.88	225.00	218.50	221.75	66.00	64.00	64.67	136.10	131.30	133.73
11	416.00	407.00	411.83	225.00	216.00	221.08	66.00	64.00	65.00	136.52	131.10	133.25
12	416.00	407.00	411.75	224.00	218.50	221.17	65.00	64.00	64.83	135.80	128.83	133.33
13	417.00	407.00	412.21	225.00	215.00	220.77	66.00	64.00	64.79	135.80	131.10	133.21
14	416.00	406.50	413.04	225.50	220.50	222.54	67.00	64.00	65.42	136.70	131.50	133.64
15	416.00	403.00	410.85	225.50	214.50	220.71	67.00	64.00	65.00	136.52	129.25	133.63
16	415.00	402.50	409.21	223.50	214.00	219.21	67.00	64.00	64.58	136.10	132.00	133.95
17	415.50	407.50	411.40	224.50	217.00	220.83	66.00	64.00	64.73	137.30	130.08	133.85
18	417.50	407.50	409.85	224.00	216.50	219.19	66.00	64.00	64.71	136.10	132.78	134.22
19	416.50	407.50	410.96	223.50	217.50	221.04	66.00	64.00	64.83	136.73	132.00	134.07
20	416.50	408.50	413.54	223.00	219.00	221.54	66.00	65.00	65.33	135.40	129.70	132.86
21	418.00	405.50	412.21	225.00	216.50	220.58	67.00	64.00	65.33	136.30	131.12	133.13
22	421.00	412.50	415.96	224.50	217.00	220.98	66.50	65.00	65.42	135.90	130.08	133.40
23	420.50	404.00	410.83	222.00	213.50	218.56	67.00	64.00	64.83	135.60	128.60	132.85
24	415.50	401.50	410.63	224.00	212.50	219.21	66.00	64.00	64.75	135.80	130.50	133.15
25	417.00	405.00	412.79	224.00	213.50	219.63	66.00	64.00	64.88	136.31	130.90	133.89
26	418.00	407.50	414.13	223.00	214.00	218.85	66.00	64.00	65.17	137.77	130.08	134.46
27	422.50	407.00	414.38	222.00	218.00	220.33	66.00	64.00	65.13	136.31	131.10	133.72
28	417.50	411.00	413.96	226.00	219.00	222.17	66.00	65.00	65.42	137.35	132.10	134.03
29	420.00	409.50	415.25	226.00	218.00	221.71	67.00	65.00	66.25	137.35	130.70	133.89
30	423.00	410.00	415.73	227.50	218.00	221.52	68.00	65.00	66.25	136.73	131.50	133.90
31	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Max	423.00			227.50			68.00			137.77		
Min		0.00			0.00			0.00			0.00	

Source: TD, BPC

Graph: Daily maximum, minimum and average Voltage for the month of April, 2021




Table: Daily maximum, minimum and average Voltage for the month of May, 2021

Date	Malbase Substation									Nangkhor Substation		
	400kV Bus Voltage (kV)			220kV Bus Voltage (kV)			66kV Bus Voltage (kV)			132kV Bus Voltage (kV)		
	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava
1	417.50	408.50	413.81	225.00	219.50	221.31	67.00	64.00	65.67	137.60	131.50	134.09
2	418.50	407.00	413.58	225.00	217.50	221.29	67.00	65.00	66.17	135.81	130.50	133.98
3	419.00	408.50	414.08	226.00	217.50	221.19	67.00	65.00	66.17	137.10	131.50	134.29
4	421.50	408.50	415.88	229.00	219.00	223.67	69.00	66.00	66.58	135.90	131.20	133.68
5	416.50	405.50	413.04	224.50	217.50	220.96	67.00	65.00	66.17	136.10	131.50	133.57
6	413.50	403.50	409.17	224.00	217.00	220.58	66.00	64.00	65.33	135.00	129.66	133.02
7	414.00	403.00	409.63	224.00	218.00	220.63	67.00	65.00	66.00	135.10	131.10	133.30
8	414.50	404.00	410.48	223.50	216.50	220.52	66.00	65.00	65.71	136.30	131.74	134.26
9	417.50	408.00	412.02	226.00	220.00	222.23	67.00	65.00	65.96	135.60	132.57	134.04
10	415.50	403.00	410.00	225.00	217.00	220.19	67.00	65.00	65.83	135.60	131.40	133.42
11	414.50	404.00	409.71	225.00	215.50	219.98	67.00	65.00	65.75	135.69	131.00	133.82
12	414.50	405.50	409.13	222.50	217.50	219.50	67.00	65.00	65.96	135.48	132.30	133.87
13	413.50	401.50	407.04	224.00	215.50	219.08	66.00	65.00	65.50	135.80	132.36	134.31
14	410.50	402.50	407.13	223.00	215.50	218.71	65.00	64.00	64.92	135.80	131.32	133.99
15	409.00	402.00	406.44	221.00	216.00	218.58	66.00	65.00	65.40	136.73	131.70	134.30
16	412.50	404.00	408.58	224.50	216.00	219.73	66.00	65.00	65.46	135.90	131.12	133.89
17	415.50	401.50	409.58	225.50	213.00	220.08	66.00	64.00	65.42	135.80	131.95	133.93
18	415.50	401.50	408.06	224.50	213.00	217.71	66.00	64.00	64.75	135.90	132.50	133.90
19	416.00	402.00	408.79	222.50	214.00	217.56	66.00	64.00	64.88	135.48	131.12	133.54
20	410.50	403.00	406.42	221.50	215.50	218.17	65.00	64.00	64.88	135.20	131.10	133.34
21	412.00	401.00	406.73	223.50	216.00	219.35	66.00	65.00	65.17	135.40	132.57	134.31
22	413.50	405.00	409.15	225.00	218.00	220.90	66.00	65.00	65.71	134.80	132.00	133.65
23	409.50	403.00	407.38	222.00	216.00	218.96	66.00	65.00	65.71	136.52	132.16	134.20
24	410.50	401.50	407.38	221.50	214.50	219.08	66.00	65.00	65.50	137.50	131.95	134.78
25	410.50	403.50	408.13	221.50	216.00	219.42	67.00	65.00	65.50	139.43	132.25	135.32
26	410.50	400.00	407.75	225.50	215.50	219.25	67.00	65.00	65.42	135.07	131.32	133.27
27	409.50	401.50	405.38	220.50	214.50	217.50	66.00	64.00	65.00	134.44	130.90	133.16
28	410.50	404.00	407.96	221.00	216.00	218.04	66.00	65.00	65.50	135.48	131.33	133.15
29	415.00	407.50	410.94	224.00	211.00	218.85	66.00	63.00	65.54	135.48	130.91	133.25
30	415.50	405.00	410.79	223.00	217.50	221.08	66.00	65.00	65.75	135.27	131.32	133.33
31	415.00	407.50	410.71	222.00	217.50	220.29	66.00	65.00	65.58	136.30	130.70	133.95
Max	421.50			229.00			69.00			139.43		
Min		400.00			211.00			63.00			129.66	

Source: TD, BPC

Graph: Daily maximum, minimum and average Voltage for the month of May, 2021





Table: Daily maximum, minimum and average Voltage for the month of June, 2021

Date	Malbase Substation									Nangkor Substation		
	400kV Bus Voltage (kV)			220kV Bus Voltage (kV)			66kV Bus Voltage (kV)			132kV Bus Voltage (kV)		
	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava
1	417.00	407.00	410.02	222.50	216.50	218.52	66.00	64.00	65.04	136.11	130.90	133.46
2	411.50	403.50	407.92	221.00	215.00	217.25	65.00	64.00	64.54	135.70	130.08	133.97
3	416.00	404.00	409.50	222.00	215.00	218.42	66.00	64.00	65.33	135.28	131.95	133.66
4	412.50	406.00	408.75	222.50	216.00	218.06	66.00	65.00	65.23	134.80	131.12	133.17
5	410.50	405.50	408.54	221.50	216.00	218.67	66.00	65.00	65.33	135.90	130.49	132.68
6	415.50	405.00	410.35	224.50	217.50	220.15	66.00	65.00	65.70	135.20	130.20	132.51
7	411.50	403.00	408.13	222.50	216.50	219.27	66.00	65.00	65.42	134.65	129.66	132.09
8	412.00	403.00	407.67	221.00	217.00	218.48	66.00	65.00	65.58	135.50	128.80	131.91
9	410.00	405.00	408.25	221.00	216.50	218.96	66.00	65.00	65.58	133.41	128.83	131.52
10	412.50	404.00	408.21	223.00	216.00	218.79	66.00	65.00	65.33	134.40	129.45	131.77
11	415.00	406.00	410.13	226.00	215.50	219.69	66.00	65.00	65.67	136.32	131.12	133.61
12	411.50	401.00	406.81	222.00	215.00	217.69	66.00	65.00	65.42	135.69	130.08	133.51
13	408.50	401.00	405.17	219.00	214.50	216.63	66.00	64.00	64.92	136.50	129.66	132.71
14	405.50	401.50	403.92	217.50	214.00	215.92	65.00	64.00	64.50	134.65	129.25	132.36
15	407.00	402.00	404.83	219.00	215.00	216.35	65.00	64.00	64.63	134.40	128.83	132.52
16	408.00	402.00	404.50	219.00	215.00	216.38	65.00	64.00	64.67	136.94	129.80	132.65
17	408.00	401.00	404.96	219.00	215.00	216.88	66.00	64.00	64.83	135.40	129.20	132.44
18	409.50	403.00	406.58	220.00	215.00	217.54	66.00	64.00	65.00	135.90	129.25	132.66
19	416.00	402.50	409.13	234.50	215.00	220.40	66.00	64.50	65.00	135.80	131.53	133.45
20	411.00	400.50	407.06	222.00	214.00	218.75	66.00	64.00	65.00	134.80	129.66	132.79
21	405.50	402.00	403.71	218.50	215.00	215.96	65.00	64.00	64.38	134.50	129.45	132.81
22	407.00	402.00	404.33	219.50	214.00	216.67	65.00	64.00	64.13	134.65	130.08	132.46
23	408.50	402.00	405.25	225.00	214.50	217.96	65.00	64.00	64.25	134.80	129.87	132.75
24	408.50	402.00	405.25	222.50	215.50	218.44	65.00	64.00	64.92	135.69	129.20	132.32
25	411.50	405.50	409.29	223.00	219.00	221.42	66.00	65.00	65.50	137.90	125.71	132.97
26	412.50	406.50	409.63	223.00	219.50	221.65	66.00	65.00	65.17	136.94	129.87	133.43
27	412.00	406.50	409.42	222.50	219.00	221.17	66.00	65.00	65.17	135.27	132.16	133.75
28	411.50	406.50	409.00	224.00	219.00	221.04	65.00	65.00	65.00	136.10	131.74	133.72
29	412.00	405.50	409.85	223.50	221.00	221.94	66.00	65.00	65.25	135.40	131.90	133.85
30	411.50	405.50	408.96	223.50	221.00	221.79	66.00	65.00	65.29	136.90	130.08	133.37
31	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Max	417.00			234.50			66.00			137.90		
Min		0.00			0.00			0.00			0.00	

Source: TD, BPC



Graph: Daily maximum, minimum and average Voltage for the month of June, 2021



Annexure-V

Eastern Grid Outages
April Month 2021

EASTERN GRID TRIPPING-OUTAGE													
Tripping Report for the of month April, 2021 under SMD Deothang, TD,BPC													
Sl. No.	Date of Tripping	Time of outages	Date of Normalization	Time of fault was cleared	Duration of Outages (Hrs)	MW before outage (MW)	Feeder Name	Name of the Substation/lines affected by the fault	Reasons of fault	Relay operations	Exact location of fault [Line segment/ Substation]	Type of outages	Remarks
1. 132/33/11kV KIRIKHAR Substation													
132kV Feeder													
	30.04.2021	16:59	30.04.2021	17:06		-13.75	132kv kirichu	All feeders	NA	Nil	kirichu end	trip	Line tripped from kirichu end. all unit are trip due to under voltage.
2. 132/33/11kV Kanglung Substation													
132kV Feeder													
1	01.04.2021	14:30	1.4.2021	14:34	0:04	-7.182	Corlung	Kanglung	E/F	E/F	Corlung Line	Tripped on fault	Line Tripped due to Lightning
2	07.04.2021	21:14	07.04.2021	21:17	0:00	-12.168	Corlung	kanglung	O/c	o/c	Corlung Line	Tripped on fault	line tripped due to over current at our end ,due to heavy rainfall with thundering &lightning
3	28.04.2021	17:03	28.04.2021	17:13	0:00	-11.412	Corlung	kanglung	O/C & E/F	O/C & E/F relay operated Ir-27.56A, Iy-801.8A, Ib-720.2A. Distance relay operated with Zone 1, at 17.88KM	Corlung Line	Tripped on fault	fidr normalised after getting clearance from ms. Karma, (engg). BPSO. At 17:13 hrs.
4	28.04.2022	17:03	28.04.2021	17:14	0:00	9.756	Phuntshothang	Kanglung	NA	nce relay zone 1 ope	Phuntshothang line	Tripped on fault	fidr normalised after getting clearance from ms. Karma, (engg). BPSO. At 17:14hrs.
5	28.04.2021	17:43	28.04.2021	17:45	0:00	-11.412	Corlung	kanglung	O/C & E/F	O/C & E/F relay operated Ir-570.8A, Iy-57.85A, Ib-621A. Distance relay operated with Zone 2, at 25.71KM	Corlung Line	Tripped on fault	fidr normalised after getting clearance from ms. Karma, (engg). BPSO. At 17:45hrs.
6	28.04.2021	17:43	28.04.2021	19:56	2:00	9.756	Phuntshothang	Kanglung	NA	nce relay zone 1 ope	Phuntshothang line	Tripped on fault	fidr normalised after getting clearance from ms. Karma, (engg). BPSO with charging code 2050
7	30.04.2021	16:55	30.04.2021	17:16	0:00	-10.872	Corlung	kanglung	O/C & E/F	O/C & E/F relay operated IA-32.78A, IB-72.53A, IC-797.6A. VAB-134.1kV,VBC-81.7kV,VCA-77.9kV. Distance relay operated with Zone 1, at 5.586KM/IA-32.71A,IB-72.2A,IC-822.3A,VAN-78.66kV,VBN-76.45kV,VCN-5.706kV	Corlung Line	Tripped on fault	Feeder normalised after getting clearance from BPSO.
8	30.04.2021	16:55	30.04.2021	17:16	0:00	9.486	Phuntshothang	Kanglung	NA	NA	Phuntshothang line	Tripped on fault	Feeder normalised after getting clearance from BPSO.



Transmission System Performance Report

Second Quarterly Report-2021

3. 132/33/11kV Deothang Substation													
132kV Feeder													
Sr	Date	Time	Date	Time	Disturbance	Value	From	To	Reason	Relay	Location	Status	Remarks
1	04.04.2021	20:50	04.04.2021	20:59	0	8.06	132kV Deothang-Motanga	Deothang-Motanga line	Overcurrent and Earth relay was operated at Motanga end	Nil	Motanga end	Tripped	Grid fail from the Nangkor & Motanga substation. At our ends Breaker was in normal condition.
2	04.04.2021	20:50	04.04.2021	21:03	0	-11.8	132kV incoiner	Nangkor	Overcurrent and Earth relay was operated at Nangkor end	Nil	Nangkor end	Tripped	Grid fail from the Nangkor & Motanga substation. At our ends Breaker was in normal condition.
3	10.04.2021	20:53	10.04.2021	21:05	0	33.33	132kV Deothang-Motanga	Deothang-Motanga line	Unknown	Nil	Deothang Substation	Tripped	Grid failed. 132kV Deothang-Nangkor & Deothang-Motanga line was both tripped at their end only. Supply was resumed at 21:05 hrs.
4	10.04.2021	20:53	10.04.2021	21:08	0	-35.28	132kV Deothang-Nangkor	Deothang-Nangkor line	Unknown	Nil	Deothang Substation	Tripped	Grid failed. 132kV Deothang-Nangkor & Deothang-Motanga line was both tripped at their end only. Supply was resumed at 21:08 hrs.
5	27.04.2021	18:14	27.04.2021	18:17	0	0.79	132/33kV 5MVA Transformer I & II	Deothang SS	Tripped	O/C	132/33/11kV Deothang Ss	Transient fault	132/33kV 5MVA Transformer I & II both tripped and test charged was done and found normal
6	28.04.2021	0:01	28.04.2021	0:04	0	0.53	132/33kV 5MVA Transformer I & II	Deothang SS	Tripped by Bangtar line	tripping relay 86	Unknow	Tripped	132/33kV 5MVA Transformer was got tripped by Bangtar feeder.Charge and found normal.
7	30.04.2021	16:58	30.04.2021	17:06	0	0.83	132kV Deothang-Nangkor	Deothang SS	Grid fail	Nil	Unknow	Tripped	Grid fail from both end,at our end all breaker condition was normal
8	30.04.2021	17:58	30.04.2022	18:06	0	0.83	132kV Deothang-Motanga	Deothang SS	Grid fail	Nil	Unknow	Tripped	Grid fail from both end,at our end all breaker condition was normal
4. 132/33/11kV Nangkor substation													
132kV Feeder													
Sr	Date	Time	Date	Time	Disturbance	Value	From	To	Reason	Relay	Location	Status	Remarks
1	04.04.2021	18:43 hrs	04.04.2021	19:57 hrs	0	0.84	132/33kV, 5MVA Trf-I	All 33kV & 11kV feeders	Transient fault	Non directional IDMT O/C Relay-50A & tripping relay 86 operated	Nangkor Substation	Tripped on fault	Tripped due to fault on 33kV Tsebar feeder
2	04.04.2021	18:43 hrs	04.04.2021	18:47 hrs	0	0.61	132/33kV, 5MVA Trf-II	All 33kV & 11kV feeders	Transient fault	Non directional IDMT O/C Relay-50A & tripping relay 86 operated	Nangkor Substation	Tripped on fault	Tripped due to fault on 33kV Tsebar feeder
3	04.04.2021	19:33 hrs	04.04.2021	19:37 hrs	0	0.46	132/33kV, 5MVA Trf-II	All 33kV & 11kV feeders	Transient fault	Non directional IDMT O/C Relay-50A & tripping relay 86 operated	Nangkor Substation	Tripped on fault	Tripped due to fault on 33kV Tsebar feeder
4	04.04.2021	20:50 hrs	04.04.2021	21:03 hrs	0	11.7	Nangkor-Deothang	Nangkor-Deothang line	Tripped on fault	Non directional E/F,O/C relay & tripping relay 86 operated	Nangkor-Deothang line	Tripped on fault	Start O CN, Trip O N. O/C start I-1, E/F start IN1>12, trip IN1>2. IA-60.16A, IB-52.54A,IC-404.0A, IN measured-353.5A. Informed to BPSO, and charged the feeder with instruction from BPSO.
5	10.04.2021	20:53 hrs	10.04.2021	21:06 hrs	0	35.7	Nangkor-Deothang	Nangkor-Deothang line	Tripped on fault	Non directional E/F,O/C relay & tripping relay 86 operated	Nangkor-Deothang line	Tripped on fault	Start O CN, Trip O N. O/C start I-1, E/F start IN1>12, trip IN1>2. IA-102.4A, IB-100.9A,IC-447.5A, IN measured-361.4A. Informed to BPSO, and charged the feeder with instruction from BPSO.
6	14.04.2021	04:32 hrs	14.04.2021	14:50 hrs	0	0.39	132/33kV, 5MVA Trf-I	All 33kV & 11kV feeders	NA	Non directional IDMT O/C Relay-50A,50C & tripping relay 86 operated	Nangkor Substation	Tripped on fault	Due to fault on 33kV Tsebar feeder.
7	16.04.2021	15:58 hrs	16.04.2021	16:03 hrs	0	0.42	132/33kV, 5MVA Trf-I	All 33kV & 11kV feeders	Transient fault	Non directional IDMT O/C Relay-50A,50C & tripping relay 86 operated	Nangkor Substation	Tripped on fault	Tripped due to fault on 33kV Yurang feeder
8	16.04.2021	15:58 hrs	16.04.2021	16:03 hrs	0	0.24	132/33kV, 5MVA Trf-II	All 33kV & 11kV feeders	Transient fault	Non directional IDMT O/C Relay-50A,50C & tripping relay 86 operated	Nangkor Substation	Tripped on fault	Tripped due to fault on 33kV Yurang feeder
9	22.04.2021	02:26 hrs	22.04.2021	02:40 hrs	0	0.38	132/33kV, 5MVA Trf-I	All 33kV & 11kV feeders	Transient fault	Non directional IDMT O/C Relay-50A,50C & tripping relay 86 operated	Nangkor Substation	Tripped on fault	Tripped due to fault on 33kV Namng feeder & Namng Feeder
10	22.04.2021	02:26 hrs	22.04.2021	02:40 hrs	0	0.43	132/33kV, 5MVA Trf-II	All 33kV & 11kV feeders	Transient fault	Non directional IDMT O/C Relay-50A,50C & tripping relay 86 operated	Nangkor Substation	Tripped on fault	Tripped due to fault on 33kV Namng feeder & Namng Feeder
11	28.04.2021	00:03 hrs	28.04.2021	00:26 hrs	0	24.1	Nangkor-Deothang	Nangkor-Deothang line	Tripped on fault	Non directional O/C,E/F Relay & tripping relay 86 operated	Nangkor-Deothang line	Tripped on fault	Start O CN, Trip O N. O/C start I-1, E/F start IN1>12, trip IN1>2. IA-100.2A, IB-96.92A,IC-467.9A, IN measured-391.2A. Informed to BPSO, and charged the feeder with instruction from BPSO.
12	28.04.2021	08:23 hrs	28.04.2021	09:58 hrs	1	0.24	132/33kV, 5MVA Trf-II	132/33kV, 5MVA Trf-II	Tripped on fault	Ass-Relay Diffref 87x,64x, 30CWDG temp. Alarm, 30D Buch. Alarm & tripping relay 86 operated	Nangkor Substation	Tripped on fault	No supply interrupted. Tripped due to Shake of Earth Quake. Charged the Xmer after inspection.
13	30.04.2021	16:03 hrs	30.04.2021	16:15 hrs	0	28.6	Nangkor-Nganglam	Nangkor-Nganglam line	Tripped on fault	Directional O/C,E/F & tripping relay 86 operated	Nangkor-Nganglam line	Tripped on fault	Directional O/C & E/F & trip relay 86 operated at our end: Start phase BN, trip phase N, O/C start I-1, E/F start E/F IN1>12, trip IN1>2. IA-78.17A, IB-670A, IC-141.2A, VAB-109.8kV, VBC-107.3kV, VCA-130.5kV, VAN-72.7kV, VBN-53.08kV, VCN-74.15kV, VN-0.00, 49.98Hz,IN measured-456.0A, IN derived-455.8A. Informed to BPSO & charged the feeder as per their instruction.
14	30.04.2021	16:57 hrs	30.04.2021	17:04 hrs	0	28.6	Main Grid	All 33kV & 11kV feeders	-	-	Motanga Substation & Tintibi Substation	Tripped on fault	Supply failed from Motanga Substation and Tintibi Substation and received from Motanga Substation.



Transmission System Performance Report

Second Quarterly Report-2021

5. 132/33/11kV Nganglam substation													
132kV Feeder													
Sl. No.	Date of Tripping	Time of Outages/ Time of Tripping	Date of Normalization	Time of Fault was Cleared	Duration of Outages (Hrs)	MW before Outage (MW)	Name of feeder	Name of the Substation lines Affected by the Fault	Reasons of Fault	Relay Operations	Fault Location(KM)	Type of outages	Remarks
1	12.04.2021	17:40	12.04.2021	17:45	0	0.44	3MVA Transformer	3MVA Transformer	Over Current	O/C & 86opted	33kV Dechenling Feeder	Tripped on Fault	After the tripping of 3MVA Transformer the load is changed over to 5MVA Transformer at 17:45hrs
2	14.04.2021	02:18	14.04.2021	02:34	0	-15.17	Nganglam-Tingibi	Nganglam-Tingibi	Earth Fault	E/F & 86opted	Nganglam-Tingibi Line	Tripped on Fault	Trip Values: Tripped ABCN Z-1 Fault location 10.75km IA- 1.495KA IB- 1.517KA IC-1.254KA
3	23.04.2021	8:12	23.04.2021	14:22	6	-24.54	Nganglam-Tingibi	Nganglam-Tingibi	Shutdown	NA	Nganglam-Tingibi Line	Tripped on Fault	Shutdown taken by TMD, Nganglam to cut/fell down fast grown tree between the line section of TN#211 to TN#212 and TN#215 to TN#216 with wide Switch off code# 0439 issued by Miss. Linley Wangmo & PTW No# 1768 issued by Substation. The supply was restored after returning of PTW No# 1768 by Mr. Dawa Tshering TMD, Line Incharge & coordination to Tingtibi end and BPSO with wide Switch On code# 2036 issued by Miss. Kinley Wangmo, BPSO.
4	30.04.2021	15:58	30.04.2021	16:30	0	-24.84	Nganglam-Tingibi	Nganglam-Tingibi	Earth Fault	E/F & 86opted	Nganglam-Tingibi Line	Tripped on Fault	Trip Values: Tripped ABCN Z-1 Fault location 10.75km IA- 3.218A IB- 776.6A IC-160.5A Fault location 131km. CB operated at both end and Nangkhor-Nganglam CB operated at Nangkhor end there by resulting Substation in Black out.
5	30.04.2021	16:58	30.04.2021	17:04	0	-24.84	Nganglam-Tingibi	Nganglam-Tingibi	Grid fail	Grid fail	Nganglam-Tingibi Line	Grid fail	Supply fail from Tingtibi end(Jigmeling -Tingtibi CB opted at Jigmeling end) and Nangkhor-Nganglam CB opted at Nangkhor end thus Black out at Nganglam Substation
6. 132kV Motanga substation													
1	4/4/2021	20:53 hrs	4/4/2021	20:58 hrs	-	-10.5	Deothang fdr incomer	-	Tripped on Fault	86A & 86B OPTD,OC/EF at one end	Motanga ss	-	Informed BPSO,as per there instruction by Karma Yangzom without closing code CB closed at 20:58hrs from our end as emergency.
2	4/8/2021	10:15 hrs	4/8/2021	13:52hrs	3	0.1	15MVA Xmer	-	Hand tripped	-	Motanga ss	-	Informed BPSO and CB closed at 13:52hrs from our end.
3	4/10/2021	20:52 hrs	4/10/2021	21:01hrs	-	-34.5	Deothang fdr incomer	-	Tripped on Fault	86A & 86B OPTD,OC/EF at one end	Motanga ss	-	Taken shutdown by DCSD for maintenance work at Azista end.
4	4/11/2021	08:02hrs	4/11/2021	08:40hrs	-	0.02	33kV POP Factory	-	Hand tripped	-	Motanga ss	-	Shutdown taken by DCSD S/Jongkhar to replace Fuse at there end.
5	28/04/201	08:25hrs	28/04/201	09:22hrs	-	-22.47	Deothang fdr incomer	-	Hand tripped	-	Motanga ss	-	Informed BPSO, Thimphu as instructed to closed CB with code no.2046 CB closed from our end at 09:22hrs.Due to heavy earthquake all isolators alignment was slightly gone out and Rangia main isolator and line isolator and Phuntshothang line isolator got burst. So firstly control the fire at isolators by hand tripping CB for Deothang,Rangia and Phuntshothang feeders and than we the staffs physically check all the structures and alignment for all bays.manually closed all isolators to confirmed fully closed and inform BPSO to charge the line.
6	28/04/201	08:25hrs	28/04/201	13:07hrs	4 hrs	6.11	Motanga-Rangia line	-	Hand tripped	-	Motanga ss	-	Informed to BPSO, Thimphu as instructed to closed CB with code no.NLDC Bht-2047,NLDC India-1349,NERLDC -1875 CB closed from our end at 13:07hrs.Due to earthquake main isolator and line isolator alignment gone out and got burst. informed maintenance team at Deothang and done all alignment works both for Rangia and Phuntshothang isolators and both line charged from our end.
7	28/04/201	08:25hrs	28/04/201	13:26hrs	5 hrs	-8.97	anga-Phuntshothang line	-	Hand tripped	-	Motanga ss	-	Informed BPSO, Thimphu as instructed to closed CB with code 2048 from our end at 13:26hrs. Due to earthquake isolator s got burst and informed maintenance team and after completing alignment works only line charged from our end.
8	28/04/201	17:04hrs	28/04/201	17:16hrs	-	-8.96	anga-Phuntshothang line	-	Tripped on Fault	86A & 86B OPTD,OC/EF at one end	Motanga ss	-	Informed BPSO and closed the CB from our end at 17:16hrs from our end.
9	28/04/201	17:39hrs	28/04/201	17:45hrs	-	-8.96	anga-Phuntshothang line	-	Tripped on Fault	86A & 86B OPTD,OC/EF at one end	Motanga ss	-	Informed BPSO and closed the CB from our end at 17:45hrs from our end.
10	30/04/201	16:55hrs	30/04/201	17:04hrs	-	-26.9	otanga-Deothang line	-	Tripped on Fault	86A & 86B OPTD,OC/EF at one end	Motanga ss	-	Informed BPSO and closed the CB from our end at 17:04hrs from our end.
11	30/04/201	16:55hrs	30/04/201	17:05hrs	-	-6.47	anga-Phuntshothang line	-	Tripped on Fault	86A & 86B OPTD,OC/EF at one end	Motanga ss	-	Informed BPSO and closed the CB from our end at 17:05hrs from our end.
7. 132/33 kV Corlung substation													
1	30.04.2021	16:58 hrs	30.04.2021	17:04 hrs	0	9.57	132 Khilihar-Corlung line and 132 kV Corlung-Kanglung Line	132 Khilihar-Corlung line and 132 kV Corlung-Kanglung Line, 132kv Corlung Substation and 33 kV T/Yantse Feeder	Incoming supply fail	NA	Kurichu Supply fail	Grid fail	At 14:58 hrs Incoming supply from khilihar substation fail and Corlung substation was blockout but no breaker tripping has occurred at Corlung substation.
7. 132/33 kV Phuntshothang substation													
1	1/04/2021	14:20	4/1/2021	14:47	-	7.02	Kanglung Line	Kanglung line	Zone one Distance Relay Trip for Kanglung s/s	86A and 86B	Kanglung Line	Trip	Kanglung s/s zone one distance relay trip
2	7/04/2021	21:09	4/7/2021	21:17	-	10.50	V incomer Kanglung	Kanglung Line	1OPTD (R,Y,B Phase	89A and 89B	Kanglung Line	Trip	Zone-1 OPTD R,Y,B Phase trip
3	28/04/2021	17:03	4/28/2021	17:24	-	9.39	KANGLUNG LINE	Kanglung Line	Zone one Distance Relay Trip for Kanglung s/s	86A and 86B	Kanglung Line	TRIP	Kanglung s/s zone one distance relay trip
4	28/04/2021	17:42	4/28/2021	19:59	2	9.39	KANGLUNG LINE	Kanglung Line	1OPTD (R,Y,B Phase zone -1OPTD(B Phase trip) and over voltage	89A and 89B	Kanglung Line	TRIP	Zone-1 OPTD B Phase trip(grid fail)
5	30-04-21	16:55	4/30/2021	17:15	-	11.03	KANGLUNG LINE	Kanglung Line	Phase trip) and over voltage	89A and 89B	Kanglung Line	TRIP	Zone-1 OPTD B Phase trip(grid fail)
1. 400/220/132/33kV Jigmeling Substation													
Sl. No.	Date of Tripping	Time of Outages/ Time of Tripping	Date of Normalization	Time of Fault was Cleared	Duration of Outages (Hrs)	MW before Outage (MW)	Name of feeder	Name of the Substation lines Affected by the Fault	Reasons of Fault	Relay Operations	Fault Location(KM)	Type of outages	Remarks
i) 400kV													
1	22.04.2021	12:44 hrs			0	64.1MW	MHPA Line-2	Jigmeling Substation	DTT trip, RYB phase Tripped.			Transient Fault (Lightening and thundering)	
2	30.04.2021	02:50 hrs	30.04.2021	14:57 hrs			Shunt Reactor-1		Rphase- Ground fault			Transient Fault (Lightening and thundering)	
ii) 220 kv and 132 kv													
1	10.04.2021	19:28hrs	10.04.2021	19:42hrs	0	136.4	80MVA ICT1 & 2	Jigmeling s/s	LV SEF optd	50N/51N Trip, (Ia=0.53kA,Ib=0kA Ic=0 kA for ICT 1), 50N/51N Trip, (Ia=0.54kA,Ib=0kA Ic=0 kA for ICT 2)		Transient (lightning and thundering)	Both ICT1&2 Trip at the sametime.
2	22.04.2020	12:02hrs	22.04.2021	01:45hrs	0	12.99MW	Tsirang Feeder	Jigmeling s/s	Earthfault(L2-E)	50N/51N pick up, L2E phase tripped, main 1 operated, dist. 23.4km	dist. 23.4km	Transient (lightning and thundering)	
3	22.04.2021	12:23hrs	22.04.2021	12:23hrs	0	1.13MW	Dagapela Feeder	Jigmeling s/s	Line Fault	Y&Bphase tripped, zone 1 optd, Dist. 21.68km	Dist. 21.68km	Transient (lightning and thundering)	
4	30.04.2021	15:26hrs	30.04.2021	15:34hrs	0	29.33	132kV Jigmeling-Gelephu Line	Jigmeling & Tingtibi	Ground fault	main 1 - Relay General Trip and R & Y phase with ground fault trip.	Distance -65.9km	Transient	
2. 220/66/33kV Dhajay Substation													
i) 66kV and above													
1	22.04.2021	00:01:50hrs	22.04.2021	1:46:30hrs	1	13.3	Jigmeling feeder	Dhajay SS	main 1-Ia=0.47KA, E86.1 & 2, Distance re Main 1=16.8km, Mai	Tripped		whole Tsirang is black out as line couldnot extend from Jigmeling since their bus	



Transmission System Performance Report

Second Quarterly Report-2021

May 2021

Division		Substation		Month	
SMD BEOTRANG		110-220KV Beotrang Substation		May 21	

Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Short-circuit/Overload)	Shutdown/ Tripping Time		Normalisation Time		Duration of Outage		MW Index Outage (MW)	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Weather Condition during the Outage	Remarks
				Date	Time	Date	Time	(Hrs)	(Min)		Protection Relay Operd	Fault Details (As recorded by relay)				
110KV Feeders																
2	Karachi	132KV	Tripping	5/27/2021	0:25 hrs	5/27/2021	0:55 hrs		10	24.11	-	-	-	Tripping	Heavy	Grid fed from Nunglar and Tugilar due to overcurrent along with grid fed from Rangit.

Division		Substation		Month	
SMD BEOTRANG		110-220KV Kunglar Substation		May 21	

Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Short-circuit/Overload)	Shutdown/ Tripping Time		Normalisation Time		Duration of Outage		MW Index Outage (MW)	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Weather Condition during the Outage	Remarks
				Date	Time	Date	Time	(Hrs)	(Min)		Protection Relay Operd	Fault Details (As recorded by relay)				
3	Kunglar-Kunglar Feeder	110KV	Tripping	01.05.2021	12:40	01.05.2021	12:41	0	1	10.00	Distance protection relay Mover (P42)	Tripping on 4RCH, Zone 1, Fault Current: 10, 711.1A, 10 - 74.1A, 3C - 762.2A, Fault Location: 17.51km	Distance Three phase fault	NA	Heavy	related to coordination with BPO.
4	Kunglar-Phanikhang Feeder	110KV	Tripping	01.05.2021	12:40	01.05.2021	12:41	0	1	9.00	Distance protection relay M2.010	Tripping on 4RCH, Zone 1, Fault Current: 10, 717A, 10 - 712A, 3C - 741A, Fault Location: 17.11km	Distance Three phase fault	NA	Heavy	related to coordination with BPO.
5	Kunglar-Phanikhang Feeder	110KV	Tripping	01.05.2021	14:12	01.05.2021	14:16	0	4	9.70	Distance protection relay M2.010 and M202 relay	Tripping on 4R, Zone 1, Fault Current: 10, 610A, 10 - 59A, 3C - 610A, Fault Location: 18.95km, DC SP 14, 107A, 10 - 42A, 3C - 12A	NA	NA	Heavy	Two changed the feeder before after referred to BPO at 13:14 hrs and 13:48 hrs but could not contained the feeder that changed the line as referred by BPO with changing code 2007 at 20:07 hrs. This feeder was changed via transfer bus at 20:02 with changing code 2008 from BPO, but it tripped again during code 2008.
16	Kunglar	110KV	NA	27.05.2021	0:18	27.05.2021	0:18	0	10	11.70	NA	NA	NA	NA	Lightning & Thundering	Feeder fed from 110KV bus Karachi but no operation into place at Kunglar Substation.
19	Phanikhang	110KV	Line fault	27.05.2021	0:18	27.05.2021	0:47	0	10	21.8	NA	NA	NA	NA	Lightning & Thundering	Tripped the feeder after contact to BPO.

Division		Substation		Month	
SMD BEOTRANG		110-220KV Nunglar Substation		May 21	

Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Short-circuit/Overload)	Shutdown/ Tripping Time		Normalisation Time		Duration of Outage		MW Index Outage (MW)	Tripping Details		Type/Cause of Fault	Reason for Shutdown	Weather Condition during the Outage	Remarks
				Date	Time	Date	Time	(Hrs)	(Min)		Protection Relay Operd	Fault Details (As recorded by relay)				
110KV Feeders																
1	110/110KV, NVA T64	132KV	Tripping	5/3/2021	11:59 hrs	5/3/2021	11:03 hrs	0	14	0.48	Non directional EMAT PROTON Relay operated	OC Relay-51A, 51C & tripping relay 50 operated	Tripped due to feeder fault	-	Clear	Tripped due to fault on 110V Nunglar Feeder
2	110/110KV, NVA T65-B	132KV	Tripping	5/3/2021	11:59 hrs	5/3/2021	11:06 hrs	0	8	0.2	Non directional EMAT PROTON Relay operated	OC Relay-51A, 51C & tripping relay 50 operated	Tripped due to feeder fault	-	Clear	Tripped due to fault on 110V Nunglar Feeder
3	Nunglar-Dorabang Line	132KV	Tripping	5/3/2021	15:19 hrs	5/3/2021	15:27 hrs	0	8	23	MCCOM F1400	Start 0 CN, OC start 1- L, E/F1 start 100-11, 100-12, 100-13, 100-14, 100-15, 100-16, 100-17, 100-18, 100-19, 100-20, 100-21, 100-22, 100-23, 100-24, 100-25, 100-26, 100-27, 100-28, 100-29, 100-30, 100-31, 100-32, 100-33, 100-34, 100-35, 100-36, 100-37, 100-38, 100-39, 100-40, 100-41, 100-42, 100-43, 100-44, 100-45, 100-46, 100-47, 100-48, 100-49, 100-50, 100-51, 100-52, 100-53, 100-54, 100-55, 100-56, 100-57, 100-58, 100-59, 100-60, 100-61, 100-62, 100-63, 100-64, 100-65, 100-66, 100-67, 100-68, 100-69, 100-70, 100-71, 100-72, 100-73, 100-74, 100-75, 100-76, 100-77, 100-78, 100-79, 100-80, 100-81, 100-82, 100-83, 100-84, 100-85, 100-86, 100-87, 100-88, 100-89, 100-90, 100-91, 100-92, 100-93, 100-94, 100-95, 100-96, 100-97, 100-98, 100-99, 100-100, 100-101, 100-102, 100-103, 100-104, 100-105, 100-106, 100-107, 100-108, 100-109, 100-110, 100-111, 100-112, 100-113, 100-114, 100-115, 100-116, 100-117, 100-118, 100-119, 100-120, 100-121, 100-122, 100-123, 100-124, 100-125, 100-126, 100-127, 100-128, 100-129, 100-130, 100-131, 100-132, 100-133, 100-134, 100-135, 100-136, 100-137, 100-138, 100-139, 100-140, 100-141, 100-142, 100-143, 100-144, 100-145, 100-146, 100-147, 100-148, 100-149, 100-150, 100-151, 100-152, 100-153, 100-154, 100-155, 100-156, 100-157, 100-158, 100-159, 100-160, 100-161, 100-162, 100-163, 100-164, 100-165, 100-166, 100-167, 100-168, 100-169, 100-170, 100-171, 100-172, 100-173, 100-174, 100-175, 100-176, 100-177, 100-178, 100-179, 100-180, 100-181, 100-182, 100-183, 100-184, 100-185, 100-186, 100-187, 100-188, 100-189, 100-190, 100-191, 100-192, 100-193, 100-194, 100-195, 100-196, 100-197, 100-198, 100-199, 100-200, 100-201, 100-202, 100-203, 100-204, 100-205, 100-206, 100-207, 100-208, 100-209, 100-210, 100-211, 100-212, 100-213, 100-214, 100-215, 100-216, 100-217, 100-218, 100-219, 100-220, 100-221, 100-222, 100-223, 100-224, 100-225, 100-226, 100-227, 100-228, 100-229, 100-230, 100-231, 100-232, 100-233, 100-234, 100-235, 100-236, 100-237, 100-238, 100-239, 100-240, 100-241, 100-242, 100-243, 100-244, 100-245, 100-246, 100-247, 100-248, 100-249, 100-250, 100-251, 100-252, 100-253, 100-254, 100-255, 100-256, 100-257, 100-258, 100-259, 100-260, 100-261, 100-262, 100-263, 100-264, 100-265, 100-266, 100-267, 100-268, 100-269, 100-270, 100-271, 100-272, 100-273, 100-274, 100-275, 100-276, 100-277, 100-278, 100-279, 100-280, 100-281, 100-282, 100-283, 100-284, 100-285, 100-286, 100-287, 100-288, 100-289, 100-290, 100-291, 100-292, 100-293, 100-294, 100-295, 100-296, 100-297, 100-298, 100-299, 100-300, 100-301, 100-302, 100-303, 100-304, 100-305, 100-306, 100-307, 100-308, 100-309, 100-310, 100-311, 100-312, 100-313, 100-314, 100-315, 100-316, 100-317, 100-318, 100-319, 100-320, 100-321, 100-322, 100-323, 100-324, 100-325, 100-326, 100-327, 100-328, 100-329, 100-330, 100-331, 100-332, 100-333, 100-334, 100-335, 100-336, 100-337, 100-338, 100-339, 100-340, 100-341, 100-342, 100-343, 100-344, 100-345, 100-346, 100-347, 100-348, 100-349, 100-350, 100-351, 100-352, 100-353, 100-354, 100-355, 100-356, 100-357, 100-358, 100-359, 100-360, 100-361, 100-362, 100-363, 100-364, 100-365, 100-366, 100-367, 100-368, 100-369, 100-370, 100-371, 100-372, 100-373, 100-374, 100-375, 100-376, 100-377, 100-378, 100-379, 100-380, 100-381, 100-382, 100-383, 100-384, 100-385, 100-386, 100-387, 100-388, 100-389, 100-390, 100-391, 100-392, 100-393, 100-394, 100-395, 100-396, 100-397, 100-398, 100-399, 100-400, 100-401, 100-402, 100-403, 100-404, 100-405, 100-406, 100-407, 100-408, 100-409, 100-410, 100-411, 100-412, 100-413, 100-414, 100-415, 100-416, 100-417, 100-418, 100-419, 100-420, 100-421, 100-422, 100-423, 100-424, 100-425, 100-426, 100-427, 100-428, 100-429, 100-430, 100-431, 100-432, 100-433, 100-434, 100-435, 100-436, 100-437, 100-438, 100-439, 100-440, 100-441, 100-442, 100-443, 100-444, 100-445, 100-446, 100-447, 100-448, 100-449, 100-450, 100-451, 100-452, 100-453, 100-454, 100-455, 100-456, 100-457, 100-458, 100-459, 100-460, 100-461, 100-462, 100-463, 100-464, 100-465, 100-466, 100-467, 100-468, 100-469, 100-470, 100-471, 100-472, 100-473, 100-474, 100-475, 100-476, 100-477, 100-478, 100-479, 100-480, 100-481, 100-482, 100-483, 100-484, 100-485, 100-486, 100-487, 100-488, 100-489, 100-490, 100-491, 100-492, 100-493, 100-494, 100-495, 100-496, 100-497, 100-498, 100-499, 100-500, 100-501, 100-502, 100-503, 100-504, 100-505, 100-506, 100-507, 100-508, 100-509, 100-510, 100-511, 100-512, 100-513, 100-514, 100-515, 100-516, 100-517, 100-518, 100-519, 100-520, 100-521, 100-522, 100-523, 100-524, 100-525, 100-526, 100-527, 100-528, 100-529, 100-530, 100-531, 100-532, 100-533, 100-534, 100-535, 100-536, 100-537, 100-538, 100-539, 100-540, 100-541, 100-542, 100-543, 100-544, 100-545, 100-546, 100-547, 100-548, 100-549, 100-550, 100-551, 100-552, 100-553, 100-554, 100-555, 100-556, 100-557, 100-558, 100-559, 100-560, 100-561, 100-562, 100-563, 100-564, 100-565, 100-566, 100-567, 100-568, 100-569, 100-570, 100-571, 100-572, 100-573, 100-574, 100-575, 100-576, 100-577, 100-578, 100-579, 100-580, 100-581, 100-582, 100-583, 100-584, 100-585, 100-586, 100-587, 100-588, 100-589, 100-590, 100-591, 100-592, 100-593, 100-594, 100-595, 100-596, 100-597, 100-598, 100-599, 100-600, 100-601, 100-602, 100-603, 100-604, 100-605, 100-606, 100-607, 100-608, 100-609, 100-610, 100-611, 100-612, 100-613, 100-614, 100-615, 100-616, 100-617, 100-618, 100-619, 100-620, 100-621, 100-622, 100-623, 100-624, 100-625, 100-626, 100-627, 100-628, 100-629, 100-630, 100-631, 100-632, 100-633, 100-634, 100-635, 100-636, 100-637, 100-638, 100-639, 100-640, 100-641, 100-642, 100-643, 100-644, 100-645, 100-646, 100-647, 100-648, 100-649, 100-650, 100-651, 100-652, 100-653, 100-654, 100-655, 100-656, 100-657, 100-658, 100-659, 100-660, 100-661, 100-662, 100-663, 100-664, 100-665, 100-666, 100-667, 100-668, 100-669, 100-670, 100-671, 100-672, 100-673, 100-674, 100-675, 100-676, 100-677, 100-678, 100-679, 100-680, 100-681, 100-682, 100-683, 100-684, 100-685, 100-686, 100-687, 100-688, 100-689, 100-690, 100-691, 100-692, 100-693, 100-694, 100-695, 100-696, 100-697, 100-698, 100-699, 100-700, 100-701, 100-702, 100-703, 100-704, 100-705, 100-706, 100-707, 100-708, 100-709, 100-710, 100-711, 100-712, 100-713, 100-714, 100-715, 100-716, 100-717, 100-718, 100-719, 100-720, 100-721, 100-722, 100-723, 100-724, 100-725, 100-726, 100-727, 100-728, 100-729, 100-730, 100-731, 100-732, 100-733, 100-734, 100-735, 100-736, 100-737, 100-738, 100-739, 100-740, 100-741, 100-742, 100-743, 100-744, 100-745, 100-746, 100-747, 100-748, 100-749, 100-750, 100-751, 100-752, 100-753, 100-754, 100-755, 100-756, 100-757, 100-758, 100-759, 100-760, 100-761, 100-762, 100-763, 100-764, 100-765, 100-766, 100-767, 100-768, 100-769, 100-770, 100-771, 100-772, 100-773, 100-774, 100-775, 100-776, 100-777, 100-778, 100-779, 100-780, 100-781, 100-782, 100-783, 100-784, 100-785, 100-786, 100-787, 100-788, 100-789, 100-790, 100-791, 100-792, 100-793, 100-794, 100-795, 100-796, 100-797, 100-798, 100-799, 100-800, 100-801, 100-802, 100-803, 100-804, 100-805, 100-806, 100-807, 100-808, 100-809, 100-810, 100-811, 100-812, 100-813, 100-814, 100-815, 100-816, 100-817, 100-818, 100-819, 100-820, 100-821, 100-822, 100-823, 100-824, 100-825, 100-826, 100-827, 100-828, 100-829, 100-830, 100-831, 100-832, 100-833, 100-834, 100-835, 100-836, 100-837, 100-838, 100-839, 100-840, 100-841, 100-842, 100-843, 100-844, 100-845, 100-846, 100-847, 100-848, 100-849, 100-850, 100-851, 100-852, 100-853, 100-854, 100-855, 100-856, 100-857, 100-858, 100-859, 100-860, 100-861, 100-862, 100-863, 100-864, 100-865, 100-866, 100-867, 100-868, 100-869, 100-870, 100-871, 100-872, 100-873, 100-874, 100-875, 100-876, 100-877, 100-878, 100-879, 100-880, 100-881, 100-882, 100-883, 100-884, 100-885, 100-886, 100-887, 100-888, 100-889, 100-890, 100-891, 100-892, 100-893, 100-894, 100-895, 100-896, 100-897, 100-898, 100-899, 100-900, 100-901, 100-902, 100-903, 100-904, 100-905, 100-906, 100-907, 100-908, 100-909, 100-910, 100-911, 100-912, 100-913, 100-914, 100-915, 100-916, 100-917, 100-918, 100-919, 100-920, 100-921, 100-922, 100-923, 100-924, 100-925, 100-926, 100-927, 100-928, 100-929, 100-930, 100-931, 100-932, 100-933, 100-934, 100-935, 100-936, 100-937, 100-938, 100-939, 100-940, 100-941, 100-942, 100-943, 100-944, 100-945, 100-946, 100-947, 100-948, 100-949, 100-950, 100-951, 100-952, 100-953, 100-954, 100-955, 100-956, 100-957, 100-958, 100-959, 100-960, 100-961, 100-962, 100-963, 100-964, 100-965, 100-966, 100-967, 100-968, 100-969, 100-970, 100-971, 100-972, 100-973, 100-974, 100-975, 100-976, 100-977, 100-978, 100-979, 100-980, 100-981, 100-982, 100-983, 100-984, 100-985, 100-986, 100-987, 100-988, 100-989, 100-990, 100-991, 100-992, 100-993, 100-994, 100-995, 100-996, 100-997, 100-998, 100-999, 100-1000	Distance Relay - Start 0 CN, Start distance element - TOC start, Tripped Edo-50, 50-100, Start distance-100 hrs, Relay trip time -0.000s, Fault location-21.50km, Zone-2, towards Dorabang, 1A-103AA, 1B-112AA, 1C-113AA, 1D-114AA, 1E-115AA,			



Transmission System Performance Report

Second Quarterly Report-2021

SMD BEOTRANG Substation: 132.75kV Mungwa Substation Month: Jun 21																
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shortness/Tripping)	Shortness Tripping		Normalization Time		Duration of Outage (Hrs)	MW before Outage (MW)	Protection Relay Operd	Tripping Details Fault Details (As recorded by relay)	Type/Cause of Fault	Reason for Shortness	Weather Condition	Remarks	
				Date	Time	Date	Time									
1	132.75kV Transformer	132kV	Tripping	6/2/2021	9:48	6/2/2021	9:54	0	0.13	BACKUP PROTIN RELAY REFUSI	9A OPTD	OC & EF	---	Normal	Informed BPSO and CB closed from our end at 09:54hrs	
2	Mungwa-Dhondang Line	132kV	Tripping	6/16/2021	2:20	6/16/2021	2:28	8	-95.84	BACKUP PROTIN RELAY REFUSI	9A & 9B OPTD, 9-PH TRIPS	OC & EF	---	Fading Thunder and lightning	Informed BPSO and line resumed at 2:28 hrs from our end	
3	Mungwa-Rangia Line	132kV	Tripping	6/16/2021	2:20	6/16/2021	2:47	25	84.59	BACKUP PROTIN RELAY REFUSI	9A & 9B OPTD, ZONE-1 OPTD, 9-PH TRIPS	OC & EF	---	Fading Thunder and lightning	Informed BPSO and with code no. NLDLDC 807-1118,NLDLDC India 909 & NERLDC 479 CB closed from our end at 2:47hrs	
4	Mungwa-Dhondang Line	132kV	Tripping	6/25/2021	20:38	6/25/2021	20:41	3	-24.5	BACKUP PROTIN RELAY REFUSI	9A & 9B OPTD	OC & EF	---	Normal	Informed BPSO and line resumed at 20:41 hrs from our end.	
5	Mungwa-Phantasholing Line	132kV	Tripping	6/25/2021	20:38	6/25/2021	20:46	8	-8.06	BACKUP PROTIN RELAY REFUSI	9A & 9B OPTD	OC & EF	---	Normal	Informed BPSO and changed the line at 20:46hrs from our end.	
6	Mungwa-Rangia Line	132kV	Tripping	6/25/2021	20:38	6/25/2021	11:46	3	9.37	MAIN DISTANCE PROTIN RELAY REFUSI	9A & 9B OPTD	OV/SV	---	Normal	Informed BPSO,as instructed to close the CB with code NLDLDC 807-1118,NLDLDC India 1401 & NERLDC-087 CB closed at 11:46hrs from our end.	
7	Mungwa-Rangia Line	132kV	Tripping	6/26/2021	1:20	6/26/2021	2:27	1	9.37	Hand tripped	---	---	---	Normal	As per the BPSO instruction CB hand tripped and later under shutdown due to grid profile at Rangia end. BPSO instruct to close CB with code no. NLDLDC 807-1118,NLDLDC India 1401 and NERLDC-011 CB closed at 2:27hrs from our end.	

SMD BEOTRANG Substation: 132.75kV Corling Substation Month: Jun 21																
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shortness/Tripping)	Shortness Tripping		Normalization Time		Duration of Outage (Hrs)	MW before Outage (MW)	Protection Relay Operd	Tripping Details Fault Details (As recorded by relay)	Type/Cause of Fault	Reason for Shortness	Weather Condition	Remarks	
				Date	Time	Date	Time									
1	132 kV Chikha-Corling Line	132 kV	Increasing supply fail	25.06.2021	20:08 hrs	25.06.2021	20:39 hrs	0	21.000	Nil	There was no increasing supply due to grid fail	Grid fail	---	Clear	At 20:08 hrs increasing supply from Chikha substation fail and Corling substation was blocked for an breaker tripping has occurred at Corling substation.	

SMD BEOTRANG Substation: 132.75kV Phantasholing Substation Month: Jun 21																
Sl. No.	Name of Feeder	Voltage Level	Type of Outage (Shortness/Tripping)	Shortness Tripping		Normalization Time		Duration of Outage (Hrs)	MW before Outage (MW)	Protection Relay Operd	Tripping Details Fault Details (As recorded by relay)	Type/Cause of Fault	Reason for Shortness	Weather Condition	Remarks	
				Date	Time	Date	Time									
1	Kangling line(132kV)	132kV	Grid Fail	6/25/2021	20:38	6/25/2021	20:54	18	7.18	SV/OV Trip	Sub value 1:1-1480A,2-2177A,3-1094A,3-57A	SB	Not available	clear	Line charged after after called receive from BPSO	
2	Mungwa line(132kV)	132kV	Grid Fail	6/25/2021	20:38	6/25/2021	20:45	7	5.89	SV/OV Trip	Sub value 1:1-1421A,2-1194A,3-1071A,3-51A	SB	Not available	clear	Line charged after after called receive from BPSO	

Annexure-VI

Western grid Outages

Tripping report of 66kV and above feeders for the month of April, 2021																
Sl No.	Date of Tripping	Time of outages	Date of Normalization	Time of fault was cleared	Duration of Outages (Hrs)	MW before outage (MW)	Feeder Name	Name of the Substation/lines affected by the fault	Reasons of fault	Relay operations	Exact location of fault (Line segment/ Substation)	Type of outages	Remarks			
(A) 400/220/66/11 kV Malbase Substation																
1	22.04.2021	12:40	22.04.2021	13:08	0	27	400kV Silguri Feeder	Silguri Substation	Transient fault	Main 1 & 9A B optd.			IL1-376.9A-100.1deg, IL2-256A-47.17deg, IL3-1613A-90.29deg, IL4+ 4342A- 87.05deg [Note: weather conditions were light rainfall with lightning]			
2	22.04.2021	12:40	22.04.2021	12:40	0	0	220kV Bus coupler	Malbase Substation	Transient fault	30- trip, 16 optd.			Earthfault. [Note: weather conditions were light rainfall with lightning]			
(B) 220/66/11 kV Singhiguan Substation																
1	22.04.2021	12:40	22.04.2021	12:47	0	5.1	66kV Bhanu Concast Idr	Singhiguan GIS	Tripped due to Overcurrent	Directional overcurrent trip, 8P Trip, 06 optd			IL1-0.11kA, IL2-0.02kA, IL3-0.08kA.			
2	22.04.2021	12:40	22.04.2021	12:40	0	0	66kV Main Bus 1	Singhiguan GIS	Tripped due to Overcurrent	O/C Trip, General Trip, 06 optd			IL1-0.22kA, IL2-0.26kA, IL3-0.04kA.			
(C) 66/33/11 kV Phantasholing Substation																
1			13.04.2021	9:05	9	idle	66kV Malbase-Pling feeder	66kV Malbase-Pling feeder					At 09:05hrs charged 66kV Pling-Malbase feeder which was under idle condition with charging code 1949 from BPSO (for supply reliability at Pling 5a), since 66kV Chikha-Gudu section was taken shutdown by TMD, Tchimabakha for carrying out annual maintenance on 66kV chikha-Gudu section (i.e replacement of insulator with glass and polymer). On dated 18.04.2021 at 17:50hrs opened CB of 66kV Pling-Malbase feeder with opening code 0413 from BPSO and again the feeder was kept under idle condition.			
2	22.04.2021	3:07	22.04.2021	3:16	0	9.00	66kV Pling-Gomtu feeder	66kV Pling-Gomtu feeder	Tripped	DSTN OPTD, 106406	Line		At 03:07hrs 66kV Pling-Gomtu feeder got tripped at our end and 66kV Chikha-Pling feeder got tripped at Chikha end causing black out at Phantasholing. Weather condition was raining with lightning during the time of tripping. At 03:16hrs charged 66kV Malbase-Pling feeder after informing from BPSO. At 03:16hrs normalized 66kV Pling-Gomtu feeder after getting clearance from BPSO. At 03:35hrs opened CB of 66kV Pling-Malbase feeder with opening code 0433 from BPSO and again the feeder was kept under idle condition.			
(D) 66/33/11 kV Gudu Substation																
(E) 66/33/11 kV Gomtu Substation																
1	22.04.2021	03:09	22.04.2021	03:33	0	-7.57	66kV Incomer Dandam & Gomtu-Phantasholing	Gomtu Substation	Transient fault	General trip Zone-4 trip R ph. Fault	Line segment	Transient Fault	66 kV Phantasholing supply resumed at 3:36 hrs. 66kV Dandam feeder charged after informing to BPSO and Dandam Substation.			



Transmission System Performance Report

Second Quarterly Report-2021

(F) 220/66/33 kV Dhandum Substation Tripping Report for the month of APRIL 2021													
Sl. No.	Date of Tripping	Time of outages	Date of Normalization	Time of fault was cleared	Duration of Outages (hrs)	MW before outage (MW)	Feeder Name	Name of the Substation/lines affected by the fault	Reasons of fault	Relay operations	Exact location of fault (Line segment/ Substation)	Type of outages	Remarks
(A) 66kV Chanda switching station (B) 66/33kV Wana Substation (C) 66/33kV Olakha Substation													
1	08/04/2021	10:40	08/04/2021	12:43	0	7.7	66kV Olakha-Changidapha Line	Olakha substation	Due to fault at Dechencholing line	Distance protection relay 21 operated. Indication 1(general trip)	66kV Gasa line from Dechencholing	Transient Fault	The supply was fail from Santsikka due to fault at 66kV Dechencholing to Gasa Line as information received from BPSO and shift duty of Santsikka Substation.
4	19/04/2021	11:58	19/04/2021	12:10	0	5	66kV Olakha-Changidapha Line	Olakha Substation	Under voltage	Only Trip relay 86 Operated	Olakha Substation	Temporary	The supply was fail due to under voltages. Reset all the relays and changed the feeder, hold normal.
5	4/22/2021	1:40	4/22/2021	1:42	0	3.3	20MVA Transformer I	Only 33kV Chabacha feeder IV was effected as the other feeders was fed from Transformer II	Due to tripping of 33kV Chabacha feeder (Fb.IV)	TRAFO DIFFL, PROTIN, RELAY 87, Indication: 1,3,4 & 5. 1.General Trip, 3.DIFF Trip Ypk.4.DIFF Trip Rpk.5.DIFF Prot.Oper.DIR.O.C & E/F PROTIN.RELAY 67 Trip Relay 86.	Line Segment	Transient Fault	The 66/33kV 20MVA Transformer I was tripped due to tripping of 33kV O/G feeder IV (Chabacha) Charged the feeder and hold normal.
6	4/22/2021	13:15	4/22/2021	13:37	0	8.80	20MVA Transformer I	Only 33kV Chabacha feeder IV was effected as the other feeders was fed from Transformer II	Due to tripping of 33kV Chabacha feeder (Fb.IV)	TRAFO DIFFL, PROTIN, RELAY 87, Indication: 1,3,4 & 5. 1. General Trip, 3.DIFF Trip Ypk.4.DIFF Trip Rpk.5.DIFF Prot.Oper. Trip Relay 86.	Line Segment	Transient Fault	66/33kV 20MVA Transformer I tripped due to tripping of 33kV O/G IV (Chabacha feeder) Charged the feeder after confirmation and clearance received from ESD personal and hold normal.
(D) 66/33/11kV Lobeysa Substation													
1	28.04.2021	20:19hrs	28.04.2021	21:45hrs	1	-9.450	66kV LSA-Basocha	Lobeysa substation	Basocha machine tripped	NA	Basocha Plant	NA	66kV LSA -Basocha feeder tripped at 20:19hrs from Basocha end and No relay& breaker operated at our end supply resumed at 21:45hrs from Basocha end.
2	28.04.2021	23:05hrs	27.04.2021	00:21hrs	1	-7.020	66kV LSA-Basocha	Lobeysa substation	Basocha machine tripped	NA	Basocha Plant	NA	66kV LSA -Basocha feeder tripped at 23:05hrs from Basocha end and No relay& breaker operated at our end supply resumed at 00:21hrs from Basocha end on 27.04.2021.
(E) 66/33/11 kV Parsu Substation Nil													
(F) 66/33/11kV Jomda Substation Nil													
(G) 66/33/11kV Dechencholing substation													
1	4/8/2021	10:47hrs	4/8/2021	11:00hrs	0	3.113	Both 10MVA Tr.	Whole o/g line.	Due to insulator Puncture/broken	only 86 relay	Opposite of Ding S/S, 66kV line Santsikka to Ding incoming line.	Tripped	Sound came out like boom blast from opposite of our substation from double circuit tower, later we have found out that one side of double stringing insulator was puncture/broken due to low rating. 66kV incoming line tripped from Santsikka end, however both 10MVA Tr. are tripped at our end.
(H) 66/11kV Haa Substation													
1	01.04.2021	11:29	01.04.2021	11:39	0	-2.28	66kV Incoming, along with all the feeders.	unknown	O/C	Pangbesa substation, Pass	66kV incoming tripped from Pangbesa substation on occurrence. The same was normalised further.		
2	08.04.2021	14:07	08.04.2021	14:10	0	-1.8	66kV Incoming, along with all the feeders.	unknown	O/C	Pangbesa substation, Pass	66kV incoming tripped from Pangbesa substation on occurrence. The same was normalised further.		
(I) 220kV Substation Santsikka													
1	08.04.2021	10:46hrs	08.04.2021	10:52hrs	0:00	21.560	50MVA Transformer 1	220kV Santsikka Substation	R phase insulator punctured above Dechencholing	HV and LV Backup protection Operd. (DF) Ia=287.2A, Ib=61.27A, Ic=63.11A; (LV) Ia= 879.5A, Ib=185.2A, Ic=185.6A	220kV Santsikka Substation	Transient	
2	08.04.2021	10:46hrs	08.04.2021	10:45hrs	0:00	21.610	50MVA Transformer 2	220kV Santsikka Substation	R phase insulator punctured above Dechencholing	HV and LV Backup protection Operd. (DF) Ia=156.1A, Ib=119.5A, Ic=84.06A; (LV) Ia= 509.5A, Ib=108.3A, Ic=181.4A	220kV Santsikka Substation	Transient	
3	28.04.2021	12:10hrs	28.04.2021	12:14hrs	0:00	17.670	50MVA Transformer 1	220kV Santsikka Substation	Due to thunder and lightning Dechencholing line tripped and simultaneously both 50MVA tripped.	Differential protection operd. HV and LV Backup protection Operd.	220kV Santsikka Substation	Transient	
4	28.04.2021	12:10hrs	28.04.2021	12:13hrs	0:00	17.900	50MVA Transformer 2	220kV Santsikka Substation	Due to thunder and lightning Dechencholing line tripped and simultaneously both 50MVA tripped.	Differential protection operd. HV and LV Backup protection Operd.	220kV Santsikka Substation	Transient	
5	08.04.2021	10:46hrs	08.04.2021	10:59hrs	0:00	6.850	66kV Santsikka-Dechencholing Feeder	220kV Santsikka Substation & 66kV Dechencholing Substation	R phase insulator punctured above Dechencholing	Ia=> Trip Ia= 1.951kA, Ib=56.87A, Ic=45.23A		Permanent	
6	28.04.2021	12:10hrs	28.04.2021	12:21hrs	0:00	7.420	66kV Santsikka-Dechencholing Feeder	220kV Santsikka Substation & 66kV Dechencholing Substation	R phase insulator punctured above Dechencholing	Distance Protection Operd. Ia=> Trip Ia= 3.318kA, Ib=74.6A, Ic=62.66A		Transient	
(J) 66/33/11kV Pangbesa substation													
1	02.04.2021	11:33hrs	02.04.2021	11:39hrs	0	2.21	66kV O/G Haa feeder	Haa	O/C			Transient	
2	09.04.2021	14:07hrs	09.04.2021	14:10hrs	0	1.74	66kV O/G Haa feeder	Haa	O/C			Transient	
(K) 66/33kV Changidapha Substation (L) 66/33kV Damji Substation													
1	08.04.2021	10:48hrs	11.04.2021	3:49hrs	76	-0.29	33kV Incoming line		Failure of insulator	NA			66kV incoming line was tripped at 10:48 hrs and line at Damji Substation had been back feed from Panakha at 14:07 hrs. 66kV line charged at 15:40 hrs as per the closing code 1961 from BPSO.
2	28.04.2021	12:14hrs	28.04.2021	12:27hrs	0	-0.29	6/33kV incoming line		Hard trip	NA			66kV line breakdown (Hard trip) from Santsikka.

May 2021

Sl. No.	Date of Tripping	Time of outages	Date of Normalization	Time of fault was cleared	Duration of Outages (hrs)	MW before outage (MW)	Feeder Name	Name of the Substation/lines affected by the fault	Reasons of fault	Relay operations	Exact location of fault (Line segment/ Substation)	Type of outages	Remarks
(A) 66/220/66/11 kV Malbase Substation 66kV & Above													
1	03.05.2021	18:25	03.05.2021	13:40	3	-46	220kV Chakha-Malbase Feeder 2	Malbase s/s	Overcurrent	zone 1 trip, 86 Operated, fault loop L2-N, distance at 18.97 km	L2-N-18.97 km	Overcurrent fault	Ia=68.66 A, Ib=5.381kA, Ic=157A
2	3.05.2021	13:25	03.05.2021	15:02	1	23	50/63 Mva Trafo 3	Malbase s/s	Overcurrent	Differential trip, 27 Trip, 86 operated, Juron BLK trip		Overcurrent fault	R phase=148.22A/6.79deg, Y phase=788.53A/1.90deg, B phase=89.23A/72.53 deg, N=229.97A/175.16deg
3	03.05.2021	14:50	03.05.2021	14:58	0	18	220kV Malbase-Santosa Feeder	Dhandum s/s	Earth fault	Main 1 trip, zone 1 trip, R/U trip, 86 operated, fault loop-L1-N, distance at 18.8 km	fault loop-L1-N-18.8 km	Overcurrent fault	R phase=4386A/283.8deg, Y phase=55.02A/114.5deg, B phase=106.4A/109.0deg, N=414A/283.8deg
4	3.05.2021	15:01	03.05.2021	15:52	0	9	220kV Malbase-Santosa Feeder	Dhandum s/s	Earth fault	Main 1 trip, zone 1 trip, R/U trip, 86 operated, fault loop-L1-N, distance at 18 km	fault loop-L1-N-18 km	Overcurrent fault	R phase= 8886A/283.8deg, Y phase= 54.86A/119.2deg, B phase= 187.2A/111 deg, N=447A/ 283.8deg
5	03.05.2021	0:22	03.05.2021	0:31	0	7	220kV Malbase-Santosa Feeder	220kV Santosa feeder	Overcurrent	Rel 51 Low overcurrent protection operated, distance protection operated, Main 1 trip, Trip R,Y,B phase, zone 1 trip		Overcurrent fault	67/67 N, G1 phase A FWD (DMTC) (285) Ia=3952A, Ib= 135.7A, Ic= FWD (DMTC)=192A, E/F (REV) Ia=137A
6	04.05.2021	1:00	04.05.2021	1:15	0	18	66kV Panakha Feeder 1	66kV panakha feeder 1.	Overcurrent	Rel 70, 51 start, 86 operated, IOC30 trip, general trip, HEPSON trip		Overcurrent fault	R phase= 231A, 17-43.77deg, Y phase= 197.79A-175.7deg, B phase= 1807.63A-51.50 deg, N=432.07A-144.14deg
7	04.05.2021	1:00	04.05.2021	1:15	0	28	66kV Panakha Feeder 2	66kV panakha feeder 2.	Overcurrent	Rel 70, 51 start, 86 operated, IOC30 trip, general trip, HEPSON trip		Overcurrent fault	R phase= 3233.90A-78.75deg, Y phase= 2128.21A-173.86deg, B phase= 525.15A-84.90 deg
8	04.05.2021	1:00	04.05.2021	1:15	0	21	66kV Panakha Feeder 4	66kV panakha feeder 4.	Overcurrent	Rel 67, 51 start, 86 operated, IOC30M trip, general trip, HEPSON trip		Overcurrent fault	R phase= 3345A-66.27deg, Y phase= 3948.35A-164.22deg, B phase= 5868.2A-35.05 deg
9	11.05.2021	18:17	12.05.2021	12:43	18	72	200 MVA ICT Malbase s/s	Malbase s/s	Backfeed Trip	R phase backfeed alarm, backfeed trip, 86 Relay trip	ICT R phase transformer		L1=0.892 A-13.83 deg, L2=0.022 A-149.4 deg, L3=0.887 A/-6.15 deg
(B) 220/66/11 kV Singhgagan Substation													
1	03.05.2021	15:11	03.05.2021	16:03	0	3.3	220kV Singga Santosa	G/S, Singhgagan s/s	Overcurrent	overcurrent trip and 86 opad.		Overcurrent Fault	L1=329A-282.9 deg, L2=189.5A-107.7deg, L3=108.3A-111.7deg



Transmission System Performance Report

Second Quarterly Report-2021

(G) 66/33/11kV Dushanbe Substation													
Sr	Date of Tripping	Time of Outages	Date of Normalization	Time of fault was cleared	Duration of Outages (Hrs)	MW before outage (MW)	Feeder Name	Substation/Lines affected by the fault	Reasons of fault	Relay operations	Exact location of fault [Line segment/Substation]	Type of outages	Remarks
1	03.05.2021	13:30hrs	03.05.2021	14:07hrs	0	-6.024	66KV VC		Supply failed from source				
2	08.05.2021	01:20hrs	08.05.2021	01:20hrs	0	0.125	66KV Gasa OG		Over current	O/C A 50 AA B	Gasa end	Tripped	File tripped the fault at Gasa end.
3	09.05.2021	16:22hrs	09.05.2021	17:12hrs	0	-6.228	66KV VC		Supply failed from source				
4	15.05.2021	18:53hrs	15.05.2021	19:00hrs	0	-4.881	30MVA Tr-I & B		Over current	50B & 50C 80	Not known	Tripped	Transformer tripped due to jolting of 33KV Thangha Hydro fault
5	17.05.2021	11:43hrs	17.05.2021	11:50hrs	0	-1.225	-		REF prot.	80 relay	-	Tripped	Transformer tripped on REF prot.
6	01.05.2021	09:42 hrs	01.05.2021	17:19hrs	7 hrs	3.784	30MVA Tr-II		Shut down taken by Project Office Olakha TPO for fixing the 30MVA Transformer accessories by Hydra machine.				
7	01.05.2021	17:25hrs	01.05.2021	19:00hrs	1 hrs 35 min	6.028	30MVA Tr-I		Shut down taken by Project Office Olakha TPO for fixing the 30MVA Transformer accessories by Hydra machine.				
8	01.05.2021	18:15hrs	01.05.2021	19:30hrs	1 hrs 15 min	6.662	30MVA Tr-II		30MVA-II Transformer shut down taken by Olakha TPO for connecting conservator accessories.				
9	03.05.2021	11:50 hrs	03.05.2021	17:40hrs	5 hrs 50 min	2.808	30MVA Tr-II		Shut down issued to TPO Olakha to install conservator tank at new 30MVA Transformer by Hydra machine.				
10	04.05.2021	11:00hrs	04.05.2021	11:52 hrs	0	3.674	30MVA Tr-I		TPO project Engineer took the shut down for unloading another filter machine at transformer yard by the Hydra machine.				
11	04.05.2021	11:30hrs	04.05.2021	12:16hrs	0	3.674	30MVA Tr-II		Same work				
12	04.05.2021	12:10hrs	04.05.2021	18:02hrs	6 hrs	7.427	30MVA Tr-II		Shifting of Filter machine to other location by Hydra Machine.				
13	08.05.2021	12:15hrs	08.05.2021	19:00hrs	6 hrs 45 min	3.884	30MVA Tr-I		Shut down taken by Project Office Olakha TPO for fixing the 30MVA Transformer-I radiator fan from HV side by Hydra Machine.				
14	12.05.2021	10:40hrs	12.05.2021	16:43hrs	6 hrs 3 min	3.077	30MVA Tr-II		Shut down taken by Project Office Olakha TPO for fixing the 30MVA-II Transformer-II HV loading current transformer with help of Hydra Machine.				
15	13.05.2021	09:10hrs	13.05.2021	18:10hrs	9 hrs	3.179	30MVA Tr-II		Installation of breaking CT at new 30MVA Case-II				
16	14.05.2021	09:15hrs	14.05.2021	18:50hrs	9 hrs 35 min	2.923	30MVA Tr-II		Shut down by PTO office to find the pipe line of conservator tank to main transformer body.				
17	15.05.2021	09:30hrs	15.05.2021	10:55hrs	0	3.043	30MVA Tr-II		For shifting the filter machine from transformer II location to near the transformer-I				
18	15.05.2021	11:10hrs	15.05.2021	14:20hrs	3 hrs 10 min	2.496	30MVA Tr-I & 2 30MVA Tr-I		Shut down taken by SMD maintenance team to make alignment of 33KV side Bus coupler isolator, square the line & bus isolator.				
19	15.05.2021	14:50hrs	15.05.2021	19:00hrs	4 hrs 10 min	4.743	30MVA Tr-II		Shut down taken by Olakha project office to connect the pipe.				
20	17.05.2021	10:30hrs	17.05.2021	15:10hrs	4 hrs 40 min	5.728	30MVA Tr-II		Shut down caused by project staff for fixing and adjustment of pipe on conservator tank.				
21	18.05.2021	10:45hrs	18.05.2021	16:20hrs	5 hrs 35 min	2.729	30MVA Tr-II		Shut down caused by SMD maintenance team to fix retrofitting new digital relay of 30MVA-II				
22	19.05.2021	10:52hrs	19.05.2021	14:00hrs	3 hrs 8 min	2.332	30MVA Tr-I		For shifting of CCTV for 66KV Gasa.				
23	19.05.2021	11:50hrs	19.05.2021	19:50hrs	8 hrs	3.908	30MVA Tr-II		Replacement of CT at HV & LV side of 30MVA Tr-II by SMD maintenance team.				
24	20.05.2021	10:10hrs	20.05.2021	19:20hrs	9 hrs 10 min	2.328	30MVA Tr-II		Commissioning of replacement of HV CT and testing of relay.				
25	21.05.2021	10:10hrs	21.05.2021	18:10hrs	8 hrs	2.376	30MVA Tr-II		30MVA transformer-II Test Delta test and HV test by SMD maintenance team.				
26	22.05.2021	10:40hrs	22.05.2021	18:10hrs	7 hrs 30 min	2.169	30MVA Tr-II		Shut down taken by Olakha TPO for testing of LV side CT of 30MVA Transformer & installation of relay.				
27	24.05.2021	10:15hrs	24.05.2021	16:23hrs	6 hrs 8 min	1.89	30MVA Tr-II		For Testing 30MVA Tr-II				
28	24.05.2021	16:24hrs	24.05.2021	19:11hrs	2 hrs 47 min	3.428	30MVA Tr-I		For installation of Radiator at 30MVA Tr-I				
29	25.05.2021	09:55hrs	25.05.2021	20:20hrs	10 hrs 25 min	2.11	30MVA Tr-II		For testing 30MVA Tr-II & installation of Meter in control room.				
30	26.05.2021	14:05hrs	26.05.2021	16:40hrs	2 hrs 35 min	1.89	30MVA Tr-II		Commissioning of testing 30MVA Tr-II				
31	27.05.2021	10:45hrs	27.05.2021	11:50hrs	1 hrs 5 min	2.269	30MVA Tr-II		For installation of HV & LV loading of 30MVA Transformer-II				
32	29.05.2021	12:12hrs	29.05.2021	14:22hrs	2 hrs 10 min	0	30MVA Tr-II		For releasing the Air from Transformer for loading.				
33	31.05.2021	11:15hrs	31.05.2021	15:45hrs	4 hrs 30 min	0	30MVA Tr-II		For testing 30MVA relay.				
34	31.05.2021	11:20hrs	31.05.2021	17:40hrs	6 hrs 20 min	0	30MVA Tr-II		For testing 30MVA Tr LV side CT.				

June 2021

Sr	Date of Tripping	Time of Outages	Date of Normalization	Time of fault was cleared	Duration of Outages (Hrs)	MW before outage (MW)	Feeder Name	Substation/Lines affected by the fault	Reasons of fault	Relay operations	Exact location of fault [Line segment/Substation]	Type of outages	Remarks
(A) 400/220/66/33 kV Malbase Substation													
66kV & Above													
1	01.06.2021	22:50	02.06.2021	1:42	1	21	50/63MVA Transformer I	Malbase s/s	Overcurrent	General trip, LBB trip, B6 optd, 51 trip.	66kV Piling line	Overcurrent fault	IL1-759.97A--1.97 deg, IL2-750.2A--124.4deg, IL3-733.06A--116.7deg, IL4-22.13A--127.06deg. Note: Due to permanent fault in piling line, Feeders connected to the same bus of it could not withstand while test charged. After knowing the fault and isolating piling line only we could charged rest of the feeders.
2	01.06.2021	22:50	02.06.2021	1:45	1	21	66kV Pasakha Feeder I	Malbase S/S	Overcurrent	50trip, 86 optd, General trip.	66kV Piling line	Overcurrent fault	IL1-991.76A--8.95 deg, IL2-1324A--134deg, IL3-1164A-115.4)deg, IL4-455.4A-5.26deg.
3	01.06.2021	22:50	02.06.2021	14:50	15	-	66kV Bus Coupler	Malbase S/S	Earth fault	-	66kV Piling line	O/C & E/F	IL3-138.67A--91.54deg, IL4-7437.5A--84.27deg, G2 PHASE A[FWD]-L5- IDMTL IA-1062A, PHASE B [FWD] 51.66A, PHASE C[FWD] IC-112.7A, E/F [FWD] IDMTL IE-974.5A.
4	05.06.2021	20:37	05.06.2021	20:42	0	81	200MVA ICT	Malbase S/S	Earth fault	67/67N optd and 86 optd.	-	O/C & E/F	IL1-29.1A-99.23 deg, IL2-69.09A--176.39deg, IL3-121.24A-126.15deg, IL4-189.78A-139.85deg.
5	05.06.2021	20:37	05.06.2021	20:45	0	21	50/63MVA Transformer III	Malbase S/S	Overcurrent	OLT-C-BUCH trip	-	Overcurrent fault	IL1-768A--3.29 deg, IL2-694.51A-133.45deg, IL3-392A-137.94deg, IL4-614A-117.75deg.
6	06.06.2021	23:20	06.06.2021	23:29	0	20	50/63MVA Transformer I	Malbase S/S	Overcurrent	LBB trip, General trip, B6 optd.	66kV Piling line	Overcurrent fault	IL1-549A-10.19deg, IL2-175.3A-139.15deg, IL3-209.96A-138.42deg, IL4-171.57A--1302deg.
7	06.06.2021	23:20	06.06.2021	23:31	0	20	66 kV Pasakha Feeder I	Malbase S/S	Overcurrent	SPAJ 140C relay optd. I- trip.	66kV Piling line	Overcurrent fault	Bus coupler tripped due to jerk from 66kV side.
8	06.06.2021	23:20	06.06.2021	23:26	0	-	220kV Bus Coupler	Malbase S/S	Overcurrent	SPAJ 140C relay optd. I- trip.	66kV Piling line	Overcurrent fault	Bus coupler tripped due to jerk from 66kV side.
9	06.06.2021	23:20	06.06.2021	23:30	0	-	66kV Bus Coupler	Malbase S/S	E/F	IOC trip, General trip, IEF 50N trip.	66kV Piling line	Overcurrent fault & E/F	IL1-7695.44A--23.75deg, IL2-290.58A--17.36deg, IL3-68.15A--33.4)deg, IL4-7695A--23.75deg.
10	12.06.2021	9:19	12.06.2021	9:24	0	24	66 kV Pasakha Feeder IV	Malbase S/S	E/F	General trip, IEF 50N trip, 86 optd.	66kV Pasakha IV line	E/F	IL1-2427.31A--45.63deg, IL2-271.05A--76.9deg, IL3-166.6A-90.27deg, IL4-2538.37A-133.82deg.
11	12.06.2021	9:19	12.06.2021	9:24	0	24	66 kV Pasakha Feeder II	Malbase S/S	Overcurrent	General trip, IEF 50N trip, 86 optd.	66kV Pasakha II line	Overcurrent fault	IL1-0.27A-40.72deg, IL2-1233.14A-35.39deg, IL3-768.98A-56.88deg.
12	12.06.2021	9:19	12.06.2021	9:24	0	25	66 kV Pasakha Feeder IV	Malbase S/S	Overcurrent	General trip, IEF 50N trip, 86 optd., IOC 50-trip.	66kV Pasakha IV line	Overcurrent fault	IL1-1111.43A-51.27deg, IL2-401.95A-166.54deg, IL3-579.73A-120.4deg.
13	19.06.2021	21:18	19.06.2021	21:25	0	23	66 kV Pasakha Feeder I	Malbase S/S	E/F	General trip, IEF 50N trip, 86 optd.	66 kV Pasakha Feeder I line	E/F	IL1-2592.08A--47.93deg, IL2-299.68A--94.45deg, IL3-151.74A-127.77deg, IL4-2651.87A-127.7deg.
14	19.06.2021	21:18	19.06.2021	21:25	0	23	66 kV Pasakha Feeder II	Malbase S/S	Overcurrent	General trip, IEF 50N trip, 86 optd.	66 kV Pasakha Feeder II line	Overcurrent fault	IL1-0.32A--140.89deg, IL2-1299.73A--147.96deg, IL3-848.99A--131.43deg.
15	19.06.2021	21:18	19.06.2021	21:25	0	24	66 kV Pasakha Feeder IV	Malbase S/S	Overcurrent	General trip, IEF 50N trip, 86 optd.	66kV Pasakha IV line	Overcurrent fault	IL1-91.17A--31.23deg, IL2-304.4A-146.04deg, IL3-615.55A-104.45deg.
16	19.06.2021	21:18	19.06.2021	21:25	0	-	66kV Bus Coupler	Malbase S/S	E/F	General trip.	-	E/F	IL1-1437.31A--46.94deg, IL2-467.77A--33.38deg, IL3-330.93A--66.28deg, IL4-2226.45A--31.4deg.
17	22.06.2021	20:30	22.06.2021	20:39	0	78	200MVA ICT	Malbase S/S	Overcurrent	67/67N optd and 86 optd.	-	-	PHASE A[FWD]-L5- IDMTL IA-1190A, PHASE B [FWD] IB- 166.1A, PHASE C[FWD]-L5-IC-1418A, E/F [FWD] IDMTL IE-923.4A.
18	22.06.2021	20:30	22.06.2021	20:43	0	27	50/63MVA Transformer III	Malbase S/S	-	DIF. trip.	-	-	IL1-21A-171.66deg, IL2-121.64A-133.03deg, IL3-175.64deg, IL4-186.2A--150.48deg.
19	22.06.2021	20:30	22.06.2021	20:53	0	51	220kV Birpara Feeder	Malbase S/S & Birpara line	Overcurrent	Zone 1 trip, 86 OPTD.	18.77 km	Overcurrent fault	IL1-4.613kA, IB=379.7A, IC =5.197kA
(B) 220/66/11 kV Singhignon Substation													
1	05.06.2021	20:37	05.06.2021	21:07	0	7	220kV Samtae Feeder	GIS, Singhignon s/s	E/F	O/C trip, 86 trip.	Samtae line	E/F	IL1-5006 A, IL2-64.75A, IL3-83.95A, I4 =4866A
2	12.06.2021	9:19	12.06.2021	9:20	0	5	66kV Bhutan Concast & Druk cement Feeder	GIS, Singhignon s/s	Overcurrent	General trip, O/C trip, IE-- trip, L-- Directional trip, IEF Directional Trip.	-	Overcurrent Fault	IL1-5.24kA, IL2-0.42kA, IL3-0.22kA
3	19.06.2021	21:18	19.06.2021	21:27	0	1	66kV Bhutan Concast & Druk cement Feeder	GIS, Singhignon s/s	Overcurrent	I--D irectional trip, General trip.	-	Overcurrent Fault	IL1-5.28kA, IL2-0.42kA, IL3-0.28kA



Transmission System Performance Report

Second Quarterly Report-2021

B) 66/33/11 kV Phuntsholing Substation													
1		04.06.2021	9:00	9	idle	66kV Malbase-Pling feeder	66kV Malbase-Pling feeder				At 09:00hrs issued shutdown to Jigme Gyale, Sr.Engineer,TMD Pling with work permit no 522 for re-string snapped conductor between location P5-3 & P5-4. After completion of works at 18:30hrs CB closed from Malbase end and 66kV Malbase-Pling feeder kept under idle position.		
2		05.06.2021	11:27	11	idle	66kV Malbase-Pling feeder	66kV Malbase-Pling feeder				At 11:27hrs charged 66kV Pling-Malbase feeder which was under idle condition with charging code 1035 as per instruction from BPSO (for supply reliability at Pling Sa), since 66kV Chukha-Pling feeder taken shutdown by Gedu substation for rectification of isolators at Gedu substation. At 13:45hrs opened CB of 66kV Pling-Malbase feeder after getting clearance from BPSO with opening code 0008 and again the feeder was kept under idle condition.		
		08.06.2021	10:00			66kV Malbase-Pling feeder	66kV Malbase-Pling feeder		Line		66kV Malbase-Pling feeder test charged with charging code 1070 for checking the healthiness of line as per instruction from BPSO. At 10:30hrs opened CB of said feeder as per instruction from BPSO with opening code 0017.		
#		20.06.2021	17:37	17	idle	66kV Malbase-Pling feeder	66kV Malbase-Pling feeder		Line		66kV Malbase-Pling feeder test charged with charging code 1753 from from BPSO, since there was shutdown on 66kV Chukha-Pling feeder. At 18:44hrs opened CB of said feeder as per instruction from BPSO with opening code 0075.		
#	30.06.2021	2:06	30.06.2021	12:08	10	0.98	66kV Pling-Gomtu feeder	66kV Pling-Gomtu feeder	DSTN OPTD, 1186A86	Gomtu substation	66kV Pling-Gomtu feeder tripped at our end and 66kV Chukha-Pling feeder got tripped at their end causing blackout at Pling. At 02:09hrs supply was extended from Malbase substation after informing to BPSO. At 02:25hrs 66kV Chukha-Pling feeder normalised from chukha end. 66kV Pling-Gomtu fdr taken shutdowns by Gomtu substation since jumper conductor got snapped at Gomtu as end. After completion rectification works at Gomtu at 12:00hrs 66kV Pling-Gomtu feeder normalised with charging code 1283 from Gomtu substation. Opened CB of 66kV Malbase-Pling with opening code 0106 from BPSO and feeder was kept under idle charged.		
D) 66/33/11 kV Gedu Substation													
1	03.06.2021	13:29	03.06.2021	13:32	0	0.17	66/33/11kV 5MVA Tr III	33kV Guranglara-II		REF	Substation	Charged the Transformer after isolating the out going feeder. 33kV Guranglara feeder-II was charged from 33kV Guranglara feeder-I.	
2	04.06.2021	9:35	20.06.2021	22:00	12	0.13	66/33/11kV 5MVA Tr III	Nil	Isolator alignment problem and oil filtration		Substation	Shutdown	Work permit No. 71 issued to Mrs. Rinchen Zangmo, Sr. Engineer of SMD Pling to carry out HV isolator alignment problem and to perform oil filtration.
3	05.06.2021	11:36	05.06.2021	13:50	2	0.18	66/33/11kV 5MVA Tr III	Nil	Isolator alignment problem		Substation	Shutdown	Work permit No. 72 issued to Mrs. Rinchen Zangmo, Sr. Engineer of SMD Pling to carry out HV isolator alignment problem on 5MVA 66/33kV transformer-III.
4	07.06.2021	18:10	07.06.2021	20:33	2	1.16	66kV Chukha-Pling Line	Black out	Rectification of isolator alignment		Substation		For rectification of 5MVA transformer-III HV side isolator alignment.
5	08.06.2021	12:17	08.06.2021	12:33	0	1.58	66kV Chukha-Pling Line	Black out	Rectification of isolator alignment		Substation		For rectification of 5MVA transformer-III HV side isolator alignment.
6	17.06.2021	12:52	23.06.2021	11:30	372	1.6	5MVA 66/11kV Tr-II	Nil	Oil filtration		Substation	Shutdown	Work permit No. 76 issued to Mrs. Rinchen Zangmo Sr. Engineer of SMD Pling for transformer oil filtration.
7	20.06.2021	18:08	20.06.2021	18:40	0	1.48	66kV Chukha-Pling Line	Black out	Rectification of isolator alignment		Substation		For rectification of 5MVA transformer-III HV side isolator alignment.
8	21.06.2021	12:27	26.06.2021	14:35	122	0.34	5MVA 66/33kV Tr	Nil	Oil filtration		Substation	Shutdown	Work permit No. 77 issued to Mrs. Rinchen Zangmo Sr. Engineer of SMD Pling for transformer oil filtration.
9	23.06.2021	11:17	27.06.2021	16:57	101	0.79	5MVA 66/11kV Tr-I	Nil	Oil filtration		Substation	Shutdown	Work permit No. 78 issued to Mrs. Rinchen Zangmo Sr. Engineer of SMD Pling for transformer oil filtration.
10	26.06.2021	14:30	27.06.2021	11:58	21	0.43	66/33/11kV 5MVA Tr III	Nil	Oil filtration		Substation	Shutdown	Work permit No 79 issued to Mrs Rinchen Zangmo, Sr Engineer for oil filtration on OLT.
11	30.06.2021	2:06	30.06.2021	2:10	0	0.51	66kV Chukha-Pling Line	Black out			Line		Supply charged from Phuntsholing end.
E) 66/33/11 kV Gomtu Substation													
1	30.06.2021	2:06	30.06.2021	02:41	0	-0.301	Dhamdum	Whole Gomtu	NA	NA	Gomtu Sub Station		Supply failed from Dhamdum Sub Station.
2	30.06.2021	2:06	30.06.2021	12:08	10	0.24	Gomtu-P/Ling	Nil	Over Current	IDMTL Over Current 51AX 51BX 51CX	Gomtu Sub Station		Y phase conductor between Wave trap and Line Isolator burned to dead.
F) 220/66/33 kV Dhamdum Substation													
220kV													
1	05.06.2021	20:37	05.06.2021	20:46	0	-6.74	220 kV Singyeoan	N/A	Transient fault	REL670-General trip, Zone-L, R Ph	N/A	N/A	220kV singyeoan feeder tripped from both the end and charge at 20:46hrs as per the clearance given by BPSO, T/plus. Dist. Showing :19.56km and 48.90% and C/B Closed from Malbase end at 21:07 hrs.
2	30.06.2021	2:06	30.06.2021	2:41	0	0.25	66kV Gomtu feeder	Gomtu	Transient fault	REF615-DIR.O/C 67 Trip. RY,B Ph fault.	N/A	N/A	66kV Gomtu Feeder feeder tripped at both the ends at 02:06hrs and charged at 02:41 hrs as per the charging code No 1289 by Phub Zangmo, BPSO Thimphu.