



ལྷན་ཁག་གི་འཕེལ་རྒྱུ་ལྷན་ཁག་གི་འཕེལ་རྒྱུ་གཞི་རྒྱུ་
 Ministry of Energy and Natural Resources
 Royal Government of Bhutan
 Office of the Bhutan Power System Operator
 Thimphu: Bhutan



THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 22-Sep-2024(-ve:import, +ve:export)

Report Details	Date	Time	National Coincidental Peak Load (MW)	Date	Time	Load
	21-Sep-24	09:00 hrs		30-Dec-23	18:00 hrs	955.51

Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks
1	6 x 170MW THP	Unit- I	185.08	400kV THP - Siliguri Line - I	227.05	
		Unit- II	185.35	400kV THP - Siliguri Line - II	225.49	
		Unit- III	185.51	400kV THP - Siliguri Line- IV	216.51	
		Unit- IV	185.32	400kV THP - Malbase Line - III	447.67	
		Unit- V	188.51	400kV Malbase - Siliguri Line	161.36	
		Unit- VI	185.64	-	-	
		Total	1,115.41	Auxiliary Consumption & Transformation Losses at Generator end	-0.12%	
2	4 x 180MW MHP	Unit-I	180.23	400kV MHP - Jigmeling Line - I	273.78	400kV MHP-JLG Line IV on Standby. 132kV MHP_Yurmoo Line-I not in Service. 400kV JLG_ALI Interim Line I on Standby.
		Unit-II	195.27	400kV MHP - Jigmeling Line - II	274.17	
		Unit-III	180.01	400kV MHP - Jigmeling Line - III	267.90	
		Unit-IV	179.62	400kV MHP - Jigmeling Line - IV	0.00	
		-	-	132kV MHP - Yurmo Line - I	0.00	
		-	-	132kV MHP - Yurmo Line - II	30.41	
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	141.58	
		-	-	400kV Jigmeling - Puna - Alipurduar Line - I	0.00	
		-	-	400kV Jigmeling - Puna - Alipurduar Line - II	167.28	
		-	-	400kV Jigmeling - Alipurduar Line - I	251.18	
		-	-	400kV Jigmeling - Alipurduar Line - II	250.77	
		-	-	80MVA, 220/132kV ICT - I (HV)	59.90	
		-	-	80MVA, 220/132kV ICT - II (HV)	59.45	
		-	-	220kV Tsirang - Jigmeling Line	-5.06	
		-	-	132kV Gelephu - Salakati Line	30.33	
Total	735.13	Auxiliary Consumption & Transformation Losses at Generator end	0.43%			
3	4 x 84MW CHP	Unit- I	91.26	220kV CHP - Birpara Line - I	27.86	
		Unit- II	91.93	220kV CHP - Birpara Line - II	27.35	
		Unit- III	91.50	220kV CHP - Gedu	81.83	
		Unit- IV	91.14	220kV CHP - Jamjee (old) - I	74.12	
		-	-	220kV CHP - Jamjee - II (new)	74.61	
		-	-	220kV CHP - Jamjee - III (new)	72.35	
		-	-	220kV Malbase - Birpara Line	25.82	
		-	-	66kV CHP - Gedu Line	7.89	
		-	-	3x3MVA, 66/11kV TFR	0.79	
Total	365.83	Auxiliary Consumption & Transformation Losses at Generator end	-0.27%			
4	2 x 12MW BHP (U/S)	Unit- I	7.46	220kV BHP - Semtokha Line	88.80	
		Unit- II	9.33	66kV BHP - Lobeyasa Line	25.94	
		Total	16.79	220kV BHP - Tsirang Line	-69.47	
5	2 x 20MW BHP (L/S)	Unit- I	14.69	5MVA, 66/11kV TFR	0.48	
		Unit- II	14.16	30MVA ICT, 220/66kV (HV)	10.00	
		Total	28.85	Auxiliary Consumption & Transformation Losses at Generator end	-0.24%	
6	2 x 63MW DHP	Unit-I	34.31	220kV DHP - Tsirang Line	66.89	220kV DHP_Dagapela Line on Standby.
		Unit-II	33.01	220kV DHP - Dagapela Line	0.00	
		-	-	220kV Jigmeling - Dagapela Line	53.13	
		-	-	5MVA, 220/33kV TFR	0.22	
Total	67.32	Auxiliary Consumption & Transformation Losses at Generator end	0.31%			
7	4 x 15MW KHP	Unit- I	16.54	132kV KHP - Nangkor Line	42.23	
		Unit-II	16.53	132kV KHP - Kilikhar Line	23.03	
		Unit- III	16.69	5MVA, 132/11kV TFR	0.29	
		Unit- IV	16.58	132kV Motanga - Rangia Line	54.44	
		Total	66.34	Auxiliary Consumption & Transformation Losses at Generator end	1.19%	
8	2 x 59MW NHP	Unit-I	60.09	132kV NHP-MHP-I	59.68	
		Unit-II	54.98	132kV NHP-MHP-II	54.60	
		Total	115.07	Auxiliary Consumption & Transformation Losses at Generator end	0.69%	

Note: Generation-Load Summary (MW) for 21-Sep-24 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,594.20	687.82	690.00	911.44	-2.18
2	Eastern Grid	916.54	157.48	152.75	754.00	4.73
	Total	2,510.74	845.30	842.75	1,665.44	2.55

Note: Generation-Load Summary for 21-Sep-23 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,443.53	684.73	664.89	795.13	19.84
2	Eastern Grid	677.88	117.37	112.96	524.18	4.41
	Total	2,121.41	802.10	777.85	1,319.31	24.25

THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 22-Sep-2024(-ve:import, +ve:export)							
Report Details	Date	Time	National Coincidental Peak Load (MW)		Date	Time	Load
	21-Sep-2024	19:00 hrs			30-Dec-2023	18:00 hrs	955.51
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks	
1	6 x 170MW THP	Unit-I	184.71	400kV THP - Siliguri Line - I	219.69		
		Unit-II	185.83	400kV THP - Siliguri Line - II	219.69		
		Unit-III	185.53	400kV THP - Siliguri Line - IV	206.77		
		Unit-IV	185.19	400kV THP - Malbase Line - III	466.94		
		Unit-V	185.09	400kV Malbase - Siliguri Line	153.00		
		Unit-VI	185.84	-	-		
		Total	1,112.19	Auxiliary Consumption & Transformation Losses at Generator end	-0.08%		
2	4 x 180MW MHP	Unit-I	197.79	400kV MHP - Jigmeling Line - I	274.64	400kV MHP-JLG Line IV on Standby. 132kV MHP_Yurmo Line- I not in Service. 400kV JLG_ALI Interim Line I on Standby.	
		Unit-II	197.84	400kV MHP - Jigmeling Line - II	275.62		
		Unit-III	193.69	400kV MHP - Jigmeling Line - III	269.27		
		Unit-IV	197.63	400kV MHP - Jigmeling Line - IV	0.00		
		-	-	132kV MHP - Yurmo Line - I	0.00		
		-	-	132kV MHP - Yurmo Line - II	63.23		
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	159.64		
		-	-	400kV Jigmeling - Puna - Alipurduar Line - I	0.00		
		-	-	400kV Jigmeling - Puna - Alipurduar Line - II	163.26		
		-	-	400kV Jigmeling - Alipurduar Line - I	244.48		
		-	-	400kV Jigmeling - Alipurduar Line - II	244.38		
		-	-	80MVA, 220/132kV ICT - I (HV)	47.97		
		-	-	80MVA, 220/132kV ICT - II (HV)	47.63		
		-	-	220kV Tsirang - Jigmeling Line	-11.09		
		-	-	132kV Gelephu - Salakati Line	26.74		
		Total	786.95	Auxiliary Consumption & Transformation Losses at Generator end	0.44%		
3	4 x 84MW CHP	Unit-I	91.54	220kV CHP - Birpara Line - I	33.80		
		Unit-II	91.32	220kV CHP - Birpara Line - II	33.39		
		Unit-III	91.66	220kV CHP - Gedu	61.52		
		Unit-IV	91.38	220kV CHP - Jamjee (old) - I	76.98		
		-	-	220kV CHP - Jamjee - II (new)	77.61		
		-	-	220kV CHP - Jamjee - III (new)	74.82		
		-	-	220kV Malbase - Birpara Line	52.00		
		-	-	66kV CHP - Gedu Line	6.84		
		-	-	3x3MVA, 66/11kV TFR	0.91		
Total	365.84	Auxiliary Consumption & Transformation Losses at Generator end	-0.01%				
4	2 x 12MW BHP (U/S)	Unit-I	7.08	220kV BHP - Sento Kha Line	89.61		
		Unit-II	9.12	66kV BHP - Lobeyasa Line	27.87		
		Total	16.20	220kV BHP - Tsirang Line	-71.90		
5	2 x 20MW BHP (L/S)	Unit-I	15.19	5MVA, 66/11kV TFR	0.66		
		Unit-II	14.62	30MVA ICT, 220/66kV (HV)	12.57		
		Total	29.81	Auxiliary Consumption & Transformation Losses at Generator end	-0.50%		
6	2 x 63MW DHP	Unit-I	32.59	220kV DHP - Tsirang Line	65.14	220kV DHP_Dagapela Line on Standby.	
		Unit-II	33.01	220kV DHP - Dagapela Line	0.00		
		-	-	220kV Jigmeling - Dagapela Line	54.09		
		-	-	5MVA, 220/33kV TFR	0.02		
Total	65.60	Auxiliary Consumption & Transformation Losses at Generator end	0.67%				
7	4 x 15MW KHP	Unit-I	16.60	132kV KHP - Nangkor Line	39.23		
		Unit-II	16.51	132kV KHP - Kilikhar Line	25.70		
		Unit-III	16.55	5MVA, 132/11kV TFR	0.42		
		Unit-IV	16.48	132kV Motanga - Rangia Line	66.24		
Total	66.14	Auxiliary Consumption & Transformation Losses at Generator end	1.19%				
8	2 x 59MW NHP	Unit-I	50.08	132kV NHP-MHP-I	49.66		
		Unit-II	49.95	132kV NHP-MHP-II	49.62		
		Total	100.03	Auxiliary Consumption & Transformation Losses at Generator end	0.75%		

Note: Generation-Load Summary (MW) for 21-Sep-2024 at 19:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,589.64	682.39	683.11	918.34	-0.72
2	Eastern Grid	953.12	196.93	191.92	745.10	5.01
	Total	2,542.76	879.32	875.03	1,663.44	4.29

Note: Generation-Load Summary (MW) for 21-Sep-2023, at 19:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,614.50	631.58	621.93	957.47	9.65
2	Eastern Grid	663.30	198.82	194.36	489.93	4.46
	Total	2,277.80	830.40	816.29	1,447.40	14.11

Note: Daily Energy (MUs) and Power(MW) Statistics for 21-Sep-2024

Sl. No.	Net Energy Export (Bilateral)	Net Energy Import (Bilateral)	Daily Energy Met	Total Energy Generation	Peak Cross-border (MW)	Imp./Exp. through Exchange (MUs)
1	39.00	0.00	20.19	58.82	1,757.13	1.70

- The Instantaneous load balance, calculated as (Total generation - (Total export-Import) - Total domestic load), do not tend towards zero. This could be due to the following reasons:
 - Not all the meters are digital and nor are all the meter at all locations can be read at same time (say 9:00hrs) due to many meter to be read manually. ii) The clocks of all the locations are not synchronized.
- This report, compiled using the SCADA data, is prepared to give an overall idea of the generation & load flow for the system at a particular instant. This report also gives energy and import/export figures.
- When SCADA data are unavailable for certain stations due to technical issues, required data are collected from the site.