

**Bhutan Power Corporation Limited**

**Bhutan Power System Operator**

**Thimphu: Bhutan**



**Transmission System Performance Report**

**Fourth Quarterly Report – October to December, 2019**



**Table of Contents**

- 1. INTRODUCTION ..... 2**
- 2. NATIONAL PEAK DEMAND ..... 2**
  - 2.1. POWER (MW) CONSUMED BY COUNTRY ..... 2
- 3. ENERGY AVAILABILITY AND REQUIREMENT FOR THE COUNTRY ..... 3**
  - 3.1. ENERGY (MU) CONSUMED BY COUNTRY ..... 3
- 4. PERFORMANCE OF GENERATING PLANTS ..... 4**
  - 4.1. POWER AND ENERGY GENERATION ..... 4
  - 4.2. PLANT CAPACITY FACTOR ..... 4
- 5. EXPORT AND IMPORT OF ELECTRICITY ..... 5**
- 6. FREQUENCY PROFILE ..... 5**
  - 6.1. FREQUENCY FOR THE MONTH OF OCTOBER, 2019 ..... 5
  - 6.2. FREQUENCY FOR THE MONTH OF NOVEMBER, 2019 ..... 6
  - 6.3. FREQUENCY FOR THE MONTH OF DECEMBER, 2019 ..... 7
  - 6.4. FREQUENCY SUMMARY FOR THE MONTH OF OCTOBER TO DECEMBER, 2019 ..... 7
- 7. VOLTAGE PROFILE OF SELECTED SUBSTATION ..... 8**
  - 7.1. VOLTAGE PROFILE FOR THE MONTH OF OCTOBER, 2019 ..... 8
  - 7.2. VOLTAGE PROFILE FOR MONTH OF NOVEMBER, 2019 ..... 9
  - 7.3. VOLTAGE PROFILE FOR THE MONTH OF DECEMBER, 2019 ..... 11
  - 7.4. VOLTAGE SUMMARY FOR THE MONTH OF OCTOBER TO DECEMBER, 2019 ..... 12
- 8. MAJOR OUTAGES OF FEEDERS AND EQUIPMENT ..... 12**
  - 8.1. MAJOR OUTAGES IN EASTERN GRID ..... 12
  - 8.2. MAJOR OUTAGES IN WESTERN GRID ..... 12
- 9. ANNEXURES ..... 13**

**1. Introduction**

The electricity transmission network in Bhutan is solely owned by Bhutan Power Corporation limited (BPC) and electricity generation is solely owned by Druk Green Power Corporation Limited (DGPC). Bhutan Power System Operator (BPSO) under BPC is responsible for safe, secure and efficient operation of Bhutan transmission network and generation.

This quarterly report is prepared in compliance to the Grid Code Regulation (GCR) 2008, clause 6.14.1, “System Operator has to submit a quarterly report covering the performance of the Transmission System to all Licensees, Authority and Ministry”. This transmission performance report contains summary of growth of peak demand, performance of generating stations (power and energy generation), energy availability and requirement for the country, export and import of electricity to/ from India, frequency profile of selected substation and voltage profile of few important substations.

All the index and other calculations in this report have been executed based on the data received from substations and generating plants.


**2. National Peak Demand**

The national peak demand till now is recorded at **399.35MW** which was occurred on 27<sup>th</sup> December, 2018 at 18:18 hours. This is calculated by summation of Feeder Loading at Plants minus Export.

Table 2.1. The National Peak Demand since 2007

Year	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019
<b>Peak Load (MW)</b>	157.36	187.05	237.17	256.95	276.24	282.44	313.94	333.41	336.52	335.87	362.09	399.35	387.66
<b>% Growth over previous Year</b>	-	18.87	26.79	8.34	7.51	2.24	11.15	6.20	0.93	-0.19	7.81	10.29	-2.93

Graph 2.1. The growth in National Peak Demand since 2007



**2.1. Power (MW) consumed by country**

Following methods are used to calculate peak demand for the Eastern Grid, Western Grid and National demand.


1. **National Demand** = (Sum of all total generation)-(Sum of all Export of Import)
2. **National Demand** = (Sum of all feeders loading at hydropower station) – (Sum of all Export/Import)
3. **National Demand** = (Sum of all substation loading)

For this report, the National Demand was calculated using method-3.

Table 2.1.2. Domestic demand for Eastern Grid, Western Grid and National using method- 3

Grid	Eastern Grid Load (MW)		Western Grid Load (MW)		National Load (MW)	
	Max	Min	Max	Min	Max	Min
October	64.00	19.47	273.03	108.71	331.07	144.28
November	69.87	0.09	276.61	170.69	338.06	197.63
December	70.48	27.21	295.71	173.97	358.73	216.22

Graph 2.1.2. Domestic demand for Eastern Grid, Western Grid and National using method- 3



The national load pattern for the month of October to December, 2019 calculated using method-3 is attached as **Annexure-II**

### 3. Energy Availability and Requirement for the country


#### 3.1. Energy (MU) consumed by Country

The total energy consumed within Bhutan is computed from the total energy DGPC had sold to BPC including the royalty energy.

Table 3.1.1. Energy (MU) consumed

Month	Total Ex-bus (MU)	Total Export/Import (MU)	Total energy sold to BPC (MU)
October	834.50933745	634.89526800	199.61406945
November	421.98731384	215.89184100	206.09547284
December	297.25389469	72.80358500	224.45030969

Graph 3.1.1. Energy (MU) consumed



4. Performance of generating plants


4.1. Power and Energy Generation

The maximum total generation for the Fourth quarter of year 2019 was 1657.31 MW in month of October and minimum generation was 569.60 MW in the December month.

Table: 4.1.1 Summary of maximum and minimum generation by various hydropower plant

Generation By	BHP (MW)		CHP (MW)		THP (MW)		KHP (MW)		DHP (MW)		TOTAL (MW)	
	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min
October	66.40	39.30	276.00	184.00	1,122.00	360.00	66.00	16.50	126.91	-4.90	1,657.31	594.90
November	47.30	14.90	223.28	107.21	460.00	200.00	43.00	17.30	50.44	29.74	824.02	369.15
December	30.00	20.20	156.11	74.47	320.00	160.00	33.22	10.08	30.27	20.15	569.60	284.90

Graph: 4.1.1 Summary of maximum and minimum generation by various hydropower plant



Daily maximum, minimum and average generation by each generating plant for the month of October to December, 2019 is attached as **Annexure-I**.

4.2.Plant Capacity Factor

The capacity factor of each generating plant was calculated as below:


$$Capacity\ factor = \frac{Total\ energy\ plant\ has\ produce\ over\ a\ period}{Total\ energy\ plant\ would\ produce\ when\ operated\ at\ full\ capacity}$$

Table 4.2.1: Total generation and capacity factor of various hydropower plants

Month	BHP (MU)	BHP (CF)	CHP (MU)	CHP (CF)	THP (MU)	THP (CF)	KHP (MU)	KHP (CF)	DHP (MU)	DHP (CF)
October	44.76583	94.01%	189.01638	75.61%	502.222545	56.73%	44.830742	100.43%	18.7572	20.01%
November	26.45050	55.55%	113.22199	45.29%	230.38036	26.02%	25.265047	56.60%	26.669412	28.45%
December	18.68769	40.55%	80.34148	33.21%	161.322909	18.83%	18.144623	42.00%	18.7572	20.68%

Source: TD, BPC

Graph 4.2.1: Capacity factor of various hydropower plants



### 5. Export and Import of Electricity

Maximum export for the Fourth quarter of year 2019 was 1117.00 MW in the month of October to Binaguri substation in India. The minimum export recorded was 15.62 MW to Salakoti and Rangia substation in India during the month of December.

Table 5.1. Export of electricity to India

Export To	Binaguri (MW)		Birpara (MW)		Salakoti and Rangia (MW)	
	Max	Min	Max	Min	Max	Min
October	1,117.00	291.00	274.60	55.00	105.20	18.44
November	519.00	127.00	135.10	0.10	47.11	0.03
December	244.00	11.00	24.00	0.30	15.62	0.03

Graph 5.1. Export of electricity to India




Table 5.2. Import of electricity from India.

Import From	Binaguri (MW)		Birpara (MW)		Salakoti and Rangia (MW)	
	Max	Min	Max	Min	Max	Min
October	0.00	0.00	0.00	0.00	0.00	0.00
November	0.00	0.00	27.50	0.20	13.62	0.03
December	0.00	0.00	108.00	0.20	22.73	0.01

### 6. Frequency profile

The nominal allowed frequency range shall be 50Hz  $\pm$  1% in Bhutan. The system is normally managed such that frequency is maintained within operational limit of 49.5 Hz to 50.5 Hz. However, frequency may move outside these limit under faulty condition.

As per the Grid Code 2008, clause 6.4.1 the frequency is classified into three different bands as follows:

- Normal state  
The transmission System frequency is within the limit of 49.5Hz to 50.5Hz.
- Alert state  
The Transmission System frequency is beyond the normal operating limit but within 49.0Hz to 50.0Hz.
- Emergency state  
There is generation deficiency and frequency is below 49.0Hz.

The frequency at 220kV Bus at 220/66/11kV Semtokha substation in the western grid and 132kV Bus at 60MW Kurichhu Hydropower Plant in the eastern grid is considered.

#### 6.1. Frequency for the month of October, 2019

Table 6.1.1. Bus Frequency profile of Semtokha Substation

Sl. No.	Operating State	220kV Bus Voltage
1	Normal State	100.00%
2	Alert State	0.00%
3	Emergency State	0.00%
4	Blackout/Other	0.00%

Graph 6.1.1. Bus Frequency of Semtokha Substation





Table 6.1.2. Bus frequency of Kurichhu Hydro Power Plant

Sl. No.	Operating State	132kV Bus Voltage
1	Normal State	99.73%
2	Alert State	0.13%
3	Emergency State	0.13%
4	Blackout/Other	0.00%

Graph 6.1.2. Bus frequency of Kurichhu Hydro Power Plant



In the month of October, 2019, the Western grid was maintained within the normal operating limit of 100% whereas Eastern grid have operated 97.73% in operating limit and deviated 0.13% and 0.13% to alert state and blackout/others respectively.

## 6.2.Frequency for the month of November, 2019

Table 6.2.1. Bus frequency of Semtokha Substation

Sl. No.	Operating State	220kV Bus Voltage
1	Normal State	96.64%
2	Alert State	0.00%
3	Emergency State	0.00%
4	Blackout/Other	3.36%

Graph 6.2.1. Bus frequency of Semtokha Substation





Table 6.2.2. Bus frequency of Kurichhu Hydro Power Plant

Sl. No.	Operating State	132kV Bus Voltage
1	Normal State	96.77%
2	Alert State	0.00%
3	Emergency State	0.00%
4	Blackout/Other	3.23%

Graph 6.2.2. Bus frequency of Kurichhu Hydro Power Plant



In the month of November, 2019, the western grid frequency was maintained at normal operating range of 96.64% and 3.36% deviated within blackout and others.

**6.3.Frequency for the month of December, 2019**

Table 6.3.1. Bus frequency of Semtokha Substation

Sl. No.	Operating State	220kV Bus Voltage
1	Normal State	96.64%
2	Alert State	0.00%
3	Emergency State	0.00%
4	Blackout/Other	3.36%

Graph 6.3.1. Bus frequency of Semtokha Substation





Table 6.3.2. Bus frequency of Kurichhu Hydro Power Plant

Sl. No.	Operating State	132kV Bus Voltage
1	Normal State	99.73%
2	Alert State	0.27%
3	Emergency State	0.00%
4	Blackout/Other	0.00%

Graph 6.3.2. Bus frequency of Kurichhu Hydro Power Plant




In the month of December, 2019, the Western grid frequency was maintained 96.64% within the normal operating range and deviated 3.36% was blackout/others. Eastern grid frequency was maintained within normal operating range of 99.73 % and system frequency was deviated 0.27 % to alert.

**6.4.Frequency Summary for the month of October to December, 2019**

Table 6.4.1. Frequency summary for the month of October to December, 2019

Substation/Plant	Bus Frequency at Semtokha Substation (Hz)		Bus Frequency at Kurichhu Hydropower Plant (Hz)	
	Max	Min	Max	Min
October	50.10	49.70	50.80	48.88
November	50.10	49.70	50.17	49.80
December	50.10	49.70	50.21	49.29

Graph 6.4.1. Frequency summary for the month of October to December, 2019



Daily maximum, minimum and average Frequency of Semtokha substation in western grid and Kurichhu Hydro Power Plant in eastern grid for the month of October to December, 2019 is attached as **Annexure-III**

**7. Voltage Profile of selected substation**

As per the Grid Code 2008, clause 6.4.1 the voltage at all connection point is classified into three different bands as follows:

- Normal State**  
The voltage at all connection points are within the limits of 0.95 times and 1.05 times of the normal values
- Alert State**  
The voltage at all connection points are outside the normal limit but within the limits of 0.9 times and 1.1 times of the nominal values.
- Emergency State**  
Transmission system voltages are outside the limit of 0.9 times and 1.1 times of nominal values.


Due to the location of 400/22/66/11kV Malbase substation in western grid and 132/33/11kV Nangkhor substation in the eastern grid, the voltage profile of these substations are considered.

**7.1. Voltage profile for the month of October, 2019**

Table 7.1.1. Voltage Profile for 400/220/66kV Malbase Substation

Sl. No.	Operating State	400kV Bus Voltage	220kV Bus Voltage	66kV Bus Voltage
1	Normal State	100.00%	100.00%	100.00%
2	Alert State	0.00%	0.00%	0.00%
3	Emergency State	0.00%	0.00%	0.00%
4	Blackout/Other	0.00%	0.00%	0.00%

Graph 7.1.1. Voltage Profile for 400/220/66kV Malbase Substation






Table 7.1.2. Voltage Profile of 220/66/11kV Semtokha Substation

Sl. No.	Operating State	220kV Bus Voltage	66kV Bus Voltage
1	Normal State	100.00%	100.00%
2	Alert State	0.00%	0.00%
3	Emergency State	0.00%	0.00%
4	Blackout/Other	0.00%	0.00%

Graph 7.1.2. Voltage Profile of 220/66/11kV Semtokha Substation





Table 7.1.3. Voltage Profile of 132/33/11kV Nangkhor Substation

Sl. No.	Operating State	132kV Bus Voltage
1	Normal State	100.00%
2	Alert State	0.00%
3	Emergency State	0.00%
4	Blackout/Other	0.00%

Graph 7.1.3. Voltage Profile of 132/33/11kV Nangkhor Substation



## 7.2. Voltage Profile for month of November, 2019

Table 7.2.1. Voltage Profile for 400/220/66kV Malbase Substation

Sl. No.	Operating State	400kV Bus Voltage	220kV Bus Voltage	66kV Bus Voltage
1	Normal State	96.77%	96.77%	96.77%
2	Alert State	0.00%	0.00%	0.00%
3	Emergency State	0.00%	0.00%	0.00%
4	Blackout/Other	3.23%	3.23%	3.23%

Graph 7.2.1. Voltage Profile for 400/220/66kV Malbase Substation




Table 7.2.2. Voltage Profile of 220/66/11kV Semtokha Substation

Sl. No.	Operating State	220kV Bus Voltage	66kV Bus Voltage
1	Normal State	96.77%	96.64%
2	Alert State	0.00%	0.00%
3	Emergency State	0.00%	0.13%
4	Blackout/Other	3.23%	3.23%

Graph 7.2.2. Voltage Profile of 220/66/11kV Semtokha Substation





Table 7.2.3. Voltage Profile of 132/33/11kV Nangkor Substation

Sl. No.	Operating State	132kV Bus Voltage
1	Normal State	96.77%
2	Alert State	0.00%
3	Emergency State	0.00%
4	Blackout/Other	3.23%

Graph 7.2.3. Voltage Profile of 132/33/11kV Nangkor Substation



**7.3.Voltage Profile for the month of December, 2019**

Table 7.3.1. Voltage Profile for 400/220/66kV Malbase Substation

Sl. No.	Operating State	400kV Bus Voltage	220kV Bus Voltage	66kV Bus Voltage
1	Normal State	100.00%	100.00%	100.00%
2	Alert State	0.00%	0.00%	0.00%
3	Emergency State	0.00%	0.00%	0.00%
4	Blackout/Other	0.00%	0.00%	0.00%

Graph 7.3.1. Voltage Profile for 400/220/66kV Malbase Substation




Table 7.3.2. Voltage Profile of 220/66/11kV Semtokha Substation

Sl. No.	Operating State	220kV Bus Voltage	66kV Bus Voltage
1	Normal State	100.00%	99.73%
2	Alert State	0.00%	0.00%
3	Emergency State	0.00%	0.13%
4	Blackout/Other	0.00%	0.13%

Graph 7.3.2. Voltage Profile of 220/66/11kV Semtokha Substation





Table 7.3.3. Voltage Profile of 132/33/11kV Nangkhor Substation

Sl. No.	Operating State	132kV Bus Voltage
1	Normal State	100.00%
2	Alert State	0.00%
3	Emergency State	0.00%
4	Blackout/Other	0.00%

Graph 7.3.3. Voltage Profile of 132/33/11kV Nangkhor Substation




#### 7.4.Voltage Summary for the Month of October to December, 2019

Table 7.4.1. Voltage Summary for the month of October to December, 2019

Substation	Malbase Substation						Nangkhor Substation	
	400kV Bus Voltage (kV)		220kV Bus Voltage (kV)		66kV Bus Voltage (kV)		132kV Bus Voltage (kV)	
Month	Max	Min	Max	Min	Max	Min	Max	Min
October	419.00	400.00	230.00	219.00	68.00	64.00	137.70	130.00
November	417.50	398.50	229.00	216.00	68.00	63.50	137.50	128.80
December	418.50	403.50	230.00	217.50	67.00	64.00	137.90	129.88

Graph 7.4.1. Voltage Summary for the month of October to December, 2019



Daily maximum, minimum and average bus voltage of Malbase substation in western grid and Nangkhor substation in eastern grid for the month of October to December, 2019 is attached as **Annexure-IV**

### 8. Major Outages of Feeders and Equipment

The transmission lines and equipment which were shut down for annual maintenance are not considered in the report.

#### 8.1.Major Outages in Eastern Grid

It had been observed that the number of tripping in eastern grid has been reduced during the fourth quarter of the year compare to other quarter of the year. There was no prolong outage for feeders in eastern grid except 400 kV MHEP Line-2 which was out of service for almost one day during the month of October.

The feeders and equipment outages for the Eastern grid is attached as **Annexure-V**.

#### 8.2.Major Outages in Western Grid

During the fourth quarter of the year, there was no major outage occurred in western grid.

The feeders and equipment outages for the Western grid is attached as **Annexure-VI**.



9. Annexures

Annexure-I

Table: Generation of October, 2019

Oct-19 Date	BHP (MW)			CHP (MW)			THP (MW)			KHP (MW)			DHP (MW)		
	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava
1	66.10	65.80	66.06	276.00	276.00	276.00	1,122.00	1,122.00	1,122.00	66.00	66.00	66.00	126.81	108.02	118.10
2	66.20	65.70	66.08	276.00	276.00	276.00	1,122.00	1,122.00	1,122.00	66.00	66.00	66.00	126.69	101.44	109.97
3	66.10	65.70	66.04	276.00	276.00	276.00	1,122.00	1,122.00	1,122.00	66.00	66.00	66.00	116.43	96.46	103.83
4	66.40	66.10	66.11	276.00	276.00	276.00	1,122.00	994.00	1,073.17	66.00	66.00	66.00	125.33	88.61	105.73
5	66.10	65.90	66.05	276.00	276.00	276.00	994.00	790.00	962.58	66.00	66.00	66.00	98.69	63.38	91.66
6	66.10	65.90	66.08	276.00	276.00	276.00	920.00	850.00	880.42	66.00	66.00	66.00	93.65	80.61	87.80
7	66.10	65.80	66.01	276.00	218.00	271.08	850.00	850.00	850.00	66.00	66.00	66.00	106.39	86.11	93.72
8	66.20	65.90	66.08	276.00	184.00	271.25	1,065.00	850.00	923.75	66.00	66.00	66.00	126.91	90.18	111.76
9	66.14	56.10	65.66	276.00	184.00	256.50	1,028.00	900.00	979.50	66.00	66.00	66.00	110.50	89.54	96.15
10	66.40	66.00	66.16	276.00	276.00	276.00	900.00	800.00	839.17	66.00	66.00	66.00	90.55	82.42	86.77
11	66.10	66.00	66.10	276.00	276.00	276.00	800.00	750.00	781.67	66.00	66.00	66.00	83.98	78.47	81.52
12	66.10	65.80	66.03	276.00	276.00	276.00	780.00	720.00	751.25	66.00	16.50	62.56	83.43	76.44	79.30
13	66.10	66.00	66.08	276.00	276.00	276.00	720.00	700.00	709.17	66.00	66.00	66.00	77.46	70.53	75.06
14	66.10	65.50	65.94	276.00	184.00	257.46	780.00	560.00	640.83	66.00	49.50	65.31	74.38	70.44	72.47
15	65.60	64.70	65.11	276.00	276.00	276.00	690.00	650.00	653.33	66.00	66.00	66.00	70.50	67.30	69.30
16	64.70	63.60	64.34	276.00	276.00	276.00	770.00	610.00	632.50	66.00	61.56	64.52	68.41	65.32	67.06
17	66.10	62.10	63.40	276.00	276.00	276.00	740.00	570.00	597.50	61.57	59.52	60.76	67.52	-4.90	62.34
18	66.10	61.80	63.45	276.00	276.00	276.00	683.00	547.00	581.96	63.62	55.74	60.22	76.69	63.19	66.58
19	61.90	60.20	61.08	276.00	276.00	276.00	590.00	570.00	577.50	58.02	57.04	57.79	63.57	60.43	62.43
20	60.10	58.80	59.44	276.00	256.00	265.08	590.00	560.00	563.38	57.52	52.62	55.26	61.49	60.44	60.92
21	59.50	58.10	58.80	276.00	254.97	264.22	561.00	561.00	561.00	66.00	56.16	61.72	60.49	22.55	58.19
22	57.80	56.20	56.99	262.00	184.00	225.33	561.00	380.00	465.67	66.00	66.00	66.00	58.50	57.41	57.97
23	56.50	55.20	55.78	275.00	200.00	249.36	600.00	380.00	520.92	66.00	54.72	58.28	58.26	54.14	56.98
24	55.30	54.30	54.77	267.00	230.00	241.89	600.00	480.00	511.67	66.00	52.97	57.16	58.12	54.13	56.27
25	54.90	53.30	54.09	254.77	219.00	231.98	520.00	360.00	487.08	55.04	52.78	54.23	65.51	2.20	55.02
26	59.80	39.30	53.07	249.00	222.00	230.13	510.00	480.00	483.75	58.56	52.94	55.78	56.24	52.96	54.44
27	52.50	50.70	51.58	244.00	213.00	221.38	480.00	440.00	450.00	57.60	50.86	54.84	53.23	52.01	52.75
28	51.10	49.70	50.57	247.00	203.00	213.55	480.00	440.00	441.67	51.19	39.93	50.00	52.20	50.20	51.47
29	50.20	48.40	49.33	241.00	204.91	211.33	440.00	420.00	425.00	64.10	45.54	48.21	51.20	49.14	50.28
30	49.00	47.70	48.29	243.60	197.00	204.89	460.00	420.00	428.33	48.72	41.70	45.65	49.69	48.00	49.16
31	48.30	46.60	47.45	219.21	197.00	201.22	460.00	410.00	412.08	45.86	42.02	44.48	49.16	47.03	47.90
Max	66.40			276.00			1,122.00			66.00			126.91		
Min		39.30			184.00			360.00			16.50			-4.90	

Source: THP, CHP, BHP, KHP (DGPC)

Graph: Generation for the month of October, 2019






Table: Generation for the month of November, 2019

Nov-19 Date	BHP (MW)			CHP (MW)			THP (MW)			KHP (MW)			DHP (MW)		
	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava
1	47.30	46.00	46.62	216.86	183.61	194.47	460.00	390.00	405.42	32.16	27.53	29.41	47.42	46.20	46.98
2	46.20	44.90	45.58	221.36	174.02	194.71	460.00	360.00	395.00	29.64	27.72	29.27	46.51	45.02	45.93
3	45.70	43.80	44.77	223.00	171.33	192.14	450.00	360.00	382.50	29.55	28.16	28.72	45.86	43.39	45.12
4	45.40	43.50	44.18	220.48	180.99	188.26	450.00	360.00	381.25	28.93	28.46	28.75	47.40	42.96	44.27
5	46.60	42.60	44.25	215.52	181.00	190.35	430.00	370.00	387.50	30.45	27.20	28.78	47.38	43.37	45.00
6	45.00	14.90	41.59	223.28	175.67	187.55	460.00	360.00	389.58	28.19	17.30	26.82	47.38	42.38	44.44
7	43.70	38.90	41.87	218.94	173.05	180.48	460.00	360.00	380.83	27.92	26.32	26.88	43.89	41.94	42.80
8	42.30	36.60	41.05	214.29	152.96	175.73	440.00	320.00	359.17	39.05	26.27	32.70	42.40	40.98	41.70
9	41.20	40.10	40.56	203.68	164.97	174.08	420.00	320.00	337.92	38.97	37.07	38.30	41.37	40.31	40.79
10	40.60	39.50	39.91	195.67	162.70	168.50	400.00	320.00	349.58	38.77	36.87	37.38	40.95	39.27	40.16
11	39.90	38.70	39.33	192.00	157.87	165.65	410.00	320.00	338.75	37.18	34.85	36.25	40.38	38.98	39.77
12	39.20	37.20	38.55	194.36	155.73	163.09	420.00	320.00	336.67	37.56	36.46	36.65	40.34	38.04	39.14
13	39.90	37.20	38.58	191.93	147.82	166.46	390.00	310.00	336.25	38.94	35.13	35.92	50.44	38.13	39.88
14	38.00	37.00	37.44	210.19	147.28	164.15	400.00	310.00	330.83	37.09	34.96	35.38	40.13	37.12	38.03
15	37.30	36.40	36.85	194.17	144.50	157.82	390.00	290.00	319.17	35.32	35.02	35.14	38.54	37.12	37.61
16	36.90	35.90	36.23	183.79	144.44	153.54	380.00	290.00	315.83	35.52	22.91	34.69	37.54	36.12	36.90
17	36.40	35.70	35.86	180.46	140.70	150.26	380.00	290.00	308.75	34.64	33.51	34.00	40.14	35.12	36.79
18	37.30	29.40	34.84	174.36	140.88	148.96	360.00	280.00	294.17	34.95	33.71	34.09	37.15	35.13	36.06
19	35.40	34.50	34.94	173.05	107.21	147.33	360.00	280.00	307.08	37.00	34.59	35.33	50.21	33.93	35.98
20	36.50	29.30	34.00	176.71	139.48	148.11	390.00	280.00	300.83	43.00	33.70	35.84	35.93	33.96	34.94
21	34.50	33.50	33.95	173.37	137.66	147.34	440.00	240.00	321.67	36.36	32.72	34.34	35.88	32.36	34.55
22	33.70	32.90	33.35	169.86	134.00	144.80	440.00	200.00	303.33	35.05	31.48	33.34	34.43	32.41	33.98
23	33.30	32.70	33.03	171.66	135.12	144.61	360.00	260.00	281.25	32.82	30.18	31.77	33.91	33.39	33.62
24	33.30	32.70	33.03	172.90	132.97	143.99	360.00	250.00	284.17	32.75	28.42	31.63	33.70	32.89	33.19
25	33.10	30.80	32.18	169.02	132.35	141.45	310.00	200.00	282.50	32.60	29.10	31.28	33.40	31.30	32.74
26	32.10	31.30	31.65	169.26	129.85	137.52	340.00	200.00	272.08	32.47	29.90	31.23	33.33	30.26	32.31
27	31.90	30.60	31.10	161.93	126.61	133.67	330.00	250.00	283.75	31.45	28.53	30.80	32.28	30.80	31.55
28	40.10	25.20	30.67	160.47	117.33	131.99	330.00	250.00	263.33	29.87	29.49	29.69	32.27	30.26	31.13
29	36.20	27.40	30.07	160.55	117.46	129.62	320.00	240.00	262.50	29.79	26.95	29.16	31.30	30.26	30.65
30	30.80	29.40	29.92	152.92	116.03	126.26	310.00	240.00	253.33	32.82	27.07	29.05	30.41	29.74	30.15
31	0.00	No Generation	Error	0.00	No Generation	Error	0.00	No Generation	Error	0.00	No Generation	Error	0.00	No Generation	Error
Max	47.30			223.28			460.00			43.00			50.44		
Min		14.90			107.21			200.00			17.30			29.74	

Source: THP, CHP, BHP, KHP (DGPC)

Graph: Generation for the month of November, 2019






Table: Generation for the month of December, 2019

Dec-19 Date	BHP (MW)			CHP (MW)			THP (MW)			KHP (MW)			DHP (MW)		
	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava
1	30.00	29.20	29.59	154.36	115.70	126.92	320.00	240.00	256.67	29.49	27.04	28.64	30.25	29.24	29.99
2	29.70	29.10	29.33	151.33	118.25	125.30	320.00	230.00	248.75	30.02	25.56	28.39	30.27	28.30	29.67
3	29.40	28.20	28.92	147.36	117.96	124.54	320.00	230.00	245.00	30.26	28.30	29.12	29.80	28.95	29.48
4	29.10	27.50	28.49	141.81	111.40	121.97	310.00	230.00	250.00	28.92	26.60	28.04	29.94	28.25	29.04
5	28.30	26.90	27.90	147.00	107.71	118.67	310.00	230.00	245.42	29.30	16.50	27.15	28.78	27.24	28.37
6	28.20	26.80	27.60	156.11	101.23	119.32	310.00	210.00	230.83	29.60	25.30	26.85	28.28	27.24	28.04
7	27.80	26.40	27.27	136.04	92.15	117.95	320.00	210.00	240.00	33.22	25.87	30.13	29.27	26.23	27.52
8	27.60	26.40	27.01	135.39	104.64	111.56	300.00	210.00	231.25	33.00	10.08	21.51	27.24	26.81	27.12
9	27.40	26.00	26.78	130.71	103.94	111.24	300.00	200.00	230.83	30.25	25.29	25.96	27.65	26.25	27.06
10	27.00	26.20	26.62	140.84	105.15	116.73	270.00	210.00	223.75	28.55	24.23	25.80	27.26	26.26	26.78
11	27.40	26.60	26.88	139.47	108.84	114.73	290.00	210.00	250.42	25.66	24.76	25.06	27.26	26.24	26.77
12	27.10	26.50	26.70	138.25	103.85	114.57	210.00	210.00	210.00	26.74	25.57	26.14	27.25	26.22	26.79
13	26.50	26.00	26.25	137.12	101.57	113.28	270.00	210.00	226.25	26.68	24.64	25.74	26.85	26.21	26.39
14	27.00	26.00	26.45	140.20	103.67	115.37	290.00	210.00	226.67	25.00	24.68	24.85	27.35	26.23	26.71
15	26.60	24.90	25.80	143.53	103.36	116.76	270.00	210.00	230.00	26.15	24.85	25.30	26.75	24.78	25.84
16	26.20	24.30	25.43	141.63	102.25	110.81	320.00	210.00	228.33	26.07	24.38	25.02	27.26	24.24	25.65
17	25.60	24.70	25.11	142.86	95.05	107.88	280.00	190.00	212.08	26.40	22.50	23.96	26.29	24.24	25.44
18	25.60	24.70	25.11	141.79	98.08	106.60	290.00	190.00	225.83	26.38	23.71	24.73	25.70	24.73	25.26
19	25.00	24.70	24.87	133.20	97.27	106.73	280.00	190.00	204.58	25.01	22.81	23.89	25.30	24.72	24.86
20	24.90	24.40	24.65	130.84	98.31	107.16	270.00	190.00	210.00	24.61	22.47	23.73	24.94	23.25	24.66
21	24.70	24.20	24.44	132.26	92.89	105.09	270.00	190.00	213.33	25.17	23.24	24.09	24.74	24.24	24.35
22	25.30	23.70	24.18	130.98	92.83	106.24	300.00	190.00	217.92	25.20	23.51	24.70	24.26	23.25	24.18
23	24.10	23.50	23.86	133.43	94.39	104.34	260.00	190.00	209.58	24.00	15.60	22.57	24.57	23.24	24.03
24	23.80	23.00	23.50	136.52	92.27	100.68	280.00	170.00	202.92	23.80	16.09	23.39	24.26	23.25	23.54
25	23.50	23.10	23.30	141.73	89.78	100.27	270.00	180.00	201.25	23.70	22.61	23.54	24.19	23.16	23.68
26	23.20	22.30	22.89	130.78	86.82	98.43	260.00	180.00	197.08	23.87	16.27	20.89	23.87	20.15	23.45
27	23.30	21.50	22.38	130.70	85.18	97.57	260.00	180.00	193.33	29.22	16.09	22.72	23.37	22.14	22.76
28	23.00	21.20	22.05	128.54	75.21	88.80	260.00	170.00	192.08	24.96	15.30	20.14	23.19	22.14	23.00
29	22.70	20.60	21.81	124.20	75.11	90.01	240.00	160.00	177.92	28.30	16.13	22.94	23.19	21.16	22.55
30	22.70	20.70	21.80	127.62	75.09	93.49	240.00	160.00	177.08	30.00	12.63	20.46	23.16	21.16	22.40
31	22.10	20.20	21.35	125.11	74.47	92.50	240.00	170.00	187.50	24.49	12.50	20.66	22.88	21.11	21.95
<b>Max</b>	<b>30.00</b>			<b>156.11</b>			<b>320.00</b>			<b>33.22</b>			<b>30.27</b>		
<b>Min</b>		<b>20.20</b>			<b>74.47</b>			<b>160.00</b>			<b>10.08</b>			<b>20.15</b>	

Source: THP, CHP, BHP, KHP (DGPC)

Graph: Generation for the month of December, 2019






Table: National demand for October, 2019

Graph: National Demand for October, 2019

Annexure-II

Oct-19	Max	Min	Ava
0:00	253.90	199.68	228.21
1:00	250.52	194.96	224.75
2:00	257.04	147.88	222.08
3:00	245.65	144.28	219.84
4:00	257.24	150.81	221.29
5:00	261.69	156.80	226.38
6:00	278.72	188.80	245.45
7:00	312.74	214.39	272.43
8:00	297.60	202.39	261.76
9:00	291.10	199.53	255.35
10:00	287.50	184.33	250.80
11:00	284.82	212.44	248.92
12:00	286.72	212.51	253.17
13:00	279.86	208.14	248.50
14:00	287.30	207.26	244.23
15:00	293.79	191.80	245.53
16:00	281.27	216.38	251.30
17:00	295.67	225.85	260.05
18:00	331.07	252.38	291.18
19:00	331.03	236.35	293.12
20:00	317.58	215.10	281.63
21:00	309.47	206.04	270.43
22:00	284.40	201.27	255.02
23:00	269.97	199.99	240.64
	<b>331.07</b>		
		<b>144.28</b>	




Table: National Demand for November, 2019

Graph: National Demand for November, 2019

Nov-19	Max	Min	Ava
0:00	270.85	224.75	239.49
1:00	264.11	197.63	233.01
2:00	264.33	211.75	230.90
3:00	262.75	213.18	230.68
4:00	261.61	219.98	234.49
5:00	267.78	227.21	241.72
6:00	287.37	248.78	258.93
7:00	317.27	270.67	287.46
8:00	313.53	259.92	280.60
9:00	310.70	251.00	272.92
10:00	299.25	250.91	265.55
11:00	298.59	239.36	260.54
12:00	293.72	223.63	262.47
13:00	292.18	221.58	257.49
14:00	284.04	206.12	251.68
15:00	284.74	224.17	254.68
16:00	293.41	242.49	258.27
17:00	301.81	254.61	271.54
18:00	338.06	289.02	304.26
19:00	335.57	284.18	299.69
20:00	319.11	264.54	288.81
21:00	311.12	252.26	278.10
22:00	291.37	239.44	261.35
23:00	275.55	223.07	246.79
	<b>338.06</b>		
		<b>197.63</b>	







Table: National Demand for December, 2019

Graph: National Demand for December, 2019

Dec-19	Max	Min	Ava
0:00	272.29	227.17	255.15
1:00	262.89	222.85	247.61
2:00	257.54	227.02	241.56
3:00	257.13	221.08	239.74
4:00	259.89	216.22	244.46
5:00	265.79	224.29	251.52
6:00	280.53	246.23	263.21
7:00	315.33	275.61	291.36
8:00	326.57	278.30	306.84
9:00	328.61	272.69	304.88
10:00	320.81	269.02	297.53
11:00	314.88	250.68	293.89
12:00	315.22	251.67	293.38
13:00	313.33	251.12	288.65
14:00	311.21	243.55	283.31
15:00	306.25	260.16	284.17
16:00	315.71	274.17	294.38
17:00	334.07	288.94	310.41
18:00	358.73	320.75	339.25
19:00	356.75	312.94	337.11
20:00	344.16	312.35	326.03
21:00	333.84	299.91	315.36
22:00	307.85	266.10	293.22
23:00	289.81	248.96	271.90
	<b>358.73</b>		
		<b>216.22</b>	





Annexure-III

Table: Daily maximum, minimum and average frequency for the month of October, 2019

Date	Bus Frequency at Semtokha Substation			Bus Frequency at Kurichhu Hydropower Plant		
	Max	Min	Ava	Max	Min	Ava
1	50.00	49.80	49.95	50.08	49.87	50.00
2	50.00	49.70	49.95	50.12	49.77	50.01
3	50.00	49.90	49.98	50.08	49.91	50.01
4	50.00	49.90	49.95	50.06	49.89	50.00
5	50.00	49.90	49.99	50.12	49.97	50.04
6	50.00	49.90	49.98	50.07	49.97	50.02
7	50.10	49.90	49.98	50.14	49.95	50.04
8	50.00	49.90	49.99	50.15	49.95	50.04
9	50.10	49.90	49.98	50.12	49.92	50.03
10	50.00	49.80	49.95	50.09	49.86	50.00
11	50.00	49.80	49.95	50.07	49.89	50.00
12	50.00	49.90	49.98	50.07	49.95	50.02
13	50.00	49.90	49.98	50.07	49.95	50.02
14	50.00	49.80	49.94	50.07	49.89	50.00
15	50.00	49.90	49.96	50.11	49.89	50.01
16	50.00	49.80	49.96	50.07	49.88	50.00
17	50.00	49.80	49.95	50.14	49.91	50.01
18	50.00	49.80	49.95	50.50	49.89	50.02
19	50.00	49.80	49.95	50.09	49.88	49.99
20	50.00	49.90	49.96	50.10	49.93	50.01
21	50.00	49.80	49.94	50.09	49.87	50.02
22	50.00	49.80	49.95	50.10	49.90	50.01
23	50.00	49.90	49.98	50.08	49.93	50.02
24	50.00	49.90	49.97	50.17	49.85	50.02
25	50.00	49.80	49.96	50.11	49.91	50.02
26	50.00	49.90	49.98	50.10	49.98	50.04
27	50.00	49.80	49.96	50.15	48.88	49.97
28	50.00	49.90	49.97	50.80	49.91	50.04
29	50.00	49.80	49.95	50.10	49.84	50.01
30	50.00	49.80	49.94	50.08	49.77	49.99
31	50.00	49.80	49.95	50.09	49.92	50.00
<b>Max</b>	<b>50.10</b>			<b>50.80</b>		
<b>Min</b>		<b>49.70</b>			<b>48.88</b>	

Source: TD (BPC), KHP (DGPC)

Graph: Daily maximum, minimum and average frequency for the month of October, 2019




Table: Daily maximum, minimum and average frequency for the month of November, 2019

Nov-19 Date	Bus Frequency at Semtokha Substation			Bus Frequency at Kurichhu Hydropower Plant		
	Max	Min	Ava	Max	Min	Ava
1	50.00	49.80	49.93	50.05	49.88	49.99
2	50.00	49.80	49.95	50.10	49.90	50.00
3	50.10	49.80	49.96	50.11	49.82	50.01
4	50.00	49.80	49.94	50.10	49.85	49.99
5	50.00	49.80	49.94	50.05	49.85	49.99
6	50.10	49.80	49.98	50.13	49.93	50.03
7	50.10	49.90	49.99	50.17	49.98	50.05
8	50.00	49.90	49.98	50.10	49.94	50.03
9	50.10	49.90	49.98	50.10	49.97	50.04
10	50.00	49.80	49.95	50.13	49.91	50.00
11	50.10	49.90	49.97	50.09	49.88	50.02
12	50.00	49.90	49.98	50.11	49.90	50.02
13	50.00	49.80	49.96	50.08	49.84	50.01
14	50.00	49.90	49.96	50.13	49.86	50.00
15	50.10	49.90	49.98	50.10	49.92	50.02
16	50.10	49.90	49.98	50.08	49.88	50.01
17	50.00	49.90	49.98	50.07	49.91	50.02
18	50.00	49.80	49.94	50.08	49.80	50.00
19	50.00	49.80	49.95	50.07	49.85	49.99
20	50.00	49.70	49.95	50.06	49.88	50.00
21	50.00	49.80	49.96	50.10	49.83	50.01
22	50.00	49.90	49.96	50.13	49.91	50.01
23	50.00	49.90	49.98	50.09	49.95	50.03
24	50.10	49.80	49.98	50.14	49.96	50.04
25	50.00	49.90	49.97	50.10	49.91	50.02
26	50.00	49.90	49.96	50.13	49.95	50.04
27	50.10	49.90	49.98	50.12	49.90	50.03
28	50.00	49.90	49.98	50.10	49.95	50.03
29	50.00	49.80	49.96	50.10	49.85	50.01
30	50.00	49.90	49.97	50.12	49.89	49.99
31	0.00	Error	Error	0.00	Error	Error
<b>Max</b>	<b>50.10</b>			<b>50.17</b>		
<b>Min</b>		<b>49.70</b>			<b>49.80</b>	

Source: TD (BPC), KHP (DGPC)

Graph: Daily maximum, minimum and average frequency for the month of November, 2019






Table: Daily maximum, minimum and average frequency for the month of December, 2019

Date	Bus Frequency at Semtokha Substation			Bus Frequency at Kurichhu Hydropower Plant		
	Max	Min	Ava	Max	Min	Ava
1	50.00	49.80	49.93	50.09	49.89	50.01
2	50.00	49.80	49.95	50.08	49.88	50.01
3	50.10	49.80	49.96	50.09	49.92	50.02
4	50.00	49.80	49.94	50.12	49.91	50.02
5	50.00	49.80	49.94	50.10	49.94	50.02
6	50.10	49.80	49.98	50.07	49.93	50.02
7	50.10	49.90	49.99	50.09	49.83	50.01
8	50.00	49.90	49.98	50.14	49.85	50.02
9	50.10	49.90	49.98	50.09	49.91	50.00
10	50.00	49.80	49.95	50.07	49.85	49.99
11	50.10	49.90	49.97	50.11	49.85	50.00
12	50.00	49.90	49.98	50.11	49.77	50.00
13	50.00	49.80	49.96	50.17	49.88	50.03
14	50.00	49.90	49.96	50.10	49.95	50.03
15	50.10	49.90	49.98	50.19	49.80	50.03
16	50.10	49.90	49.98	50.21	49.91	50.04
17	50.00	49.90	49.98	50.11	49.91	50.03
18	50.00	49.80	49.94	50.12	49.85	50.01
19	50.00	49.80	49.95	50.10	49.90	50.00
20	50.00	49.70	49.95	50.09	49.79	50.00
21	50.00	49.80	49.96	50.09	49.90	50.02
22	50.00	49.90	49.96	50.10	49.87	50.01
23	50.00	49.90	49.98	50.09	49.86	49.99
24	50.10	49.80	49.98	50.09	49.88	49.99
25	50.00	49.90	49.97	50.13	49.87	50.01
26	50.00	49.90	49.96	50.14	49.94	50.05
27	50.10	49.90	49.98	50.10	49.94	50.03
28	50.00	49.90	49.98	50.10	49.48	49.99
29	50.00	49.80	49.96	50.10	49.86	50.02
30	50.00	49.90	49.97	50.10	49.78	49.98
31	0.00	Error	Error	50.12	49.29	49.96
<b>Max</b>	<b>50.10</b>			<b>50.21</b>		
<b>Min</b>		<b>49.70</b>			<b>49.29</b>	

Source: TD (BPC), KHP (DGPC)

Graph: Daily maximum, minimum and average frequency for the month of December, 2019






Table: Daily maximum, minimum and average Voltage for the month of October, 2019

Oct-19 Date	Malbase Substation									Nangkhor Substation		
	400kV Bus Voltage (kV)			220kV Bus Voltage (kV)			66kV Bus Voltage (kV)			132kV Bus Voltage (kV)		
	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava
1	412.00	406.50	410.17	227.00	222.50	224.71	67.00	66.00	66.58	136.70	130.30	134.59
2	410.50	401.00	407.50	225.50	219.00	222.75	67.00	64.00	65.58	136.90	131.30	134.03
3	409.50	401.50	405.69	223.50	220.00	222.17	66.00	65.00	65.38	137.50	131.50	133.50
4	406.50	400.00	403.83	222.50	219.50	221.08	66.00	64.00	65.21	134.80	130.00	132.73
5	407.50	404.50	405.46	225.00	221.50	222.75	66.00	64.00	65.13	136.30	131.90	134.42
6	414.00	403.00	408.52	225.50	220.00	222.65	67.00	64.00	65.17	135.80	131.12	134.36
7	413.50	407.50	410.88	226.00	223.00	224.63	67.00	65.00	66.08	136.31	132.10	134.48
8	412.50	406.50	410.69	225.00	222.50	224.40	67.00	65.00	66.13	136.20	132.50	134.68
9	413.00	407.50	410.42	226.00	223.00	224.92	67.00	66.00	66.42	135.40	131.95	134.13
10	412.50	405.00	409.25	226.00	222.00	223.96	67.00	66.00	66.38	136.30	131.12	134.27
11	413.50	404.50	408.96	227.00	221.50	224.29	67.00	65.00	66.17	136.50	131.12	134.28
12	414.50	405.50	410.81	227.50	222.00	224.77	68.00	66.00	66.58	137.70	131.90	134.10
13	415.50	405.50	410.79	227.00	222.00	224.96	67.00	66.00	66.50	135.70	131.50	134.18
14	414.50	407.00	411.40	226.00	222.00	224.67	67.00	65.00	66.08	135.70	130.00	133.40
15	415.50	405.50	411.19	228.00	222.00	224.52	67.00	66.00	66.38	135.90	130.60	133.64
16	415.50	403.50	410.88	228.00	221.50	225.00	68.00	65.00	66.42	135.60	130.29	133.70
17	415.50	405.50	410.60	227.00	221.00	224.08	67.00	65.00	66.00	136.11	130.20	133.69
18	415.50	404.00	411.42	227.00	220.50	224.42	67.00	65.00	66.00	136.70	130.20	134.06
19	416.50	404.50	411.10	228.00	221.00	224.81	67.00	65.00	66.04	135.90	131.50	134.33
20	414.50	405.50	411.75	226.00	219.50	224.40	66.00	65.00	65.79	135.40	131.50	134.13
21	417.50	405.50	412.96	228.00	221.00	225.33	67.00	65.00	66.21	136.30	132.37	135.02
22	416.50	408.50	413.42	227.00	222.50	225.56	67.00	65.00	66.17	135.80	131.32	134.18
23	417.00	405.50	413.08	227.00	221.50	225.38	67.00	66.00	66.38	135.90	131.74	134.64
24	418.50	409.50	414.02	228.00	223.50	225.90	67.00	65.00	66.29	135.90	132.50	134.75
25	419.00	408.50	414.17	228.50	222.00	225.83	67.00	65.00	66.00	136.50	132.90	135.17
26	417.50	409.50	414.42	229.00	223.00	226.38	67.00	65.00	66.13	137.10	131.33	134.67
27	416.50	409.50	414.33	228.00	224.00	226.71	67.00	65.00	66.33	135.90	132.10	134.43
28	418.00	410.00	415.54	229.00	224.00	227.67	67.00	66.00	66.83	135.70	131.70	134.39
29	418.00	408.00	413.96	230.00	224.50	227.23	68.00	66.00	66.71	136.10	133.40	134.89
30	414.50	406.50	412.04	228.00	224.00	226.35	67.00	66.00	66.71	135.90	131.33	133.87
31	416.00	406.00	411.79	228.00	222.50	225.79	68.00	65.00	66.42	136.20	130.70	134.37
<b>Max</b>	<b>419.00</b>			<b>230.00</b>			<b>68.00</b>			<b>137.70</b>		
<b>Min</b>		<b>400.00</b>			<b>219.00</b>			<b>64.00</b>			<b>130.00</b>	

Source: TD, BPC

Graph: Daily maximum, minimum and average Voltage for the month of October, 2019






Table: Daily maximum, minimum and average Voltage for the month of November, 2019

Nov-19 Date	Malbase Substation									Nangkor Substation		
	400kV Bus Voltage (kV)			220kV Bus Voltage (kV)			66kV Bus Voltage (kV)			132kV Bus Voltage (kV)		
	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava
1	415.50	400.50	408.79	227.50	220.00	224.25	66.00	65.00	65.88	136.30	130.00	134.41
2	411.50	401.50	407.96	227.50	220.00	224.83	67.00	64.00	66.21	136.10	130.70	133.88
3	416.50	408.00	413.29	229.00	221.50	226.17	67.00	65.00	66.29	136.10	132.50	134.71
4	414.50	401.50	410.46	228.00	221.00	225.17	67.00	65.00	66.00	135.90	130.00	134.12
5	413.50	405.00	410.58	228.00	221.00	224.94	67.00	65.00	66.08	136.30	132.20	134.57
6	413.00	403.50	409.92	226.50	220.50	224.19	67.00	65.00	65.92	136.90	131.91	134.37
7	414.50	404.50	410.42	228.00	221.00	224.52	67.00	65.00	65.96	137.10	131.70	134.26
8	414.00	402.00	409.54	227.50	219.00	223.75	67.00	64.00	65.92	135.60	130.20	133.54
9	414.00	405.50	410.67	227.50	221.00	224.44	67.00	65.00	65.88	136.10	131.10	134.13
10	414.50	402.50	409.73	227.50	221.00	224.44	67.00	65.00	66.13	136.31	131.10	133.91
11	413.00	402.50	409.31	227.00	218.50	223.56	67.00	64.00	65.67	136.10	130.50	133.79
12	414.50	402.50	408.75	227.00	220.50	223.52	67.00	65.00	65.75	135.70	131.30	133.95
13	414.50	402.00	409.81	227.00	221.00	224.29	67.00	65.00	66.33	136.50	130.00	134.01
14	414.00	402.50	409.63	227.00	220.50	223.63	67.00	64.00	65.92	136.10	131.53	134.20
15	415.50	403.50	409.19	227.00	220.00	223.06	67.00	64.00	65.92	137.10	128.80	133.73
16	414.00	401.50	408.35	226.50	220.00	223.48	67.00	64.00	65.67	135.90	129.80	133.24
17	413.50	405.50	410.71	226.00	220.50	223.96	66.00	65.00	65.75	136.31	131.30	133.74
18	415.00	403.50	408.63	227.00	220.00	223.35	67.00	65.00	65.63	136.70	130.90	133.89
19	414.00	404.50	408.79	227.00	221.00	224.21	67.00	65.00	65.67	136.30	130.70	133.97
20	413.50	406.50	409.83	227.00	221.50	224.33	67.00	65.00	66.08	136.50	132.90	134.46
21	414.00	406.50	410.50	227.00	222.00	224.81	67.00	65.00	66.38	137.10	131.95	134.82
22	415.50	405.00	410.46	228.00	221.00	224.60	67.00	65.00	65.88	136.30	131.50	134.51
23	415.00	405.50	411.35	228.00	222.50	225.56	68.00	65.00	66.38	136.70	130.00	134.16
24	415.00	406.50	411.17	227.50	222.00	224.83	67.00	65.00	65.92	135.69	131.50	133.63
25	417.50	407.00	413.06	229.00	222.00	225.52	67.00	65.00	66.00	136.50	131.70	134.02
26	417.00	405.50	411.31	227.00	219.50	223.88	67.00	64.00	65.79	136.30	130.40	134.09
27	416.00	400.50	409.10	228.00	217.50	223.29	67.00	64.00	65.58	137.10	131.53	134.29
28	415.50	398.50	408.46	228.00	216.00	222.77	67.00	63.50	65.31	137.50	131.53	134.59
29	417.50	405.50	412.17	227.00	219.50	223.88	67.00	64.00	65.92	136.90	131.33	134.24
30	415.50	404.50	410.90	228.00	220.50	223.88	67.00	65.00	66.21	136.70	130.50	134.35
31	0.00	Error	Error	0.00	Error	Error	0.00	Error	Error	0.00	Error	Error
<b>Max</b>	<b>417.50</b>			<b>229.00</b>			<b>68.00</b>			<b>137.50</b>		
<b>Min</b>		<b>398.50</b>			<b>216.00</b>			<b>63.50</b>			<b>128.80</b>	

Source: TD, BPC

Graph: Daily maximum, minimum and average Voltage for the month of November, 2019







Table: Daily maximum, minimum and average Voltage for the month of December, 2019

Dec-19 Date	Malbase Substation									Nangkhor Substation		
	400kV Bus Voltage (kV)			220kV Bus Voltage (kV)			66kV Bus Voltage (kV)			132kV Bus Voltage (kV)		
	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava	Max	Min	Ava
1	414.50	407.50	412.21	227.00	223.50	225.85	67.00	66.00	66.58	136.40	131.12	134.22
2	415.50	405.50	411.21	228.00	220.00	224.29	67.00	65.00	66.00	137.30	130.71	134.61
3	414.50	405.50	409.88	227.00	221.00	224.08	67.00	64.00	65.83	136.90	131.12	134.40
4	415.50	404.50	409.46	230.00	221.00	224.50	67.00	65.00	65.79	136.70	131.12	134.36
5	413.50	404.50	409.67	228.00	220.00	224.08	67.00	65.00	65.83	136.90	130.90	134.37
6	414.50	405.00	410.63	227.00	220.50	224.00	67.00	65.00	65.92	136.31	130.50	133.61
7	414.50	404.50	411.63	227.00	221.00	225.17	67.00	65.00	66.42	136.70	131.33	134.17
8	414.50	406.00	410.83	227.00	221.00	224.56	67.00	65.00	66.04	137.90	130.91	135.03
9	413.50	404.50	409.46	226.50	220.00	223.25	67.00	65.00	65.71	136.10	129.88	133.71
10	415.50	406.50	411.48	226.50	221.00	224.75	67.00	65.00	66.38	137.30	131.70	135.06
11	418.50	405.50	411.46	228.00	220.00	224.65	67.00	65.00	66.04	137.70	132.20	134.90
12	416.50	405.50	411.58	228.00	220.50	224.52	67.00	65.00	66.25	137.90	131.90	135.08
13	414.50	404.50	410.79	227.00	219.50	224.13	67.00	65.00	66.08	136.30	130.70	134.32
14	414.00	404.50	411.19	226.50	220.50	224.40	67.00	65.00	65.92	136.80	132.80	134.63
15	413.50	405.50	411.06	226.00	220.00	223.98	67.00	65.00	66.19	137.70	132.30	135.28
16	414.50	405.50	410.27	226.50	221.50	223.54	67.00	65.00	65.88	136.50	131.80	134.72
17	415.50	405.50	411.10	227.00	220.50	224.60	67.00	65.00	66.04	136.20	130.70	134.59
18	413.50	406.50	410.58	226.50	221.50	224.44	67.00	65.00	66.29	136.90	131.12	134.55
19	414.50	404.50	410.29	227.00	219.50	224.15	67.00	65.00	66.04	136.50	131.50	134.16
20	415.50	405.50	409.77	227.50	218.00	222.46	67.00	65.00	65.75	136.90	132.10	134.47
21	414.50	406.50	411.58	228.00	220.50	224.71	67.00	65.00	66.08	136.70	132.70	135.11
22	415.50	407.50	412.00	227.00	222.00	224.54	67.00	65.00	65.83	135.90	132.10	134.57
23	415.50	406.00	411.65	227.00	221.00	224.23	67.00	65.00	65.92	137.10	133.40	135.40
24	414.50	404.50	411.17	227.00	220.50	224.63	67.00	65.00	65.92	136.90	132.00	135.09
25	414.00	406.50	410.21	226.50	222.00	224.19	66.00	65.00	65.75	136.70	132.40	134.48
26	415.50	404.50	410.67	227.00	220.00	223.75	67.00	65.00	65.71	136.31	130.50	134.22
27	415.50	404.50	410.44	227.00	220.50	224.31	67.00	65.00	65.83	135.80	131.70	134.34
28	415.50	403.50	410.44	227.50	217.50	224.17	67.00	64.00	65.79	136.20	131.12	134.34
29	415.00	405.50	410.52	227.50	221.00	224.29	67.00	65.00	66.25	136.31	131.20	134.74
30	416.50	405.50	411.00	228.00	221.00	224.13	67.00	65.00	66.17	136.90	131.90	134.31
31	415.50	406.50	411.54	227.50	221.00	223.85	67.00	65.00	65.96	137.50	131.90	134.87
<b>Max</b>	<b>418.50</b>			<b>230.00</b>			<b>67.00</b>			<b>137.90</b>		
<b>Min</b>		<b>403.50</b>			<b>217.50</b>			<b>64.00</b>			<b>129.88</b>	

Source: TD, BPC

Graph: Daily maximum, minimum and average Voltage for the month of December, 2019





Eastern Grid Outages

October, 2019												
<b>132/33/11kV, Kilikhar substation</b>												
Sl. No	Date of Tripping	Time of Outage (Hrs)	Date of Normalization	Time of Fault cleared (Hrs)	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
1	12.10.19	14:24	12.10.19	14:40	16	4.17	132kV Kurichu I/C	All O/G fdrs	Nil	Tingtibi	Grid fail	Grid fail at Tingtibi end.
<b>132/33/11kV, Kanglung substation</b>												
Sl. No	Date of Tripping	Time of Outage (Hrs)	Date of Normalization	Time of Fault cleared (Hrs)	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
1	12.10.2019	14:24	12.10.2019	14:40	0:16	2.68	132kV I/C	All Feeders	Nil	Tingtibi end	Grid fail	Grid fail from Tingtibi to Ngalam
<b>132/33/11kV, Nangkor substation</b>												
Sl. No	Date of Tripping	Time of Outage (Hrs)	Date of Normalization	Time of Fault cleared (Hrs)	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
1	12.10.2019	14:24 hrs	12.10.2019	14:40 hrs	16	-0.82	Main Grid	All Feeders	-	Tintibi Substation	Grid fail	Supply failed from Tintibi Substation.
2	12.10.2019	14:29 hrs	12.10.2019	14:41 hrs	12	-0.82	132kV Nangkor-Nganglam	All Feeders	Start Ø AB, tripped Ø ABC, TOC start, SOTF TOR, AR lockout short > .50.18Hz.	Nangkor-Nganglam line	Tripped on fault	
3	12.10.2019	14:29 hrs	12.10.2019	15:12 hrs	43	60.66	132kV Nangkor-Deothang	All Feeders	Start Ø AB, tripped Ø ABC, TOC start, SOTF TOR, AR lockout short > .50.18Hz.	Nangkor-Nganglam line	Tripped on fault	
<b>132/33/11kV, Deothang substation</b>												
Sl. No	Date of Tripping	Time of Outage (Hrs)	Date of Normalization	Time of Fault cleared (Hrs)	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
1	12.10.2019	14:21	12.10.2019	15:14	53	-59.8	132kV Incomer Nangkor fdr	Deothang S/s	Nil			Grid fail
2	12.10.2019	14:21	12.10.2019	15:14	53	57.64	132kV Motonga fdr	Deothang to Motongia line	Nil			Grid fail
<b>132/33/11kV, Nganglam substation</b>												
Sl. No	Date of Tripping	Time of Outage (Hrs)	Date of Normalization	Time of Fault cleared (Hrs)	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
1	12.10.2019	14:27	12.10.2019	14:38	11	2.44	132kV Nangkor-Nganglam	Nangkor-Nganglam	Grid fail	Nangkor-Nganglam line		
<b>132kV, Motanga substation</b>												
Sl. No	Date of Tripping	Time of Outage (Hrs)	Date of Normalization	Time of Fault cleared (Hrs)	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
1	12.10.2019	14:22	12.10.2019	15:14	52	57.7	132kV Deothang Fdr	All Feeders	Nil	Grid fail		
<b>220/132/33kV, Jigmeling substation</b>												
Sl. No	Date of Tripping	Time of Outage (Hrs)	Date of Normalization	Time of Fault cleared (Hrs)	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
1	7.10.2019	19:41	07.10.2019	20:07	26	136.710	400kV MHEP Line 1	400kV MHEP Line 1 and MHEP Generation	Bad weather	86.1 & 86.2 optd. Distance relay 1 and distance relay 2	main 1=30.9km main 2= 31km	
2	7.10.2019	19:41	08.10.2019	19:33	52	135.990	400kV MHEP Line 2	400kV MHEP Line 2	Bad weather	86.1 & 86.2 optd. Distance relay 1 and distance relay 2	Not available	
3	8.10.2019	1:49	8.10.2019	19:33	45	133.800	400kV MHEP Line 2	400kV MHEP Line 2	Earth Fault on R&Y phase	Distance relay main 1 and main 2 optd. DT trip	Line segment	
4	8.10.2019	1:49	8.10.2019	19:33	45	266.880	400kV Alipurduar CKT.1	400kV Alipurduar Ckt.1	Earth Fault on R&Y phase	Distance relay main 1 and main 2 optd. DT trip	Line segment	
5	31.10.2019	15:45	31.10.2019	16:20	35	120.710	400kV MHEP Line 2	400kV MHEP Line 2	Over current	Distance relay main 1 and main 2.	Main1=59.1km main2= 58.2km	
<b>220/66/33kV, Dhajay substation</b>												
Sl. No	Date of Tripping	Time of Outage (Hrs)	Date of Normalization	Time of Fault cleared (Hrs)	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
No tripping												
<b>132/66/33/11kV, Gelephu substation</b>												
Sl. No	Date of Tripping	Time of Outage (Hrs)	Date of Normalization	Time of Fault cleared (Hrs)	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
No Tripping												



Transmission System Performance Report

Fourth Quarterly Report-2019

**132/33/11kV, Tingtibi substation**

Sl. No	Date of Tripping	Time of Outage (Hrs)	Date of Normalization	Time of Fault cleared (Hrs)	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
1	10/12/2019	14:22 Hrs	10/12/2019	14:29Hrs	7	5.220	132kV Tingtibi-Nanglam Fdr.	132kV Tingtibi-Nanglam Fdr.	Over current	Over current Relay:Start phase ABC,Trip phase:B,O/C trip > 1,IA-305.2,IB-331.4A,IC-307.6 A.IN Measured:7.640,IN derived:7.565A.	132kV Tingtibi-Nanglam Fdr.	

**132/33kV, Yurmoo substation**

Sl. No	Date of Tripping	Time of Outage (Hrs)	Date of Normalization	Time of Fault cleared (Hrs)	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
No Tripping												

**November, 2019**

**132/33/11kV, Kilikhar substation**

Sl. No	Date of Tripping	Time of Outage (Hrs)	Date of Normalization	Time of Fault cleared (Hrs)	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
1	12.11.19	14:24	12.11.19	14:40	0:16	4.17	132kV Kurichu I/C	All O/G fdrs	NA	Null	Tingtibi	Grid fail at Tingtibi end.

**132/33/11kV, Kanglung substation**

Sl. No	Date of Tripping	Time of Outage (Hrs)	Date of Normalization	Time of Fault cleared (Hrs)	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
1	12.11.2019	14:24	12.11.2019	14:40	0:16	2.68	132kV I/C	All Feeders	Tripped on Fault	Null	Tingtibi end	Grid fail from Tingtibi to Ngalam

**132/33/11kV, Nangkor substation**

Sl. No	Date of Tripping	Time of Outage (Hrs)	Date of Normalization	Time of Fault cleared (Hrs)	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
1	12.11.2019	14:24 hrs	12.11.2019	14:40 hrs	0:16	-0.82	Main Grid	All Feeders	Tripped on fault	-	Tingtibi Substation	Supply failed from Tingtibi Substation.
2	12.11.2019	14:29 hrs	12.11.2019	14:41 hrs	0:12	-0.82	132kV Nangkor-Nganglam	All Feeders	Tripped on fault	Start Ø AB, tripped Ø ABC,TOC start,SOTF TOR,AR lockout short>.50.18Hz	Nangkor-Nganglam line	
3	12.11.2019	14:29 hrs	12.11.2019	15:12 hrs	0:43	60.66	132kV Nangkor-Deothang	All Feeders	Tripped on fault	Start Ø AB, tripped Ø ABC,TOC start,SOTF TOR,AR lockout short>.50.18Hz	Nangkor-Nganglam line	

**132/33/11kV, Deothang substation**

Sl. No	Date of Tripping	Time of Outage (Hrs)	Date of Normalization	Time of Fault cleared (Hrs)	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
1	12.11.2019	14:21	12.11.2019	15:14	0:53	-59.8	132kV Incomer Nangkor fdr	Deothang S/s	Tripped on fault	Null	Tingtibi end	Grid failed from Tingtibi S/s and at our end all breaker are in normal condition.
2	12.11.2019	14:21	12.11.2019	15:14	0:53	57.64	132kV Motonga fdr	Deothang to Motongia line	Tripped on fault	Null	Tingtibi end	Grid failed from Tingtibi S/s and at our end all breaker are in normal condition.

**132/33/11kV, Nganglam substation**

Sl. No	Date of Tripping	Time of Outage (Hrs)	Date of Normalization	Time of Fault cleared (Hrs)	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
1	12.11.2019	14:27	12.11.2019	14:38	0:11	2.44	132kV Nangkor-Nganglam	Nangkor-Nganglam	Tripped on fault	86opted.	Nangkor-Nganglam line	Tripped Value; IA-69.34A IB-98.04A IC-156.

**132kV, Motanga substation**

Sl. No	Date of Tripping	Time of Outage (Hrs)	Date of Normalization	Time of Fault cleared (Hrs)	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
1	12.11.2019	14:22	12.11.2019	15:14	0:52	57.7	132kV Deothang Fdr	All Feeders	Tripped on fault	Null	Tingtibi end	Grid failed from Tingtibi end.



Transmission System Performance Report

Fourth Quarterly Report-2019

220/132/33kV, Jigmeling substation												
Sl. No	Date of Tripping	Time of Outage (Hrs)	Date of Normalization	Time of Fault cleared (Hrs)	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
1	28.11.2019	10:22hrs	28.11.2019	10:35hrs	13	-79.260	Jigmeling-MHPA Line-1	Line segment		Main1: R,Y &Bph Trip Main-2: R,Y &Bph Trip		
2	28.11.2019	10:22hrs	28.11.2019	11:51hrs	29	-79.450	Jigmeling-MHPA Line-2	Line segment		Main1: R,Y &Bph Trip Main-2: R,Y &Bph Trip		
3	28.11.2019	10:22hrs	28.11.2019	12:25hrs	3	78.540	Jigmeling-Alipur Line 1	Line segment	Over Voltage	Main1: Yph Overtage		
4	13.11.2019	14:34hrs	13.11.2019	15:12hrs	38	-17.47	Jigmeling-Tsirang	Jigmeling-Tsirang Line	3Phase Fault	Main1: R,Y &Bph Trip Main-2: Relay General trip		
5	13.11.2019	14:34 hrs	13.11.2019	14:53hrs	19	-8.280	Jigmeling-Tingtibi	Tingtibi Substation	3Phase Fault	Main1: R,Y &Bph Trip Main-2: Relay General trip		
6	13.11.2019	14:34hrs	13.11.2019	15:15hrs	41	0.71	Jigmeling-Dagapela	Dagapela Substation	3Phase Fault	Main1: R,Y &Bph Trip Main-2: Relay General trip		
7	13.11.2019	15:58hrs	13.11.2019	16:19hrs	21	-87.59	Jigmeling-Tsirang	Jigmeling-Tsirang Line	3Phase Fault	Main1: R,Y &Bph Trip Main-2: Relay General trip		
8	13.11.2019	15:58hrs	13.11.2019	16:19hrs	21	0.99	Jigmeling-Dagapela	Dagapela Substation	3Phase Fault	Main1: R,Y &Bph Trip Main-2: Relay General trip		
9	13.11.2019	15:58hrs	13.11.2019	19:48hrs	50	15.31	Jigmeling-Tingtibi	Tingtibi Substation	3Phase Fault	Main1: R,Y &Bph Trip Main-2: Relay General trip	main I= 27.8km	

220/66/33kV, Dhajay substation												
Sl. No	Date of Tripping	Time of Outage (Hrs)	Date of Normalization	Time of Fault cleared (Hrs)	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
1	13.11.2019	14:34hrs	13.11.2019	15:03hrs	29	17.5	220kV Tsirang-Jigmeling Line	Dhajay Substation	Over Voltage		Line segment	
2	13.11.2019	14:34hrs	13.11.2019	15:03hrs	29	37.4	220kV Tsirang-DHPC Line	Dhajay Substation	Over Voltage		Line segment	
3	13.11.2019	15:58hrs	13.11.2019	16:17hrs	19	87.4	220kV Tsirang-Jigmeling Line	Dhajay Substation	Over Voltage		Line segment	
4	13.11.2019	15:58hrs	13.11.2019	16:15hrs	17	61.9	220kV Tsirang-DHPC Line	Dhajay Substation	Over Voltage		Line segment	

132/66/33/11kV, Gelephu substation												
Sl. No	Date of Tripping	Time of Outage (Hrs)	Date of Normalization	Time of Fault cleared (Hrs)	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
No tripping												

132/33/11kV, Tingtibi substation												
Sl. No	Date of Tripping	Time of Outage (Hrs)	Date of Normalization	Time of Fault cleared (Hrs)	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
1	11/13/2019	15:57 Hrs	11/13/2019	16:04Hrs	7	54.000	132kV Tingtibi-Nanglam Fdr.	132kV Tingtibi-Nanglam Fdr.	Over current	Over current Relay:Start phase ABC,Trip phase:B	132kV Tingtibi-Nanglam Fdr.	

132/33kV, Yurmoo substation												
Sl. No	Date of Tripping	Time of Outage (Hrs)	Date of Normalization	Time of Fault cleared (Hrs)	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
No tripping												

December, 2019

132/33/11kV, Kilikhar substation												
Sl. No	Date of Tripping	Time of Outage (Hrs)	Date of Normalization	Time of Fault cleared (Hrs)	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
1	17.12.2019	7:01	17.12.2019	7:26	25	7.92	132kV kurichu incomer	All O/G feeder	Tripped on fault	86 relay operated	Kurichu	Tripped on fault
2	30.12.2019	21:41	30.12.2019	22:15	34	4.39	132kV Corlung fdr	Corlung & kanglung s/s	Tripped on fault	86 relay operated	corlung	Tripped on fault
3	30.12.2019	22:25	31.12.2019	9:22	7	4.39	132kV Corlung fdr	Corlung & kanglung s/s	Tripped on fault	86 relay operated	corlung	Tripped on fault

132/33/11kV, Kanglung substation												
Sl. No	Date of Tripping	Time of Outage (Hrs)	Date of Normalization	Time of Fault cleared (Hrs)	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
1	17.12.2019	7:01	17.12.2019	7:25	0:24	4.98	132kV Incomer	Kanglung ss	incomer fail	Nil	Kurichu end	Tripped on fault

132/33/11kV, Nangkhor substation												
Sl. No	Date of Tripping	Time of Outage (Hrs)	Date of Normalization	Time of Fault cleared (Hrs)	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
1	08.12.2019	04:18 hrs	08.12.2019	04:25 hrs	7	8.89	Main Grid	All 33kV & 11kV feeders	Tripped on fault	-	MHEP	Tripped on fault

132/33/11kV, Deothang substation												
Sl. No	Date of Tripping	Time of Outage (Hrs)	Date of Normalization	Time of Fault cleared (Hrs)	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
1	03.12.2019	6:52	03.12.2019	6:57	5	1.12	132/33kV 5MVA Transformer I & II	All 33and 11kV Feeders	Tripped on fault	O/C&E/C	unknown	
2	10.12.2019	16:45	10.12.2019	16:50	5	0.83	132/33 5MVA Transformer I & II	All 33and 11kV Feeders	Bamboo fall on the conductor	Only 86 relay opeted	S/Jongkhar Hig School	



**Transmission System Performance Report**

**Fourth Quarterly Report-2019**

132/33/11kV, Nganglam substation												
Sl. No	Date of Tripping	Time of Outage (Hrs)	Date of Normalization	Time of Fault cleared (Hrs)	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
1	31.12.2019	14:41	31.12.2019	14:44	3	0.378	5MVA Tr-I( HV side)	5MVA Tr-I( HV side)	Conductor snapped	EF	33kV Druk GYP Fdr	
2	31.12.2019	14:41	31.12.2019	18:02	21	0.231	5MVA Tr-II( LV side)	5MVA Tr-II( LV side)	Conductor snapped	EF	33kV Druk GYP Fdr	
132kV, Motanga substation												
Sl. No	Date of Tripping	Time of Outage (Hrs)	Date of Normalization	Time of Fault cleared (Hrs)	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
No Tripping												
220/132/33kV, Jigmeling substation												
Sl. No	Date of Tripping	Time of Outage (Hrs)	Date of Normalization	Time of Fault cleared (Hrs)	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
1	5/12/2019	16:57hrs	5/12/2019	18:34hrs	37		MHPA Line-II	MHPA Line & Jigmeling ss	Over Voltage	Main-I & Main-II R, Y, Bph pick up	Line Segment	
220/66/33kV, Dhajay substation												
Sl. No	Date of Tripping	Time of Outage (Hrs)	Date of Normalization	Time of Fault cleared (Hrs)	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
No tripping												
132/66/33/11kV, Gelephu substation												
Sl. No	Date of Tripping	Time of Outage (Hrs)	Date of Normalization	Time of Fault cleared (Hrs)	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
No tripping												
132/33/11kV, Tingtibi substation												
Sl. No	Date of Tripping	Time of Outage (Hrs)	Date of Normalization	Time of Fault cleared (Hrs)	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
1	1	12/8/2019	04:15 Hrs	12/8/2019	15:11Hrs	56	4.000	132kV Grid Fail	132kV Grid Fail	-	-	132kV Gird
132/33kV, Yurmoo substation												
Sl. No	Date of Tripping	Time of Outage (Hrs)	Date of Normalization	Time of Fault cleared (Hrs)	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
No Tripping												



Transmission System Performance Report

Fourth Quarterly Report-2019

Annexure-VI

Western grid Outages

October, 2019												
<b>400/220/66/11kV Malbase substation</b>												
Sl. No	Date of Tripping	Time of Outage	Date of Normalization	Time of Fault cleared	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders/Equipment Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
1	14.10.2019	6:01	14.10.2019	6:18	17	13	200MVA ICT	200MVA ICT	Tripped	67(H.V), O/C Optd.		
2	14.10.2019	6:01	14.10.2019	6:21	20	154	220kV Malbase - Chhukha Feeder	220kV Malbase - Chhukha Feeder	Tripped	Distance start,Distance Trip A,B,C.Zone 1 Trip, IL3=456.1A.	fault loop=L1-L2,Distance=13.68km	
<b>220/66/11kV Singhigaon substation</b>												
Sl. No	Date of Tripping	Time of Outage	Date of Normalization	Time of Fault cleared	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders/Equipment Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
1	04.10.2019	14:53	04.10.2019	15:02	9	-	66kV Bus Coupler	66kV Bus Coupler	Tripped	Relay general trip, time overcurrent trip, IEP Trip. Trip Values: IL1 = 0.44kA IL2 = 0.34A IL3 = 0.29kA		
2	04.10.2019	14:53	04.10.2019	15:03	10	25	66kV Bhutan Concast Feeder	66kV Bhutan Concast Feeder	Tripped	Relay general trip, Directional time overcurrent trip, IEP directional Trip. Trip Values: IL1 = 0.06kA IL2 = 0.10kA IL3 = 0.14kA		
<b>66/33/11kV Phuentsholing substation</b>												
Sl. No	Date of Tripping	Time of Outage (Hrs)	Date of Normalization	Time of Fault cleared (Hrs)	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
1	07.10.2019	17:40	07.10.2019	17:54	14	-6.67	66kV Chukha-Pling	66kV Pling-Gedu section	Tripped	186,86	Substation	
2	14.10.2019	6:03	14.10.2019	6:20	17	2.37	66kV Pling-Gomtu fdr	66kV Pling-Gomtu fdr	Overcurrent	IA-280.2A, IB-280.7A, IC-25.94, VAB-52.1kV, VBC-62.70kV, VCA-59.08kV, 86 & 186.	Line	
<b>66/33/11kV Gomtu substation</b>												
Sl. No	Date of Tripping	Time of Outage	Date of Normalization	Time of Fault cleared	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders/Equipment Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
1	14.10.2019	06:03	14.10.2019	06:20	17	1.27	66kV Pling feeder	Nil	Over current	51 IDMT O/C	Line segment	
<b>220/66/33kV Dhamdum substation</b>												
Sl. No	Date of Tripping	Time of Outage	Date of Normalization	Time of Fault cleared	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders/Equipment Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
No Tripping												
<b>66/33/11kV Gedu substation</b>												
Sl. No	Date of Tripping	Time of Outage (Hrs)	Date of Normalization	Time of Fault cleared (Hrs)	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
1	07.10.2019	17:38	07.10.2019	17:53	15	2.420	66kV Chukha-P/ling fdr.	Whole Gedu blackout.	Tripped from Chukha.	1. Distance protection relay. 2.Master tripping relay 86. 3.General Zone-1. 4.PU time-82ms. 5.Trip time-0ms. 6.Distance-18.3km. 7.EF-pickup.	Line segment	
2	10.10.2019	7:19	10.10.2019	7:20	1	0.340	8MVA 66/33kV transformer	33kV Gurungdara feeder-I		Differential relay and tripping relay 86.	Line segment	
<b>66/33/11kV Lobeysa substation</b>												
Sl. No	Date of Tripping	Time of Outage	Date of Normalization	Time of Fault cleared	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders/Equipment Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
No tripping												
<b>220/66/11kV Semtokha substation</b>												
Sl. No	Date of Tripping	Time of Outage	Date of Normalization	Time of Fault cleared	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders/Equipment Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
No Tripping												
<b>66/33/11kV Dechenchholing substation</b>												
Sl. No	Date of Tripping	Time of Outage	Date of Normalization	Time of Fault cleared	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders/Equipment Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
No Tripping												
<b>66/33kV Olakha substation</b>												
Sl. No	Date of Tripping	Time of Outage	Date of Normalization	Time of Fault cleared	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders/Equipment Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
No Tripping												
<b>66/33/11kV Jemina substation</b>												
Sl. No	Date of Tripping	Time of Outage	Date of Normalization	Time of Fault cleared	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders/Equipment Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
No Tripping												



Transmission System Performance Report

Fourth Quarterly Report-2019

66kV Chumdo switching station												
Sl. No	Date of Tripping	Time of Outage	Date of Normalization	Time of Fault cleared	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders/Equipment Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
No Tripping												
66/33/11kV Paro substation												
Sl. No	Date of Tripping	Time of Outage	Date of Normalization	Time of Fault cleared	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders/Equipment Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
No Tripping												
66/11kV Haa substation												
Sl. No	Date of Tripping	Time of Outage	Date of Normalization	Time of Fault cleared	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders/Equipment Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
1	04.10.2019	16:00	04.10.2	16:03	3minutes	-1.25	66kV Incomer	All feeders	Unknown	Nil	Chumdo switching station.	
2	26.10.2019	11:20	26.10.2019	11:40	20minutes	-1.71	66kV Incomer	All feeders	Unknown	Nil	Chumdo switching station.	
3	28.10.2019	9:54	28.10.2019	10:02	8minutes	-1.9	66kV Incomer	All feeders	Grid fail	Nil	Chukha power house	
66/33kV Watsa substation												
Sl. No	Date of Tripping	Time of Outage	Date of Normalization	Time of Fault cleared	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders/Equipment Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
1	10/28/2019	9:53hrs	10/28/2019	9:59hrs	6min	.350MW	66kV Incomer	Feeder I and II	66kV incomer fail from chukha end	66kV incomer fail from chukha end	66kV incomer fail from chukha end	
November, 2019												
400/220/66/11kV Malbase substation												
Sl. No	Date of Tripping	Time of Outage	Date of Normalization	Time of Fault cleared	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders/Equipment Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
No Tripping												
220/66/11kV Singhigaon substation												
Sl. No	Date of Tripping	Time of Outage	Date of Normalization	Time of Fault cleared	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders/Equipment Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
No Tripping												
66/33/11kV Phuentsholing substation												
Sl. No	Date of Tripping	Time of Outage (Hrs)	Date of Normalization	Time of Fault cleared (Hrs)	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
No Tripping												
66/33/11kV Gomtu substation												
Sl. No	Date of Tripping	Time of Outage	Date of Normalization	Time of Fault cleared	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders/Equipment Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
No Tripping												
220/66/33kV Dhamdum substation												
Sl. No	Date of Tripping	Time of Outage	Date of Normalization	Time of Fault cleared	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders/Equipment Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
No Tripping												
66/33/11kV Gedu substation												
Sl. No	Date of Tripping	Time of Outage (Hrs)	Date of Normalization	Time of Fault cleared (Hrs)	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
1	09.11.2019	10:15	09.11.2019	10:20		5	0.640		6MVA 66/11kV Tr-I			
2	09.11.2019	10:15	09.11.2019	10:20		5	0.640		6MVA 66/11kV Tr-II			
66/33/11kV Lobeysa substation												
Sl. No	Date of Tripping	Time of Outage	Date of Normalization	Time of Fault cleared	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders/Equipment Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
No tripping												
220/66/11kV Semtokha substation												
Sl. No	Date of Tripping	Time of Outage	Date of Normalization	Time of Fault cleared	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders/Equipment Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
No Tripping												
66/33/11kV Dechenchholing substation												
Sl. No	Date of Tripping	Time of Outage	Date of Normalization	Time of Fault cleared	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders/Equipment Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
No Tripping												
66/33kV Olakha substation												
Sl. No	Date of Tripping	Time of Outage	Date of Normalization	Time of Fault cleared	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders/Equipment Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
1	11/11/2019	14:33	11/11/2019	14:36	3	6.60	66/33kV 20MVA Transformer I	All 33kV out going feeder	Differential Protection, Over current and Earth fault protection			



Transmission System Performance Report

Fourth Quarterly Report-2019

66/33/11kV Jemina substation																	
Sl. No	Date of Tripping	Time of Outage	Date of Normalization	Time of Fault cleared	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders/Equipment Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks					
No Tripping																	
66kV Chumdo switching station																	
Sl. No	Date of Tripping	Time of Outage	Date of Normalization	Time of Fault cleared	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders/Equipment Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks					
1	10.11.2019	1420hrs	10.11.2019	1425hrs	5min	2.05MW	66KV O/G Pangbasa Feeder	Pangbasa Substation	Transient Fault	C.B open, Main II optd	Chumdo substation						
2		1429hrs		1459hrs	30min												
3		1429hrs		1434hrs	5min												
4	16.11.2019	1447hrs	16.11.2019	1520hrs	33min	1.94MW											
5		1544hrs		1550hrs	6min												
6		1817hrs		1833hrs	16min	3.07MW											
7	19.11.2019	1806hrs	19.11.2019	1823hrs	17min	3.27MW									O/C on R,Y,B		
66/33/11kV Paro substation																	
Sl. No	Date of Tripping	Time of Outage	Date of Normalization	Time of Fault cleared	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders/Equipment Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks					
No Tripping																	
66/11kV Haa substation																	
Sl. No	Date of Tripping	Time of Outage	Date of Normalization	Time of Fault cleared	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders/Equipment Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks					
1	19.11.2019	17:56	19.11.2019	18:00	4minutes	-1.54	66kV Incomer	All feeders	Unknown	O/C	Chumdo switching station.						
2	19.11.2019	18:06	19.11.2019	18:23	17minutes	-2.75	66kV Incomer	All feeders	Unknown	O/C in R&BØ	Chumdo switching station.						
66/33kV Watsa substation																	
Sl. No	Date of Tripping	Time of Outage	Date of Normalization	Time of Fault cleared	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders/Equipment Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks					
1	11/11/2019	14:01hrs	11/11/2019	14:07hrs	6min	.350MW	66kV SF breaker	Feeder I and II	Over Current and Earth Fault ( Rand Y phase)	Over current & earth fault relay operated	Feeder II watsa and Damchu						
2	26/11/2019	13:05hrs	26/11/2019	13:08hrs	3min	.300MW	66kV SF breaker	Feeder I and II	Over Current and Earth Fault	Over current & earth fault relay operated	Feeder I Betikha						
December, 2019																	
400/220/66/11kV Malbase substation																	
Sl. No	Date of Tripping	Time of Outage	Date of Normalization	Time of Fault cleared	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders/Equipment Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks					
No Tripping																	
220/66/11kV Singhigaon substation																	
Sl. No	Date of Tripping	Time of Outage	Date of Normalization	Time of Fault cleared	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders/Equipment Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks					
No Tripping																	
66/33/11kV Phuentsholing substation																	
Sl. No	Date of Tripping	Time of Outage (Hrs)	Date of Normalization	Time of Fault cleared (Hrs)	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks					
1	11.12.2019	21:29	11.12.2019	21:32		2.51	10MVA Trf (66/33kV) Votlamps	10MVA Trf (66/33kV) Votlamps	Overcurrent	50 RY&B phase, 86	Line						
2	11.12.2019	23:09	11.12.2019	23:14		1.96	10MVA Trf (66/33kV) Votlamps	All 33kV feeders.	Overcurrent	51 RY&B phase, 86	Line						
66/33/11kV Gomtu substation																	
Sl. No	Date of Tripping	Time of Outage	Date of Normalization	Time of Fault cleared	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders/Equipment Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks					
No Tripping																	
220/66/33kV Dhamdum substation																	
Sl. No	Date of Tripping	Time of Outage	Date of Normalization	Time of Fault cleared	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders/Equipment Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks					
No Tripping																	
66/33/11kV Gedu substation																	
Sl. No	Date of Tripping	Time of Outage (Hrs)	Date of Normalization	Time of Fault cleared (Hrs)	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks					
No Tripping																	



Transmission System Performance Report

Fourth Quarterly Report-2019

66/33/11kV Lobeysa substation												
Sl. No	Date of Tripping	Time of Outage	Date of Normalization	Time of Fault cleared	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders/Equipment Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
No tripping												
220/66/11kV Semtokha substation												
Sl. No	Date of Tripping	Time of Outage	Date of Normalization	Time of Fault cleared	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders/Equipment Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
No Tripping												
66/33/11kV Dechenchholing substation												
Sl. No	Date of Tripping	Time of Outage	Date of Normalization	Time of Fault cleared	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders/Equipment Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
No Tripping												
66/33kV Olakha substation												
Sl. No	Date of Tripping	Time of Outage	Date of Normalization	Time of Fault cleared	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders/Equipment Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
No Tripping												
66/33/11kV Jemina substation												
Sl. No	Date of Tripping	Time of Outage	Date of Normalization	Time of Fault cleared	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders/Equipment Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
No Tripping												
66kV Chumdo switching station												
Sl. No	Date of Tripping	Time of Outage	Date of Normalization	Time of Fault cleared	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders/Equipment Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
1	04.12.2019	1325hrs	04.12.2019	1337hrs	12min	2.82MW	66KV O/G Pangbasa Feeder	Pangbasa Substation	Transient Fault	C.B open, Main II optd, O/C	Chumdo substation	
2	04.12.2019	1437hrs	04.12.2019	1447hrs	10min	0.66MW	66KV O/G Pangbasa Feeder	Pangbasa Substation	Transient Fault	O/C on B phase	Chumdo substation	
3	10.12.2019	1517hrs	10.12.2019	1524hrs	7min	2.6MW	66KV O/G Pangbasa Feeder	Pangbasa Substation	Transient Fault	O/C on Y & B phase	Chumdo substation	
4	22.12.2019	1350hrs	22.12.2019	1400hrs	10min	2.36MW	66KV O/G Pangbasa Feeder	Pangbasa Substation	Transient Fault	O/C on Y & B phase	Chumdo substation	
5	22.12.2019	1437hrs	22.12.2019	1450hrs	13min	2.22MW	66KV O/G Pangbasa Feeder	Pangbasa Substation	Transient Fault	O/C on Y & B phase	Chumdo substation	
6	22.12.2019	1539hrs	22.12.2019	1550hrs	11min	2.29MW	66KV O/G Pangbasa Feeder	Pangbasa Substation	Transient Fault	O/C on Y & B phase	Chumdo substation	
No Tripping												
66/33/11kV Paro substation												
Sl. No	Date of Tripping	Time of Outage	Date of Normalization	Time of Fault cleared	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders/Equipment Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
No Tripping												
66/11kV Haa substation												
Sl. No	Date of Tripping	Time of Outage	Date of Normalization	Time of Fault cleared	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders/Equipment Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
1	04.12.2019	13:01	04.12.2019	13:18	17minutes	-1.97	66kV Incomer	All feeders	Unknown	O/C		
2	04.12.2019	13:23	04.12.2019	13:57	39minutes	-1.97	66kV Incomer	All feeders	Unknown	O/C		
3	04.12.2019	14:38	04.12.2019	15:24	46minutes	-2.2	66kV Incomer	All feeders	Unknown	O/C		
4	22.12.2019	14:24	22.12.2019	14:50	26minutes	-1.51	66kV Incomer	All feeders	Unknown	O/C	Chumdo switching station.	
5	22.12.2019	15:40	22.12.2019	15:51	11minutes	-1.59	66kV Incomer	All feeders	Unknown	O/C		
No Tripping												
66/33kV Watsa substation												
Sl. No	Date of Tripping	Time of Outage	Date of Normalization	Time of Fault cleared	Duration of Outages (hh:mm)	Load before Outage (MW)	Name of Feeders/Equipment Tripped	Name of Substations/Line affected by fault	Reason of Fault	Relay indication and operation	Exact location of fault (Line segment/substation)	Remarks
1	20/12/2019	12:50hrs	20/12/2019	12:58hrs	8min	.400MW	66kV SF breaker	Feeder I and II	Over Current on Y phase	Over Current relay operated	Feeder II Damchu	
2	21/12/2019	13:05hrs	21/12/2019	13:08hrs	3min	.360MW	66kV SF breaker	Feeder I and II	Earth Fault	Earth fault relay operated	Feeder II chapcha	
3	21/12/2019	16:42hrs	21/12/2019	16:45hrs	3min	.460MW	66kV SF breaker	Feeder I and II	Earth Fault	Earth fault relay operated	Feeder II chapcha	
4	22/12/2019	12:24hrs	22/12/2019	12:28hrs	4min	.400MW	66kV SF breaker	Feeder I and II	Earth fault	Earth fault relay operated	Feeder I Wanakha	
5	23/12/2019	12:49hrs	23/12/2019	12:52hrs	3min	.189MW	66kV SF breaker	Feeder I and II	Earth fault	Earth fault relay operated	Feeder I Wanakha	
6	23/12/2019	15:27hrs	23/12/2019	15:30hrs	3min	.360MW	66kV SF breaker	Feeder I and II	Earth Fault	Earth fault relay operated	Feeder II chapcha	