



འབྲུག་རྒྱལ་ཁབ་ལོ་ནུ་རྒྱུ་ཉེན་འགོ་སྐྱོལ་ལྷན་ཁག་ རྒྱལ་ཁབ་ཤུགས་རྒྱུག་ལྟེན་པོ།
 Ministry of Energy and Natural Resources
 Royal Government of Bhutan
Bhutan Power System Operator
 Thimphu: Bhutan



THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 26-Feb-2026(=vc:import, +=vc:export)

Report Details	Date	Time	National Coincidental Peak Load (MW)		Date	Time	Load
	February 25, 2026	9:00 AM			08-Nov-25	19:03:00	1,477.00
Sl.No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks	
1	6 x 170MW THP	Unit-I	174.53	400kV THP - Siliguri Line - I	0.00	Unit- IV, V & VI under Shutdown (Annual Maintenance). 400kV THP_SIL line I under Shutdown.	
		Unit-II	185.64	400kV THP - Siliguri Line - II	82.06		
		Unit-III	184.73	400kV THP - Norbugang - IV	148.63		
		Unit-IV	0.00	400kV THP - Malbase Line - III	309.66		
		Unit-V	0.00	400kV Malbase - Siliguri Line	23.69		
		Unit-VI	0.00	400kV Norbugang-Siliguri Line	0.76		
		Total	544.90	Auxiliary Consumption & Transformation Losses at Generator end	0.84%		
2	4 x 180MW MHP	Unit-I	180.23	400kV MHP - Jigmeling Line - I	0.00	Unit-III under Shutdown. Unit-IV under AMP. 400kV MHP-JLG Line - I & line - III on Standby.	
		Unit-II	190.87	400kV MHP - Jigmeling Line - II	133.21		
		Unit-III	0.00	400kV MHP - Jigmeling Line - III	0.00		
		Unit-IV	0.00	400kV MHP - Jigmeling Line - IV	134.43		
		-	-	220kV Jigmeling - BitDeer Line - I	185.35		
		-	-	220kV Jigmeling - BitDeer Line - II	199.04		
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	418.18		
		-	-	400kV Jigmeling - Alipurduar Line - I	2.91		
		-	-	400kV Jigmeling - Alipurduar Line - II	1.45		
		-	-	80MVA, 220/132kV ICT - I (HV)	-17.50		
		-	-	80MVA, 220/132kV ICT - II (HV)	-17.30		
		-	-	132kV MHP - Yurmo Line - II	64.09		
		-	-	132kV MHP - Tintibi Line	57.00		
		-	-	132kV Gelephu - Salakati Line	-45.09		
		Total	371.10	Auxiliary Consumption & Transformation Losses at Generator end	0.60%		
3	6 x 170MW PHP-II	Unit-I	0.00	400kV PHP II - Jigmeling -I	158.82	Unit-I, II & IV under Shutdown (Annual Maintenance). Unit-III on Standby. 400kV PHPII - JLG-II on Standby. 400kV PHPII - ALI-II on standby.	
		Unit-II	0.00	400kV PHP II - Jigmeling -II	0.00		
		Unit-III	0.00	400kV PHP II - Alipurduar -I	83.19		
		Unit-IV	0.00	400kV PHP II - Alipurduar -II	0.00		
		Unit-V	120.33	-	-		
		Unit-VI	119.76	-	-		
		Total	240.09	Auxiliary Consumption & Transformation Losses at Generator end	-0.80%		
4	4 x 84MW CHP	Unit-I	75.32	220kV CHP - Birpara Line - I	-51.06	Unit-II & IV under Shutdown (Annual Maintenance).	
		Unit-II	0.00	220kV CHP - Birpara Line - II	-50.75		
		Unit-III	74.58	220kV CHP - Gedu	-80.20		
		Unit-IV	0.00	220kV CHP - Jamjee - I	110.26		
		-	-	220kV CHP - Jamjee - II	109.56		
		-	-	220kV CHP - Jamjee - III	105.72		
		-	-	220kV Malbase - Birpara Line	-6.61		
		-	-	66kV CHP - Gedu Line	4.38		
		Total	149.90	Auxiliary Consumption & Transformation Losses at Generator end	1.33%		
5	2 x 12MW BHP (U/S)	Unit-I	0.00	220kV BHP - Semtokha Line	24.14	L/S Unit-II under AMP. U/S Unit-I under AMP.	
		Unit-II	5.20	66kV BHP - Lobeyssa Line	19.46		
		Total	5.20	220kV BHP - Tsirang Line	-27.86		
6	2 x 20MW BHP (L/S)	Unit-I	10.90	5MVA, 66/11kV TFR	0.50	Total Plant Shutdown from 10:27 hrs (09.10.2025) due to Seepage in HRC .	
		Unit-II	0.00	30MVA ICT, 220/66kV (HV)	14.72		
		Total	10.90	Auxiliary Consumption & Transformation Losses at Generator end	-0.87%		
7	2 x 63MW DHP	Unit-I	0.00	220kV DHP - Tsirang Line	0.00	Total Plant Shutdown from 10:27 hrs (09.10.2025) due to Seepage in HRC .	
		Unit-II	0.00	220kV DHP - Dagapela Line	0.00		
		-	-	220kV BitDeer - Dagapela Line	55.00		
		-	-	5MVA, 220/33kV TFR	0.00		
Total	0.00	Auxiliary Consumption & Transformation Losses at Generator end	0.00%				
8	4 x 15MW KHP	Unit-I	0.00	132kV KHP - Nangkor Line	9.78	Unit-II under AMP. Unit- I on Standby.	
		Unit-II	0.00	132kV KHP - Kilikhar Line	11.96		
		Unit-III	11.21	5MVA, 132/11kV TFR	0.38		
		Unit-IV	11.23	132kV Motanga - Rangia Line	-20.89		
		Total	22.44	Auxiliary Consumption & Transformation Losses at Generator end	1.43%		
9	2 x 59MW NHP	Unit-I	0.00	132kV NHP-MHP-I	0.00	Unit I under Shutdown. 132kV NHP-MHP line I under ideal charge at NHP end.	
		Unit-II	20.05	132kV NHP-MHP-II	19.86		
		Total	20.05	Auxiliary Consumption & Transformation Losses at Generator end	0.95%		
10	2 x 9MW SHP	Unit-I	0.00	66kV SHP-Damdum (Samtse)	0.00	Unit-I on Standby. Interim measure: Evacuation is through 33kV System.	
		Unit-II	3.70	-	-		
		Total	3.70	Auxiliary Consumption & Transformation Losses at Generator end	100.00%		
11	17.38 MWp Sephu (Solar)	Inverter-1	0.93	33kV SSP-Wangdue	5.25	All Inverters & Feeders in Service.	
		Inverter-2	1.99	33kV SSP-Trongsang	4.05		
		Inverter-3	2.33	-	-		
		Inverter-4	1.82	-	-		
		Inverter-5	2.23	-	-		
		Total	9.30	Auxiliary Consumption & Transformation Losses at Generator end	-0.03%		


Note: Generation-Load Summary (MW) for 25-Feb-26 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	1,377.58	1,357.92	19.66

Note: Generation-Load Summary (MW) for 25-Feb-25 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	851.53	806.22	45.31

09:00 hrs Statistical Comparison (MW) for this and last year



THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 26-Feb-2026(-ve:import, +ve:export)

Report Details	Date	Time	National Coincidental Peak Load (MW)		Date	Time	Load
	February 25, 2026	18:00:00			08-Nov-25	19:03:00	1,477.00
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks	
1	6 x 170MW THP	Unit-I	10.54	400kV THP - Siliguri Line - I	0.00	Unit-V & VI under Shutdown (Annual Maintenance). 400kV THP_SIL line I under Shutdown. 400kV NIP-TALA FDR is declared faulty after tripping @ 13:15 Hrs today.	
		Unit-II	11.63	400kV THP - Siliguri Line - II	-154.83		
		Unit-III	15.12	400kV THP - Norbugang Line - IV	134.80		
		Unit-IV	30.23	400kV THP - Malbase Line - III	87.01		
		Unit-V	0.00	400kV Malbase - Siliguri Line	-193.48		
		Unit-VI	0.00	400kV Norbugang-Siliguri Line	0.00		
		Total	67.52	Auxiliary Consumption & Transformation Losses at Generator end	0.80%		
2	4 x 180MW MHP	Unit-I	20.78	400kV MHP - Jigmeling Line - I	-26.95	Unit-III under Shutdown. Unit-IV under AMP. 400kV MHP-JLG Line - I & line - III on Standby. 400kV JLG-ALI Line - II under shutdown	
		Unit-II	20.23	400kV MHP - Jigmeling Line - II	-26.90		
		Unit-III	0.00	400kV MHP - Jigmeling Line - III	0.00		
		Unit-IV	0.00	400kV MHP - Jigmeling Line - IV	0.00		
		-	-	220kV Jigmeling - BitDeer Line - I	186.40		
		-	-	220kV Jigmeling - BitDeer Line - II	190.00		
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	406.91		
		-	-	400kV Jigmeling - Alipurduar Line - I	-231.27		
		-	-	400kV Jigmeling - Alipurduar Line - II	0.00		
		-	-	80MVA, 220/132kV ICT - I (HV)	-16.22		
		-	-	80MVA, 220/132kV ICT - II (HV)	-15.99		
		-	-	132kV MHP - Yurno Line - II	69.90		
		-	-	132kV MHP - Tintibi Line	44.40		
		-	-	132kV Gelephu - Salakati Line	-73.80		
		Total	41.01	Auxiliary Consumption & Transformation Losses at Generator end	0.98%		
3	6 x 170MW PHP-II	Unit-I	0.00	400kV PHP II - Jigmeling -I	233.16	Unit-I, II & IV under Shutdown (Annual Maintenance). Unit-III & V on Standby. 400kV PHPII - JLG-II on Standby. 400kV PHPII - ALI-II on Standby.	
		Unit-II	0.00	400kV PHP II - Jigmeling -II	0.00		
		Unit-III	0.00	400kV PHP II - Alipurduar -I	-112.39		
		Unit-IV	0.00	400kV PHP II - Alipurduar -II	0.00		
		Unit-V	120.07	-	-		
		Unit-VI	-	-	-		
Total	120.07	Auxiliary Consumption & Transformation Losses at Generator end	-0.58%				
4	4 x 84MW CHP	Unit-I	45.73	220kV CHP - Birpara Line - I	-89.40	Unit-II & IV under Shutdown (Annual Maintenance).	
		Unit-II	0.00	220kV CHP - Birpara Line - II	-88.30		
		Unit-III	44.81	220kV CHP - Gedu	-96.01		
		Unit-IV	0.00	220kV CHP - Jamjee - I	121.60		
		-	-	220kV CHP - Jamjee - II	120.00		
		-	-	220kV CHP - Jamjee - III	118.00		
		-	-	220kV Malbase - Birpara Line	-57.71		
		-	-	66kV CHP - Gedu Line	4.05		
Total	90.54	Auxiliary Consumption & Transformation Losses at Generator end	0.66%				
5	2 x 12MW BHP (U/S)	Unit-I	0.00	220kV BHP - Sementokha Line	10.77	L/S Unit-II under AMP. U/S unit-I under AMP.	
		Unit-II	3.70	66kV BHP - Lobeyasa Line	22.53		
		Total	3.70	220kV BHP - Tsirang Line	-17.98		
6	2 x 20MW BHP (L/S)	Unit-I	10.88	5MVA, 66/11kV TFR	0.65		
		Unit-II	0.00	30MVA ICT, 220/66kV (HV)	18.25		
		Total	10.88	Auxiliary Consumption & Transformation Losses at Generator end	-9.53%		
7	2 x 63MW DHP	Unit-I	0.00	220kV DHP - Tsirang Line	-56.00	Total Plant Shutdown from 10:27 hrs (09.10.2025) due to Seepage in HRC . 220kV Bitdeer-Dagapela line under shutdown.	
		Unit-II	0.00	220kV DHP - Dagapela Line	55.30		
		-	-	220kV BitDeer - Dagapela Line	0.00		
		-	-	5MVA, 220/33kV TFR	0.00		
Total	0.00	Auxiliary Consumption & Transformation Losses at Generator end	0.00%				
8	4 x 15MW KHP	Unit-I	12.16	132kV KHP - Nangkhor Line	10.27	Unit-I & III on Standby. Unit-II under Shutdown (AMP).	
		Unit-II	0.00	132kV KHP - Kihkhar Line	13.51		
		Unit-III	0.00	5MVA, 132/11kV TFR	0.38		
		Unit-IV	12.22	132kV Motanga - Rangia Line	-31.76		
		Total	24.38	Auxiliary Consumption & Transformation Losses at Generator end	0.90%		
9	2 x 59MW NHP	Unit-I	20.00	132kV NHP-MHP-I	19.84	Unit I under Shutdown 132kV NHP-MHP line I under ideal charge at NHP end.	
		Unit-II	0.00	132kV NHP-MHP-II	0.00		
		Total	20.00	Auxiliary Consumption & Transformation Losses at Generator end	0.80%		
10	2 x 9MW SHP	Unit-I	0.00	66kV SHP-Damdhum (Samtse)	0.00	Unit-I on Standby. Interim measure: Evacuation is through 33kV System.	
		Unit-II	3.55	-	-		
		Total	3.55	Auxiliary Consumption & Transformation Losses at Generator end	100.00%		

Note: Generation-Load Summary (MW) for 25-Feb-2026 at 18:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	381.65	1,414.59	-1,032.94

Note: Generation-Load Summary (MW) for 25-Feb-2025, at 18:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	921.11	887.50	33.61

Note: Daily Energy (MUs) and Power(MW) Statistics for 25-Feb-2026

Sl. No.	Total Energy Generation	Daily Energy Met	Net Energy Import (IEX and Solar)	Net Energy Export	Peak Cross-border (MW)
1	13.64	32.58	18.91	0.00	-1,060.46

19:00 hrs Statistical Comparison (MW) for this and last year



- The Instantaneous load balance does not tend towards zero. This could be due to the following reasons:
 - Not all the meters are digital and nor are all the meter at all locations can be read at same time (say 9:00hrs) due to many meter to be read manually.
 - The clocks of all the locations are not synchronized.
- This report, compiled using the SCADA data, is prepared to give an overall idea of the generation & load flow for the system at a particular instant. This report also gives energy and import/export figures.
- When SCADA data are unavailable for certain stations due to technical issues, required data are collected from the site.