



འབྲུག་རྒྱལ་ཁབ་ལོ་ནུ་རྒྱུ་ཉེན་འགག་དཔལ་ལྷན་ཁག་གཞུང་།
 Ministry of Energy and Natural Resources
 Royal Government of Bhutan
Bhutan Power System Operator
 Thimphu: Bhutan



THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 03-Mar-2026(-ve:import, +ve:export)

Report Details	Date	Time	National Coincidental Peak Load (MW)		Date	Time	Load
	March 2, 2026	9:00 AM			08-Nov-25	19:03:00	1,477.00
Sl.No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks	
1	6 x 170MW THP	Unit-I	163.39	400kV THP - Siliguri Line - I	0.00	Unit- III & V under Shutdown (Annual Maintenance). Unit II on Standby 400kV THP_SIL line I under Shutdown. 400kV THP_Norbugang-Siliguri line and 400kV THP_SIL line II tripped and it's under inspection.	
		Unit-II	0.00	400kV THP - Siliguri Line - II	0.00		
		Unit-III	0.00	400kV THP - Norbugang - IV	152.59		
		Unit-IV	186.05	400kV THP - Malbase Line - III	377.72		
		Unit-V	0.00	400kV Malbase - Siliguri Line	96.35		
		Unit-VI	184.77	400kV Norbugang-Siliguri Line	0.00		
		Total	534.21	Auxiliary Consumption & Transformation Losses at Generator end	0.73%		
2	4 x 180MW MHP	Unit-I	196.12	400kV MHP - Jigmeling Line - I	135.13	Unit-III under Shutdown. Unit-IV under AMP. 400kV MHP-JLG Line - III under Shutdown. 400kV MHP-JLG Line - IV on Standby.	
		Unit-II	181.13	400kV MHP - Jigmeling Line - II	134.80		
		Unit-III	0.00	400kV MHP - Jigmeling Line - III	0.00		
		Unit-IV	0.00	400kV MHP - Jigmeling Line - IV	0.00		
		-	-	220kV Jigmeling - BitDeer Line - I	188.40		
		-	-	220kV Jigmeling - BitDeer Line - II	188.90		
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	424.00		
		-	-	400kV Jigmeling - Alipurduar Line - I	1.46		
		-	-	400kV Jigmeling - Alipurduar Line - II	2.18		
		-	-	80MVA, 220/132kV ICT - I (HV)	-17.26		
		-	-	80MVA, 220/132kV ICT - II (HV)	-17.02		
		-	-	132kV MHP - Yurno Line - II	63.76		
		-	-	132kV MHP - Tintibi Line	56.98		
		-	-	132kV Gelephu - Salakati Line	-39.51		
		Total	377.25	Auxiliary Consumption & Transformation Losses at Generator end	1.44%		
3	6 x 170MW PHP-II	Unit-I	0.00	400kV PHP II - Jigmeling -I	159.30	Unit-I, II & IV under Shutdown (Annual Maintenance). Unit-III on Standby. 400kV PHPII - JLG-II on Standby. 400kV PHPII - ALI-II on standby	
		Unit-II	0.00	400kV PHP II - Jigmeling -II	0.00		
		Unit-III	0.00	400kV PHP II - Alipurduar -I	82.24		
		Unit-IV	0.00	400kV PHP II - Alipurduar -II	0.00		
		Unit-V	119.37	-	-		
		Unit-VI	120.24	-	-		
		Total	239.61	Auxiliary Consumption & Transformation Losses at Generator end	-0.81%		
4	4 x 84MW CHP	Unit-I	74.35	220kV CHP - Birpara Line - I	-81.33	Unit-II & IV under Shutdown (Annual Maintenance). 220kV CHP_Gedu tripped at 09:09hrs	
		Unit-II	0.00	220kV CHP - Birpara Line - II	-80.37		
		Unit-III	75.57	220kV CHP - Gedu	0.00		
		Unit-IV	0.00	220kV CHP - Jamjee - I	104.94		
		-	-	220kV CHP - Jamjee - II	104.20		
		-	-	220kV CHP - Jamjee - III	102.10		
		-	-	220kV Malbase - Birpara Line	51.22		
		-	-	66kV CHP - Gedu Line	0.89		
		Total	149.92	Auxiliary Consumption & Transformation Losses at Generator end	-0.34%		
5	2 x 12MW BHP (U/S)	Unit-I	0.00	220kV BHP - Semtokha Line	45.99	L/S Unit-II under AMP. U/S Unit-I under AMP.	
		Unit-II	6.50	66kV BHP - Lobeyssa Line	21.30		
		Total	6.50	220kV BHP - Tsirang Line	-49.18		
6	2 x 20MW BHP (L/S)	Unit-I	12.53	5MVA, 66/11kV TFR	0.61		
		Unit-II	0.00	30MVA ICT, 220/66kV (HV)	16.02		
		Total	12.53	Auxiliary Consumption & Transformation Losses at Generator end	1.63%		
7	2 x 63MW DHP	Unit-I	0.00	220kV DHP - Tsirang Line	0.00	Total Plant Shutdown from 10:27 hrs (09.10.2025) due to Seepage in HRC .	
		Unit-II	0.00	220kV DHP - Dagapela Line	0.00		
		-	-	220kV BitDeer - Dagapela Line	57.39		
		-	-	5MVA, 220/33kV TFR	0.00		
Total	0.00	Auxiliary Consumption & Transformation Losses at Generator end	0.00%				
8	4 x 15MW KHP	Unit-I	12.18	132kV KHP - Nangkor Line	10.38	Unit-II under AMP. Unit-III on Standby.	
		Unit-II	0.00	132kV KHP - Kilikhar Line	13.33		
		Unit-III	0.00	5MVA, 132/11kV TFR	0.39		
		Unit-IV	12.23	132kV Motanga - Rangia Line	-22.21		
		Total	24.41	Auxiliary Consumption & Transformation Losses at Generator end	1.27%		
9	2 x 59MW NHP	Unit-I	19.00	132kV NHP-MHP-I	18.87	Unit II under AMP. 132kV NHP-MHP line II under ideal charge at MHP end.	
		Unit-II	0.00	132kV NHP-MHP-II	0.00		
		Total	19.00	Auxiliary Consumption & Transformation Losses at Generator end	0.68%		
10	2 x 9MW SHP	Unit-I	0.00	66kV SHP-Damdhum (Samtse)	0.00	Unit-I on Standby. Interim measure: Evacuation is through 33kV System.	
		Unit-II	4.50	-	-		
		Total	4.50	Auxiliary Consumption & Transformation Losses at Generator end	100.00%		
11	17.38 MWp Sephu (Solar)	Inverter-1	1.74	33kV SSP-Wangdue	4.66	All Inverter and 33kV Feedes are in service	
		Inverter-2	1.29	33kV SSP-Trongsang	3.55		
		Inverter-3	1.63	-	-		
		Inverter-4	1.87	-	-		
		Inverter-5	1.66	-	-		
		Total	8.19	Auxiliary Consumption & Transformation Losses at Generator end	-0.24%		

Note: Generation-Load Summary (MW) for 02-Mar-26 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	1,376.12	1,366.09	10.03

Note: Generation-Load Summary (MW) for 02-Mar-25 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	851.91	812.79	39.12

09:00 hrs Statistical Comparison (MW) for this and last year



THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 03-Mar-2026(-ve:import, +ve:export)

Report Details	Date	Time	National Coincidental Peak Load (MW)		Date	Time	Load
	March 2, 2026	18:00:00			08-Nov-25	19:03:00	1,477.00
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks	
1	6 x 170MW THP	Unit-I	11.53	400kV THP - Siliguri Line - I	0.00	Unit-II on Standby. Unit-III and V under Shutdown. 400kV THP_SIL line I under Shutdown. 400kV THP_Norbugang-Siliguri line and 400kV THP_SIL line II tripped and it's under inspection.	
		Unit-II	0.00	400kV THP - Siliguri Line - II	0.00		
		Unit-III	0.00	400kV THP - Norbugang Line - IV	0.00		
		Unit-IV	14.20	400kV THP - Malbase Line - III	45.36		
		Unit-V	0.00	400kV Malbase - Siliguri Line	-269.80		
		Unit-VI	20.07	400kV Norbugang-Siliguri Line	0.00		
		Total	45.80	Auxiliary Consumption & Transformation Losses at Generator end	0.96%		
2	4 x 180MW MHP	Unit-I	20.30	400kV MHP - Jigmeling Line - I	-28.28	Unit-III under Shutdown. Unit-IV under AMP. 400kV MHP-JLG Line - III under Shutdown. 400kV MHP-JLG Line - IV on Standby.	
		Unit-II	20.17	400kV MHP - Jigmeling Line - II	-28.36		
		Unit-III	0.00	400kV MHP - Jigmeling Line - III	0.00		
		Unit-IV	0.00	400kV MHP - Jigmeling Line - IV	0.00		
		-	-	220kV Jigmeling - BitDeer Line - I	190.45		
		-	-	220kV Jigmeling - BitDeer Line - II	193.36		
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	419.27		
		-	-	400kV Jigmeling - Alipurduar Line - I	-149.82		
		-	-	400kV Jigmeling - Alipurduar Line - II	-149.82		
		-	-	80MVA, 220/132kV ICT - I (HV)	-12.74		
		-	-	80MVA, 220/132kV ICT - II (HV)	-12.53		
		-	-	132kV MHP - Yurmo Line - II	68.07		
		-	-	132kV MHP - Tintibi Line	47.92		
		-	-	132kV Gelephu - Salakati Line	-62.95		
		Total	40.47	Auxiliary Consumption & Transformation Losses at Generator end	0.07%		
3	6 x 170MW PHP-II	Unit-I	0.00	400kV PHP II - Jigmeling -I	179.52	Unit-I, II & IV under Shutdown (Annual Maintenance). Unit-III & V on Standby. 400kV PHPII - JLG-II on Standby. 400kV PHPII - ALI-II on Standby.	
		Unit-II	0.00	400kV PHP II - Jigmeling -II	0.00		
		Unit-III	0.00	400kV PHP II - Alipurduar -I	-58.17		
		Unit-IV	0.00	400kV PHP II - Alipurduar -II	0.00		
		Unit-V	0.00	-	-		
		Unit-VI	120.71	-	-		
Total	120.71	Auxiliary Consumption & Transformation Losses at Generator end	-0.53%				
4	4 x 84MW CHP	Unit-I	38.10	220kV CHP - Birpara Line - I	-99.27	Unit-II & IV under Shutdown (Annual Maintenance).	
		Unit-II	0.00	220kV CHP - Birpara Line - II	-98.51		
		Unit-III	34.78	220kV CHP - Gedu	-46.27		
		Unit-IV	0.00	220kV CHP - Jamjee - I	106.74		
		-	-	220kV CHP - Jamjee - II	103.30		
		-	-	220kV CHP - Jamjee - III	99.60		
		-	-	220kV Malbase - Birpara Line	-111.56		
-	-	66kV CHP - Gedu Line	6.61				
Total	72.88	Auxiliary Consumption & Transformation Losses at Generator end	0.93%				
5	2 x 12MW BHP (U/S)	Unit-I	0.00	220kV BHP - Sementokha Line	55.50	L/S Unit-II under AMP. U/S unit-I under AMP.	
		Unit-II	5.90	66kV BHP - Lobeyasa Line	23.29		
		Total	5.90	220kV BHP - Tsirang Line	-62.20		
6	2 x 20MW BHP (L/S)	Unit-I	11.58	5MVA, 66/11kV TFR	0.77		
		Unit-II	0.00	30MVA ICT, 220/66kV (HV)	19.05		
		Total	11.58	Auxiliary Consumption & Transformation Losses at Generator end	0.69%		
7	2 x 63MW DHP	Unit-I	0.00	220kV DHP - Tsirang Line	0.00	Total Plant Shutdown from 10:27 hrs (09.10.2025) due to Seepage in HRC . 220kV DHP-Dagapela line & 220kV DHP-Tsirang line on Standby.	
		Unit-II	0.00	220kV DHP - Dagapela Line	0.00		
		-	-	220kV BitDeer - Dagapela Line	57.39		
		-	-	5MVA, 220/33kV TFR	0.00		
Total	0.00	Auxiliary Consumption & Transformation Losses at Generator end	0.00%				
8	4 x 15MW KHP	Unit-I	12.18	132kV KHP - Nangkhor Line	9.28	Unit-III on Standby. Unit-II under Shutdown (AMP).	
		Unit-II	0.00	132kV KHP - Kihkhar Line	14.33		
		Unit-III	0.00	5MVA, 132/11kV TFR	0.56		
		Unit-IV	12.20	132kV Motanga - Rangia Line	-30.55		
		Total	24.38	Auxiliary Consumption & Transformation Losses at Generator end	0.86%		
9	2 x 59MW NHP	Unit-I	19.01	132kV NHP-MHP-I	18.91	Unit II under AMP. 132kV NHP-MHP line II on ideal charge at MHP end.	
		Unit-II	0.00	132kV NHP-MHP-II	0.00		
		Total	19.01	Auxiliary Consumption & Transformation Losses at Generator end	0.53%		
10	2 x 9MW SHP	Unit-I	0.00	66kV SHP-Damdhum (Samtse)	0.00	Unit-I on Standby. Interim measure: Evacuation is through 33kV System.	
		Unit-II	3.80	-	-		
		Total	3.80	Auxiliary Consumption & Transformation Losses at Generator end	100.00%		

Note: Generation-Load Summary (MW) for 02-Mar-2026 at 18:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	344.53	1,374.98	-1,030.45

Note: Generation-Load Summary (MW) for 02-Mar-2025, at 18:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	870.70	834.18	2.58

19:00 hrs Statistical Comparison (MW) for this and last year



Note: Daily Energy (MUs) and Power(MW) Statistics for 02-Mar-2026

Sl. No.	Total Energy Generation	Daily Energy Met	Net Energy Import (IEX and Solar)	Net Energy Export	Peak Cross-border (MW)
1	13.96	31.96	18.40	0.20	-1,025.53

- The Instantaneous load balance does not tend towards zero. This could be due to the following reasons:
 - Not all the meters are digital and nor are all the meter at all locations can be read at same time (say 9:00hrs) due to many meter to be read manually.
 - The clocks of all the locations are not synchronized.
- This report, compiled using the SCADA data, is prepared to give an overall idea of the generation & load flow for the system at a particular instant. This report also gives energy and import-export figures.
- When SCADA data are unavailable for certain stations due to technical issues, required data are collected from the site.