



འབྲུག་རྒྱལ་ཁབ་ཀྱི་རྒྱུ་རྩལ་དང་ལྷན་རྒྱུ་གཞི་སྒྲིག་ཁང་།
Ministry of Energy and Natural Resources
Royal Government of Bhutan
Bhutan Power System Operator
Thimphu: Bhutan



THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 17-May-2026(-ve:import, +ve:export)						
Report	Date	Time	National Coincidental Peak Load (MW)		Date	Time
	May 16, 2026	9:00 AM			08-Nov-25	19:03:00
						1,477.00
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks
1	6 x 170 MW THP (Tala)	Unit-I	187.43	400kV THP - Siliguri Line - I	141.75	Unit-IV under Shutdown.
		Unit-II	187.73	400kV THP - Siliguri Line - II	140.32	
		Unit-III	175.01	400kV THP - Norbugang - IV	199.52	
		Unit-IV	0.00	400kV THP - Malbase Line - III	378.75	
		Unit-V	140.00	400kV Malbase - Siliguri Line	77.39	
		Unit-VI	171.51	400kV Norbugang-Siliguri Line	38.92	
		Total	861.68	Auxiliary Consumption & Transformation Losses at Generator end	0.16%	
2	4 x 180 MW MHP (Mangdechhu)	Unit-I	155.19	400kV MHP - Jigmeling Line - I	153.73	400kV MHP-JLG line-II under Shutdown. 400kV JLG-ALI Line-I under Shutdown.
		Unit-II	79.70	400kV MHP - Jigmeling Line - II	0.00	
		Unit-III	160.58	400kV MHP - Jigmeling Line - III	158.62	
		Unit-IV	77.06	400kV MHP - Jigmeling Line - IV	159.26	
		-	-	220kV Jigmeling - BitDeer Line - I	191.01	
		-	-	220kV Jigmeling - BitDeer Line - II	176.52	
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	447.64	
		-	-	400kV Jigmeling - Alipurdhar Line - I	0.00	
		-	-	400kV Jigmeling - Alipurdhar Line - II	204.36	
		-	-	80MVA, 220/132kV ICT - I (HV)	40.80	
		-	-	80MVA, 220/132kV ICT - II (HV)	40.33	
		-	-	132kV MHP - Yurmo Line - II	33.86	
		-	-	132kV MHP - Tintibi Line	33.00	
		-	-	132kV Gelephu - Salakati Line	-33.84	
		Total	472.53	Auxiliary Consumption & Transformation Losses at Generator end	0.75%	
3	6 x 170 MW PHP-II (Punatsangchhu)	Unit-I	163.00	400kV PHP II - Jigmeling - I	93.00	Unit-V & VI under AMP.
		Unit-II	172.00	400kV PHP II - Jigmeling - II	90.00	
		Unit-III	175.17	400kV PHP II - Alipurdhar - I	255.25	
		Unit-IV	171.87	400kV PHP II - Alipurdhar - II	255.60	
		Unit-V	0.00	-	-	
		Unit-VI	0.00	-	-	
		Total	682.04	Auxiliary Consumption & Transformation Losses at Generator end	-1.73%	
4	4 x 84 MW CHP (Chukha)	Unit-I	91.44	220kV CHP - Birpara Line - I	-44.82	Unit-II & III under Shutdown (Annual Maintenance).
		Unit-II	0.00	220kV CHP - Birpara Line - II	-44.30	
		Unit-III	0.00	220kV CHP - Gedu	5.69	
		Unit-IV	91.56	220kV CHP - Jamjee - I	87.55	
		-	-	220kV CHP - Jamjee - II	86.30	
		-	-	220kV CHP - Jamjee - III	83.98	
		-	-	220kV Malbase - Birpara Line	-36.21	
		-	-	66kV CHP - Gedu Line	6.68	
		Total	183.00	Auxiliary Consumption & Transformation Losses at Generator end	1.05%	
5	2 x 12 MW BHP (U/S) (Basochhu)	Unit-I	4.10	220kV BHP - Semtokha Line	64.10	
		Unit-II	5.10	66kV BHP - Lobeysa Line	21.99	
		Total	9.20	220kV BHP - Tsirang Line	-57.00	
6	2 x 20 MW BHP (L/S) (Basochhu)	Unit-I	10.00	5MVA, 66/11kV TFR	0.41	
		Unit-II	10.10	30MVA ICT, 220/66kV (HV)	13.25	
		Total	20.10	Auxiliary Consumption & Transformation Losses at Generator end	-0.68%	
7	2 x 63 MW DHP (Dagachhu)	Unit-I	0.00	220kV DHP - Tsirang Line	0.00	220kV DHP-Tsirang line under Shutdown. DHP Unit-I on standby.
		Unit-II	30.00	220kV DHP - Dagapela Line	29.50	
		-	-	220kV BitDeer - Dagapela Line	27.60	
		-	-	5MVA, 220/33kV TFR	0.35	
		Total	30.00	Auxiliary Consumption & Transformation Losses at Generator end	0.50%	
8	4 x 15 MW KHP (Kurichhu)	Unit-I	15.98	132kV KHP - Nangkhor Line	52.56	All Units & Feeders are in Service.
		Unit-II	16.54	132kV KHP - Kilikhar Line	12.50	
		Unit-III	16.64	5MVA, 132/11kV TFR	0.28	
		Unit-IV	16.45	132kV Motanga - Rangja Line	18.90	
		Total	65.61	Auxiliary Consumption & Transformation Losses at Generator end	0.41%	
9	2 x 59 MW NHP (Nikachhu)	Unit-I	49.97	132kV NHP-MHP-I	49.65	All Units & Feeders are in Service.
		Unit-II	19.97	132kV NHP-MHP-II	19.84	
		Total	69.94	Auxiliary Consumption & Transformation Losses at Generator end	0.64%	
10	2 x 9 MW SHP (Suchhu)	Unit-I	5.00	66kV SHP-Damdhum (Samtse)	0.00	Interim measure: Evacuation is through 33kV System.
		Unit-II	5.00	-	-	
		Total	10.00	Auxiliary Consumption & Transformation Losses at Generator end	100.00%	
11	17.38 MWp SSP (Sephu Solar Plant)	Inverter-1	0.64	33kV SSP-Wangdue	2.65	All Inverters & Feeders are in Service.
		Inverter-2	1.06	33kV SSP-Trongsa	2.46	
		Inverter-3	0.98	-	-	
		Inverter-4	1.37	-	-	
		Inverter-5	1.11	-	-	
		Total	5.15	Auxiliary Consumption & Transformation Losses at Generator end	0.80%	
12	2 x 16 MW YHP (Yungichhu)	Unit-I	0.00	132kV YHP-Kilikhar	14.87	Test charge not yet done for Unit-I.
		Unit-II	16.02	5MVA, 132/33kV TFR	0.92	
		Total	16.02	Auxiliary Consumption & Transformation Losses at Generator end	1.44%	
13	2 x 27 MW BSHP (Burgangchhu Small HP)	Unit-I	0.00	132kV BSHP-Panbang	21.29	Test charge not yet done for Unit-I.
		Unit-II	27.54	132kV BSHP-Tintibi	5.95	
		Total	27.54	Auxiliary Consumption & Transformation Losses at Generator end	1.09%	


Note: Generation-Load Summary (MW) for 16-May-26 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	2,452.81	1,479.49	973.32

Note: Generation-Load Summary (MW) for 16-May-25 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	2,121.51	944.91	1,176.60

09:00 hrs Statistical Comparison
(MW) for this and last year



THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 17-May-2026(-ve:import, +ve:export)						
Report Details	Date	Time	National Coincidental Peak Load (MW)		Date	Time
	May 16, 2026	19:00:00			08-Nov-25	19:03:00
						1,477.00
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks
1	6 x 170 MW THP (Tola)	Unit-I	170.55	400kV THP - Siliguri Line - I	153.61	
		Unit-II	170.83	400kV THP - Siliguri Line - II	152.53	
		Unit-III	177.22	400kV THP - Norbugang Line - IV	216.12	
		Unit-IV	101.56	400kV THP - Malbase Line - III	417.52	
		Unit-V	160.13	400kV Malbase - Siliguri Line	82.56	
		Unit-VI	160.23	400kV Norbugang-Siliguri Line	41.75	
		Total	940.52	Auxiliary Consumption & Transformation Losses at Generator end	0.08%	
2	4 x 180 MW MHP (Mangdechhu)	Unit-I	151.83	400kV MHP - Jigmeling Line - I	150.40	400kV MHP-JLG line-II & 400kV Jigmeling_Alipurduar Line-I under Shutdown.
		Unit-II	73.11	400kV MHP - Jigmeling Line - II	0.00	
		Unit-III	155.74	400kV MHP - Jigmeling Line - III	155.22	
		Unit-IV	82.00	400kV MHP - Jigmeling Line - IV	155.76	
		-	-	220kV Jigmeling - BitDeer Line - I	189.10	
		-	-	220kV Jigmeling - BitDeer Line - II	143.05	
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	441.09	
		-	-	400kV Jigmeling - Alipurduar Line - I	0.00	
		-	-	400kV Jigmeling - Alipurduar Line - II	163.64	
		-	-	80MVA, 220/132kV ICT - I (HV)	55.13	
		-	-	80MVA, 220/132kV ICT - II (HV)	54.72	
		-	-	132kV MHP - Yurmo Line - II	24.58	
		-	-	132kV MHP - Tintibi Line	24.57	
		-	-	132kV Gelephu - Salakati Line	-43.27	
		Total	462.68	Auxiliary Consumption & Transformation Losses at Generator end	0.37%	
3	6 x 170 MW PHP-II (Punatsangchhu)	Unit-I	187.00	400kV PHP II - Jigmeling -I	74.78	Unit-II tripped at 18:09hrs. Unit -V & VI under AMP.
		Unit-II	0.00	400kV PHP II - Jigmeling -II	74.16	
		Unit-III	187.12	400kV PHP II - Alipurduar -I	204.86	
		Unit-IV	184.04	400kV PHP II - Alipurduar -II	205.10	
		Unit-V	0.00	-	-	
		Unit-VI	0.00	-	-	
		Total	558.16	Auxiliary Consumption & Transformation Losses at Generator end	-0.13%	
4	4 x 84 MW CHP (Chhukha)	Unit-I	91.40	220kV CHP - Birpara Line - I	-41.50	Unit-II & III under Shutdown (Annual Maintenance).
		Unit-II	0.00	220kV CHP - Birpara Line - II	-41.11	
		Unit-III	0.00	220kV CHP - Gedu	-14.32	
		Unit-IV	91.63	220kV CHP - Jamjee - I	91.49	
		-	-	220kV CHP - Jamjee - II	90.98	
		-	-	220kV CHP - Jamjee - III	88.47	
		-	-	220kV Malbase - Birpara Line	-13.35	
		-	-	66kV CHP - Gedu Line	6.12	
		Total	183.03	Auxiliary Consumption & Transformation Losses at Generator end	1.58%	
5	2 x 12 MW BHP (U/S) (Basochhu)	Unit-I	3.68	220kV BHP - Semtokha Line	70.11	
		Unit-II	4.90	66kV BHP - Lobeyssa Line	25.00	
		Total	8.58	220kV BHP - Tsirang Line	-67.85	
6	2 x 20 MW BHP (L/S) (Basochhu)	Unit-I	9.58	5MVA, 66/11kV TFR	0.67	
		Unit-II	9.38	30MVA ICT, 220/66kV (HV)	17.21	
		Total	18.96	Auxiliary Consumption & Transformation Losses at Generator end	-1.42%	
7	2 x 63 MW DHP (Dagachhu)	Unit-I	0.00	220kV DHP - Tsirang Line	0.00	Unit-I on Standby. 220kV DHP-Tsirang Line under Shutdown.
		Unit-II	29.00	220kV DHP - Dagapela Line	28.00	
		-	-	220kV BitDeer - Dagapela Line	56.00	
		-	-	5MVA, 220/33kV TFR	0.50	
		Total	29.00	Auxiliary Consumption & Transformation Losses at Generator end	-1.03%	
8	4 x 15 MW KHP (Kurichhu)	Unit-I	15.98	132kV KHP - Nangkor Line	39.84	All Units & Feeders are in Service.
		Unit-II	16.52	132kV KHP - Kilikhar Line	25.49	
		Unit-III	16.58	5MVA, 132/11kV TFR	0.35	
		Unit-IV	16.46	132kV Motanga - Rangla Line	14.20	
		Total	65.54	Auxiliary Consumption & Transformation Losses at Generator end	-0.21%	
9	2 x 59 MW NHP (Nikachhu)	Unit-I	25.06	132kV NHP-MHP-I	24.76	All Units & Feeders are in Service.
		Unit-II	24.95	132kV NHP-MHP-II	24.80	
		Total	50.01	Auxiliary Consumption & Transformation Losses at Generator end	0.90%	
10	2 x 9 MW SHP (Suchhu)	Unit-I	5.00	66kV SHP-Damdhum (Samtse)	0.00	Interim measure: Evacuation is through 33kV System.
		Unit-II	5.00	-	-	
		Total	10.00	Auxiliary Consumption & Transformation Losses at Generator end	100.00%	
11	2 x 16 MW YHP (Yungichhu)	Unit-I	0.00	132kV YHP-Kilikhar	-1.50	Unit-II under Shutdown. Test charge not yet done for Unit-I.
		Unit-II	0.00	5MVA, 132/33kV TFR	1.49	
		Total	0.00	Auxiliary Consumption & Transformation Losses at Generator end	0.00%	
12	2 x 27 MW BSHP (Burgangchhu Small HP)	Unit-I	0.00	132kV BSHP-Panbang	32.97	Test charge not yet done for Unit-I.
		Unit-II	27.52	132kV BSHP-Tintibi	-5.76	
		Total	27.52	Auxiliary Consumption & Transformation Losses at Generator end	1.13%	

Note: Generation-Load Summary (MW) for 16-May-2026 at 18:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	2,354.00	1,474.98	879.02


Note: Generation-Load Summary (MW) for 16-May-2025, at 19:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	2,265.81	966.11	1,299.70

Note: Daily Energy (MUS) and Power(MW) Statistics for 16-May-2026

Sl. No.	Total Energy Generation	Daily Energy Met	Net Energy Import (IEX and Solar)	Net Energy Export	Peak Cross- border (MW)
1	56.09	34.81	21.28	19.18	1,264.15

19:00 hrs Statistical Comparison
(MW) for this and last year



- The Instantaneous load balance does not tend towards zero. This could be due to the following reasons:
 - Not all the meters are digital and not all the meter at all locations can be read at same time (say 9:00hrs) due to many meter to be read manually. ii) The clocks of all the locations are not synchronized.
- This report, compiled using the SCADA data, is prepared to give an overall idea of the generation & load flow for the system at a particular instant. This report also gives energy and import/export figures.
- When SCADA data are unavailable for certain stations due to technical issues, required data are collected from the site.