



ལྷན་ཁག་གི་འཕེལ་རྒྱུ་ལྟོན་ལྷན་གྱི་འཕེལ་རྒྱུ་གཞི་རྒྱུ་
 Ministry of Energy and Natural Resources
 Royal Government of Bhutan
 Office of the Bhutan Power System Operator
 Thimphu: Bhutan



THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 26-Sep-2024(-ve:import, +ve:export)

Report Details	Date	Time	National Coincidental Peak Load (MW)	Date	Time	Load
	25-Sep-24	09:00 hrs		30-Dec-23	18:00 hrs	955.51

Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks
1	6 x 170MW THP	Unit- I	186.23	400kV THP - Siliguri Line - I	303.30	400kV THP-SIL Line IV was handtripped from India end.
		Unit- II	185.20	400kV THP - Siliguri Line - II	300.64	
		Unit- III	185.52	400kV THP - Siliguri Line - IV	0.00	
		Unit- IV	185.44	400kV THP - Malbase Line - III	513.65	
		Unit- V	185.06	400kV Malbase - Siliguri Line	237.00	
		Unit- VI	187.37	-	-	
		Total	1,114.82	Auxiliary Consumption & Transformation Losses at Generator end	-0.25%	
2	4 x 180MW MHP	Unit-I	197.22	400kV MHP - Jigmeling Line - I	0.00	MHP Unit IV Under Shutdown 400kV MHP-JLG Line I under Shutdown. 132kV MHP_Yurmoo Line-I not in Service. 400kV JLG_ALI Interim Line I on Standby.
		Unit-II	197.14	400kV MHP - Jigmeling Line - II	214.07	
		Unit-III	197.69	400kV MHP - Jigmeling Line - III	222.84	
		Unit-IV	0.00	400kV MHP - Jigmeling Line - IV	220.35	
		-	-	132kV MHP - Yurmo Line - I	0.00	
		-	-	132kV MHP - Yurmo Line - II	60.98	
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	92.00	
		-	-	400kV Jigmeling - Puna - Alipurduar Line - I	0.00	
		-	-	400kV Jigmeling - Puna - Alipurduar Line - II	140.89	
		-	-	400kV Jigmeling - Alipurduar Line - I	211.05	
		-	-	400kV Jigmeling - Alipurduar Line - II	209.86	
		-	-	80MVA, 220/132kV ICT - I (HV)	32.27	
		-	-	80MVA, 220/132kV ICT - II (HV)	31.99	
		-	-	220kV Tsirang - Jigmeling Line	24.44	
		-	-	132kV Gelephu - Salakati Line	24.50	
Total	592.05	Auxiliary Consumption & Transformation Losses at Generator end	0.18%			
3	4 x 84MW CHP	Unit- I	91.67	220kV CHP - Birpara Line - I	29.40	
		Unit- II	91.13	220kV CHP - Birpara Line - II	29.10	
		Unit- III	91.52	220kV CHP - Gedu	81.60	
		Unit- IV	91.67	220kV CHP - Jamjee (old) - I	72.91	
		-	-	220kV CHP - Jamjee - II (new)	73.74	
		-	-	220kV CHP - Jamjee - III (new)	71.13	
		-	-	220kV Malbase - Birpara Line	28.00	
		-	-	66kV CHP - Gedu Line	7.61	
		-	-	3x3MVA, 66/11kV TFR	0.77	
Total	365.99	Auxiliary Consumption & Transformation Losses at Generator end	-0.07%			
4	2 x 12MW BHP (U/S)	Unit- I	9.10	220kV BHP - Semtokha Line	87.90	
		Unit- II	10.12	66kV BHP - Lobeyasa Line	26.28	
		Total	19.22	220kV BHP - Tsirang Line	-60.64	
5	2 x 20MW BHP (L/S)	Unit- I	17.64	5MVA, 66/11kV TFR	0.41	
		Unit- II	17.00	30MVA ICT, 220/66kV (HV)	7.95	
		Total	34.64	Auxiliary Consumption & Transformation Losses at Generator end	-0.17%	
6	2 x 63MW DHP	Unit-I	44.39	220kV DHP - Tsirang Line	88.94	220kV DHP_Dagapela Line on Standby.
		Unit-II	45.05	220kV DHP - Dagapela Line	0.00	
		-	-	220kV Jigmeling - Dagapela Line	52.70	
		-	-	5MVA, 220/33kV TFR	0.30	
Total	89.44	Auxiliary Consumption & Transformation Losses at Generator end	0.22%			
7	4 x 15MW KHP	Unit- I	16.58	132kV KHP - Nangkor Line	41.37	
		Unit-II	16.60	132kV KHP - Kilikhar Line	22.19	
		Unit- III	15.53	5MVA, 132/11kV TFR	0.33	
		Unit- IV	15.90	132kV Motanga - Rangia Line	47.94	
		Total	64.61	Auxiliary Consumption & Transformation Losses at Generator end	1.11%	
8	2 x 59MW NHP	Unit-I	64.06	132kV NHP-MHP-I	63.63	
		Unit-II	64.06	132kV NHP-MHP-II	63.61	
		Total	128.12	Auxiliary Consumption & Transformation Losses at Generator end	0.69%	

Note: Generation-Load Summary (MW) for 25-Sep-24 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,624.11	672.23	675.16	927.44	-2.93
2	Eastern Grid	784.78	174.98	172.33	634.24	2.65
	Total	2,408.89	847.21	847.49	1,561.68	-0.28

Note: Generation-Load Summary for 25-Sep-23 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,668.05	634.45	620.34	1,011.38	14.11
2	Eastern Grid	747.98	199.63	196.23	570.57	3.40
	Total	2,416.03	834.08	816.57	1,581.95	17.51

THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 26-Sep-2024(-ve:import, +ve:export)							
Report Details	Date	Time	National Coincidental Peak Load (MW)		Date	Time	Load
	25-Sep-2024	19:00 hrs			30-Dec-2023	18:00 hrs	955.51
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks	
1	6 x 170MW THP	Unit-I	185.51	400kV THP - Siliguri Line - I	220.89		
		Unit-II	185.26	400kV THP - Siliguri Line - II	220.19		
		Unit-III	185.49	400kV THP - Siliguri Line - IV	212.43		
		Unit-IV	184.96	400kV THP - Malbase Line - III	458.18		
		Unit-V	185.70	400kV Malbase - Siliguri Line	153.85		
		Unit-VI	185.62	-	-		
		Total	1,112.54	Auxiliary Consumption & Transformation Losses at Generator end	0.08%		
2	4 x 180MW MHP	Unit-I	197.91	400kV MHP - Jigmeling Line - I	0.00	400kV MHP-JLG Line I under Shutdown. 132kV MHP_Yurmo Line- I not in Service. 400kV JLG_ALI Interim Line II on Standby.	
		Unit-II	197.72	400kV MHP - Jigmeling Line - II	276.96		
		Unit-III	194.23	400kV MHP - Jigmeling Line - III	286.55		
		Unit-IV	197.51	400kV MHP - Jigmeling Line - IV	284.81		
		-	-	132kV MHP - Yurmo Line - I	0.00		
		-	-	132kV MHP - Yurmo Line - II	60.98		
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	154.57		
		-	-	400kV Jigmeling - Puna - Alipurduar Line - I	170.49		
		-	-	400kV Jigmeling - Puna - Alipurduar Line - II	0.00		
		-	-	400kV Jigmeling - Alipurduar Line - I	256.00		
		-	-	400kV Jigmeling - Alipurduar Line - II	256.00		
		-	-	80MVA, 220/132kV ICT - I (HV)	44.37		
		-	-	80MVA, 220/132kV ICT - II (HV)	44.81		
		-	-	220kV Tsirang - Jigmeling Line	-12.32		
		-	-	132kV Gelephu - Salakati Line	27.34		
Total	787.37	Auxiliary Consumption & Transformation Losses at Generator end	0.66%				
3	4 x 84MW CHP	Unit-I	91.79	220kV CHP - Birpara Line - I	32.62		
		Unit-II	91.16	220kV CHP - Birpara Line - II	32.45		
		Unit-III	91.39	220kV CHP - Gedu	71.19		
		Unit-IV	91.47	220kV CHP - Jamjee (old) - I	73.59		
		-	-	220kV CHP - Jamjee - II (new)	74.26		
		-	-	220kV CHP - Jamjee - III (new)	72.01		
		-	-	220kV Malbase - Birpara Line	42.35		
		-	-	66kV CHP - Gedu Line	8.38		
		-	-	3x3MVA, 66/11kV TFR	0.89		
Total	365.81	Auxiliary Consumption & Transformation Losses at Generator end	0.11%				
4	2 x 12MW BHP (U/S)	Unit-I	8.30	220kV BHP - Sentsokha Line	102.17		
		Unit-II	8.30	66kV BHP - Lobeyasa Line	29.06		
		Total	16.60	220kV BHP - Tsirang Line	-81.69		
5	2 x 20MW BHP (L/S)	Unit-I	16.90	5MVA, 66/11kV TFR	0.64		
		Unit-II	16.80	30MVA ICT, 220/66kV (HV)	12.49		
		Total	33.70	Auxiliary Consumption & Transformation Losses at Generator end	0.24%		
6	2 x 63MW DHP	Unit-I	37.33	220kV DHP - Tsirang Line	72.84	220kV DHP_Dagapela Line on Standby.	
		Unit-II	36.00	220kV DHP - Dagapela Line	0.00		
		-	-	220kV Jigmeling - Dagapela Line	53.83		
		-	-	5MVA, 220/33kV TFR	0.48		
Total	73.33	Auxiliary Consumption & Transformation Losses at Generator end	0.01%				
7	4 x 15MW KHP	Unit-I	16.54	132kV KHP - Nangkor Line	39.04		
		Unit-II	16.51	132kV KHP - Kilikhar Line	25.33		
		Unit-III	16.18	5MVA, 132/11kV TFR	0.38		
		Unit-IV	16.44	132kV Motanga - Rangia Line	63.00		
		Total	65.67	Auxiliary Consumption & Transformation Losses at Generator end	1.40%		
8	2 x 59MW NHP	Unit-I	63.97	132kV NHP-MHP-I	63.55		
		Unit-II	63.99	132kV NHP-MHP-II	63.56		
		Total	127.96	Auxiliary Consumption & Transformation Losses at Generator end	0.66%		

Note: Generation-Load Summary (MW) for 25-Sep-2024 at 19:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,601.98	699.52	698.12	914.78	1.40
2	Eastern Grid	981.00	195.85	188.90	772.83	6.95
	Total	2,582.98	895.37	887.02	1,687.61	8.35

Note: Generation-Load Summary (MW) for 25-Sep-2023, at 19:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,657.08	666.3	656.50	975.36	9.80
2	Eastern Grid	647.63	212.41	208.88	450.64	3.53
	Total	2,304.71	878.71	865.38	1,426.00	13.33

Note: Daily Energy (MUs) and Power(MW) Statistics for 25-Sep-2024

Sl. No.	Net Energy Export (Bilateral)	Net Energy Import (Bilateral)	Daily Energy Met	Total Energy Generation	Peak Cross-border (MW)	Imp./Exp. through Exchange (MUs)
1	38.42	0.00	20.05	60.24	1,799.60	1.93

- The Instantaneous load balance, calculated as (Total generation - (Total export-Import) - Total domestic load), do not tend towards zero. This could be due to the following reasons:
 - Not all the meters are digital and nor are all the meter at all locations can be read at same time (say 9:00hrs) due to many meter to be read manually. ii) The clocks of all the locations are not synchronized.
- This report, compiled using the SCADA data, is prepared to give an overall idea of the generation & load flow for the system at a particular instant. This report also gives energy and import/export figures.
- When SCADA data are unavailable for certain stations due to technical issues, required data are collected from the site.