



ལྷན་ཁག་གི་འཕེལ་རྒྱུ་ལྟོན་ལྷན་གྱི་འཕེལ་རྒྱུ་གཞི་རྒྱུ་
 Ministry of Energy and Natural Resources
 Royal Government of Bhutan
 Office of the Bhutan Power System Operator
 Thimphu: Bhutan



THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 28-Sep-2024(-ve:import, +ve:export)

Report Details	Date	Time	National Coincidental Peak Load (MW)	Date	Time	Load
	27-Sep-24	09:00 hrs		30-Dec-23	18:00 hrs	955.51

Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks
1	6 x 170MW THP	Unit- I	185.69	400kV THP - Siliguri Line - I	231.13	
		Unit- II	185.13	400kV THP - Siliguri Line - II	229.35	
		Unit- III	185.46	400kV THP - Siliguri Line - IV	221.10	
		Unit- IV	185.11	400kV THP - Malbase Line - III	431.03	
		Unit- V	185.51	400kV Malbase - Siliguri Line	180.90	
		Unit- VI	184.92	-	-	
		Total	1,111.82	Auxiliary Consumption & Transformation Losses at Generator end	-0.07%	
2	4 x 180MW MHP	Unit-I	197.91	400kV MHP - Jigmeling Line - I	0.00	400kV MHP-JLG Line I under Shutdown. 132kV MHP_Yurmoo Line-I not in Service. 400kV JLG_ALI Interim Line II on Standby.
		Unit-II	197.95	400kV MHP - Jigmeling Line - II	277.85	
		Unit-III	194.56	400kV MHP - Jigmeling Line - III	287.72	
		Unit-IV	198.32	400kV MHP - Jigmeling Line - IV	285.88	
		-	-	132kV MHP - Yurmo Line - I	0.00	
		-	-	132kV MHP - Yurmo Line - II	61.26	
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	76.36	
		-	-	400kV Jigmeling - Puna - Alipurduar Line - I	192.00	
		-	-	400kV Jigmeling - Puna - Alipurduar Line - II	0.00	
		-	-	400kV Jigmeling - Alipurduar Line - I	285.82	
		-	-	400kV Jigmeling - Alipurduar Line - II	287.27	
		-	-	80MVA, 220/132kV ICT - I (HV)	29.98	
		-	-	80MVA, 220/132kV ICT - II (HV)	29.79	
		-	-	220kV Tsirang - Jigmeling Line	36.04	
		-	-	132kV Gelephu - Salakati Line	30.37	
Total	788.74	Auxiliary Consumption & Transformation Losses at Generator end	0.40%			
3	4 x 84MW CHP	Unit- I	91.32	220kV CHP - Birpara Line - I	33.35	
		Unit- II	91.56	220kV CHP - Birpara Line - II	33.08	
		Unit- III	91.52	220kV CHP - Gedu	104.94	
		Unit- IV	91.32	220kV CHP - Jamjee (old) - I	61.71	
		-	-	220kV CHP - Jamjee - II (new)	62.55	
		-	-	220kV CHP - Jamjee - III (new)	60.06	
		-	-	220kV Malbase - Birpara Line	16.09	
		-	-	66kV CHP - Gedu Line	8.95	
		-	-	3x3MVA, 66/11kV TFR	0.85	
Total	365.72	Auxiliary Consumption & Transformation Losses at Generator end	0.06%			
4	2 x 12MW BHP (U/S)	Unit- I	11.98	220kV BHP - Semtokha Line	122.73	
		Unit- II	12.22	66kV BHP - Lobeyasa Line	27.18	
		Total	24.20	220kV BHP - Tsirang Line	-84.30	
5	2 x 20MW BHP (L/S)	Unit- I	21.04	5MVA, 66/11kV TFR	0.30	
		Unit- II	20.11	30MVA ICT, 220/66kV (HV)	3.90	
		Total	41.15	Auxiliary Consumption & Transformation Losses at Generator end	-0.86%	
6	2 x 63MW DHP	Unit-I	63.61	220kV DHP - Tsirang Line	126.15	220kV DHP_Dagapela Line on Standby.
		Unit-II	63.11	220kV DHP - Dagapela Line	0.00	
		-	-	220kV Jigmeling - Dagapela Line	52.84	
		-	-	5MVA, 220/33kV TFR	0.19	
Total	126.72	Auxiliary Consumption & Transformation Losses at Generator end	0.30%			
7	4 x 15MW KHP	Unit- I	16.56	132kV KHP - Nangkor Line	42.65	
		Unit-II	16.54	132kV KHP - Kilikhar Line	22.49	
		Unit- III	16.66	5MVA, 132/11kV TFR	0.26	
		Unit- IV	16.58	132kV Motanga - Rangia Line	39.06	
		Total	66.34	Auxiliary Consumption & Transformation Losses at Generator end	1.42%	
8	2 x 59MW NHP	Unit-I	64.02	132kV NHP-MHP-I	63.51	
		Unit-II	64.07	132kV NHP-MHP-II	63.64	
		Total	128.09	Auxiliary Consumption & Transformation Losses at Generator end	0.73%	

Note: Generation-Load Summary (MW) for 27-Sep-24 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,669.61	688.57	689.31	945.00	-0.74
2	Eastern Grid	983.17	184.69	179.63	834.52	5.06
	Total	2,652.78	873.26	868.94	1,779.52	4.32

Note: Generation-Load Summary for 27-Sep-23 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,415.12	664.58	648.33	760.66	16.25
2	Eastern Grid	606.75	171.70	169.30	424.93	2.40
	Total	2,021.87	836.28	817.63	1,185.59	18.65

THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 28-Sep-2024(-ve:import, +ve:export)							
Report Details	Date	Time	National Coincidental Peak Load (MW)		Date	Time	Load
	27-Sep-2024	19:00 hrs			30-Dec-2023	18:00 hrs	955.51
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks	
1	6 x 170MW THP	Unit-I	185.06	400kV THP - Siliguri Line - I	231.02		
		Unit-II	185.28	400kV THP - Siliguri Line - II	229.35		
		Unit-III	185.02	400kV THP - Siliguri Line - IV	221.76		
		Unit-IV	185.16	400kV THP - Malbase Line - III	433.49		
		Unit-V	185.88	400kV Malbase - Siliguri Line	173.09		
		Unit-VI	185.30	-	-		
		Total	1,111.70	Auxiliary Consumption & Transformation Losses at Generator end	-0.35%		
2	4 x 180MW MHP	Unit-I	197.93	400kV MHP - Jigmeling Line - I	0.00	400kV MHP-JLG Line I under Shutdown. 132kV MHP_Yurmo Line- I not in Service. 400kV JLG_ALI Interim Line II on Standby.	
		Unit-II	197.70	400kV MHP - Jigmeling Line - II	277.57		
		Unit-III	194.16	400kV MHP - Jigmeling Line - III	287.30		
		Unit-IV	197.96	400kV MHP - Jigmeling Line - IV	285.68		
		-	-	132kV MHP - Yurmo Line - I	0.00		
		-	-	132kV MHP - Yurmo Line - II	60.98		
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	101.31		
		-	-	400kV Jigmeling - Puna - Alipurduar Line - I	185.46		
		-	-	400kV Jigmeling - Puna - Alipurduar Line - II	0.00		
		-	-	400kV Jigmeling - Alipurduar Line - I	274.91		
		-	-	400kV Jigmeling - Alipurduar Line - II	275.64		
		-	-	80MVA, 220/132kV ICT - I (HV)	39.16		
		-	-	80MVA, 220/132kV ICT - II (HV)	38.84		
		-	-	220kV Tsirang - Jigmeling Line	28.46		
		-	-	132kV Gelephu - Salakati Line	28.30		
Total	787.75	Auxiliary Consumption & Transformation Losses at Generator end	0.41%				
3	4 x 84MW CHP	Unit-I	91.12	220kV CHP - Birpara Line - I	35.44		
		Unit-II	91.40	220kV CHP - Birpara Line - II	34.86		
		Unit-III	91.60	220kV CHP - Gedu	87.23		
		Unit-IV	91.44	220kV CHP - Jamjee (old) - I	66.81		
		-	-	220kV CHP - Jamjee - II (new)	67.83		
		-	-	220kV CHP - Jamjee - III (new)	65.41		
		-	-	220kV Malbase - Birpara Line	35.52		
		-	-	66kV CHP - Gedu Line	7.40		
-	-	3x3MVA, 66/11kV TFR	0.89				
Total	365.56	Auxiliary Consumption & Transformation Losses at Generator end	-0.08%				
4	2 x 12MW BHP (U/S)	Unit-I	12.00	220kV BHP - Sentokha Line	126.73		
		Unit-II	12.00	66kV BHP - Lobeyasa Line	31.63		
		Total	24.00	220kV BHP - Tsirang Line	-93.10		
5	2 x 20MW BHP (L/S)	Unit-I	20.60	5MVA, 66/11kV TFR	0.52		
		Unit-II	21.00	30MVA ICT, 220/66kV (HV)	8.64		
		Total	41.60	Auxiliary Consumption & Transformation Losses at Generator end	-0.27%		
6	2 x 63MW DHP	Unit-I	63.66	220kV DHP - Tsirang Line	126.18	220kV DHP_Dagapela Line on Standby.	
		Unit-II	63.12	220kV DHP - Dagapela Line	0.00		
		-	-	220kV Jigmeling - Dagapela Line	53.37		
		-	-	5MVA, 220/33kV TFR	0.59		
Total	126.78	Auxiliary Consumption & Transformation Losses at Generator end	0.01%				
7	4 x 15MW KHP	Unit-I	16.45	132kV KHP - Nangkor Line	41.06		
		Unit-II	16.50	132kV KHP - Kilikhar Line	24.31		
		Unit-III	16.58	5MVA, 132/11kV TFR	0.36		
		Unit-IV	16.64	132kV Motanga - Rangia Line	60.00		
Total	66.17	Auxiliary Consumption & Transformation Losses at Generator end	0.66%				
8	2 x 59MW NHP	Unit-I	63.97	132kV NHP-MHP-I	63.50		
		Unit-II	63.95	132kV NHP-MHP-II	63.51		
		Total	127.92	Auxiliary Consumption & Transformation Losses at Generator end	0.71%		

Note: Generation-Load Summary (MW) for 27-Sep-2024 at 19:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,669.64	680.14	684.54	961.04	-4.40
2	Eastern Grid	981.84	185.99	181.41	824.31	4.58
	Total	2,651.48	866.13	865.95	1,785.35	0.18

Note: Generation-Load Summary (MW) for 27-Sep-2023, at 19:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,381.63	673.13	662.50	714.89	10.63
2	Eastern Grid	577.82	209.63	207.95	361.8	1.68
	Total	1,959.45	882.76	870.45	1,076.69	12.31

Note: Daily Energy (MUs) and Power(MW) Statistics for 27-Sep-2024

Sl. No.	Net Energy Export (Bilateral)	Net Energy Import (Bilateral)	Daily Energy Met	Total Energy Generation	Peak Cross-border (MW)	Imp./Exp. through Exchange (MUs)
1	40.87	0.00	19.38	63.28	1,860.71	2.30

- The Instantaneous load balance, calculated as (Total generation - (Total export-Import) - Total domestic load), do not tend towards zero. This could be due to the following reasons:
 - Not all the meters are digital and nor are all the meter at all locations can be read at same time (say 9:00hrs) due to many meter to be read manually. ii) The clocks of all the locations are not synchronized.
- This report, compiled using the SCADA data, is prepared to give an overall idea of the generation & load flow for the system at a particular instant. This report also gives energy and import/export figures.
- When SCADA data are unavailable for certain stations due to technical issues, required data are collected from the site.