



ལྷན་ཁག་དང་ལས་ཁུངས་ཀྱི་འཛིན་སྐྱོང་གི་དཔལ་ལྷན་གྱི་འཛིན་སྐྱོང་།
Ministry of Energy and Natural Resources
Royal Government of Bhutan
Bhutan Power System Operator
Thimphu: Bhutan



THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 28-Jun-2026(-ve:import, +ve:export)						
Report Details	Date	Time	National Coincidental Peak Load (MW)		Date	Time
	June 27, 2026	9:00 AM			08-Nov-25	19:03:00
						1,477.00
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks
1	6 x 170 MW THP (Tala)	Unit-I	100.69	400kV THP - Siliguri Line - I	77.66	Unit-VI under Shutdown.
		Unit-II	100.98	400kV THP - Siliguri Line - II	76.31	
		Unit-III	103.52	400kV THP - Norbugang - IV	146.31	
		Unit-IV	140.41	400kV THP - Malbase Line - III	280.27	
		Unit-V	140.13	400kV Malbase - Siliguri Line	26.66	
		Unit-VI	0.00	400kV Norbugang-Siliguri Line	-9.45	
		Total	585.73	Auxiliary Consumption & Transformation Losses at Generator end	0.92%	
2	4 x 180 MW MHP (Mangdechhu)	Unit-I	0.00	400kV MHP - Jigmeling Line - I	190.01	Unit-I on E-Spin (in process of synchronising). 400kV MHP-JLG line- II under Shutdown.
		Unit-II	197.00	400kV MHP - Jigmeling Line - II	0.00	
		Unit-III	189.39	400kV MHP - Jigmeling Line - III	196.80	
		Unit-IV	198.29	400kV MHP - Jigmeling Line - IV	196.66	
		-	-	220kV Jigmeling - BitDeer Line - I	181.99	
		-	-	220kV Jigmeling - BitDeer Line - II	163.36	
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	350.18	
		-	-	400kV Jigmeling - Alipurduar Line - I	215.27	
		-	-	400kV Jigmeling - Alipurduar Line - II	213.82	
		-	-	80MVA, 220/132kV ICT - I (HV)	3.47	
		-	-	80MVA, 220/132kV ICT - II (HV)	3.40	
		-	-	132kV MHP - Yurmo Line - II	52.03	
		-	-	132kV MHP - Tintibi Line	12.19	
		-	-	132kV Gelephu - Salakati Line	10.00	
		Total	584.68	Auxiliary Consumption & Transformation Losses at Generator end	0.24%	
3	6 x 170 MW PHP-II (Punatsangchhu)	Unit-I	187.00	400kV PHP II - Jigmeling-I	102.91	Unit-II under Shutdown. Unit-V on Standby.
		Unit-II	0.00	400kV PHP II - Jigmeling-II	102.29	
		Unit-III	185.81	400kV PHP II - Alipurduar-I	271.26	
		Unit-IV	185.76	400kV PHP II - Alipurduar-II	271.20	
		Unit-V	0.00	-	-	
		Unit-VI	184.92	-	-	
		Total	743.49	Auxiliary Consumption & Transformation Losses at Generator end	-0.56%	
4	4 x 84 MW CHP (Chukha)	Unit-I	90.95	220kV CHP - Birpara Line - I	-11.95	All Units & Feeders are in Service.
		Unit-II	91.08	220kV CHP - Birpara Line - II	-11.96	
		Unit-III	91.33	220kV CHP - Gedu	74.56	
		Unit-IV	9.37	220kV CHP - Jamjee - I	75.30	
		-	-	220kV CHP - Jamjee - II	73.50	
		-	-	220kV CHP - Jamjee - III	71.88	
		-	-	220kV Malbase - Birpara Line	-34.82	
		-	-	66kV CHP - Gedu Line	8.79	
		Total	282.73	Auxiliary Consumption & Transformation Losses at Generator end	0.92%	
5	2 x 12 MW BHP (U/S) (Basochhu)	Unit-I	6.50	220kV BHP - Semtokha Line	68.62	All Units and Feeders are in Service.
		Unit-II	6.27	66kV BHP - Lobeysa Line	22.28	
		Total	12.77	220kV BHP - Tsirang Line	-53.50	
6	2 x 20 MW BHP (L/S) (Basochhu)	Unit-I	12.76	5MVA, 66/11kV TFR	0.45	All Units and Feeders are in Service.
		Unit-II	12.28	30MVA ICT, 220/66kV (HV)	9.46	
		Total	25.04	Auxiliary Consumption & Transformation Losses at Generator end	-0.11%	
7	2 x 63 MW DHP (Dagachhu)	Unit-I	0.00	220kV DHP - Tsirang Line	0.00	220kV DHP-Tsirang line & Unit-I under Shutdown.
		Unit-II	34.98	220kV DHP - Dagapela Line	34.50	
		-	-	220kV BitDeer - Dagapela Line	10.66	
		-	-	5MVA, 220/33kV TFR	0.20	
		Total	34.98	Auxiliary Consumption & Transformation Losses at Generator end	0.80%	
8	4 x 15 MW KHP (Kurichhu)	Unit-I	16.51	132kV KHP - Nangkor Line	42.12	All Units and Feeders are in Service.
		Unit-II	16.51	132kV KHP - Kilikhar Line	23.25	
		Unit-III	16.54	5MVA, 132/11kV TFR	0.33	
		Unit-IV	16.54	132kV Motanga - Rangja Line	49.93	
		Total	66.10	Auxiliary Consumption & Transformation Losses at Generator end	0.61%	
9	2 x 59 MW NHP (Nikachhu)	Unit-I	64.90	132kV NHP-MHP-I	64.39	Unit-II and 132kV NHP_MHP line-II tripped at 08:27hrs
		Unit-II	0.00	132kV NHP-MHP-II	0.00	
		Total	64.90	Auxiliary Consumption & Transformation Losses at Generator end	0.79%	
10	2 x 9 MW SHP (Suchhu)	Unit-I	5.02	66kV SHP-Damdhum (Samtse)	0.00	Interim measure: Evacuation is through 33kV System.
		Unit-II	5.07	-	-	
		Total	10.09	Auxiliary Consumption & Transformation Losses at Generator end	100.00%	
11	22.38 MWp SSP (Sephu Solar Plant)	Inverter-1	0.48	33kV SSP-Wangdue	2.07	All Inverters & Feeders are in Service.
		Inverter-2	0.82	33kV SSP-Trongsa	1.92	
		Inverter-3	0.78	-	-	
		Inverter-4	1.04	-	-	
		Inverter-5	0.89	-	-	
		Total	4.01	Auxiliary Consumption & Transformation Losses at Generator end	0.40%	
12	2 x 16 MW YHP (Yungichhu)	Unit-I	0.00	132kV YHP-Kilikhar	14.84	Unit-I under Shutdown.
		Unit-II	16.02	5MVA, 132/33kV TFR	0.95	
		Total	16.02	Auxiliary Consumption & Transformation Losses at Generator end	1.44%	
13	2 x 27 MW BSHP (Burgangchhu Small HP)	Unit-I	23.36	132kV BSHP-Panbang	22.80	Unit-II under Shutdown.
		Unit-II	0.00	132kV BSHP-Tintibi	0.47	
		Total	23.36	Auxiliary Consumption & Transformation Losses at Generator end	0.39%	


Note: Generation-Load Summary (MW) for 27-Jun-26 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	2,453.90	1,310.16	1,143.73

Note: Generation-Load Summary (MW) for 27-Jun-25 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	3,143.13	937.34	2,205.79

09:00 hrs Statistical Comparison (MW) for this and last year



THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 28-Jun-2026(-ve:import,+ve:export)						
Report Details	Date	Time	National Coincidental Peak Load (MW)		Date	Time
	June 27, 2026	19:00:00			08-Nov-25	19:03:00
						1,477.08
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks
1	6 x 170 MW THP (Tala)	Unit-I	108.69	400kV THP - Siliguri Line - I	66.65	Unit VI on Standby.
		Unit-II	138.42	400kV THP - Siliguri Line - II	65.38	
		Unit-III	144.07	400kV THP - Norbugang Line - IV	151.63	
		Unit-IV	148.41	400kV THP - Malbase Line - III	306.68	
		Unit-V	88.18	400kV Malbase - Siliguri Line	8.10	
		Unit-VI	0.00	400kV Norbugang-Siliguri Line	-15.82	
		Total	595.77	Auxiliary Consumption & Transformation Losses at Generator end	0.91%	
2	4 x 180 MW MHP (Mangdechhu)	Unit-I	78.28	400kV MHP - Jigmeling Line - I	156.58	400kV MHP-JLG line- II under Shutdown.
		Unit-II	52.22	400kV MHP - Jigmeling Line - II	0.00	
		Unit-III	162.04	400kV MHP - Jigmeling Line - III	162.15	
		Unit-IV	196.75	400kV MHP - Jigmeling Line - IV	162.11	
		-	-	220kV Jigmeling - BitDeer Line - I	165.50	
		-	-	220kV Jigmeling - BitDeer Line - II	151.51	
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	430.91	
		-	-	400kV Jigmeling - Alipurdwar Line - I	148.36	
		-	-	400kV Jigmeling - Alipurdwar Line - II	147.64	
		-	-	80MVA, 220/132kV ICT - I (HV)	57.54	
		-	-	80MVA, 220/132kV ICT - II (HV)	57.10	
		-	-	132kV MHP - Yurmo Line - II	56.88	
		-	-	132kV MHP - Tintibi Line	1.44	
		-	-	132kV Gelephu - Salakati Line	-24.16	
		Total	481.21	Auxiliary Consumption & Transformation Losses at Generator end	0.31%	
3	6 x 170 MW PHP-II (Punatsangchhu)	Unit-I	135.00	400kV PHP II - Jigmeling -I	126.80	Unit-II under Shutdown.
		Unit-II	0.00	400kV PHP II - Jigmeling -II	126.34	
		Unit-III	127.88	400kV PHP II - Alipurdwar -I	215.21	
		Unit-IV	129.16	400kV PHP II - Alipurdwar -II	215.61	
		Unit-V	158.75	-	-	
		Unit-VI	129.63	-	-	
		Total	680.42	Auxiliary Consumption & Transformation Losses at Generator end	-0.52%	
4	4 x 84 MW CHP (Chhukha)	Unit-I	59.83	220kV CHP - Birpara Line - I	-17.95	All Units & Feeders are in Service..
		Unit-II	57.66	220kV CHP - Birpara Line - II	-17.80	
		Unit-III	91.25	220kV CHP - Gedu	36.04	
		Unit-IV	59.72	220kV CHP - Jamjee - I	88.23	
		-	-	220kV CHP - Jamjee - II	87.18	
		-	-	220kV CHP - Jamjee - III	84.08	
		-	-	220kV Malbase - Birpara Line	-14.46	
		-	-	66kV CHP - Gedu Line	7.60	
		Total	268.46	Auxiliary Consumption & Transformation Losses at Generator end	0.40%	
5	2 x 12 MW BHP (U/S) (Basochhu)	Unit-I	5.84	220kV BHP - Sertokha Line	49.68	All Units and Feeders are in Service.
		Unit-II	7.00	66kV BHP - Lobeysa Line	23.17	
		Total	12.84	220kV BHP - Tsirang Line	-35.53	
6	2 x 20 MW BHP (L/S) (Basochhu)	Unit-I	12.67	5MVA, 66/11kV TFR	0.56	
		Unit-II	12.39	30MVA ICT, 220/66kV (HV)	11.08	
		Total	25.06	Auxiliary Consumption & Transformation Losses at Generator end	0.05%	
7	2 x 63 MW DHP (Dagachhu)	Unit-I	0.00	220kV DHP - Tsirang Line	0.00	Unit-I under shutdown. 220kV DHP-Tsirang line on Standby.
		Unit-II	34.02	220kV DHP - Dagapela Line	33.94	
		-	-	220kV BitDeer - Dagapela Line	11.50	
		-	-	5MVA, 220/33kV TFR	0.30	
		Total	34.02	Auxiliary Consumption & Transformation Losses at Generator end	-0.65%	
8	4 x 15 MW KHP (Kurichhu)	Unit-I	16.54	132kV KHP - Nangkor Line	50.17	All Units & Feeders are in Service.
		Unit-II	16.47	132kV KHP - Kilikhar Line	15.02	
		Unit-III	16.59	5MVA, 132/11kV TFR	0.37	
		Unit-IV	16.51	132kV Motanga - Rangla Line	54.40	
		Total	66.11	Auxiliary Consumption & Transformation Losses at Generator end	0.83%	
9	2 x 59 MW NHP (Nikachhu)	Unit-I	20.00	132kV NHP-MHP-I	19.80	All Units & Feeders are in Service.
		Unit-II	40.18	132kV NHP-MHP-II	39.66	
		Total	60.18	Auxiliary Consumption & Transformation Losses at Generator end	1.20%	
10	2 x 9 MW SHP (Suchhu)	Unit-I	5.02	66kV SHP-Damdhum (Samtse)	0.00	Interim measure: Evacuation is through 33kV System.
		Unit-II	5.05	-	-	
		Total	10.07	Auxiliary Consumption & Transformation Losses at Generator end	100.00%	
11	2 x 16 MW YHP (Yungichhu)	Unit-I	0.00	132kV YHP-Kilikhar	14.36	Unit-I under Shutdown.
		Unit-II	16.01	5MVA, 132/33kV TFR	1.41	
		Total	16.01	Auxiliary Consumption & Transformation Losses at Generator end	1.50%	
12	2 x 27 MW BSHP (Burgangchhu Small HP)	Unit-I	26.14	132kV BSHP-Panbang	31.05	All Units & Feeders are in Service.
		Unit-II	12.11	132kV BSHP-Tintibi	6.82	
		Total	38.25	Auxiliary Consumption & Transformation Losses at Generator end	0.99%	

Note: Generation-Load Summary (MW) for 27-Jun-2026 at 18:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	2,288.40	1,457.24	831.16

Note: Generation-Load Summary (MW) for 27-Jun-2025, at 19:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	3,048.90	961.83	2,087.07

Note: Daily Energy (MUS) and Power(MW) Statistics for 27-Jun-2026

Sl. No.	Total Energy Generation	Daily Energy Met	Net Energy Import (IEX and Solar)	Net Energy Export	Peak Cross- border (MW)
1	53.80	32.25	0.00	2.36	1,259.76

1. The instantaneous load balance does not tend towards zero. This could be due to the following reasons:

- i) Not all the meters are digital and not all the meter at all locations can be read at same time (say 9:00hrs) due to many meter to be read manually. ii) The clocks of all the locations are not synchronized.
2. This report, compiled using the SCADA data, is prepared to give an overall idea of the generation & load flow for the system at a particular instant. This report also gives energy and import/export figures.
3. When SCADA data are unavailable for certain stations due to technical issues, required data are collected from the site.

