



Metric	2025 (MW)	2026 (MW)
Tt Exp./min	2,448.87	2,473.36
Tt Load	959.72	2,271.31
Tt Gen.	3,363.94	3,745.70

THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 24-Jul-2026(+ve:import, +ve:export)						
Report Details	Date	Time	National Coincidental Peak Load (MW)		Date	Time
	July 23, 2026	19:00:00			10-Jul-26	8:02:13
						1,584.59
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks
1	6 x 170 MW THP (Tala)	Unit-I	185.08	400kV THP - Siliguri Line - I	201.54	All Units & Feeders are in Service.
		Unit-II	185.66	400kV THP - Siliguri Line - II	200.55	
		Unit-III	185.15	400kV THP - Norbugang Line - IV	241.74	
		Unit-IV	185.17	400kV THP - Malbase Line - III	469.79	
		Unit-V	186.90	400kV Malbase - Siliguri Line	127.22	
		Unit-VI	185.15	400kV Norbugang-Siliguri Line	78.87	
		Total	1,113.11	Auxiliary Consumption & Transformation Losses at Generator end	-0.05%	
2	4 x 180 MW MHP (Mangdechhu)	Unit-I	197.94	400kV MHP - Jigmeling Line - I	263.94	500MVA, 400/220 kV ICTat Jigmeling (HV), 220kV Jigmeling - BitDeer Line - I, 220kV Jigmeling - BitDeer Line - II, 80MVA, 220/132kV ICT-I (HV) & 80MVA, 220/132kV ICT-II (HV) under shutdown. 400kV MHP-JLG Line -III on Standby
		Unit-II	197.84	400kV MHP - Jigmeling Line - II	263.32	
		Unit-III	192.39	400kV MHP - Jigmeling Line - III	0.00	
		Unit-IV	198.38	400kV MHP - Jigmeling Line - IV	256.99	
		-	-	220kV Jigmeling - BitDeer Line - I	0.00	
		-	-	220kV Jigmeling - BitDeer Line - II	0.00	
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	0.00	
		-	-	400kV Jigmeling - Aliparduar Line - I	440.73	
		-	-	400kV Jigmeling - Aliparduar Line - II	440.73	
		-	-	80MVA, 220/132kV ICT - I (HV)	0.00	
		-	-	80MVA, 220/132kV ICT - II (HV)	0.00	
		-	-	132kV MHP - Yurmo Line - II	57.96	
		-	-	132kV MHP - Tintibi Line	68.96	
		-	-	132kV Gelephu - Salakati Line	-58.07	
		Total	786.55	Auxiliary Consumption & Transformation Losses at Generator end	0.54%	
3	6 x 170 MW PHP-II (Punatsangchhu)	Unit-I	179.64	400kV PHP II - Jigmeling -I	53.08	All Units & Feeders are in Service.
		Unit-II	172.29	400kV PHP II - Jigmeling -II	52.21	
		Unit-III	177.90	400kV PHP II - Aliparduar -I	476.74	
		Unit-IV	176.05	400kV PHP II - Aliparduar -II	475.83	
		Unit-V	173.82	-	-	
		Unit-VI	178.58	-	-	
		Total	1,058.28	Auxiliary Consumption & Transformation Losses at Generator end	0.04%	
4	4 x 84 MW CHP (Chhukha)	Unit-I	91.47	220kV CHP - Birpara Line - I	-34.62	All Units & Feeders are in Service.
		Unit-II	91.21	220kV CHP - Birpara Line - II	-34.41	
		Unit-III	87.79	220kV CHP - Gedu	-3.35	
		Unit-IV	91.62	220kV CHP - Jamjee - I	146.38	
		-	-	220kV CHP - Jamjee - II	145.04	
		-	-	220kV CHP - Jamjee - III	140.00	
		-	-	220kV Malbase - Birpara Line	-13.25	
		-	-	66kV CHP - Gedu Line	3.24	
		Total	362.09	Auxiliary Consumption & Transformation Losses at Generator end	-0.05%	
5	2 x 12 MW BHP (U/S) (Basochhu)	Unit-I	12.06	220kV BHP - Sertokha Line	-114.96	All Units and Feeders are in Service.
		Unit-II	12.00	66kV BHP - Lobeyssa Line	21.10	
		Total	24.06	220kV BHP - Tsirang Line	156.60	
6	2 x 20 MW BHP (L/S) (Basochhu)	Unit-I	28.49	5MVA, 66/11kV TFR	0.61	
		Unit-II	28.75	30MVA ICT, 220/66kV (HV)	-2.01	
		Total	41.24	Auxiliary Consumption & Transformation Losses at Generator end	2.99%	
7	2 x 63 MW DHP (Dagachhu)	Unit-I	59.70	220kV DHP - Tsirang Line	0.00	220kV DHP-Tsirang line on Standby.
		Unit-II	50.59	220kV DHP - Dagapela Line	112.56	
		-	-	220kV BitDeer - Dagapela Line	-61.42	
		-	-	5MVA, 220/33kV TFR	0.30	
		Total	110.29	Auxiliary Consumption & Transformation Losses at Generator end	-2.33%	
8	4 x 15 MW KHP (Kurichhu)	Unit-I	16.51	132kV KHP - Nangkor Line	50.45	All Units & Feeders are in Service.
		Unit-II	16.54	132kV KHP - Kilikhar Line	14.01	
		Unit-III	16.61	5MVA, 132/11kV TFR	1.14	
		Unit-IV	16.51	132kV Motanga - Rangla Line	31.80	
		Total	66.17	Auxiliary Consumption & Transformation Losses at Generator end	0.86%	
9	2 x 59 MW NHP (Nikachhu)	Unit-I	64.92	132kV NHP-MHP-I	64.48	All Units & Feeders are in Service.
		Unit-II	64.87	132kV NHP-MHP-II	64.41	
		Total	129.79	Auxiliary Consumption & Transformation Losses at Generator end	0.69%	
10	2 x 9 MW SHP (Suchhu)	Unit-I	0.00	66kV SHP-Damdhum (Samtse)	-0.03	Both units under Shutdown since 18:30 hrs (15.07.26) due to heavy tunnel leakage (penstock issue).
		Unit-II	0.00	-	-	
		Total	0.00	Auxiliary Consumption & Transformation Losses at Generator end	0.00%	
11	2 x 16 MW YHP (Yungichhu)	Unit-I	0.00	132kV YHP-Kilikhar	14.35	Unit-I under Shutdown.
		Unit-II	16.06	5MVA, 132/33kV TFR	1.47	
		Total	16.06	Auxiliary Consumption & Transformation Losses at Generator end	1.49%	
12	2 x 27 MW BSHP (Burgangchhu Small HP)	Unit-I	0.00	132kV BSHP-Panbang	29.62	Unit-I under Shutdown.
		Unit-II	27.31	132kV BSHP-Tintibi	-2.67	
		Total	27.31	Auxiliary Consumption & Transformation Losses at Generator end	1.32%	

Note: Generation-Load Summary (MW) for 23-Jul-2026 at 18:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	3,734.95	1,401.29	2,333.66


Note: Generation-Load Summary (MW) for 23-Jul-2025, at 19:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	3,349.49	1,001.07	2,348.42

Note: Daily Energy (MUS) and Power(MW) Statistics for 23-Jul-2026

Sl. No.	Total Energy Generation	Daily Energy Met	Net Energy Import (IEX and Solar)	Net Energy Export	Peak Cross- border (MW)
1	89.54	34.32	0.00	55.22	2,491.42

19:00 hrs Statistical Comparison
(MW) for this and last year



1. The instantaneous load balance does not tend towards zero. This could be due to the following reasons:

- i) Not all the meters are digital and not all the meter at all locations can be read at same time (say 9:00hrs) due to many meter to be read manually. ii) The clocks of all the locations are not synchronized.
2. This report, compiled using the SCADA data, is prepared to give an overall idea of the generation & load flow for the system at a particular instant. This report also gives energy and import/export figures.
3. When SCADA data are unavailable for certain stations due to technical issues, required data are collected from the site.