



ལྷན་ཁག་གི་འཕེལ་རྒྱུ་ལྟོན་ལྷན་གྱི་འཕེལ་རྒྱུ་གཞི་རྒྱུ་
 Ministry of Energy and Natural Resources
 Royal Government of Bhutan
 Office of the Bhutan Power System Operator
 Thimphu: Bhutan



THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 05-Oct-2024(-ve:import, +ve:export)

Report Details	Date	Time	National Coincidental Peak Load (MW)	Date	Time	Load
	04-Oct-24	09:00 hrs		30-Dec-23	18:00 hrs	955.51

Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks
1	6 x 170MW THP	Unit- I	185.19	400kV THP - Siliguri Line - I	237.22	
		Unit- II	185.74	400kV THP - Siliguri Line - II	236.51	
		Unit- III	185.38	400kV THP - Siliguri Line - IV	228.09	
		Unit- IV	186.26	400kV THP - Malbase Line - III	411.82	
		Unit- V	184.93	400kV Malbase - Siliguri Line	183.96	
		Unit- VI	186.13	-	-	
		Total	1,113.63	Auxiliary Consumption & Transformation Losses at Generator end	0.00%	
2	4 x 180MW MHP	Unit-I	197.73	400kV MHP - Jigmeling Line - I	0.00	400kV MHP-JLG Line I on Standby. 132kV MHP_Yurmoo Line- I not in Service. 400kV JLG_ALI Interim Line II on Standby.
		Unit-II	197.83	400kV MHP - Jigmeling Line - II	278.54	
		Unit-III	194.20	400kV MHP - Jigmeling Line - III	289.16	
		Unit-IV	198.08	400kV MHP - Jigmeling Line - IV	287.22	
		-	-	132kV MHP - Yurmo Line - I	0.00	
		-	-	132kV MHP - Yurmo Line - II	60.98	
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	72.36	
		-	-	400kV Jigmeling - Puna - Alipurduar Line - I	194.91	
		-	-	400kV Jigmeling - Puna - Alipurduar Line - II	0.00	
		-	-	400kV Jigmeling - Alipurduar Line - I	287.27	
		-	-	400kV Jigmeling - Alipurduar Line - II	288.00	
		-	-	80MVA, 220/132kV ICT - I (HV)	21.93	
		-	-	80MVA, 220/132kV ICT - II (HV)	21.61	
		-	-	220kV Tsirang - Jigmeling Line	25.02	
		-	-	132kV Gelephu - Salakati Line	19.83	
Total	787.84	Auxiliary Consumption & Transformation Losses at Generator end	0.06%			
3	4 x 84MW CHP	Unit- I	91.45	220kV CHP - Birpara Line - I	29.93	
		Unit- II	91.30	220kV CHP - Birpara Line - II	29.79	
		Unit- III	90.77	220kV CHP - Gedu	121.57	
		Unit- IV	91.61	220kV CHP - Jamjee (old) - I	57.75	
		-	-	220kV CHP - Jamjee - II (new)	58.61	
		-	-	220kV CHP - Jamjee - III (new)	56.56	
		-	-	220kV Malbase - Birpara Line	-2.19	
		-	-	66kV CHP - Gedu Line	9.92	
-	-	3x3MVA, 66/11kV TFR	0.76			
Total	365.13	Auxiliary Consumption & Transformation Losses at Generator end	0.07%			
4	2 x 12MW BHP (U/S)	Unit- I	12.00	220kV BHP - Semtokha Line	134.00	
		Unit- II	12.24	66kV BHP - Lobeyasa Line	28.00	
		Total	24.24	220kV BHP - Tsirang Line	-96.63	
5	2 x 20MW BHP (L/S)	Unit- I	21.21	5MVA, 66/11kV TFR	0.48	
		Unit- II	20.45	30MVA ICT, 220/66kV (HV)	5.10	
		Total	41.66	Auxiliary Consumption & Transformation Losses at Generator end	0.08%	
6	2 x 63MW DHP	Unit-I	63.57	220kV DHP - Tsirang Line	126.13	220kV DHP_Dagapela Line on Standby.
		Unit-II	63.17	220kV DHP - Dagapela Line	0.00	
		-	-	220kV Jigmeling - Dagapela Line	53.56	
		-	-	5MVA, 220/33kV TFR	0.20	
Total	126.74	Auxiliary Consumption & Transformation Losses at Generator end	0.32%			
7	4 x 15MW KHP	Unit- I	16.34	132kV KHP - Nangkor Line	35.69	
		Unit-II	16.64	132kV KHP - Kilikhar Line	29.58	
		Unit- III	16.59	5MVA, 132/11kV TFR	0.28	
		Unit- IV	16.56	132kV Motanga - Rangia Line	29.33	
		Total	66.13	Auxiliary Consumption & Transformation Losses at Generator end	0.88%	
8	2 x 59MW NHP	Unit-I	64.29	132kV NHP-MHP-I	64.20	
		Unit-II	64.35	132kV NHP-MHP-II	64.35	
		Total	128.64	Auxiliary Consumption & Transformation Losses at Generator end	0.07%	

Note: Generation-Load Summary (MW) for 04-Oct-24 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,671.40	703.07	702.38	943.31	0.69
2	Eastern Grid	982.61	188.29	187.13	819.34	1.16
	Total	2,654.01	891.36	889.51	1,762.65	1.85

Note: Generation-Load Summary for 04-Oct-23 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,667.88	634.90	624.15	1,003.13	10.75
2	Eastern Grid	597.03	190.72	183.13	436.16	7.59
	Total	2,264.91	825.62	807.28	1,439.29	18.34

THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 05-Oct-2024(-ve:import, +ve:export)							
Report Details	Date	Time	National Coincidental Peak Load (MW)		Date	Time	Load
	4-Oct-2024	19:00 hrs			30-Dec-2023	18:00 hrs	955.51
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks	
1	6 x 170MW THP	Unit-I	185.06	400kV THP - Siliguri Line - I	231.60		
		Unit-II	185.52	400kV THP - Siliguri Line - II	230.51		
		Unit-III	185.59	400kV THP - Siliguri Line - IV	221.00		
		Unit-IV	186.31	400kV THP - Malbase Line - III	432.50		
		Unit-V	185.00	400kV Malbase - Siliguri Line	173.81		
		Unit-VI	185.98	-	-		
		Total	1,113.46	Auxiliary Consumption & Transformation Losses at Generator end	-0.19%		
2	4 x 180MW MHP	Unit-I	197.73	400kV MHP - Jigmeling Line - I	0.00	400kV MHP-JLG Line I on Standby. 132kV MHP_Yurmo Line- I not in Service. 400kV JLG_ALI Interim Line II on Standby.	
		Unit-II	197.83	400kV MHP - Jigmeling Line - II	278.54		
		Unit-III	194.20	400kV MHP - Jigmeling Line - III	289.16		
		Unit-IV	198.08	400kV MHP - Jigmeling Line - IV	287.22		
		-	-	132kV MHP - Yurmo Line - I	0.00		
		-	-	132kV MHP - Yurmo Line - II	60.98		
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	95.64		
		-	-	400kV Jigmeling - Puna - Alipurduar Line - I	186.00		
		-	-	400kV Jigmeling - Puna - Alipurduar Line - II	0.00		
		-	-	400kV Jigmeling - Alipurduar Line - I	278.55		
		-	-	400kV Jigmeling - Alipurduar Line - II	278.55		
		-	-	80MVA, 220/132kV ICT - I (HV)	30.43		
		-	-	80MVA, 220/132kV ICT - II (HV)	30.30		
		-	-	220kV Tsirang - Jigmeling Line	19.10		
		-	-	132kV Gelephu - Salakati Line	21.81		
Total	787.84	Auxiliary Consumption & Transformation Losses at Generator end	0.08%				
3	4 x 84MW CHP	Unit-I	91.47	220kV CHP - Birpara Line - I	30.70		
		Unit-II	91.17	220kV CHP - Birpara Line - II	30.70		
		Unit-III	91.33	220kV CHP - Gedu	102.36		
		Unit-IV	91.53	220kV CHP - Jamjee (old) - I	63.13		
		-	-	220kV CHP - Jamjee - II (new)	63.95		
		-	-	220kV CHP - Jamjee - III (new)	61.41		
		-	-	220kV Malbase - Birpara Line	16.00		
		-	-	66kV CHP - Gedu Line	10.13		
		-	-	3x3MVA, 66/11kV TFR	0.98		
Total	365.50	Auxiliary Consumption & Transformation Losses at Generator end	0.59%				
4	2 x 12MW BHP (U/S)	Unit-I	11.94	220kV BHP - Sentsokha Line	137.94		
		Unit-II	12.17	66kV BHP - Lobeyasa Line	30.68		
		Total	24.11	220kV BHP - Tsirang Line	-101.97		
5	2 x 20MW BHP (L/S)	Unit-I	21.17	5MVA, 66/11kV TFR	0.54		
		Unit-II	20.39	30MVA ICT, 220/66kV (HV)	7.76		
		Total	41.56	Auxiliary Consumption & Transformation Losses at Generator end	-2.31%		
6	2 x 63MW DHP	Unit-I	63.57	220kV DHP - Tsirang Line	126.20	220kV DHP_Dagapela Line on Standby.	
		Unit-II	63.15	220kV DHP - Dagapela Line	0.00		
		-	-	220kV Jigmeling - Dagapela Line	53.18		
		-	-	5MVA, 220/33kV TFR	0.50		
Total	126.72	Auxiliary Consumption & Transformation Losses at Generator end	0.02%				
7	4 x 15MW KHP	Unit-I	16.09	132kV KHP - Nangkor Line	40.76		
		Unit-II	16.73	132kV KHP - Kilikhar Line	24.08		
		Unit-III	16.49	5MVA, 132/11kV TFR	0.37		
		Unit-IV	16.61	132kV Motanga - Rangia Line	57.93		
Total	65.92	Auxiliary Consumption & Transformation Losses at Generator end	1.08%				
8	2 x 59MW NHP	Unit-I	64.74	132kV NHP-MHP-I	64.30		
		Unit-II	64.86	132kV NHP-MHP-II	64.39		
		Total	129.60	Auxiliary Consumption & Transformation Losses at Generator end	0.70%		

Note: Generation-Load Summary (MW) for 04-Oct-2024 at 19:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,671.35	717.93	719.44	934.32	-1.51
2	Eastern Grid	983.36	179.62	177.37	822.84	2.25
	Total	2,654.71	897.55	896.81	1,757.16	0.74

Note: Generation-Load Summary (MW) for 04-Oct-2023, at 19:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,652.79	668.82	659.61	989.38	9.21
2	Eastern Grid	845.16	202.17	197.17	637.58	5.00
	Total	2,497.95	870.99	856.78	1,626.96	14.21

Note: Daily Energy (MUs) and Power(MW) Statistics for 04-Oct-2024

Sl. No.	Net Energy Export (Bilateral)	Net Energy Import (Bilateral)	Daily Energy Met	Total Energy Generation	Peak Cross-border (MW)	Imp./Exp. through Exchange (MUs)
	40.84	0.00	20.82	63.68	1,830.04	2.02

- The Instantaneous load balance, calculated as (Total generation - (Total export-Import) - Total domestic load), do not tend towards zero. This could be due to the following reasons:
 - Not all the meters are digital and nor are all the meter at all locations can be read at same time (say 9:00hrs) due to many meter to be read manually. ii) The clocks of all the locations are not synchronized.
- This report, compiled using the SCADA data, is prepared to give an overall idea of the generation & load flow for the system at a particular instant. This report also gives energy and import/export figures.
- When SCADA data are unavailable for certain stations due to technical issues, required data are collected from the site.