



ལྷན་ཁག་དང་འཕེལ་རྒྱུ་ཚོད་ཀྱི་ཉམས་ཞུག་ དཔལ་འདུན་པ་ལྷན་ཁག་གི་ལྷན་ཁག་
 Ministry of Energy and Natural Resources
 Royal Government of Bhutan
 Office of the Bhutan Power System Operator
 Thimphu: Bhutan



THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 06-Oct-2024(-ve:import, +ve:export)

Report Details	Date	Time	National Coincidental Peak Load (MW)	Date	Time	Load
	05-Oct-24	09:00 hrs		30-Dec-23	18:00 hrs	955.51

Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks
1	6 x 170MW THP	Unit- I	185.66	400kV THP - Siliguri Line - I	240.50	
		Unit- II	185.66	400kV THP - Siliguri Line - II	240.40	
		Unit- III	185.17	400kV THP - Siliguri Line - IV	231.84	
		Unit- IV	186.82	400kV THP - Malbase Line - III	482.17	
		Unit- V	186.37	400kV Malbase - Siliguri Line	188.87	
		Unit- VI	186.61	-	-	
		Total	1,116.29	Auxiliary Consumption & Transformation Losses at Generator end	0.12%	
2	4 x 180MW MHP	Unit-I	197.73	400kV MHP - Jigmeling Line - I	0.00	400kV MHP-JLG Line I on Standby. 132kV MHP_Yurmoo Line- I not in Service. 400kV JLG_ALI Interim Line II on Standby. 132kV Gelephu_Salakati line tripped at 1:16hrs.
		Unit-II	197.83	400kV MHP - Jigmeling Line - II	278.54	
		Unit-III	194.20	400kV MHP - Jigmeling Line - III	289.16	
		Unit-IV	198.08	400kV MHP - Jigmeling Line - IV	287.22	
		-	-	132kV MHP - Yurmo Line - I	0.00	
		-	-	132kV MHP - Yurmo Line - II	61.97	
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	59.66	
		-	-	400kV Jigmeling - Puna - Alipurduar Line - I	195.93	
		-	-	400kV Jigmeling - Puna - Alipurduar Line - II	0.00	
		-	-	400kV Jigmeling - Alipurduar Line - I	293.24	
		-	-	400kV Jigmeling - Alipurduar Line - II	292.51	
		-	-	80MVA, 220/132kV ICT - I (HV)	15.47	
		-	-	80MVA, 220/132kV ICT - II (HV)	15.25	
		-	-	220kV Tsirang - Jigmeling Line	23.90	
		-	-	132kV Gelephu - Salakati Line	0.00	
Total	787.84	Auxiliary Consumption & Transformation Losses at Generator end	-0.07%			
3	4 x 84MW CHP	Unit- I	91.47	220kV CHP - Birpara Line - I	33.09	
		Unit- II	91.17	220kV CHP - Birpara Line - II	33.01	
		Unit- III	91.33	220kV CHP - Gedu	116.86	
		Unit- IV	91.53	220kV CHP - Jamjee (old) - I	57.41	
		-	-	220kV CHP - Jamjee - II (new)	58.39	
		-	-	220kV CHP - Jamjee - III (new)	56.35	
		-	-	220kV Malbase - Birpara Line	8.01	
		-	-	66kV CHP - Gedu Line	9.89	
		-	-	3x3MVA, 66/11kV TFR	0.86	
Total	365.50	Auxiliary Consumption & Transformation Losses at Generator end	-0.10%			
4	2 x 12MW BHP (U/S)	Unit- I	12.00	220kV BHP - Semtokha Line	135.58	
		Unit- II	12.00	66kV BHP - Lobeyasa Line	27.94	
		Total	24.00	220kV BHP - Tsirang Line	-97.96	
5	2 x 20MW BHP (L/S)	Unit- I	20.70	5MVA, 66/11kV TFR	0.48	
		Unit- II	20.39	30MVA ICT, 220/66kV (HV)	4.87	
		Total	41.09	Auxiliary Consumption & Transformation Losses at Generator end	-1.46%	
6	2 x 63MW DHP	Unit-I	63.56	220kV DHP - Tsirang Line	126.17	220kV DHP_Dagapela Line on Standby.
		Unit-II	63.15	220kV DHP - Dagapela Line	0.31	
		-	-	220kV Jigmeling - Dagapela Line	53.24	
		-	-	5MVA, 220/33kV TFR	0.22	
Total	126.71	Auxiliary Consumption & Transformation Losses at Generator end	0.01%			
7	4 x 15MW KHP	Unit- I	15.95	132kV KHP - Nangkor Line	42.00	
		Unit-II	16.39	132kV KHP - Kilikhar Line	22.46	
		Unit- III	16.59	5MVA, 132/11kV TFR	0.25	
		Unit- IV	16.57	132kV Motanga - Rangia Line	45.05	
		Total	65.50	Auxiliary Consumption & Transformation Losses at Generator end	1.21%	
8	2 x 59MW NHP	Unit-I	64.66	132kV NHP-MHP-I	64.22	
		Unit-II	64.74	132kV NHP-MHP-II	64.31	
		Total	129.40	Auxiliary Consumption & Transformation Losses at Generator end	0.67%	

Note: Generation-Load Summary (MW) for 05-Oct-24 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,673.59	673.97	673.58	975.72	0.39
2	Eastern Grid	982.74	179.91	178.77	826.73	1.14
	Total	2,656.33	853.88	852.35	1,802.45	1.53

Note: Generation-Load Summary for 05-Oct-23 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,668.70	651.23	642.49	1,014.00	8.74
2	Eastern Grid	851.16	188.49	184.10	666.14	4.39
	Total	2,519.86	839.72	826.59	1,680.14	13.13

THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 06-Oct-2024(-ve:import, +ve:export)							
Report Details	Date	Time	National Coincidental Peak Load (MW)		Date	Time	Load
	5-Oct-2024	19:00 hrs			30-Dec-2023	18:00 hrs	955.51
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks	
1	6 x 170MW THP	Unit-I	185.49	400kV THP - Siliguri Line - I	230.66		
		Unit-II	185.49	400kV THP - Siliguri Line - II	230.97		
		Unit-III	185.79	400kV THP - Siliguri Line - IV	222.75		
		Unit-IV	186.91	400kV THP - Malbase Line - III	429.51		
		Unit-V	186.29	400kV Malbase - Siliguri Line	174.54		
		Unit-VI	186.29	-	-		
		Total	1,116.26	Auxiliary Consumption & Transformation Losses at Generator end	0.21%		
2	4 x 180MW MHP	Unit-I	197.02	400kV MHP - Jigmeling Line - I	0.00	400kV MHP-JLG Line I under maintenance. 132kV MHP_Yurmo Line- I not in Service. 400kV JLG_ALI Interim Line II on Standby.	
		Unit-II	197.76	400kV MHP - Jigmeling Line - II	277.53		
		Unit-III	194.17	400kV MHP - Jigmeling Line - III	288.08		
		Unit-IV	197.15	400kV MHP - Jigmeling Line - IV	286.19		
		-	-	132kV MHP - Yurmo Line - I	0.00		
		-	-	132kV MHP - Yurmo Line - II	63.54		
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	96.73		
		-	-	400kV Jigmeling - Puna - Alipurduar Line - I	186.91		
		-	-	400kV Jigmeling - Puna - Alipurduar Line - II	0.00		
		-	-	400kV Jigmeling - Alipurduar Line - I	278.55		
		-	-	400kV Jigmeling - Alipurduar Line - II	280.00		
		-	-	80MVA, 220/132kV ICT - I (HV)	31.04		
		-	-	80MVA, 220/132kV ICT - II (HV)	30.87		
		-	-	220kV Tsirang - Jigmeling Line	19.88		
		-	-	132kV Gelephu - Salakati Line	19.20		
		Total	786.10	Auxiliary Consumption & Transformation Losses at Generator end	-0.09%		
		3	4 x 84MW CHP	Unit-I	91.53		
Unit-II	91.22			220kV CHP - Birpara Line - II	31.64		
Unit-III	91.34			220kV CHP - Gedu	105.63		
Unit-IV	91.53			220kV CHP - Jamjee (old) - I	62.16		
-	-			220kV CHP - Jamjee - II (new)	62.92		
-	-			220kV CHP - Jamjee - III (new)	60.57		
-	-			220kV Malbase - Birpara Line	12.87		
-	-			66kV CHP - Gedu Line	9.99		
-	-			3x3MVA, 66/11kV TFR	0.14		
Total	365.62			Auxiliary Consumption & Transformation Losses at Generator end	0.24%		
4	2 x 12MW BHP (U/S)	Unit-I	11.96	220kV BHP - Sentsokha Line	136.72		
		Unit-II	12.21	66kV BHP - Lobeyasa Line	30.52		
		Total	24.17	220kV BHP - Tsirang Line	-101.81		
5	2 x 20MW BHP (L/S)	Unit-I	21.16	5MVA, 66/11kV TFR	0.65		
		Unit-II	20.40	30MVA ICT, 220/66kV (HV)	7.63		
		Total	41.56	Auxiliary Consumption & Transformation Losses at Generator end	-0.53%		
6	2 x 63MW DHP	Unit-I	63.59	220kV DHP - Tsirang Line	126.30	220kV DHP_Dagapela Line on Standby.	
		Unit-II	63.33	220kV DHP - Dagapela Line	0.00		
		-	-	220kV Jigmeling - Dagapela Line	53.40		
		-	-	5MVA, 220/33kV TFR	0.25		
Total	126.92	Auxiliary Consumption & Transformation Losses at Generator end	0.29%				
7	4 x 15MW KHP	Unit-I	15.98	132kV KHP - Nangkor Line	40.56		
		Unit-II	16.35	132kV KHP - Kilikhar Line	24.06		
		Unit-III	16.46	5MVA, 132/11kV TFR	0.31		
		Unit-IV	16.44	132kV Motanga - Rangia Line	51.46		
Total	65.23	Auxiliary Consumption & Transformation Losses at Generator end	0.46%				
8	2 x 59MW NHP	Unit-I	64.73	132kV NHP-MHP-I	64.22		
		Unit-II	64.77	132kV NHP-MHP-II	64.31		
		Total	129.50	Auxiliary Consumption & Transformation Losses at Generator end	0.75%		

Note: Generation-Load Summary (MW) for 05-Oct-2024 at 19:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,674.53	719.54	716.26	935.11	3.28
2	Eastern Grid	980.83	184.59	184.03	816.12	0.56
	Total	2,655.36	904.13	900.29	1,751.23	3.84

Note: Generation-Load Summary (MW) for 05-Oct-2023, at 19:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,668.44	669.32	658.69	990.33	10.63
2	Eastern Grid	748.05	208.57	204.95	548.27	3.62
	Total	2,416.49	877.89	863.64	1,538.60	14.25

Note: Daily Energy (MUs) and Power(MW) Statistics for 05-Oct-2024

Sl. No.	Net Energy Export (Bilateral)	Net Energy Import (Bilateral)	Daily Energy Met	Total Energy Generation	Peak Cross-border (MW)	Imp./Exp. through Exchange (MUs)
1	40.98	0.00	20.37	63.42	1,847.96	1.96

- The Instantaneous load balance, calculated as (Total generation - (Total export-Import) - Total domestic load), do not tend towards zero. This could be due to the following reasons:
 - Not all the meters are digital and nor are all the meter at all locations can be read at same time (say 9:00hrs) due to many meter to be read manually. ii) The clocks of all the locations are not synchronized.
- This report, compiled using the SCADA data, is prepared to give an overall idea of the generation & load flow for the system at a particular instant. This report also gives energy and import/export figures.
- When SCADA data are unavailable for certain stations due to technical issues, required data are collected from the site.