



ལྷན་ཁག་དང་འཛམ་གླིང་གི་ལྷན་ཁག་གི་དཔལ་འདུན་འཇུག་གཞུང་།
 Ministry of Energy and Natural Resources
 Royal Government of Bhutan
 Office of the Bhutan Power System Operator
 Thimphu: Bhutan



THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 07-Oct-2024(-ve:import, +ve:export)

Report Details	Date	Time	National Coincidental Peak Load (MW)	Date	Time	Load
	06-Oct-24	09:00 hrs		30-Dec-23	18:00 hrs	955.51

Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks
1	6 x 170MW THP	Unit- I	185.88	400kV THP - Siliguri Line - I	240.98	
		Unit- II	184.67	400kV THP - Siliguri Line - II	240.27	
		Unit- III	185.16	400kV THP - Siliguri Line - IV	231.71	
		Unit- IV	187.10	400kV THP - Malbase Line - III	480.68	
		Unit- V	188.14	400kV Malbase - Siliguri Line	191.65	
		Unit- VI	185.67	-	-	
		Total	1,116.62	Auxiliary Consumption & Transformation Losses at Generator end	0.27%	
2	4 x 180MW MHP	Unit-I	197.73	400kV MHP - Jigmeling Line - I	0.00	400kV MHP-JLG Line I on Standby. 132kV MHP_Yurmoo Line- I not in Service. 400kV JLG_ALI Interim Line II on Standby.
		Unit-II	197.83	400kV MHP - Jigmeling Line - II	278.54	
		Unit-III	194.20	400kV MHP - Jigmeling Line - III	289.16	
		Unit-IV	198.08	400kV MHP - Jigmeling Line - IV	287.22	
		-	-	132kV MHP - Yurmo Line - I	0.00	
		-	-	132kV MHP - Yurmo Line - II	62.30	
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	70.88	
		-	-	400kV Jigmeling - Puna - Alipurduar Line - I	193.46	
		-	-	400kV Jigmeling - Puna - Alipurduar Line - II	0.00	
		-	-	400kV Jigmeling - Alipurduar Line - I	290.18	
		-	-	400kV Jigmeling - Alipurduar Line - II	290.91	
		-	-	80MVA, 220/132kV ICT - I (HV)	21.97	
		-	-	80MVA, 220/132kV ICT - II (HV)	21.80	
		-	-	220kV Tsirang - Jigmeling Line	27.66	
-	-	132kV Gelephu - Salakati Line	19.48			
Total	787.84	Auxiliary Consumption & Transformation Losses at Generator end	-0.08%			
3	4 x 84MW CHP	Unit- I	91.55	220kV CHP - Birpara Line - I	29.92	
		Unit- II	91.37	220kV CHP - Birpara Line - II	29.78	
		Unit- III	91.06	220kV CHP - Gedu	118.57	
		Unit- IV	91.45	220kV CHP - Jamjee (old) - I	59.58	
		-	-	220kV CHP - Jamjee - II (new)	60.33	
		-	-	220kV CHP - Jamjee - III (new)	58.14	
		-	-	220kV Malbase - Birpara Line	0.55	
		-	-	66kV CHP - Gedu Line	8.81	
-	-	3x3MVA, 66/11kV TFR	0.88			
Total	365.43	Auxiliary Consumption & Transformation Losses at Generator end	-0.16%			
4	2 x 12MW BHP (U/S)	Unit- I	11.91	220kV BHP - Semtokha Line	131.39	
		Unit- II	12.15	66kV BHP - Lobeyasa Line	28.15	
		Total	24.06	220kV BHP - Tsirang Line	-94.11	
5	2 x 20MW BHP (L/S)	Unit- I	21.14	5MVA, 66/11kV TFR	0.46	
		Unit- II	20.36	30MVA ICT, 220/66kV (HV)	5.18	
		Total	41.50	Auxiliary Consumption & Transformation Losses at Generator end	-0.50%	
6	2 x 63MW DHP	Unit-I	63.62	220kV DHP - Tsirang Line	126.23	220kV DHP_Dagapela Line on Standby.
		Unit-II	63.11	220kV DHP - Dagapela Line	0.00	
		-	-	220kV Jigmeling - Dagapela Line	52.98	
		-	-	5MVA, 220/33kV TFR	0.30	
Total	126.73	Auxiliary Consumption & Transformation Losses at Generator end	0.16%			
7	4 x 15MW KHP	Unit- I	15.87	132kV KHP - Nangkor Line	42.89	
		Unit-II	16.19	132kV KHP - Kilikhar Line	21.38	
		Unit- III	16.68	5MVA, 132/11kV TFR	0.23	
		Unit- IV	16.61	132kV Motanga - Rangia Line	35.47	
		Total	65.35	Auxiliary Consumption & Transformation Losses at Generator end	1.30%	
8	2 x 59MW NHP	Unit-I	64.76	132kV NHP-MHP-I	64.34	
		Unit-II	64.87	132kV NHP-MHP-II	64.39	
		Total	129.63	Auxiliary Consumption & Transformation Losses at Generator end	0.69%	

Note: Generation-Load Summary (MW) for 06-Oct-24 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,674.34	681.82	679.55	964.86	2.27
2	Eastern Grid	982.82	180.98	179.88	829.50	1.10
	Total	2,657.16	862.80	859.43	1,794.36	3.37

Note: Generation-Load Summary for 06-Oct-23 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,667.78	648.78	640.31	1,006.81	8.47
2	Eastern Grid	727.89	172.35	169.39	567.73	2.96
	Total	2,395.67	821.13	809.70	1,574.54	11.43

THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 07-Oct-2024(-ve:import, +ve:export)							
Report Details	Date	Time	National Coincidental Peak Load (MW)		Date	Time	Load
	6-Oct-2024	19:00 hrs			30-Dec-2023	18:00 hrs	955.51
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks	
1	6 x 170MW THP	Unit-I	185.79	400kV THP - Siliguri Line - I	235.35		
		Unit-II	185.75	400kV THP - Siliguri Line - II	233.50		
		Unit-III	185.93	400kV THP - Siliguri Line - IV	225.10		
		Unit-IV	187.68	400kV THP - Malbase Line - III	424.57		
		Unit-V	184.54	400kV Malbase - Siliguri Line	177.60		
		Unit-VI	186.49	-	-		
		Total	1,116.18	Auxiliary Consumption & Transformation Losses at Generator end	-0.21%		
2	4 x 180MW MHP	Unit-I	197.86	400kV MHP - Jigmeling Line - I	0.00	400kV MHP-JLG Line I under maintenance. 132kV MHP_Yurmo Line- I not in Service. 400kV JLG_ALI Interim Line II on Standby.	
		Unit-II	197.91	400kV MHP - Jigmeling Line - II	278.54		
		Unit-III	194.30	400kV MHP - Jigmeling Line - III	289.16		
		Unit-IV	198.18	400kV MHP - Jigmeling Line - IV	287.22		
		-	-	132kV MHP - Yurmo Line - I	0.00		
		-	-	132kV MHP - Yurmo Line - II	64.40		
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	99.25		
		-	-	400kV Jigmeling - Puna - Alipurduar Line - I	186.18		
		-	-	400kV Jigmeling - Puna - Alipurduar Line - II	0.00		
		-	-	400kV Jigmeling - Alipurduar Line - I	277.09		
		-	-	400kV Jigmeling - Alipurduar Line - II	278.55		
		-	-	80MVA, 220/132kV ICT - I (HV)	33.66		
		-	-	80MVA, 220/132kV ICT - II (HV)	33.35		
		-	-	220kV Tsirang - Jigmeling Line	22.05		
		-	-	132kV Gelephu - Salakati Line	19.31		
Total	788.25	Auxiliary Consumption & Transformation Losses at Generator end	-0.35%				
3	4 x 84MW CHP	Unit-I	91.57	220kV CHP - Birpara Line - I	31.26		
		Unit-II	91.42	220kV CHP - Birpara Line - II	31.30		
		Unit-III	91.29	220kV CHP - Gedu	99.84		
		Unit-IV	91.34	220kV CHP - Jamjee (old) - I	64.79		
		-	-	220kV CHP - Jamjee - II (new)	65.48		
		-	-	220kV CHP - Jamjee - III (new)	63.39		
		-	-	220kV Malbase - Birpara Line	17.19		
		-	-	66kV CHP - Gedu Line	8.47		
		-	-	3x3MVA, 66/11kV TFR	1.02		
Total	365.62	Auxiliary Consumption & Transformation Losses at Generator end	0.02%				
4	2 x 12MW BHP (U/S)	Unit-I	12.00	220kV BHP - Sentsokha Line	133.00		
		Unit-II	12.00	66kV BHP - Lobeyasa Line	30.19		
		Total	24.00	220kV BHP - Tsirang Line	-98.67		
5	2 x 20MW BHP (L/S)	Unit-I	20.70	5MVA, 66/11kV TFR	0.62		
		Unit-II	20.30	30MVA ICT, 220/66kV (HV)	7.40		
		Total	41.00	Auxiliary Consumption & Transformation Losses at Generator end	-0.22%		
6	2 x 63MW DHP	Unit-I	63.54	220kV DHP - Tsirang Line	126.00	220kV DHP_Dagapela Line on Standby.	
		Unit-II	63.25	220kV DHP - Dagapela Line	0.00		
		-	-	220kV Jigmeling - Dagapela Line	53.64		
		-	-	5MVA, 220/33kV TFR	0.72		
Total	126.79	Auxiliary Consumption & Transformation Losses at Generator end	0.01%				
7	4 x 15MW KHP	Unit-I	16.31	132kV KHP - Nangkor Line	40.14		
		Unit-II	16.33	132kV KHP - Kilikhar Line	24.68		
		Unit-III	16.56	5MVA, 132/11kV TFR	0.36		
		Unit-IV	16.60	132kV Motanga - Rangia Line	49.61		
Total	65.80	Auxiliary Consumption & Transformation Losses at Generator end	0.94%				
8	2 x 59MW NHP	Unit-I	64.68	132kV NHP-MHP-I	64.09		
		Unit-II	64.74	132kV NHP-MHP-II	64.20		
		Total	129.42	Auxiliary Consumption & Transformation Losses at Generator end	0.87%		

Note: Generation-Load Summary (MW) for 06-Oct-2024 at 19:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,673.59	700.24	702.64	951.30	-2.40
2	Eastern Grid	983.47	194.78	195.81	810.74	-1.03
	Total	2,657.06	895.02	898.45	1,762.04	-3.43

Note: Generation-Load Summary (MW) for 06-Oct-2023, at 19:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,666.07	678.17	667.47	981.34	10.70
2	Eastern Grid	628.06	189.81	187.97	444.81	1.84
	Total	2,294.13	867.98	855.44	1,426.15	12.54

Note: Daily Energy (MUs) and Power(MW) Statistics for 06-Oct-2024

Sl. No.	Net Energy Export (Bilateral)	Net Energy Import (Bilateral)	Daily Energy Met	Total Energy Generation	Peak Cross-border (MW)	Imp./Exp. through Exchange (MUs)
1	41.61	0.00	20.15	63.70	1,872.32	1.94

- The Instantaneous load balance, calculated as (Total generation - (Total export-Import) - Total domestic load), do not tend towards zero. This could be due to the following reasons:
 - Not all the meters are digital and nor are all the meter at all locations can be read at same time (say 9:00hrs) due to many meter to be read manually. ii) The clocks of all the locations are not synchronized.
- This report, compiled using the SCADA data, is prepared to give an overall idea of the generation & load flow for the system at a particular instant. This report also gives energy and import/export figures.
- When SCADA data are unavailable for certain stations due to technical issues, required data are collected from the site.