



འབྲུག་རྒྱལ་ཁབ་ཀྱི་རྒྱུ་རྩུབ་ལྷན་ཁག་
Ministry of Energy and Natural Resources
Royal Government of Bhutan
Bhutan Power System Operator
Thimphu: Bhutan



THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 20-Sep-2026(-ve:import, +ve:export)						
Report Details	Date	Time	National Coincidental Peak Load (MW)		Date	Time
	September 20, 2026	9:00 AM			08-Sep-26	19:01:50
						1,645.81
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks
1	6 x 170 MW THP (Tala)	Unit-I	187.58	400kV THP - Siliguri Line - I	298.87	400kV THP-Norbugang-IV tripped at 00:29 hrs (11.09.2026).
		Unit-II	187.53	400kV THP - Siliguri Line - II	297.10	
		Unit-III	186.96	400kV THP - Norbugang - IV	0.00	
		Unit-IV	187.15	400kV THP - Malbase Line - III	517.52	
		Unit-V	186.83	400kV Malbase - Siliguri Line	227.49	
		Unit-VI	187.17	400kV Norbugang-Siliguri Line	-104.58	
		Total	1,123.22	Auxiliary Consumption & Transformation Losses at Generator end	0.87%	
2	4 x 180 MW MHP (Mangdechhu)	Unit-I	197.81	400kV MHP - Jigmeling Line - I	265.09	400kV MHP-JLG Line -III on Standby.
		Unit-II	197.77	400kV MHP - Jigmeling Line - II	264.25	
		Unit-III	195.02	400kV MHP - Jigmeling Line - III	0.00	
		Unit-IV	198.31	400kV MHP - Jigmeling Line - IV	257.90	
		-	-	220kV Jigmeling - BitDeer Line - I	189.49	
		-	-	220kV Jigmeling - BitDeer Line - II	170.45	
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	403.27	
		-	-	400kV Jigmeling - Alipurduar Line - I	294.55	
		-	-	400kV Jigmeling - Alipurduar Line - II	293.82	
		-	-	80MVA, 220/132kV ICT - I (HV)	22.34	
		-	-	80MVA, 220/132kV ICT - II (HV)	22.10	
		-	-	132kV MHP - Yurmo Line - II	61.21	
		-	-	132kV MHP - Tintibi Line	56.00	
		-	-	132kV Gelephu - Salakati Line	-19.76	
		Total	788.91	Auxiliary Consumption & Transformation Losses at Generator end	1.70%	
3	6 x 170 MW PHP-II (Punatsangchhu)	Unit-I	183.17	400kV PHP II - Jigmeling -I	107.44	Unit-V under Shutdown.
		Unit-II	179.63	400kV PHP II - Jigmeling -II	106.57	
		Unit-III	185.49	400kV PHP II - Alipurduar -I	354.97	
		Unit-IV	184.84	400kV PHP II - Alipurduar -II	354.69	
		Unit-V	0.00	-	-	
		Unit-VI	186.08	-	-	
		Total	919.19	Auxiliary Consumption & Transformation Losses at Generator end	-0.49%	
4	4 x 84 MW CHP (Chukha)	Unit-I	91.36	220kV CHP - Birpara Line - I	15.58	All Units and Feeders are in Service.
		Unit-II	91.23	220kV CHP - Birpara Line - II	14.98	
		Unit-III	91.30	220kV CHP - Gedu	109.75	
		Unit-IV	91.52	220kV CHP - Jamjee - I	73.26	
		-	-	220kV CHP - Jamjee - II	72.63	
		-	-	220kV CHP - Jamjee - III	70.12	
		-	-	220kV Malbase - Birpara Line	-18.94	
		-	-	66kV CHP - Gedu Line	7.81	
		Total	365.41	Auxiliary Consumption & Transformation Losses at Generator end	0.35%	
5	2 x 12 MW BHP (U/S) (Basochhu)	Unit-I	11.85	220kV BHP - Semtokha Line	74.12	All Units & Feeders are in Service.
		Unit-II	12.00	66kV BHP - Lobeysa Line	25.03	
		Total	23.85	220kV BHP - Tsirang Line	-34.65	
6	2 x 20 MW BHP (L/S) (Basochhu)	Unit-I	20.41	5MVA, 66/11kV TFR	0.26	All Units & Feeders are in Service.
		Unit-II	20.69	30MVA ICT, 220/66kV (HV)	1.79	
		Total	41.10	Auxiliary Consumption & Transformation Losses at Generator end	0.29%	
7	2 x 63 MW DHP (Dagachhu)	Unit-I	43.52	220kV DHP - Tsirang Line	0.00	220kV DHP-Tsirang line on Standby.
		Unit-II	42.03	220kV DHP - Dagapela Line	92.82	
		-	-	220kV BitDeer - Dagapela Line	-42.11	
		-	-	5MVA, 220/33kV TFR	0.23	
		Total	85.55	Auxiliary Consumption & Transformation Losses at Generator end	-8.77%	
8	4 x 15 MW KHP (Kurichhu)	Unit-I	16.54	132kV KHP - Nangkor Line	62.51	All Units & Feeders are in Service.
		Unit-II	16.51	132kV KHP - Kilikhar Line	3.00	
		Unit-III	16.68	5MVA, 132/11kV TFR	0.27	
		Unit-IV	16.52	132kV Motanga - Rangja Line	55.32	
		Total	66.25	Auxiliary Consumption & Transformation Losses at Generator end	0.71%	
9	2 x 59 MW NHP (Nikachhu)	Unit-I	64.91	132kV NHP-MHP-I	64.45	All Units & Feeders are in Service.
		Unit-II	64.89	132kV NHP-MHP-II	64.49	
		Total	129.80	Auxiliary Consumption & Transformation Losses at Generator end	0.66%	
10	2 x 9 MW SHP (Suchhu)	Unit-I	0.00	66kV SHP-Damdhum (Samtse)	-0.03	Unit I & Unit II under Shutdown. 66kV SHP-Damdhum Line on Standby
		Unit-II	0.00	-	-	
		Total	0.00	Auxiliary Consumption & Transformation Losses at Generator end	0.00%	
11	22.38 MWp SSP (Sephu Solar Plant)	Inverter-1	0.00	33kV SSP-Wangdue	0.00	SSP_Trongsa feeder under shutdown SSP_Wangdue feeder under shutdown.
		Inverter-2	0.00	33kV SSP-Trongsas	0.00	
		Inverter-3	0.00	-	-	
		Inverter-4	0.00	-	-	
		Inverter-5	0.00	-	-	
		Total	0.00	Auxiliary Consumption & Transformation Losses at Generator end	0.00%	
12	2 x 16 MW YHP (Yungichhu)	Unit-I	16.01	132kV YHP-Kilikhar	30.84	All Units & Feeders are in Service.
		Unit-II	16.07	5MVA, 132/33kV TFR	0.80	
		Total	32.08	Auxiliary Consumption & Transformation Losses at Generator end	1.37%	
13	2 x 27 MW BSHP (Burgangchhu Small HP)	Unit-I	27.18	132kV BSHP-Panbang	38.24	All Units & Feeders are in Service.
		Unit-II	27.14	132kV BSHP-Tintibi	15.39	
		Total	54.32	Auxiliary Consumption & Transformation Losses at Generator end	1.27%	


Note: Generation-Load Summary (MW) for 20-Sep-26 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	3,629.68	1,565.59	2,064.09

Note: Generation-Load Summary (MW) for 20-Sep-25 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	3,385.45	1,119.75	2,265.70

09:00 hrs Statistical Comparison (MW) for this and last year



THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 20-Sep-2026(+ve:import, +ve:export)						
Report Details	Date	Time	National Coincidental Peak Load (MW)		Date	Time
	September 19, 2026	19:00:00			08-Sep-26	19:01:50
						1,645.81
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks
1	6 x 170 MW THP (Tala)	Unit-I	187.53	400kV THP - Siliguri Line - I	281.26	400kV THP-Norbugang-IV tripped at 00:29 hrs (11.09.2026).
		Unit-II	187.63	400kV THP - Siliguri Line - II	279.70	
		Unit-III	187.04	400kV THP - Norbugang Line - IV	0.00	
		Unit-IV	187.13	400kV THP - Malbase Line - III	552.72	
		Unit-V	186.83	400kV Malbase - Siliguri Line	199.50	
		Unit-VI	187.05	400kV Norbugang-Siliguri Line	-104.58	
		Total	1,123.21	Auxiliary Consumption & Transformation Losses at Generator end	0.85%	
2	4 x 180 MW MHP (Mangdechhu)	Unit-I	197.86	400kV MHP - Jigmeling Line - I	265.15	400kV MHP-JLG Line -III on Standby.
		Unit-II	197.97	400kV MHP - Jigmeling Line - II	264.54	
		Unit-III	195.35	400kV MHP - Jigmeling Line - III	0.00	
		Unit-IV	198.37	400kV MHP - Jigmeling Line - IV	258.13	
		-	-	220kV Jigmeling - BitDeer Line - I	187.50	
		-	-	220kV Jigmeling - BitDeer Line - II	169.57	
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	429.46	
		-	-	400kV Jigmeling - Alipurdur Line - I	286.55	
		-	-	400kV Jigmeling - Alipurdur Line - II	285.82	
		-	-	80MVA, 220/132kV ICT - I (HV)	37.01	
		-	-	80MVA, 220/132kV ICT - II (HV)	36.61	
		-	-	132kV MHP - Yumo Line - II	62.86	
		-	-	132kV MHP - Tintibi Line	64.49	
		-	-	132kV Gelephu - Salakati Line	-7.30	
		Total	789.55	Auxiliary Consumption & Transformation Losses at Generator end	0.41%	
3	6 x 170 MW PHP-II (Punatsangchhu)	Unit-I	183.17	400kV PHP II - Jigmeling -I	112.04	Unit-V under Shutdown.
		Unit-II	179.83	400kV PHP II - Jigmeling -II	111.37	
		Unit-III	184.45	400kV PHP II - Alipurdur -I	349.36	
		Unit-IV	185.05	400kV PHP II - Alipurdur -II	349.06	
		Unit-V	0.00	-	-	
		Unit-VI	186.26	-	-	
		Total	918.76	Auxiliary Consumption & Transformation Losses at Generator end	-0.33%	
4	4 x 84 MW CHP (Chhukha)	Unit-I	91.43	220kV CHP - Birpara Line - I	19.01	All Units & Feeders are in Service.
		Unit-II	91.04	220kV CHP - Birpara Line - II	18.78	
		Unit-III	91.35	220kV CHP - Gedu	81.58	
		Unit-IV	91.30	220kV CHP - Jamjee - I	80.04	
		-	-	220kV CHP - Jamjee - II	79.37	
		-	-	220kV CHP - Jamjee - III	76.44	
		-	-	220kV Malbase - Birpara Line	10.15	
		-	-	66kV CHP - Gedu Line	7.94	
		Total	365.12	Auxiliary Consumption & Transformation Losses at Generator end	0.54%	
5	2 x 12 MW BHP (U/S) (Basochhu)	Unit-I	11.87	220kV BHP - Sertokha Line	78.21	All Units and Feeders are in Service.
		Unit-II	12.00	66kV BHP - Lobeysa Line	28.57	
		Total	23.87	220kV BHP - Tsirang Line	-42.48	
6	2 x 20 MW BHP (L/S) (Basochhu)	Unit-I	28.46	5MVA, 66/11kV TFR	0.66	
		Unit-II	20.73	30MVA ICT, 220/66kV (HV)	5.76	
		Total	41.19	Auxiliary Consumption & Transformation Losses at Generator end	0.15%	
7	2 x 63 MW DHP (Dagachhu)	Unit-I	44.49	220kV DHP - Tsirang Line	0.00	220kV DHP-Tsirang line on Standby.
		Unit-II	43.04	220kV DHP - Dagapela Line	87.03	
		-	-	220kV BitDeer - Dagapela Line	-42.78	
		-	-	5MVA, 220/33kV TFR	0.25	
		Total	87.53	Auxiliary Consumption & Transformation Losses at Generator end	0.29%	
8	4 x 15 MW KHP (Kurichhu)	Unit-I	16.53	132kV KHP - Nangkor Line	51.38	All Units & Feeders are in Service.
		Unit-II	16.54	132kV KHP - Kilikhar Line	13.88	
		Unit-III	16.61	5MVA, 132/11kV TFR	0.43	
		Unit-IV	16.56	132kV Motanga - Rangla Line	50.94	
		Total	66.24	Auxiliary Consumption & Transformation Losses at Generator end	0.83%	
9	2 x 59 MW NHP (Nikachhu)	Unit-I	64.88	132kV NHP-MHP-I	64.44	All Units & Feeders are in Service.
		Unit-II	64.86	132kV NHP-MHP-II	64.39	
		Total	129.74	Auxiliary Consumption & Transformation Losses at Generator end	0.70%	
10	2 x 9 MW SHP (Suchhu)	Unit-I	0.00	66kV SHP-Damdhum (Samtse)	-0.05	Unit I & Unit II under Shutdown 66kV SHP-Damdhum Line on Standby
		Unit-II	0.00	-	-	
		Total	0.00	Auxiliary Consumption & Transformation Losses at Generator end	0.00%	
11	2 x 16 MW YHP (Yungichhu)	Unit-I	16.30	132kV YHP-Kilikhar	30.26	All Units & Feeders are in Service.
		Unit-II	16.06	5MVA, 132/33kV TFR	1.66	
		Total	32.36	Auxiliary Consumption & Transformation Losses at Generator end	1.36%	
12	2 x 27 MW BSHP (Burgangchhu Small HP)	Unit-I	27.16	132kV BSHP-Panbang	52.39	All Units and Feeders are in Service.
		Unit-II	27.20	132kV BSHP-Tintibi	1.37	
		Total	54.36	Auxiliary Consumption & Transformation Losses at Generator end	1.10%	

Note: Generation-Load Summary (MW) for 19-Sep-2026 at 18:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	3,631.93	1,613.68	2,018.25

Note: Generation-Load Summary (MW) for 19-Sep-2025, at 19:00 hrs

Sl. No.	Region	Total Generation	Total Domestic Load (Total Generation - Total Export)	Total Export(+ve)/ Import(-ve)
1	Both Eastern & Western (Whole Bhutan)	3,411.59	1,196.11	2,215.48

Note: Daily Energy (MUS) and Power(MW) Statistics for 19-Sep-2026

Sl. No.	Total Energy Generation	Daily Energy Met	Net Energy Import (IEX and Solar)	Net Energy Export	Peak Cross- border (MW)
1	88.186	37.03	0.00	51.16	2,241.85

- The Instantaneous load balance does not tend towards zero. This could be due to the following reasons:
 - Not all the meters are digital and not all the meter at all locations can be read at same time (say 9:00hrs) due to many meter to be read manually. ii) The clocks of all the locations are not synchronized.
- This report, compiled using the SCADA data, is prepared to give an overall idea of the generation & load flow for the system at a particular instant. This report also gives energy and import/export figures.
- When SCADA data are unavailable for certain stations due to technical issues, required data are collected from the site.