



ལྷན་ཁག་དང་སངས་མཁོན་ཚོའི་ཕྱོད་ཁག་ དཔལ་དཀར་འཇུག་གཞུང་།
 Ministry of Energy and Natural Resources
 Royal Government of Bhutan
 Office of the Bhutan Power System Operator
 Thimphu: Bhutan



THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 11-Oct-2024(-ve:import, +ve:export)

Report Details	Date	Time	National Coincidental Peak Load (MW)	Date	Time	Load
	10-Oct-24	09:00 hrs		30-Dec-23	18:00 hrs	955.51

Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks
1	6 x 170MW THP	Unit- I	185.16	400kV THP - Siliguri Line - I	240.32	
		Unit- II	185.87	400kV THP - Siliguri Line - II	241.33	
		Unit- III	185.08	400kV THP - Siliguri Line- IV	231.73	
		Unit- IV	185.30	400kV THP - Malbase Line - III	397.85	
		Unit- V	185.72	400kV Malbase - Siliguri Line	195.63	
		Unit- VI	185.91	-	-	
		Total	1,113.04	Auxiliary Consumption & Transformation Losses at Generator end	0.16%	
2	4 x 180MW MHP	Unit-I	170.09	400kV MHP - Jigmeling Line - I	0.00	400kV MHP-JLG Line I on Standby. 132kV MHP_Yurmoo Line- I not in Service. 400kV JLG_ALI Interim Line II on Standby.
		Unit-II	197.97	400kV MHP - Jigmeling Line - II	257.24	
		Unit-III	175.64	400kV MHP - Jigmeling Line - III	267.18	
		Unit-IV	180.80	400kV MHP - Jigmeling Line - IV	265.43	
		-	-	132kV MHP - Yurmo Line - I	0.00	
		-	-	132kV MHP - Yurmo Line - II	61.22	
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	63.64	
		-	-	400kV Jigmeling - Puna - Alipurduar Line - I	179.40	
		-	-	400kV Jigmeling - Puna - Alipurduar Line - II	0.00	
		-	-	400kV Jigmeling - Alipurduar Line - I	269.72	
		-	-	400kV Jigmeling - Alipurduar Line - II	268.79	
		-	-	80MVA, 220/132kV ICT - I (HV)	27.51	
		-	-	80MVA, 220/132kV ICT - II (HV)	27.23	
		-	-	220kV Tsirang - Jigmeling Line	43.58	
		-	-	132kV Gelephu - Salakati Line	26.80	
Total	724.50	Auxiliary Consumption & Transformation Losses at Generator end	0.32%			
3	4 x 84MW CHP	Unit- I	91.48	220kV CHP - Birpara Line - I	35.70	
		Unit- II	91.26	220kV CHP - Birpara Line - II	36.10	
		Unit- III	91.29	220kV CHP - Gedu	106.69	
		Unit- IV	91.33	220kV CHP - Jamjee (old) - I	58.60	
		-	-	220kV CHP - Jamjee - II (new)	59.63	
		-	-	220kV CHP - Jamjee - III (new)	57.68	
		-	-	220kV Malbase - Birpara Line	21.12	
		-	-	66kV CHP - Gedu Line	8.30	
		-	-	3x3MVA, 66/11kV TFR	0.80	
Total	365.36	Auxiliary Consumption & Transformation Losses at Generator end	0.51%			
4	2 x 12MW BHP (U/S)	Unit- I	11.95	220kV BHP - Semtokha Line	116.75	
		Unit- II	12.15	66kV BHP - Lobeyasa Line	27.40	
		Total	24.10	220kV BHP - Tsirang Line	-78.78	
5	2 x 20MW BHP (L/S)	Unit- I	21.16	5MVA, 66/11kV TFR	0.43	
		Unit- II	20.36	30MVA ICT, 220/66kV (HV)	4.37	
		Total	41.52	Auxiliary Consumption & Transformation Losses at Generator end	-0.27%	
6	2 x 63MW DHP	Unit-I	63.59	220kV DHP - Tsirang Line	126.01	220kV DHP_Dagapela Line on Standby.
		Unit-II	63.00	220kV DHP - Dagapela Line	0.00	
		-	-	220kV Jigmeling - Dagapela Line	52.68	
		-	-	5MVA, 220/33kV TFR	0.58	
Total	126.59	Auxiliary Consumption & Transformation Losses at Generator end	0.00%			
7	4 x 15MW KHP	Unit- I	16.60	132kV KHP - Nangkor Line	44.03	
		Unit-II	16.59	132kV KHP - Kilikhar Line	21.43	
		Unit- III	16.40	5MVA, 132/11kV TFR	0.24	
		Unit- IV	16.74	132kV Motanga - Rangia Line	43.82	
		Total	66.33	Auxiliary Consumption & Transformation Losses at Generator end	0.95%	
8	2 x 59MW NHP	Unit-I	64.89	132kV NHP-MHP-I	64.39	
		Unit-II	64.95	132kV NHP-MHP-II	64.48	
		Total	129.84	Auxiliary Consumption & Transformation Losses at Generator end	0.75%	

Note: Generation-Load Summary (MW) for 10-Oct-24 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,670.61	625.10	621.61	1,001.93	3.49
2	Eastern Grid	920.67	175.72	171.82	788.53	3.90
	Total	2,591.28	800.82	793.43	1,790.46	7.39

Note: Generation-Load Summary for 10-Oct-23 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,412.40	650.18	641.86	759.18	8.32
2	Eastern Grid	498.06	179.07	176.05	322.03	3.02
	Total	1,910.46	829.25	817.91	1,081.21	11.34

THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 11-Oct-2024(-ve:import, +ve:export)							
Report Details	Date	Time	National Coincidental Peak Load (MW)		Date	Time	Load
	10-Oct-2024	19:00 hrs			30-Dec-2023	18:00 hrs	955.51
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks	
1	6 x 170MW THP	Unit-I	184.78	400kV THP - Siliguri Line - I	230.86		
		Unit-II	185.78	400kV THP - Siliguri Line - II	229.18		
		Unit-III	185.37	400kV THP - Siliguri Line - IV	221.94		
		Unit-IV	185.36	400kV THP - Malbase Line - III	427.50		
		Unit-V	184.71	400kV Malbase - Siliguri Line	171.84		
		Unit-VI	186.39	-	-		
		Total	1,112.39	Auxiliary Consumption & Transformation Losses at Generator end	0.26%		
2	4 x 180MW MHP	Unit-I	160.16	400kV MHP - Jigmeling Line - I	0.00	400kV MHP-JLG Line I on Standby. 132kV MHP_Yurmoo Line- I not in Service. 400kV JLG_ALI Interim Line II on Standby.	
		Unit-II	197.93	400kV MHP - Jigmeling Line - II	243.18		
		Unit-III	160.94	400kV MHP - Jigmeling Line - III	252.51		
		Unit-IV	162.57	400kV MHP - Jigmeling Line - IV	250.81		
		-	-	132kV MHP - Yurmo Line - I	0.00		
		-	-	132kV MHP - Yurmo Line - II	61.21		
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	67.65		
		-	-	400kV Jigmeling - Puna - Alipurduar Line - I	160.91		
		-	-	400kV Jigmeling - Puna - Alipurduar Line - II	0.00		
		-	-	400kV Jigmeling - Alipurduar Line - I	240.00		
		-	-	400kV Jigmeling - Alipurduar Line - II	241.46		
		-	-	80MVA, 220/132kV ICT - I (HV)	35.98		
		-	-	80MVA, 220/132kV ICT - II (HV)	35.75		
		-	-	220kV Tsirang - Jigmeling Line	29.04		
		-	-	132kV Gelephu - Salakati Line	22.15		
Total	681.60	Auxiliary Consumption & Transformation Losses at Generator end	0.41%				
3	4 x 84MW CHP	Unit-I	91.48	220kV CHP - Birpara Line - I	34.59		
		Unit-II	91.26	220kV CHP - Birpara Line - II	34.14		
		Unit-III	91.29	220kV CHP - Gedu	83.03		
		Unit-IV	91.33	220kV CHP - Jamjee (old) - I	68.55		
		-	-	220kV CHP - Jamjee - II (new)	69.31		
		-	-	220kV CHP - Jamjee - III (new)	67.14		
		-	-	220kV Malbase - Birpara Line	35.22		
		-	-	66kV CHP - Gedu Line	7.49		
		-	-	3x3MVA, 66/11kV TFR	1.04		
Total	365.36	Auxiliary Consumption & Transformation Losses at Generator end	0.02%				
4	2 x 12MW BHP (U/S)	Unit-I	11.94	220kV BHP - Sento Kha Line	121.16		
		Unit-II	12.14	66kV BHP - Lobeyasa Line	29.77		
		Total	24.08	220kV BHP - Tsirang Line	-85.68		
5	2 x 20MW BHP (L/S)	Unit-I	21.13	5MVA, 66/11kV TFR	0.58		
		Unit-II	20.33	30MVA ICT, 220/66kV (HV)	6.93		
		Total	41.46	Auxiliary Consumption & Transformation Losses at Generator end	-0.44%		
6	2 x 63MW DHP	Unit-I	61.31	220kV DHP - Tsirang Line	119.78	220kV DHP_Dagapela Line on Standby.	
		Unit-II	59.03	220kV DHP - Dagapela Line	0.00		
		-	-	220kV Jigmeling - Dagapela Line	53.27		
		-	-	5MVA, 220/33kV TFR	0.28		
Total	120.34	Auxiliary Consumption & Transformation Losses at Generator end	0.23%				
7	4 x 15MW KHP	Unit-I	16.47	132kV KHP - Nangkor Line	41.63		
		Unit-II	16.59	132kV KHP - Kilikhar Line	23.41		
		Unit-III	16.51	5MVA, 132/11kV TFR	0.31		
		Unit-IV	16.55	132kV Motanga - Rangia Line	53.49		
Total	66.12	Auxiliary Consumption & Transformation Losses at Generator end	1.16%				
8	2 x 59MW NHP	Unit-I	64.90	132kV NHP-MHP-I	64.41		
		Unit-II	64.89	132kV NHP-MHP-II	64.47		
		Total	129.79	Auxiliary Consumption & Transformation Losses at Generator end	0.70%		

Note: Generation-Load Summary (MW) for 10-Oct-2024 at 19:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,663.63	676.82	673.85	957.77	2.97
2	Eastern Grid	877.51	188.54	184.09	718.01	4.45
Total		2,541.14	865.36	857.94	1,675.78	7.42

Note: Generation-Load Summary (MW) for 10-Oct-2023, at 19:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,373.30	657.61	653.64	719.48	3.97
2	Eastern Grid	511.41	189.99	186.34	317.63	3.65
Total		1,884.71	847.60	839.98	1,037.11	7.62

Note: Daily Energy (MUs) and Power(MW) Statistics for 10-Oct-2024

Sl. No.	Net Energy Export (Bilateral)	Net Energy Import (Bilateral)	Daily Energy Met	Total Energy Generation	Peak Cross-border (MW)	Imp./Exp. through Exchange (MUs)
1	39.97	0.00	19.61	61.84	1,844.25	2.28

- The Instantaneous load balance, calculated as (Total generation - (Total export-Import) - Total domestic load), do not tend towards zero. This could be due to the following reasons:
 - Not all the meters are digital and nor are all the meter at all locations can be read at same time (say 9:00hrs) due to many meter to be read manually. ii) The clocks of all the locations are not synchronized.
- This report, compiled using the SCADA data, is prepared to give an overall idea of the generation & load flow for the system at a particular instant. This report also gives energy and import/export figures.
- When SCADA data are unavailable for certain stations due to technical issues, required data are collected from the site.