



ལྷན་ཁག་གི་འཕེལ་རྒྱུ་ལྷན་ཁག་གི་འཕེལ་རྒྱུ་གཞི་རྒྱུ་ལྷན་ཁག་གི་འཕེལ་རྒྱུ་གཞི་རྒྱུ་
 Ministry of Energy and Natural Resources
 Royal Government of Bhutan
 Office of the Bhutan Power System Operator
 Thimphu: Bhutan



THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 13-Oct-2024(-ve:import, +ve:export)

Report Details	Date	Time	National Coincidental Peak Load (MW)	Date	Time	Load
	12-Oct-24	09:00 hrs		30-Dec-23	18:00 hrs	955.51

Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks
1	6 x 170MW THP	Unit- I	134.60	400kV THP - Siliguri Line - I	205.59	
		Unit- II	185.46	400kV THP - Siliguri Line - II	204.98	
		Unit- III	94.27	400kV THP - Siliguri Line - IV	197.68	
		Unit- IV	186.62	400kV THP - Malbase Line - III	364.48	
		Unit- V	185.75	400kV Malbase - Siliguri Line	159.62	
		Unit- VI	186.02	-	-	
		Total	972.72	Auxiliary Consumption & Transformation Losses at Generator end	0.00%	
2	4 x 180MW MHP	Unit-I	169.80	400kV MHP - Jigmeling Line - I	0.00	400kV MHP-JLG Line I on Standby. 132kV MHP_Yurmoo Line- I not in Service. 400kV JLG_ALI Interim Line II on Standby.
		Unit-II	197.74	400kV MHP - Jigmeling Line - II	247.91	
		Unit-III	161.62	400kV MHP - Jigmeling Line - III	257.16	
		Unit-IV	165.15	400kV MHP - Jigmeling Line - IV	255.50	
		-	-	132kV MHP - Yurmo Line - I	0.00	
		-	-	132kV MHP - Yurmo Line - II	60.46	
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	67.27	
		-	-	400kV Jigmeling - Puna - Alipurduar Line - I	171.37	
		-	-	400kV Jigmeling - Puna - Alipurduar Line - II	0.00	
		-	-	400kV Jigmeling - Alipurduar Line - I	256.73	
		-	-	400kV Jigmeling - Alipurduar Line - II	257.46	
		-	-	80MVA, 220/132kV ICT - I (HV)	24.71	
		-	-	80MVA, 220/132kV ICT - II (HV)	24.55	
		-	-	220kV Tsirang - Jigmeling Line	23.31	
		-	-	132kV Gelephu - Salakati Line	21.34	
Total	694.31	Auxiliary Consumption & Transformation Losses at Generator end	0.04%			
3	4 x 84MW CHP	Unit- I	91.48	220kV CHP - Birpara Line - I	24.37	
		Unit- II	91.26	220kV CHP - Birpara Line - II	24.24	
		Unit- III	91.29	220kV CHP - Gedu	113.06	
		Unit- IV	91.33	220kV CHP - Jamjee (old) - I	64.59	
		-	-	220kV CHP - Jamjee - II (new)	65.07	
		-	-	220kV CHP - Jamjee - III (new)	62.83	
		-	-	220kV Malbase - Birpara Line	-5.07	
		-	-	66kV CHP - Gedu Line	9.28	
-	-	3x3MVA, 66/11kV TFR	0.88			
Total	365.36	Auxiliary Consumption & Transformation Losses at Generator end	0.28%			
4	2 x 12MW BHP (U/S)	Unit- I	11.09	220kV BHP - Semtokha Line	120.00	
		Unit- II	11.80	66kV BHP - Lobeyasa Line	27.20	
		Total	22.89	220kV BHP - Tsirang Line	-85.30	
5	2 x 20MW BHP (L/S)	Unit- I	20.18	5MVA, 66/11kV TFR	0.48	
		Unit- II	19.41	30MVA ICT, 220/66kV (HV)	5.52	
		Total	39.59	Auxiliary Consumption & Transformation Losses at Generator end	0.16%	
6	2 x 63MW DHP	Unit-I	58.33	220kV DHP - Tsirang Line	112.79	220kV DHP_Dagapela Line on Standby.
		Unit-II	54.95	220kV DHP - Dagapela Line	0.00	
		-	-	220kV Jigmeling - Dagapela Line	41.08	
		-	-	5MVA, 220/33kV TFR	0.20	
Total	113.28	Auxiliary Consumption & Transformation Losses at Generator end	0.26%			
7	4 x 15MW KHP	Unit- I	16.46	132kV KHP - Nangkor Line	43.80	
		Unit-II	16.49	132kV KHP - Kilikhar Line	21.50	
		Unit- III	16.52	5MVA, 132/11kV TFR	0.23	
		Unit- IV	16.52	132kV Motanga - Rangia Line	32.62	
		Total	65.99	Auxiliary Consumption & Transformation Losses at Generator end	0.70%	
8	2 x 59MW NHP	Unit-I	64.41	132kV NHP-MHP-I	63.62	
		Unit-II	64.46	132kV NHP-MHP-II	63.41	
		Total	128.87	Auxiliary Consumption & Transformation Losses at Generator end	1.43%	

Note: Generation-Load Summary (MW) for 12-Oct-24 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,513.84	679.12	677.70	811.41	1.42
2	Eastern Grid	889.17	172.96	170.35	739.52	2.61
	Total	2,403.01	852.08	848.05	1,550.93	4.03

Note: Generation-Load Summary for 12-Oct-23 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,301.25	562.67	556.45	729.48	6.22
2	Eastern Grid	456.60	200.56	196.24	265.14	4.32
	Total	1,757.85	763.23	752.69	994.62	10.54

THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 13-Oct-2024(-ve:import, +ve:export)							
Report Details	Date	Time	National Coincidental Peak Load (MW)		Date	Time	Load
	12-Oct-2024	19:00 hrs			30-Dec-2023	18:00 hrs	955.51
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks	
1	6 x 170MW THP	Unit-I	134.86	400kV THP - Siliguri Line - I	202.12		
		Unit-II	187.01	400kV THP - Siliguri Line - II	202.33		
		Unit-III	94.23	400kV THP - Siliguri Line- IV	195.13		
		Unit-IV	186.15	400kV THP - Malbase Line - III	374.13		
		Unit-V	186.60	400kV Malbase - Siliguri Line	151.08		
		Unit-VI	185.68	-	-		
		Total	974.53	Auxiliary Consumption & Transformation Losses at Generator end	0.08%		
2	4 x 180MW MHP	Unit-I	169.75	400kV MHP - Jigmeling Line - I	0.00	400kV MHP-JLG Line I on Standby. 132kV MHP_Yurmo Line- I not in Service. 400kV JLG_ALI Interim Line II on Standby.	
		Unit-II	197.75	400kV MHP - Jigmeling Line - II	243.86		
		Unit-III	160.83	400kV MHP - Jigmeling Line - III	253.31		
		Unit-IV	165.21	400kV MHP - Jigmeling Line - IV	251.59		
		-	-	132kV MHP - Yurmo Line - I	0.00		
		-	-	132kV MHP - Yurmo Line - II	61.73		
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	93.46		
		-	-	400kV Jigmeling - Puna - Alipurduar Line - I	162.30		
		-	-	400kV Jigmeling - Puna - Alipurduar Line - II	0.00		
		-	-	400kV Jigmeling - Alipurduar Line - I	243.89		
		-	-	400kV Jigmeling - Alipurduar Line - II	243.09		
		-	-	80MVA, 220/132kV ICT - I (HV)	30.01		
		-	-	80MVA, 220/132kV ICT - II (HV)	29.80		
		-	-	220kV Tsirang - Jigmeling Line	18.49		
		-	-	132kV Gelephu - Salakati Line	18.35		
Total	693.54	Auxiliary Consumption & Transformation Losses at Generator end	0.29%				
3	4 x 84MW CHP	Unit-I	91.48	220kV CHP - Birpara Line - I	27.63		
		Unit-II	91.26	220kV CHP - Birpara Line - II	27.32		
		Unit-III	91.29	220kV CHP - Gedu	96.60		
		Unit-IV	91.33	220kV CHP - Jamjee (old) - I	68.59		
		-	-	220kV CHP - Jamjee - II (new)	69.10		
		-	-	220kV CHP - Jamjee - III (new)	66.53		
		-	-	220kV Malbase - Birpara Line	13.21		
		-	-	66kV CHP - Gedu Line	7.90		
		-	-	3x3MVA, 66/11kV TFR	0.99		
Total	365.36	Auxiliary Consumption & Transformation Losses at Generator end	0.19%				
4	2 x 12MW BHP (U/S)	Unit-I	11.20	220kV BHP - Sentsokha Line	119.70		
		Unit-II	11.50	66kV BHP - Lobeyasa Line	27.70		
		Total	22.70	220kV BHP - Tsirang Line	-85.36		
5	2 x 20MW BHP (L/S)	Unit-I	19.90	5MVA, 66/11kV TFR	0.41		
		Unit-II	20.00	30MVA ICT, 220/66kV (HV)	5.96		
		Total	39.90	Auxiliary Consumption & Transformation Losses at Generator end	0.24%		
6	2 x 63MW DHP	Unit-I	54.28	220kV DHP - Tsirang Line	107.76	220kV DHP_Dagapela Line on Standby.	
		Unit-II	54.01	220kV DHP - Dagapela Line	0.00		
		-	-	220kV Jigmeling - Dagapela Line	52.55		
		-	-	5MVA, 220/33kV TFR	0.30		
Total	108.29	Auxiliary Consumption & Transformation Losses at Generator end	0.21%				
7	4 x 15MW KHP	Unit-I	16.45	132kV KHP - Nangkor Line	41.86		
		Unit-II	16.54	132kV KHP - Kilikhar Line	23.22		
		Unit-III	16.49	5MVA, 132/11kV TFR	0.34		
		Unit-IV	16.58	132kV Motanga - Rangia Line	42.31		
		Total	66.06	Auxiliary Consumption & Transformation Losses at Generator end	0.97%		
8	2 x 59MW NHP	Unit-I	60.84	132kV NHP-MHP-I	60.40		
		Unit-II	58.99	132kV NHP-MHP-II	58.53		
		Total	119.83	Auxiliary Consumption & Transformation Losses at Generator end	0.75%		

Note: Generation-Load Summary (MW) for 12-Oct-2024 at 19:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,510.78	673.47	671.57	818.82	1.90
2	Eastern Grid	879.43	187.98	184.46	709.94	3.52
	Total	2,390.21	861.45	856.03	1,528.76	5.42

Note: Generation-Load Summary (MW) for 12-Oct-2023, at 19:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,325.88	638.77	633.94	706.88	4.83
2	Eastern Grid	549.96	182.49	178.26	347.7	4.23
	Total	1,875.84	821.26	812.20	1,054.58	9.06

Note: Daily Energy (MUs) and Power(MW) Statistics for 12-Oct-2024

Sl. No.	Net Energy Export (Bilateral)	Net Energy Import (Bilateral)	Daily Energy Met	Total Energy Generation	Peak Cross-border (MW)	Imp./Exp. through Exchange (MUs)
1	35.12	0.00	19.98	57.01	1,642.17	1.88

- The Instantaneous load balance,calculated as (Total generation - (Total export-Import) - Total domestic load), do not tend towards zero. This could be due to the following reasons:
 - Not all the meters are digital and nor are all the meter at all locations can be read at same time (say 9:00hrs) due to many meter to be read manually. ii) The clocks of all the locations are not synchronized.
- This report, compiled using the SCADA data, is prepared to give an overall idea of the generation & load flow for the system at a particular instant. This report also gives energy and import/export figures.
- When SCADA data are unavailable for certain stations due to technical issues, required data are collected from the site.