



ལྷན་ཁག་དང་འཇམ་ཚལ་གྱི་ཚོད་ཀྱི་འཇགས་ དཔལ་འདུན་འཇམ་གསལ་གསལ་གྲུབ་པ།  
 Ministry of Energy and Natural Resources  
 Royal Government of Bhutan  
 Office of the Bhutan Power System Operator  
 Thimphu: Bhutan



**THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 15-Oct-2024(-ve:import, +ve:export)**

Report Details	Date	Time	National Coincidental Peak Load (MW)	Date	Time	Load
	14-Oct-24	09:00 hrs		30-Dec-23	18:00 hrs	955.51

Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks
1	6 x 170MW THP	Unit- I	94.75	400kV THP - Siliguri Line - I	174.17	
		Unit- II	185.66	400kV THP - Siliguri Line - II	172.07	
		Unit- III	14.78	400kV THP - Siliguri Line - IV	166.38	
		Unit- IV	183.86	400kV THP - Malbase Line - III	340.56	
		Unit- V	185.99	400kV Malbase - Siliguri Line	125.45	
		Unit- VI	186.00	-	-	
		<b>Total</b>	<b>851.04</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>-0.25%</b>	
2	4 x 180MW MHP	Unit-I	123.27	400kV MHP - Jigmeling Line - I	0.00	400kV MHP-JLG Line I under Breakdown. 132kV MHP_Yurmoo Line- I not in Service. 400kV JLG_ALI Interim Line II on Standby. 80MVA transformer II under Breakdown.
		Unit-II	197.76	400kV MHP - Jigmeling Line - II	207.14	
		Unit-III	126.66	400kV MHP - Jigmeling Line - III	215.45	
		Unit-IV	135.47	400kV MHP - Jigmeling Line - IV	213.88	
		-	-	132kV MHP - Yurmo Line - I	0.00	
		-	-	132kV MHP - Yurmo Line - II	62.45	
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	65.46	
		-	-	400kV Jigmeling - Puna - Alipurduar Line - I	141.12	
		-	-	400kV Jigmeling - Puna - Alipurduar Line - II	0.00	
		-	-	400kV Jigmeling - Alipurduar Line - I	212.25	
		-	-	400kV Jigmeling - Alipurduar Line - II	211.33	
		-	-	80MVA, 220/132kV ICT - I (HV)	36.15	
		-	-	80MVA, 220/132kV ICT - II (HV)	0.00	
		-	-	220kV Tsirang - Jigmeling Line	22.84	
-	-	132kV Gelephu - Salakati Line	13.20			
<b>Total</b>	<b>583.16</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>-0.26%</b>			
3	4 x 84MW CHP	Unit- I	91.48	220kV CHP - Birpara Line - I	18.57	
		Unit- II	91.26	220kV CHP - Birpara Line - II	18.51	
		Unit- III	91.29	220kV CHP - Gedu	112.91	
		Unit- IV	91.33	220kV CHP - Jamjee (old) - I	68.89	
		-	-	220kV CHP - Jamjee - II (new)	69.00	
		-	-	220kV CHP - Jamjee - III (new)	66.68	
		-	-	220kV Malbase - Birpara Line	-14.16	
		-	-	66kV CHP - Gedu Line	10.01	
		-	-	3x3MVA, 66/11kV TFR	0.74	
<b>Total</b>	<b>365.36</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.01%</b>			
4	2 x 12MW BHP (U/S)	Unit- I	10.20	220kV BHP - Semtokha Line	107.00	
		Unit- II	11.00	66kV BHP - Lobeyasa Line	26.54	
		<b>Total</b>	<b>21.20</b>	220kV BHP - Tsirang Line	-75.13	
5	2 x 20MW BHP (L/S)	Unit- I	18.40	5MVA, 66/11kV TFR	0.41	
		Unit- II	19.00	30MVA ICT, 220/66kV (HV)	6.11	
		<b>Total</b>	<b>37.40</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>-0.38%</b>	
6	2 x 63MW DHP	Unit-I	51.27	220kV DHP - Tsirang Line	101.81	220kV DHP_Dagapela Line on Standby.
		Unit-II	50.99	220kV DHP - Dagapela Line	0.00	
		-	-	220kV Jigmeling - Dagapela Line	52.44	
		-	-	5MVA, 220/33kV TFR	0.20	
<b>Total</b>	<b>102.26</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.24%</b>			
7	4 x 15MW KHP	Unit- I	16.53	132kV KHP - Nangkor Line	44.02	
		Unit-II	16.55	132kV KHP - Kilikhar Line	21.25	
		Unit- III	16.50	5MVA, 132/11kV TFR	0.22	
		Unit- IV	16.57	132kV Motanga - Rangia Line	42.69	
		<b>Total</b>	<b>66.15</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>1.00%</b>	
8	2 x 59MW NHP	Unit-I	55.95	132kV NHP-MHP-I	55.62	
		Unit-II	58.98	132kV NHP-MHP-II	58.62	
		<b>Total</b>	<b>114.93</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.60%</b>	

Note: Generation-Load Summary (MW) for 14-Oct-24 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,377.26	693.43	695.49	660.99	-2.06
2	Eastern Grid	764.24	166.49	166.66	620.59	-0.17
	<b>Total</b>	<b>2,141.50</b>	<b>859.92</b>	<b>862.15</b>	<b>1,281.58</b>	<b>-2.23</b>

Note: Generation-Load Summary for 14-Oct-23 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,194.70	562.82	548.65	621.59	14.17
2	Eastern Grid	482.76	206.94	206.46	286.10	0.48
	<b>Total</b>	<b>1,677.46</b>	<b>769.76</b>	<b>755.11</b>	<b>907.69</b>	<b>14.65</b>

THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 15-Oct-2024(-ve:import, +ve:export)							
Report Details	Date	Time	National Coincidental Peak Load (MW)		Date	Time	Load
	14-Oct-2024	19:00 hrs			30-Dec-2023	18:00 hrs	955.51
Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks	
1	6 x 170MW THP	Unit-I	50.25	400kV THP - Siliguri Line - I	164.24		
		Unit-II	184.78	400kV THP - Siliguri Line - II	163.76		
		Unit-III	59.47	400kV THP - Siliguri Line - IV	157.93		
		Unit-IV	185.16	400kV THP - Malbase Line - III	365.62		
		Unit-V	186.09	400kV Malbase - Siliguri Line	110.90		
		Unit-VI	185.79	-	-		
		<b>Total</b>	<b>851.54</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.00%</b>		
2	4 x 180MW MHP	Unit-I	130.21	400kV MHP - Jigmeling Line - I	0.00	400kV MHP-JLG Line I under Breakdown. 132kV MHP_Yurmo Line-I not in Service. 400kV JLG_ALI Interim Line II on Standby. 80MVA transformer II under Breakdown.	
		Unit-II	197.84	400kV MHP - Jigmeling Line - II	193.88		
		Unit-III	130.76	400kV MHP - Jigmeling Line - III	201.41		
		Unit-IV	85.40	400kV MHP - Jigmeling Line - IV	199.97		
		-	-	132kV MHP - Yurmo Line - I	0.00		
		-	-	132kV MHP - Yurmo Line - II	60.46		
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	81.82		
		-	-	400kV Jigmeling - Puna - Alipurduar Line - I	127.27		
		-	-	400kV Jigmeling - Puna - Alipurduar Line - II	0.00		
		-	-	400kV Jigmeling - Alipurduar Line - I	189.82		
		-	-	400kV Jigmeling - Alipurduar Line - II	190.55		
		-	-	80MVA, 220/132kV ICT - I (HV)	44.88		
		-	-	80MVA, 220/132kV ICT - II (HV)	0.00		
		-	-	220kV Tsirang - Jigmeling Line	16.31		
		-	-	132kV Gelephu - Salakati Line	10.43		
<b>Total</b>	<b>544.21</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.50%</b>				
3	4 x 84MW CHP	Unit-I	91.48	220kV CHP - Birpara Line - I	22.38	66kV CHP-Gedu Line under shutdown.	
		Unit-II	91.26	220kV CHP - Birpara Line - II	22.27		
		Unit-III	91.29	220kV CHP - Gedu	100.37		
		Unit-IV	91.33	220kV CHP - Jamjee (old) - I	73.92		
		-	-	220kV CHP - Jamjee - II (new)	74.37		
		-	-	220kV CHP - Jamjee - III (new)	71.84		
		-	-	220kV Malbase - Birpara Line	1.49		
		-	-	66kV CHP - Gedu Line	0.00		
		-	-	3x3MVA, 66/11kV TFR	0.38		
<b>Total</b>	<b>365.36</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>-0.05%</b>				
4	2 x 12MW BHP (U/S)	Unit-I	10.33	220kV BHP - Sentsokha Line	111.00		
		Unit-II	10.90	66kV BHP - Lobeyasa Line	29.15		
		<b>Total</b>	<b>21.23</b>	220kV BHP - Tsirang Line	-82.48		
5	2 x 20MW BHP (L/S)	Unit-I	18.93	5MVA, 66/11kV TFR	0.56		
		Unit-II	18.24	30MVA ICT, 220/66kV (HV)	9.11		
		<b>Total</b>	<b>37.17</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.29%</b>		
6	2 x 63MW DHP	Unit-I	51.82	220kV DHP - Tsirang Line	102.99	220kV DHP_Dagapela Line on Standby.	
		Unit-II	51.69	220kV DHP - Dagapela Line	0.00		
		-	-	220kV Jigmeling - Dagapela Line	53.13		
		-	-	5MVA, 220/33kV TFR	0.20		
<b>Total</b>	<b>103.51</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.31%</b>				
7	4 x 15MW KHP	Unit-I	16.56	132kV KHP - Nangkor Line	41.21		
		Unit-II	16.57	132kV KHP - Kilikhar Line	23.93		
		Unit-III	16.56	5MVA, 132/11kV TFR	0.34		
		Unit-IV	16.50	132kV Motanga - Rangia Line	54.55		
		<b>Total</b>	<b>66.19</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>1.07%</b>		
8	2 x 59MW NHP	Unit-I	56.08	132kV NHP-MHP-I	55.66		
		Unit-II	59.01	132kV NHP-MHP-II	58.59		
		<b>Total</b>	<b>115.09</b>	<b>Auxiliary Consumption &amp; Transformation Losses at Generator end</b>	<b>0.73%</b>		

Note: Generation-Load Summary (MW) for 14-Oct-2024 at 19:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,378.81	719.53	719.22	642.97	0.31
2	Eastern Grid	725.49	169.18	164.89	572.62	4.29
	<b>Total</b>	<b>2,104.30</b>	<b>888.71</b>	<b>884.11</b>	<b>1,215.59</b>	<b>4.60</b>

Note: Generation-Load Summary (MW) for 14-Oct-2023, at 19:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,282.35	547.63	540.11	724.44	7.52
2	Eastern Grid	457.60	202.48	198.54	265.4	3.94
	<b>Total</b>	<b>1,739.95</b>	<b>750.11</b>	<b>738.65</b>	<b>989.84</b>	<b>11.46</b>

Note: Daily Energy (MUs) and Power(MW) Statistics for 14-Oct-2024

Sl. No.	Net Energy Export (Bilateral)	Net Energy Import (Bilateral)	Daily Energy Met	Total Energy Generation	Peak Cross-border (MW)	Imp./Exp. through Exchange (MUs)
1	28.68	0.00	20.37	51.30	1,370.80	2.21

- The Instantaneous load balance, calculated as (Total generation - (Total export-Import) - Total domestic load), do not tend towards zero. This could be due to the following reasons:
  - Not all the meters are digital and nor are all the meter at all locations can be read at same time (say 9:00hrs) due to many meter to be read manually. ii) The clocks of all the locations are not synchronized.
- This report, compiled using the SCADA data, is prepared to give an overall idea of the generation & load flow for the system at a particular instant. This report also gives energy and import/export figures.
- When SCADA data are unavailable for certain stations due to technical issues, required data are collected from the site.