



ལྷན་ཁག་གི་འཕེལ་རྒྱུ་ལྟོན་ལྷན་ཁག་ རྒྱལ་ཁབ་འཕེལ་རྒྱུ་གཞི་གཉེན་ལྷན་ཁག་
 Ministry of Energy and Natural Resources
 Royal Government of Bhutan
 Office of the Bhutan Power System Operator
 Thimphu: Bhutan



THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 17-Oct-2024(-ve:import, +ve:export)

Report Details	Date	Time	National Coincidental Peak Load (MW)	Date	Time	Load
	16-Oct-24	09:00 hrs		30-Dec-23	18:00 hrs	955.51

Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks
1	6 x 170MW THP	Unit- I	124.43	400kV THP - Siliguri Line - I	149.41	Unit V Under Shutdown
		Unit- II	183.59	400kV THP - Siliguri Line - II	148.90	
		Unit- III	92.08	400kV THP - Siliguri Line - IV	143.66	
		Unit- IV	182.49	400kV THP - Malbase Line - III	327.14	
		Unit- V	0.00	400kV Malbase - Siliguri Line	101.81	
		Unit- VI	186.59	-	-	
		Total	769.18	Auxiliary Consumption & Transformation Losses at Generator end	0.01%	
2	4 x 180MW MHP	Unit-I	140.25	400kV MHP - Jigmeling Line - I	0.00	400kV MHP-JLG Line I under Breakdown. 132kV MHP_Yurmoo Line- I not in Service. 400kV JLG_ALI Interim Line II on Standby. 80MVA transformer II under Breakdown.
		Unit-II	198.11	400kV MHP - Jigmeling Line - II	220.49	
		Unit-III	146.84	400kV MHP - Jigmeling Line - III	229.07	
		Unit-IV	140.56	400kV MHP - Jigmeling Line - IV	227.27	
		-	-	132kV MHP - Yurmo Line - I	0.00	
		-	-	132kV MHP - Yurmo Line - II	59.86	
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	78.18	
		-	-	400kV Jigmeling - Puna - Alipurduar Line - I	147.65	
		-	-	400kV Jigmeling - Puna - Alipurduar Line - II	0.00	
		-	-	400kV Jigmeling - Alipurduar Line - I	221.82	
		-	-	400kV Jigmeling - Alipurduar Line - II	223.27	
		-	-	80MVA, 220/132kV ICT - I (HV)	43.92	
		-	-	80MVA, 220/132kV ICT - II (HV)	0.00	
		-	-	220kV Tsirang - Jigmeling Line	17.21	
		-	-	132kV Gelephu - Salakati Line	14.17	
Total	625.76	Auxiliary Consumption & Transformation Losses at Generator end	0.52%			
3	4 x 84MW CHP	Unit- I	91.48	220kV CHP - Birpara Line - I	22.52	66kV CHP-Gedu line under shutdown.
		Unit- II	91.26	220kV CHP - Birpara Line - II	22.50	
		Unit- III	91.29	220kV CHP - Gedu	114.10	
		Unit- IV	91.33	220kV CHP - Jamjee (old) - I	68.69	
		-	-	220kV CHP - Jamjee - II (new)	69.22	
		-	-	220kV CHP - Jamjee - III (new)	66.91	
		-	-	220kV Malbase - Birpara Line	-8.62	
		-	-	66kV CHP - Gedu Line	0.00	
		-	-	3x3MVA, 66/11kV TFR	0.90	
Total	365.36	Auxiliary Consumption & Transformation Losses at Generator end	0.14%			
4	2 x 12MW BHP (U/S)	Unit- I	10.10	220kV BHP - Semtokha Line	104.10	
		Unit- II	10.00	66kV BHP - Lobeyasa Line	26.02	
		Total	20.10	220kV BHP - Tsirang Line	-74.69	
5	2 x 20MW BHP (L/S)	Unit- I	17.60	5MVA, 66/11kV TFR	0.36	
		Unit- II	18.10	30MVA ICT, 220/66kV (HV)	6.68	
		Total	35.70	Auxiliary Consumption & Transformation Losses at Generator end	0.02%	
6	2 x 63MW DHP	Unit-I	47.79	220kV DHP - Tsirang Line	95.07	220kV DHP_Dagapela Line on Standby.
		Unit-II	47.75	220kV DHP - Dagapela Line	0.00	
		-	-	220kV Jigmeling - Dagapela Line	52.43	
		-	-	5MVA, 220/33kV TFR	0.30	
Total	95.54	Auxiliary Consumption & Transformation Losses at Generator end	0.18%			
7	4 x 15MW KHP	Unit- I	16.56	132kV KHP - Nangkor Line	44.02	
		Unit-II	16.52	132kV KHP - Kilikhar Line	21.20	
		Unit- III	16.61	5MVA, 132/11kV TFR	0.25	
		Unit- IV	16.50	132kV Motanga - Rangia Line	37.11	
		Total	66.19	Auxiliary Consumption & Transformation Losses at Generator end	1.09%	
8	2 x 59MW NHP	Unit-I	56.03	132kV NHP-MHP-I	55.53	
		Unit-II	59.06	132kV NHP-MHP-II	58.65	
		Total	115.09	Auxiliary Consumption & Transformation Losses at Generator end	0.79%	

Note: Generation-Load Summary (MW) for 16-Oct-24 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,285.88	688.49	687.72	500.18	0.77
2	Eastern Grid	807.04	180.23	175.35	644.02	4.88
Total		2,092.92	868.72	863.07	1,224.20	5.65

Note: Generation-Load Summary for 16-Oct-23 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,051.98	358.56	349.55	926.73	9.01
2	Eastern Grid	472.52	93.77	90.68	439.50	3.09
Total		1,524.50	452.33	440.23	1,366.23	12.10

THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 17-Oct-2024(-ve:import, +ve:export)

Report Details	Date	Time	National Coincidental Peak Load (MW)		Date	Time	Load
	16-Oct-2024	19:00 hrs			30-Dec-2023	18:00 hrs	955.51

Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks
1	6 x 170MW THP	Unit-I	128.26	400kV THP - Siliguri Line - I	182.13	
		Unit-II	184.03	400kV THP - Siliguri Line - II	182.15	
		Unit-III	98.92	400kV THP - Siliguri Line- IV	176.52	
		Unit-IV	185.09	400kV THP - Malbase Line - III	339.25	
		Unit-V	98.70	400kV Malbase - Siliguri Line	137.35	
		Unit-VI	185.59	-	-	
		Total	880.59	Auxiliary Consumption & Transformation Losses at Generator end	0.06%	
2	4 x 180MW MHP	Unit-I	153.83	400kV MHP - Jigmeling Line - I	0.00	400kV MHP-JLG Line I under Breakdown. 132kV MHP_Yurmo Line- I not in Service. 400kV JLG_ALI Interim Line II on Standby.
		Unit-II	197.78	400kV MHP - Jigmeling Line - II	194.88	
		Unit-III	150.91	400kV MHP - Jigmeling Line - III	202.37	
		Unit-IV	50.29	400kV MHP - Jigmeling Line - IV	200.92	
		-	-	132kV MHP - Yurmo Line - I	0.00	
		-	-	132kV MHP - Yurmo Line - II	62.80	
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	108.00	
		-	-	400kV Jigmeling - Puna - Alipurduar Line - I	120.27	
		-	-	400kV Jigmeling - Puna - Alipurduar Line - II	0.00	
		-	-	400kV Jigmeling - Alipurduar Line - I	178.91	
		-	-	400kV Jigmeling - Alipurduar Line - II	179.64	
		-	-	80MVA, 220/132kV ICT - I (HV)	27.04	
		-	-	80MVA, 220/132kV ICT - II (HV)	26.87	
		-	-	220kV Tsirang - Jigmeling Line	-2.14	
		-	-	132kV Gelephu - Salakati Line	15.16	
Total	552.81	Auxiliary Consumption & Transformation Losses at Generator end	0.19%			
3	4 x 84MW CHP	Unit-I	91.48	220kV CHP - Birpara Line - I	15.67	66kV CHP-Gedu Line under shutdown.
		Unit-II	91.26	220kV CHP - Birpara Line - II	15.67	
		Unit-III	91.29	220kV CHP - Gedu	115.00	
		Unit-IV	91.33	220kV CHP - Jamjee (old) - I	72.83	
		-	-	220kV CHP - Jamjee - II (new)	73.36	
		-	-	220kV CHP - Jamjee - III (new)	70.92	
		-	-	220kV Malbase - Birpara Line	-20.87	
		-	-	66kV CHP - Gedu Line	0.00	
-	-	3x3MVA, 66/11kV TFR	1.04			
Total	365.36	Auxiliary Consumption & Transformation Losses at Generator end	0.24%			
4	2 x 12MW BHP (U/S)	Unit-I	9.80	220kV BHP - Sento Kha Line	115.43	
		Unit-II	10.10	66kV BHP - Lobeyasa Line	29.27	
		Total	19.90	220kV BHP - Tsirang Line	-90.29	
5	2 x 20MW BHP (L/S)	Unit-I	17.60	5MVA, 66/11kV TFR	0.59	
		Unit-II	18.10	30MVA ICT, 220/66kV (HV)	10.26	
		Total	35.70	Auxiliary Consumption & Transformation Losses at Generator end	1.08%	
6	2 x 63MW DHP	Unit-I	46.83	220kV DHP - Tsirang Line	92.31	220kV DHP_Dagapela Line on Standby.
		Unit-II	46.01	220kV DHP - Dagapela Line	0.00	
		-	-	220kV Jigmeling - Dagapela Line	53.01	
		-	-	5MVA, 220/33kV TFR	0.30	
Total	92.84	Auxiliary Consumption & Transformation Losses at Generator end	0.25%			
7	4 x 15MW KHP	Unit-I	16.49	132kV KHP - Nangkor Line	41.31	
		Unit-II	16.51	132kV KHP - Kilikhar Line	23.63	
		Unit-III	16.44	5MVA, 132/11kV TFR	0.35	
		Unit-IV	16.53	132kV Motanga - Rangia Line	54.10	
		Total	65.97	Auxiliary Consumption & Transformation Losses at Generator end	1.03%	
8	2 x 59MW NHP	Unit-I	55.98	132kV NHP-MHP-I	55.64	
		Unit-II	53.99	132kV NHP-MHP-II	53.58	
		Total	109.97	Auxiliary Consumption & Transformation Losses at Generator end	0.68%	

Note: Generation-Load Summary (MW) for 16-Oct-2024 at 19:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,394.39	707.91	705.67	688.62	2.24
2	Eastern Grid	728.75	178.53	176.04	548.08	2.49
	Total	2,123.14	886.44	881.71	1,236.70	4.73

Note: Generation-Load Summary (MW) for 16-Oct-2023, at 19:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,116.39	617.11	613.16	489	3.95
2	Eastern Grid	472.96	246.6	244.10	236.64	2.50
	Total	1,589.35	863.71	857.26	725.64	6.45

Note: Daily Energy (MUs) and Power(MW) Statistics for 16-Oct-2024

Sl. No.	Net Energy Export (Bilateral)	Net Energy Import (Bilateral)	Daily Energy Met	Total Energy Generation	Peak Cross-border (MW)	Imp./Exp. through Exchange (MUs)
1	28.54	0.00	20.13	48.85	1,344.44	1.78

1. The Instantaneous load balance, calculated as (Total generation - (Total export-Import) - Total domestic load), do not tend towards zero. This could be due to the following reasons:
 i) Not all the meters are digital and nor are all the meter at all locations can be read at same time (say 9:00hrs) due to many meter to be read manually. ii) The clocks of all the locations are not synchronized.
 2. This report, compiled using the SCADA data, is prepared to give an overall idea of the generation & load flow for the system at a particular instant. This report also gives energy and import/export figures.
 3. When SCADA data are unavailable for certain stations due to technical issues, required data are collected from the site.