



འཇུག་ལྷན་པོའི་འཕེལ་རྒྱུ་ལྷན་ཁག་ འཕེལ་རྒྱུ་ལྷན་ཁག་གི་འཕེལ་རྒྱུ་ལྷན་ཁག་
 Ministry of Energy and Natural Resources
 Royal Government of Bhutan
 Office of the Bhutan Power System Operator
 Thimphu: Bhutan



THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 25-Oct-2024(-ve:import, +ve:export)

Report Details	Date	Time	National Coincidental Peak Load (MW)	Date	Time	Load
	24-Oct-24	09:00 hrs		30-Dec-23	18:00 hrs	955.51

Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks
1	6 x 170MW THP	Unit- I	109.95	400kV THP - Siliguri Line - I	0.00	Unit-V on AMP. 400kV THP_Siliguri Line-I on Standby.
		Unit- II	148.37	400kV THP - Siliguri Line - II	132.91	
		Unit- III	103.55	400kV THP - Siliguri Line- IV	125.17	
		Unit- IV	148.18	400kV THP - Malbase Line - III	350.99	
		Unit- V	0.00	400kV Malbase - Siliguri Line	80.00	
		Unit- VI	100.01	-	-	
		Total	610.06	Auxiliary Consumption & Transformation Losses at Generator end	0.16%	
2	4 x 180MW MHP	Unit-I	145.25	400kV MHP - Jigmeling Line - I	0.00	400kV MHP-JLG Line I & II under Shutdown. Unit-II under shutdown. 132kV MHP_Yurmo Line- I not in Service. 400kV JLG_ALI Interim Line II on Standby.
		Unit-II	0.00	400kV MHP - Jigmeling Line - II	0.00	
		Unit-III	145.86	400kV MHP - Jigmeling Line - III	225.69	
		Unit-IV	142.43	400kV MHP - Jigmeling Line - IV	224.47	
		-	-	132kV MHP - Yurmo Line - I	0.00	
		-	-	132kV MHP - Yurmo Line - II	61.37	
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	102.55	
		-	-	400kV Jigmeling - Puna - Alipurduar Line - I	86.55	
		-	-	400kV Jigmeling - Puna - Alipurduar Line - II	0.00	
		-	-	400kV Jigmeling - Alipurduar Line - I	128.00	
		-	-	400kV Jigmeling - Alipurduar Line - II	129.46	
		-	-	80MVA, 220/132kV ICT - I (HV)	21.98	
		-	-	80MVA, 220/132kV ICT - II (HV)	21.79	
		-	-	220kV Tsirang - Jigmeling Line	-6.23	
		-	-	132kV Gelephu - Salakati Line	12.59	
Total	433.54	Auxiliary Consumption & Transformation Losses at Generator end	0.34%			
3	4 x 84MW CHP	Unit- I	70.20	220kV CHP - Birpara Line - I	-9.61	
		Unit- II	70.10	220kV CHP - Birpara Line - II	-4.20	
		Unit- III	71.55	220kV CHP - Gedu	63.26	
		Unit- IV	71.50	220kV CHP - Jamjee (old) - I	75.04	
		-	-	220kV CHP - Jamjee - II (new)	75.48	
		-	-	220kV CHP - Jamjee - III (new)	72.72	
		-	-	220kV Malbase - Birpara Line	-14.94	
		-	-	66kV CHP - Gedu Line	8.71	
		-	-	3x3MVA, 66/11kV TFR	1.05	
Total	283.35	Auxiliary Consumption & Transformation Losses at Generator end	0.32%			
4	2 x 12MW BHP (U/S)	Unit- I	8.50	220kV BHP - Semtokha Line	96.90	
		Unit- II	8.93	66kV BHP - Lobeyasa Line	25.15	
		Total	17.43	220kV BHP - Tsirang Line	-75.35	
5	2 x 20MW BHP (L/S)	Unit- I	15.26	5MVA, 66/11kV TFR	0.37	
		Unit- II	14.71	30MVA ICT, 220/66kV (HV)	9.12	
		Total	29.97	Auxiliary Consumption & Transformation Losses at Generator end	0.70%	
6	2 x 63MW DHP	Unit-I	36.81	220kV DHP - Tsirang Line	72.35	220kV DHP_Dagapela Line on Standby.
		Unit-II	35.99	220kV DHP - Dagapela Line	0.00	
		-	-	220kV Jigmeling - Dagapela Line	52.62	
		-	-	5MVA, 220/33kV TFR	0.20	
Total	72.80	Auxiliary Consumption & Transformation Losses at Generator end	0.34%			
7	4 x 15MW KHP	Unit- I	13.06	132kV KHP - Nangkhor Line	32.53	
		Unit-II	12.51	132kV KHP - Kilikhar Line	17.96	
		Unit- III	13.08	5MVA, 132/11kV TFR	0.21	
		Unit- IV	12.55	132kV Motanga - Rangia Line	28.56	
		Total	51.20	Auxiliary Consumption & Transformation Losses at Generator end	0.98%	
8	2 x 59MW NHP	Unit-I	39.97	132kV NHP-MHP-I	39.74	
		Unit-II	39.97	132kV NHP-MHP-II	39.74	
		Total	79.94	Auxiliary Consumption & Transformation Losses at Generator end	0.58%	

Note: Generation-Load Summary (MW) for 24-Oct-24 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,013.61	710.51	708.04	309.33	2.47
2	Eastern Grid	564.68	173.29	170.84	385.16	2.45
	Total	1,578.29	883.80	878.88	694.49	4.92

Note: Generation-Load Summary for 24-Oct-23 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	842.14	663.06	662.49	211.30	0.57
2	Eastern Grid	335.40	187.26	186.65	115.92	0.61
	Total	1,177.54	850.32	849.14	327.22	1.18

THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 25-Oct-2024(-ve:import, +ve:export)

Report Details	Date	Time	National Coincidental Peak Load (MW)		Date	Time	Load
	24-Oct-2024	19:00 hrs			30-Dec-2023	18:00 hrs	955.51

Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks
1	6 x 170MW THP	Unit-I	119.39	400kV THP - Siliguri Line - I	0.00	400kV THP-Siliguri Line - I on Standby. Unit-V on AMP
		Unit-II	148.31	400kV THP - Siliguri Line - II	138.69	
		Unit-III	113.70	400kV THP - Siliguri Line- IV	130.18	
		Unit-IV	148.59	400kV THP - Malbase Line - III	361.94	
		Unit-V	0.00	400kV Malbase - Siliguri Line	81.03	
		Unit-VI	100.35		-	
		Total	630.34	Auxiliary Consumption & Transformation Losses at Generator end	-0.07%	
2	4 x 180MW MHP	Unit-I	130.14	400kV MHP - Jigmeling Line - I	0.00	Unit III Under shutdown. 400kV MHP-JLG Line I under breakdown. 400kV MHP-JLG line II under standby. 132kV MHP_Yurmoo Line- I not in Service. 400kV JLG_ALI Interim Line II on Standby.
		Unit-II	132.84	400kV MHP - Jigmeling Line - II	0.00	
		Unit-III	0.00	400kV MHP - Jigmeling Line - III	205.44	
		Unit-IV	130.45	400kV MHP - Jigmeling Line - IV	204.25	
		-	-	132kV MHP - Yurmo Line - I	0.00	
		-	-	132kV MHP - Yurmo Line - II	61.93	
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	110.55	
		-	-	400kV Jigmeling - Puna - Alipurduar Line - I	73.46	
		-	-	400kV Jigmeling - Puna - Alipurduar Line - II	0.00	
		-	-	400kV Jigmeling - Alipurduar Line - I	109.09	
		-	-	400kV Jigmeling - Alipurduar Line - II	109.82	
		-	-	80MVA, 220/132kV ICT - I (HV)	19.59	
		-	-	80MVA, 220/132kV ICT - II (HV)	19.36	
		-	-	220kV Tsirang - Jigmeling Line	-17.00	
		-	-	132kV Gelephu - Salakati Line	2.80	
Total	393.43	Auxiliary Consumption & Transformation Losses at Generator end	0.34%			
3	4 x 84MW CHP	Unit-I	71.08	220kV CHP - Birpara Line - I	-7.11	
		Unit-II	72.58	220kV CHP - Birpara Line - II	-4.56	
		Unit-III	70.56	220kV CHP - Gedu	57.60	
		Unit-IV	69.97	220kV CHP - Jamjee (old) - I	77.01	
		-	-	220kV CHP - Jamjee - II (new)	77.41	
		-	-	220kV CHP - Jamjee - III (new)	74.50	
		-	-	220kV Malbase - Birpara Line	-9.31	
		-	-	66kV CHP - Gedu Line	7.90	
		-	-	3x3MVA, 66/11kV TFR	1.07	
		Total	284.19	Auxiliary Consumption & Transformation Losses at Generator end	0.13%	
4	2 x 12MW BHP (U/S)	Unit-I	7.87	220kV BHP - Sentokha Line	105.13	
		Unit-II	8.92	66kV BHP - Lobeyasa Line	27.94	
		Total	16.79	220kV BHP - Tsirang Line	-86.83	
5	2 x 20MW BHP (L/S)	Unit-I	15.27	5MVA, 66/11kV TFR	0.54	
		Unit-II	15.00	30MVA ICT, 220/66kV (HV)	12.37	
		Total	30.27	Auxiliary Consumption & Transformation Losses at Generator end	0.59%	
6	2 x 63MW DHP	Unit-I	36.31	220kV DHP - Tsirang Line	71.82	220kV DHP_Dagapela Line on Standby.
		Unit-II	35.96	220kV DHP - Dagapela Line	0.00	
		-	-	220kV Jigmeling - Dagapela Line	53.28	
		-	-	5MVA, 220/33kV TFR	0.30	
Total	72.27	Auxiliary Consumption & Transformation Losses at Generator end	0.21%			
7	4 x 15MW KHP	Unit-I	13.61	132kV KHP - Nangkor Line	32.80	
		Unit-II	13.67	132kV KHP - Kilikhar Line	20.82	
		Unit-III	13.64	5MVA, 132/11kV TFR	0.33	
		Unit-IV	13.70	132kV Motanga - Rangia Line	27.52	
		Total	54.62	Auxiliary Consumption & Transformation Losses at Generator end	1.23%	
8	2 x 59MW NHP	Unit-I	30.02	132kV NHP-MHP-I	29.84	
		Unit-II	50.18	132kV NHP-MHP-II	49.70	
		Total	80.20	Auxiliary Consumption & Transformation Losses at Generator end	0.82%	

Note: Generation-Load Summary (MW) for 24-Oct-2024 at 19:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	1,033.86	722.74	722.41	328.92	0.33
2	Eastern Grid	528.25	187.76	185.08	322.69	2.68
	Total	1,562.11	910.50	907.49	651.61	3.01

Note: Generation-Load Summary (MW) for 24-Oct-2023, at 19:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	840.57	682.18	681.66	209.06	0.52
2	Eastern Grid	335.82	195.61	194.03	89.54	1.58
	Total	1,176.39	877.79	875.69	298.60	2.10

Note: Daily Energy (MUs) and Power(MW) Statistics for 24-Oct-2024

Sl. No.	Net Energy Export (Bilateral)	Net Energy Import (Bilateral)	Daily Energy Met	Total Energy Generation	Peak Cross-border (MW)	Imp./Exp. through Exchange (MUs)
1	16.30	0.00	20.72	38.33	794.14	1.12

- The Instantaneous load balance, calculated as (Total generation - (Total export-Import) - Total domestic load), do not tend towards zero. This could be due to the following reasons:
 - Not all the meters are digital and nor are all the meter at all locations can be read at same time (say 9:00hrs) due to many meter to be read manually.
 - The clocks of all the locations are not synchronized.
- This report, compiled using the SCADA data, is prepared to give an overall idea of the generation & load flow for the system at a particular instant. This report also gives energy and import/export figures.
- When SCADA data are unavailable for certain stations due to technical issues, required data are collected from the site.