



ལྷན་ཁག་དང་འཛམ་གླིང་གི་རྒྱུ་ཕྱི་ཕན་ལག་ དཔལ་ལྷན་འབྲུག་གཞུང་།
 Ministry of Energy and Natural Resources
 Royal Government of Bhutan
 Office of the Bhutan Power System Operator
 Thimphu: Bhutan



THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 12-Nov-2024(-ve:import, +ve:export)

Report Details	Date	Time	National Coincidental Peak Load (MW)	Date	Time	Load
	11-Nov-24	09:00 hrs		30-Dec-23	18:00 hrs	955.51

Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks
1	6 x 170MW THP	Unit- I	114.61	400kV THP - Siliguri Line - I	139.09	Unit- IV under Shutdown. Unit-V under AMP. 400kV THP-MAL line under Shutdown
		Unit- II	78.34	400kV THP - Siliguri Line - II	138.68	
		Unit- III	118.41	400kV THP - Siliguri Line- IV	133.74	
		Unit- IV	0.00	400kV THP - Malbase Line - III	0.00	
		Unit- V	0.00	400kV Malbase - Siliguri Line	-220.79	
		Unit- VI	100.16	-	-	
		Total	411.52	Auxiliary Consumption & Transformation Losses at Generator end	0.00%	
2	4 x 180MW MHP	Unit-I	0.00	400kV MHP - Jigmeling Line - I	0.00	Unit-I under AMP. Unit-II on Standby. 400kV MHP-JLG Line I under Breakdown. 400kV MHP-JLG line II on Standby. 132kV MHP_Yurmo Line- I not in Service. 400kV JLG_ALI Interim Line II on Standby.
		Unit-II	0.00	400kV MHP - Jigmeling Line - II	0.00	
		Unit-III	146.87	400kV MHP - Jigmeling Line - III	129.74	
		Unit-IV	135.60	400kV MHP - Jigmeling Line - IV	128.92	
		-	-	132kV MHP - Yurmo Line - I	0.00	
		-	-	132kV MHP - Yurmo Line - II	62.79	
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	135.64	
		-	-	400kV Jigmeling - Puna - Alipurduar Line - I	29.82	
		-	-	400kV Jigmeling - Puna - Alipurduar Line - II	0.00	
		-	-	400kV Jigmeling - Alipurduar Line - I	45.09	
		-	-	400kV Jigmeling - Alipurduar Line - II	45.82	
		-	-	80MVA, 220/132kV ICT - I (HV)	22.10	
		-	-	80MVA, 220/132kV ICT - II (HV)	21.93	
		-	-	220kV Tsiurang - Jigmeling Line	-40.14	
		-	-	132kV Gelephu - Salakati Line	9.29	
Total	282.47	Auxiliary Consumption & Transformation Losses at Generator end	0.22%			
3	4 x 84MW CHP	Unit- I	70.97	220kV CHP - Birpara Line - I	-46.99	Unit-IV on Standby.
		Unit- II	58.64	220kV CHP - Birpara Line - II	-46.43	
		Unit- III	60.10	220kV CHP - Gedu	51.61	
		Unit- IV	0.00	220kV CHP - Jamjee (old) - I	75.36	
		-	-	220kV CHP - Jamjee - II (new)	75.63	
		-	-	220kV CHP - Jamjee - III (new)	73.23	
		-	-	220kV Malbase - Birpara Line	-73.42	
		-	-	66kV CHP - Gedu Line	7.60	
		-	-	3x3MVA, 66/11kV TFR	1.13	
Total	189.71	Auxiliary Consumption & Transformation Losses at Generator end	-0.75%			
4	2 x 12MW BHP (U/S)	Unit- I	6.11	220kV BHP - Semtokha Line	96.09	
		Unit- II	6.51	66kV BHP - Lobeyasa Line	24.09	
Total	12.62	220kV BHP - Tsiurang Line	-84.63			
5	2 x 20MW BHP (L/S)	Unit- I	11.86	5MVA, 66/11kV TFR	0.38	
		Unit- II	11.44	30MVA ICT, 220/66kV (HV)	12.63	
Total	23.30	Auxiliary Consumption & Transformation Losses at Generator end	-0.03%			
6	2 x 63MW DHP	Unit-I	0.00	220kV DHP - Tsiurang Line	47.71	Unit I on Standby. 220kV DHP_Dagapela Line on Standby.
		Unit-II	47.95	220kV DHP - Dagapela Line	0.00	
		-	-	220kV Jigmeling - Dagapela Line	52.86	
		-	-	5MVA, 220/33kV TFR	0.20	
Total	47.95	Auxiliary Consumption & Transformation Losses at Generator end	0.08%			
7	4 x 15MW KHP	Unit- I	11.13	132kV KHP - Nangkhor Line	18.81	KHP Unit-IV on Standby.
		Unit-II	11.15	132kV KHP - Kilikhar Line	13.92	
		Unit- III	11.14	5MVA, 132/11kV TFR	0.23	
		Unit- IV	0.00	132kV Motanga - Rangia Line	18.38	
		Total	33.42	Auxiliary Consumption & Transformation Losses at Generator end	1.38%	
8	2 x 59MW NHP	Unit-I	20.02	132kV NHP-MHP-I	19.77	
		Unit-II	20.02	132kV NHP-MHP-II	19.83	
Total	40.04	Auxiliary Consumption & Transformation Losses at Generator end	1.10%			

Note: Generation-Load Summary (MW) for 11-Nov-24 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	685.10	701.36	702.75	23.88	-1.39
2	Eastern Grid	355.93	167.39	165.87	148.40	1.52
Total		1,041.03	868.75	868.62	172.28	0.13

Note: Generation-Load Summary for 11-Nov-23 at 09:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	617.97	659.79	653.80	33.80	5.99
2	Eastern Grid	250.00	189.01	187.56	-14.63	1.45
Total		867.97	848.80	841.36	19.17	7.44

THE DAILY BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT & ENERGY FIGURES ISSUED ON 12-Nov-2024(-ve:import, +ve:export)

Report Details	Date	Time	National Coincidental Peak Load (MW)	Date	Time	Load
	11-Nov-2024	18:00 hrs		30-Dec-2023	18:00 hrs	955.51

Sl. No.	Hydropower Plant	Unit	MW	Transmission Lines and Elements	Load (MW)	Remarks
1	6 x 170MW THP	Unit-I	114.76	400kV THP - Siliguri Line - I	139.14	Unit- IV under Shutdown. Unit-V under AMP. 400kV THP-MAL line under Shutdown
		Unit- II	78.09	400kV THP - Siliguri Line - II	138.73	
		Unit- III	118.84	400kV THP - Siliguri Line- IV	133.79	
		Unit- IV	0.00	400kV THP - Malbase Line - III	0.00	
		Unit- V	0.00	400kV Malbase - Siliguri Line	-239.40	
		Unit- VI	99.97		-	
		Total	411.66	Auxiliary Consumption & Transformation Losses at Generator end	0.00%	
2	4 x 180MW MHP	Unit-I	0.00	400kV MHP - Jigmeling Line - I	0.00	Unit-I under AMP. Unit-II on Standby. 400kV MHP-JLG Line I under Breakdown. 400kV MHP-JLG line II on Standby. 132kV MHP_Yurmo Line- I not in Service. 400kV JLG_ALI Interim Line I & II on Standby.
		Unit-II	0.00	400kV MHP - Jigmeling Line - II	0.00	
		Unit-III	130.40	400kV MHP - Jigmeling Line - III	122.17	
		Unit-IV	140.15	400kV MHP - Jigmeling Line - IV	121.53	
		-	-	132kV MHP - Yurmo Line - I	0.00	
		-	-	132kV MHP - Yurmo Line - II	65.56	
		-	-	500MVA, 400/220kV ICT at Jigmeling (HV)	162.55	
		-	-	400kV Jigmeling - Puna - Alipurduar Line - I	0.00	
		-	-	400kV Jigmeling - Puna - Alipurduar Line - II	0.00	
		-	-	400kV Jigmeling - Alipurduar Line - I	39.50	
		-	-	400kV Jigmeling - Alipurduar Line - II	40.73	
		-	-	80MVA, 220/132kV ICT - I (HV)	23.10	
		-	-	80MVA, 220/132kV ICT - II (HV)	22.91	
		-	-	220kV Tsirang - Jigmeling Line	-61.71	
		-	-	132kV Gelephu - Salakati Line	2.83	
Total	270.55	Auxiliary Consumption & Transformation Losses at Generator end	0.38%			
3	4 x 84MW CHP	Unit- I	71.26	220kV CHP - Birpara Line - I	-52.42	Unit-IV on Standby.
		Unit- II	58.59	220kV CHP - Birpara Line - II	-52.01	
		Unit- III	60.28	220kV CHP - Gedu	41.62	
		Unit- IV	0.00	220kV CHP - Jamjee (old) - I	82.80	
				220kV CHP - Jamjee - II (new)	83.54	
				220kV CHP - Jamjee - III (new)	80.74	
		-	-	220kV Malbase - Birpara Line	-73.44	
		-	-	66kV CHP - Gedu Line	5.38	
		-	-	3x3MVA, 66/11kV TFR	1.72	
		Total	190.13	Auxiliary Consumption & Transformation Losses at Generator end	-0.65%	
4	2 x 12MW BHP (U/S)	Unit- I	5.99	220kV BHP - Semothka Line	110.50	
		Unit- II	6.32	66kV BHP - Lobeyasa Line	28.35	
		Total	12.31	220kV BHP - Tsirang Line	-104.30	
5	2 x 20MW BHP (L/S)	Unit- I	11.78	5MVA, 66/11kV TFR	0.61	
		Unit- II	11.35	30MVA ICT, 220/66kV (HV)	16.70	
		Total	23.13	Auxiliary Consumption & Transformation Losses at Generator end	0.79%	
6	2 x 63MW DHP	Unit-I	0.00	220kV DHP - Tsirang Line	46.78	Unit I on Standby. 220kV DHP_Dagapela line on Standby.
		Unit-II	47.03	220kV DHP - Dagapela Line	0.00	
		-	-	220kV Jigmeling - Dagapela Line	53.86	
		-	-	5MVA, 220/33kV TFR	0.20	
Total	47.03	Auxiliary Consumption & Transformation Losses at Generator end	0.11%			
7	4 x 15MW KHP	Unit- I	14.07	132kV KHP - Nangkhor Line	22.21	KHP Unit-IV on Standby.
		Unit-II	14.10	132kV KHP - Kilikhar Line	19.19	
		Unit- III	14.13	5MVA, 132/11kV TFR	0.35	
		Unit- IV	0.00	132kV Motanga - Rangia Line	27.48	
		Total	42.30	Auxiliary Consumption & Transformation Losses at Generator end	1.30%	
8	2 x 59MW NHP	Unit-I	39.99	132kV NHP-MHP-I	39.74	Unit II Under Shutdown
		Unit-II	0.00	132kV NHP-MHP-II	0.00	
		Total	39.99	Auxiliary Consumption & Transformation Losses at Generator end	0.63%	

Note: Generation-Load Summary (MW) for 11-Nov-2024 at 18:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	684.26	751.58	752.49	-5.61	-0.91
2	Eastern Grid	352.84	180.59	178.76	110.54	1.83
	Total	1,037.10	932.17	931.25	104.93	0.92

Note: Generation-Load Summary (MW) for 11-Nov-2023, at 18:00 hrs

Sl. No.	Region	Total Generation	Total Load (Gen. - Exp.)	Total Load (Feeder Summation)	Total Export/Import	Auxiliary Consumption & Transformation Losses
1	Western Grid	635.23	699.97	694.95	26.59	5.02
2	Eastern Grid	235.26	194.38	192.43	-50.45	1.95
	Total	870.49	894.35	887.38	-23.86	6.97

Note: Daily Energy (MUs) and Power(MW) Statistics for 11-Nov-2024

Sl. No.	Net Energy Export (Bilateral)	Net Energy Import (Bilateral)	Daily Energy Met	Total Energy Generation	Peak Cross-border (MW)	Imp./Exp. through Exchange (MUs)
1	4.17	0.00	20.55	24.77	275.90	0.00

1. The instantaneous load balance, calculated as (Total generation - (Total export-Import) - Total domestic load), do not tend towards zero. This could be due to the following reasons:
 i) Not all the meters are digital and nor are all the meter at all locations can be read at same time (say 9:00hrs) due to many meter to be read manually. ii) The clocks of all the locations are not synchronized.
 2. This report, compiled using the SCADA data, is prepared to give an overall idea of the generation & load flow for the system at a particular instant. This report also gives energy and import/export figures.
 3. When SCADA data are unavailable for certain stations due to technical issues, required data are collected from the site.